

IEC 61850 – TICS

High **PROTEC** | PROTECTION TECHNOLOGY
MADE SIMPLE

MCDLV4 |

Tissue Implementation Conformance Statement (TICS)

UCA International Users Group Testing Sub Committee

Version: 3.7

Original document

English

Original reference manual

SEG Electronics GmbH

Krefelder Weg 47 • D-47906 Kempen (Germany)

Telephone: +49 (0) 21 52 145 1

Internet: www.SEGelectronics.de

Sales

Telephone: +49 (0) 21 52 145 331

Fax: +49 (0) 21 52 145 354

E-mail: info@SEGelectronics.de

Service

Telephone: +49 (0) 21 52 145 614

Fax: +49 (0) 21 52 145 354

E-mail: info@SEGelectronics.de

© 2020 SEG Electronics GmbH. All rights reserved.

Table of Contents

1	Introduction	4
2	Mandatory Intop Tissues	5
3	Optional IntOp Tissues	7

1 Introduction

This document provides a template for the tissues conformance statement. According to the UCA IUG QAP the tissue conformance statement is required to perform a conformance test and is referenced on the certificate.

This document is applicable for MCDLV4 Version 3.7.

2 Mandatory Intop Tissues

During the October 2006 meeting IEC TC57 working group 10 decided that:

- green Tissues with the category “IntOp” are mandatory for IEC 61850 edition 1
- Tissues with the category “Ed.2” Tissues should not be implemented.

Below table gives an overview of the implemented IntOp Tissues.

Part	Tissue No.	Description	Implemented (Y/na)
8-1	116	GetNameList with empty response?	Y
	165	Improper Error Response for GetDataSetValues	Y
	183	GetNameList error handling	Y
7-4	None		
7-3	28	Definition of APC	na
	54	Point def xVal, not cVal	na
	55	Ineut = Ires ?	Y
	60	Services missing in tables	na
	63	mag in CDC CMV	Y
	65	Deadband calculation of a Vector and trigger option	na
	219	operTm in ACT	na
	270	WYE and DEL rms values	na
7-2	30	control parameter T	Y
	31	Typo	Y
	32	Typo in syntax	Y
	35	Typo Syntax Control time	Y
	36	Syntax parameter DSet-Ref missing	Y
	37	Syntax GOOSE "T" type	Y
	39	Add DstAddr to GoCB	Y
	40	GOOSE Message “AppID” to “GoID”	Y
	41	GsCB “AppID” to “GsID”	Y
	42	SV timestamp: “EntryTime” to “TimeStamp”	na
	43	Control "T" semantic	Y
	44	AddCause - Object not sel	Y
45	Missing AddCauses (neg range)	na	

Part	Tissue No.	Description	Implemented (Y/na)
	46	Synchro check cancel	na
	47	"." in LD Name?	Y
	49	BRCB TimeOfEntry (part of #453)	Y
	50	LNName start with number?	Y
	51	ARRAY [0..num] missing	na
	52	Ambiguity GOOSE SqNum	Y
	53	Add DstAddr to GsCB, SV	Y
	151	Name constraint for control blocks etc.	Y
	166	DataRef attribute in Log	na
	185	Logging - Integrity periode	na
	189	SV Format	na
	190	BRCB: EntryId and TimeOfEntry (part of #453)	Y
	191	BRCB: Integrity and buffering reports (part of #453)	Y
	234	New type CtxInt (Enums are mapped to 8 bit integer)	Y
	275	Confusing statement on GI usage (part of #453)	Y
Part 6	1	Syntax	Y
	5	tExtensionAttributeNameEnum is restricted	Y
	8	SIUnit enumeration for W	Y
	10	Base type for bitstring usage	na
	17	DAI/SDI elements syntax	Y
	169	Ordering of enum differs from 7-3	na

NOTE: Tissue 49, 190, 191, 275 and 278 are part of the optional tissue #453, all other technical tissues in the table are mandatory if applicable.

NOTE: Editorial tissues are marked as "na".

NOTE: Final proposal on tissue 45 is not defined yet


3 Optional IntOp Tissues

After the approval of the server conformance test procedures version 2.2 the following IntOp tissues were added or changed. It is optional to implement these tissues.

Part	Tissue No.	Description	Implemented (Y/N/na)
8-1	235	Extension of Name length	Y
8-1	246	Control negative response (SBOs) with LastApplError	na
8-1	545	Skip file directories with no files	na
7-2	333	Enabling of an incomplete GoCB	na
7-2	453	Combination of all reporting and logging tissues	Y
6	245	Attribute RptId in SCL	N
6	529	Replace sev - Unknown by unknown	na

High PROTEC

docs.SEGelectronics.de/HighPROTEC



SEG Electronics GmbH reserves the right to update any portion of this publication at any time. Information provided by SEG Electronics GmbH is believed to be correct and reliable. However, SEG Electronics GmbH assumes no responsibility unless otherwise expressly undertaken.



SEG Electronics GmbH
Krefelder Weg 47 • D-47906 Kempen (Germany)
Telephone: +49 (0) 21 52 145 1

Internet: www.SEGelectronics.de

Sales
Telephone: +49 (0) 21 52 145 331
Fax: +49 (0) 21 52 145 354

Service
Telephone: +49 (0) 21 52 145 614
Fax: +49 (0) 21 52 145 354

Complete address / phone / fax / email information for all locations is available on our website.