

High **PROTEC**

**MCDLV4**

**IEC 61850 (Edition 1) – MICS**

**Model Implementation Conformance Statement (MICS)**

**UCA International Users Group Testing Sub Committee**

Build 62591

Revision A

Version: 3.11

Date: 2024-07-15

Original document English

© 2024 SEG Electronics GmbH. All rights reserved.

**SEG Electronics GmbH**

Krefelder Weg 47 • D-47906 Kempen (Germany)

Telephone: +49 (0) 21 52 145 0

Internet: [www.SEGelectronics.de](http://www.SEGelectronics.de)

Sales

Telephone: +49 (0) 21 52 145 331

Fax: +49 (0) 21 52 145 354

E-mail: [sales@SEGelectronics.de](mailto:sales@SEGelectronics.de)

Service

Telephone: +49 (0) 21 52 145 600

Fax: +49 (0) 21 52 145 354

E-mail: [support@SEGelectronics.de](mailto:support@SEGelectronics.de)

SEG Electronics GmbH reserves the right to update any portion of this publication at any time.

Information provided by SEG Electronics GmbH is believed to be correct and reliable.

However, no responsibility is assumed by SEG Electronics GmbH unless otherwise expressly undertaken.

Complete address / phone / fax / email information for all locations is available on our website.

# Table of Contents

<b>1</b>	<b>Introduction</b>	<b>7</b>
<b>2</b>	<b>Logical Nodes</b>	<b>8</b>
2.1	Logical Nodes List	8
2.2	Logical Node Definitions	10
2.3	Logical Nodes Types	13
2.3.1	CILO1	13
2.3.2	CSWI1	13
2.3.3	GAPC1	14
2.3.4	GGIO1	14
2.3.5	GGIO2	15
2.3.6	GGIO3	17
2.3.7	GGIO4	18
2.3.8	GGIO6	19
2.3.9	GGIO7	20
2.3.10	IHMI1	20
2.3.11	ITPC1 - (Extension)	21
2.3.12	LLN0CON	21
2.3.13	LLN0EXT	22
2.3.14	LLN0MEA	22
2.3.15	LLN0PRO	22
2.3.16	LLN0REC	23
2.3.17	LLN0SYS	23
2.3.18	LPHDCON	23
2.3.19	LPHDEXT	24
2.3.20	LPHDMEA	24
2.3.21	LPHDPRO	24
2.3.22	LPHDREC	25
2.3.23	LPHDSYS	25
2.3.24	MMTR1	25
2.3.25	MMXU1	26

## Table of Contents

2.3.26	MMXU2	26
2.3.27	MMXU3	27
2.3.28	MMXU8	27
2.3.29	MSTA1	28
2.3.30	MSTA2	28
2.3.31	MSTA3	29
2.3.32	PDIF1	30
2.3.33	PDIF2	30
2.3.34	PDIF3	31
2.3.35	PDIF4	31
2.3.36	PDOP1	32
2.3.37	PDUP1	32
2.3.38	PFRC1	33
2.3.39	PFRC2	33
2.3.40	PHAR1	33
2.3.41	PPAM1	34
2.3.42	PRTT1 – (Extension)	34
2.3.43	PSDE1	35
2.3.44	PSDE2	35
2.3.45	PSOF1 – (Extension)	36
2.3.46	PTOC1	36
2.3.47	PTOC2	37
2.3.48	PTOC3	37
2.3.49	PTOF1	37
2.3.50	PTOV1	38
2.3.51	PTOV2	38
2.3.52	PTOV3	39
2.3.53	PTRC1	39
2.3.54	PTRC2	40
2.3.55	PTTR1	40
2.3.56	PTUF1	41
2.3.57	PTUV1	41

2.3.58	PTUV2	41
2.3.59	PTUV3	42
2.3.60	PTUV4	42
2.3.61	PTUV5	43
2.3.62	PUPF1	43
2.3.63	PVPH1	44
2.3.64	RBRF1	44
2.3.65	RDRE1	45
2.3.66	RREC1	45
2.3.67	RSYN1	46
2.3.68	SCBR1 – (Extension)	46
2.3.69	XCBR1	47
2.3.70	XSWI1	47
<b>3</b>	<b>Common Data Class</b>	<b>49</b>
3.1	Common Data Class Definitions	49
3.1.1	Data Objects Type Definitions	50
3.2	Data Attributes Type Definitions	59
3.2.1	analogValue1	59
3.2.2	Cancel1	59
3.2.3	Oper1	59
3.2.4	origin1	59
3.2.5	PulseConfig1	60
3.2.6	units1	60
3.2.7	vector1	60
3.3	Enumerated Type Definitions	61
3.3.1	AutoRecSt	61
3.3.2	Beh1	61
3.3.3	Beh2	61
3.3.4	CBOPCap	61
3.3.5	cmdQual	62
3.3.6	ctlModel	62
3.3.7	Dbpos	62

3.3.8	dir	62
3.3.9	Health	62
3.3.10	Mod1	63
3.3.11	Mod2	63
3.3.12	multiplier	63
3.3.13	orCategory	64
3.3.14	sboClass	64
3.3.15	SIUnit	64
<b>4</b>	<b>Appendix</b>	<b>67</b>
4.1	Register Maps	67
4.1.1	LDevice::CTRL	67
4.1.2	LDevice::DR	75
4.1.3	LDevice::EXT	76
4.1.4	LDevice::MEAS	85
4.1.5	LDevice::PROT	89
4.2	Device Planning Dependencies	123

# 1 Introduction

This model implementation conformance statement is applicable to the MCDLV4 version 3.11.

This MICS document specifies the modelling extensions compared to IEC 61850 edition 1.

## 2 Logical Nodes

### 2.1 Logical Nodes List

The following table contains the list of logical nodes implemented in the device:

<b>C</b>	<b>Supervisory control</b>
<b>CILO</b>	Interlocking
<b>CSWI</b>	Switch controller
<b>G</b>	<b>Generic Function References</b>
<b>GAPC</b>	Generic automatic process control
<b>GGIO</b>	Generic process I/O
<b>I</b>	<b>Interfacing and Archiving</b>
<b>IHMI</b>	Human machine interface
<b>ITPC</b>	
<b>L</b>	<b>System Logical Nodes</b>
<b>LLNO</b>	Logical node zero
<b>LPHD</b>	Physical device information
<b>M</b>	<b>Metering and Measurement</b>
<b>MMTR</b>	Metering
<b>MMXU</b>	Measurement
<b>MSTA</b>	Metering Statistics
<b>P</b>	<b>Protection Functions</b>
<b>PDIF</b>	Differential
<b>PDOP</b>	Directional overpower
<b>PDUP</b>	Directional underpower
<b>PFRC</b>	Rate of change of frequency
<b>PHAR</b>	Harmonic restraint
<b>PPAM</b>	Phase angle measuring
<b>PRTT</b>	
<b>PSDE</b>	Sensitive directional earthfault
<b>PSOF</b>	Switch onto fault
<b>PTOC</b>	Time overcurrent
<b>PTOF</b>	Overfrequency
<b>PTOV</b>	Overvoltage



<b>P</b>	<b>Protection Functions</b>
<b>PTRC</b>	Protection trip conditioning
<b>PTTR</b>	Thermal overload
<b>PTUF</b>	Underfrequency
<b>PTUV</b>	Undervoltage
<b>PUPF</b>	Underpower factor
<b>PVPH</b>	Volts per Hz

<b>R</b>	<b>Protection Related Functions</b>
<b>RBRF</b>	Breaker failure
<b>RDRE</b>	Disturbance recorder function
<b>RREC</b>	Autoreclosing
<b>RSYN</b>	Synchronism-check or synchronising

<b>S</b>	<b>Sensors, Monitoring</b>
<b>SCBR</b>	Circuit breaker supervision

<b>X</b>	<b>Switchgear</b>
<b>XCBR</b>	Circuit breaker
<b>XSWI</b>	Circuit switch

## 2.2 Logical Node Definitions

Abbreviations used in the following table:

- **T**: Data is a transient data object in the IEC 61850-7-4 Ed. 1.
- **M**: Data is mandatory in the IEC 61850-7-4 Ed. 1.
- **O**: Data is optional in the IEC 61850-7-4 Ed. 1 and is used in the device.
- **C**: Data is conditional in the IEC 61850-7-4 Ed. 1.
- **E**: Data is an extension to the IEC 61850-7-4 Ed. 1.

LN Type	LN Class	Description
CILO1	CILO	Interlocking
CSWI1	CSWI	Switch controller
GAPC1	GAPC	Generic automatic process control
GGIO1	GGIO	Generic process I/O
GGIO2	GGIO	Generic process I/O
GGIO3	GGIO	Generic process I/O
GGIO4	GGIO	Generic process I/O
GGIO6	GGIO	Generic process I/O
GGIO7	GGIO	Generic process I/O
IHMI1	IHMI	Human machine interface
ITPC1	ITPC	
LLN0CON	LLN0	Logical node zero
LLN0EXT	LLN0	Logical node zero
LLN0MEA	LLN0	Logical node zero
LLN0PRO	LLN0	Logical node zero
LLN0REC	LLN0	Logical node zero
LPHDCON	LPHD	Physical device information
LPHDEXT	LPHD	Physical device information
LPHDMEA	LPHD	Physical device information
LPHDPRO	LPHD	Physical device information
LPHDREC	LPHD	Physical device information
MMTR1	MMTR	Metering
MMXU1	MMXU	Measurement
MMXU2	MMXU	Measurement
MMXU3	MMXU	Measurement
MMXU8	MMXU	Measurement
MSTA1	MSTA	Metering Statistics
MSTA2	MSTA	Metering Statistics

LN Type	LN Class	Description
MSTA3	MSTA	Metering Statistics
PDIF1	PDIF	Differential
PDIF2	PDIF	Differential
PDIF3	PDIF	Differential
PDIF4	PDIF	Differential
PDOP1	PDOP	Directional overpower
PDUP1	PDUP	Directional underpower
PFRC1	PFRC	Rate of change of frequency
PFRC2	PFRC	Rate of change of frequency
PHAR1	PHAR	Harmonic restraint
PPAM1	PPAM	Phase angle measuring
PRTT1	PRTT	
PSDE1	PSDE	Sensitive directional earthfault
PSDE2	PSDE	Sensitive directional earthfault
PSOF1	PSOF	Switch onto fault
PTOC1	PTOC	Time overcurrent
PTOC2	PTOC	Time overcurrent
PTOC3	PTOC	Time overcurrent
PTOF1	PTOF	Overfrequency
PTOV1	PTOV	Overvoltage
PTOV2	PTOV	Overvoltage
PTOV3	PTOV	Overvoltage
PTRC1	PTRC	Protection trip conditioning
PTRC2	PTRC	Protection trip conditioning
PTTR1	PTTR	Thermal overload
PTUF1	PTUF	Underfrequency
PTUV1	PTUV	Undervoltage
PTUV2	PTUV	Undervoltage
PTUV3	PTUV	Undervoltage
PTUV4	PTUV	Undervoltage
PTUV5	PTUV	Undervoltage
PUPF1	PUPF	Underpower factor
PVPH1	PVPH	Volts per Hz
RBRF1	RBRF	Breaker failure
RDRE1	RDRE	Disturbance recorder function
RREC1	RREC	Autoreclosing
RSYN1	RSYN	Synchronism-check or synchronising
SCBR1	SCBR	Circuit breaker supervision

## 2 Logical Nodes

### 2.2 Logical Node Definitions

<b>LN Type</b>	<b>LN Class</b>	<b>Description</b>
<a href="#">XCBR1</a>	XCBR	Circuit breaker
<a href="#">XSWI1</a>	XSWI	Circuit switch

## 2.3 Logical Nodes Types

### 2.3.1 CILO1

Attribute Name	Attribute Type	Explanation	T, M/O/C/E	Remarks
<b>CILO class</b>				
CILO	CILO1	Interlocking		
<b>Data</b>				
<i>Common Mandatory Logical Node Information</i>				
Mod	INC_Mod2	Mode	M	Status-only
Beh	INS_Beh2	Behaviour	M	
Health	INS_Health	Health	M	
NamPlt	LPL1	Name plate	M	
<i>Status Information</i>				
EnaOpn	SPS1	Enable Open	M	
EnaCls	SPS1	Enable Close	M	

### 2.3.2 CSWI1

Attribute Name	Attribute Type	Explanation	T, M/O/C/E	Remarks
<b>CSWI class</b>				
CSWI	CSWI1	Switch controller		
<b>Data</b>				
<i>Common Mandatory Logical Node Information</i>				
Mod	INC_Mod2	Mode	M	Status-only
Beh	INS_Beh2	Behaviour	M	
Health	INS_Health	Health	M	
NamPlt	LPL1	Name plate	M	
<i>Logical Node Information</i>				
Loc	SPS1	Local operation	O	
<i>Controls</i>				
Pos	DPC2	Position	M	

### 2.3.3 GAPC1

Attribute Name	Attribute Type	Explanation	T, M/O/C/E	Remarks
<b>GAPC class</b>				
GAPC	GAPC1	Generic automatic process control		
<b>Data</b>				
<i>Common Mandatory Logical Node Information</i>				
Mod	INC_Mod1	Mode	M	Status-only
Beh	INS_Beh1	Behaviour	M	
Health	INS_Health	Health	M	
NamPlt	LPL1	Name plate	M	
<i>Status Information</i>				
Str	ACD1	Start	M	
Op	ACT1	Trip	M	

### 2.3.4 GGIO1

Attribute Name	Attribute Type	Explanation	T, M/O/C/E	Remarks
<b>GGIO class</b>				
GGIO	GGIO1	Generic process I/O		
<b>Data</b>				
<i>Common Mandatory Logical Node Information</i>				
Mod	INC_Mod2	Mode	M	Status-only
Beh	INS_Beh2	Behaviour	M	
Health	INS_Health	Health	M	
NamPlt	LPL1	Name plate	M	
<i>Status Information</i>				
Ind1	SPS1	General indication (binary input)	O	
Ind2	SPS1	General indication (binary input)	O	
Ind3	SPS1	General indication (binary input)	O	
Ind4	SPS1	General indication (binary input)	O	
Ind5	SPS1	General indication (binary input)	O	
Ind6	SPS1	General indication (binary input)	O	
Ind7	SPS1	General indication (binary input)	O	
Ind8	SPS1	General indication (binary input)	O	
Ind9	SPS1	General indication (binary input)	O	

Attribute Name	Attribute Type	Explanation	T, M/O/C/E	Remarks
Ind10	SPS1	General indication (binary input)	O	
Ind11	SPS1	General indication (binary input)	O	
Ind12	SPS1	General indication (binary input)	O	
Ind13	SPS1	General indication (binary input)	O	
Ind14	SPS1	General indication (binary input)	O	
Ind15	SPS1	General indication (binary input)	O	
Ind16	SPS1	General indication (binary input)	O	
Ind17	SPS1	General indication (binary input)	O	
Ind18	SPS1	General indication (binary input)	O	
Ind19	SPS1	General indication (binary input)	O	
Ind20	SPS1	General indication (binary input)	O	
Ind21	SPS1	General indication (binary input)	O	
Ind22	SPS1	General indication (binary input)	O	
Ind23	SPS1	General indication (binary input)	O	
Ind24	SPS1	General indication (binary input)	O	
Ind25	SPS1	General indication (binary input)	O	
Ind26	SPS1	General indication (binary input)	O	
Ind27	SPS1	General indication (binary input)	O	
Ind28	SPS1	General indication (binary input)	O	
Ind29	SPS1	General indication (binary input)	O	
Ind30	SPS1	General indication (binary input)	O	
Ind31	SPS1	General indication (binary input)	O	
Ind32	SPS1	General indication (binary input)	O	

## 2.3.5 GGIO2

Attribute Name	Attribute Type	Explanation	T, M/O/C/E	Remarks
<b>GGIO class</b>				
GGIO	GGIO2	Generic process I/O		
<b>Data</b>				
<i>Common Mandatory Logical Node Information</i>				
Mod	INC_Mod2	Mode	M	Status-only
Beh	INS_Beh2	Behaviour	M	
Health	INS_Health	Health	M	
NamPlt	LPL1	Name plate	M	

## 2 Logical Nodes

### 2.3.5 GGIO2

Attribute Name	Attribute Type	Explanation	T, M/O/C/E	Remarks
<i>Status Information</i>				
Ind1	SPS1	General indication (binary input)	0	
Ind2	SPS1	General indication (binary input)	0	
Ind3	SPS1	General indication (binary input)	0	
Ind4	SPS1	General indication (binary input)	0	
Ind5	SPS1	General indication (binary input)	0	
Ind6	SPS1	General indication (binary input)	0	
Ind7	SPS1	General indication (binary input)	0	
Ind8	SPS1	General indication (binary input)	0	
Ind9	SPS1	General indication (binary input)	0	
Ind10	SPS1	General indication (binary input)	0	
Ind11	SPS1	General indication (binary input)	0	
Ind12	SPS1	General indication (binary input)	0	
Ind13	SPS1	General indication (binary input)	0	
Ind14	SPS1	General indication (binary input)	0	
Ind15	SPS1	General indication (binary input)	0	
Ind16	SPS1	General indication (binary input)	0	
Ind17	SPS1	General indication (binary input)	0	
Ind18	SPS1	General indication (binary input)	0	
Ind19	SPS1	General indication (binary input)	0	
Ind20	SPS1	General indication (binary input)	0	
Ind21	SPS1	General indication (binary input)	0	
Ind22	SPS1	General indication (binary input)	0	
Ind23	SPS1	General indication (binary input)	0	
Ind24	SPS1	General indication (binary input)	0	
Ind25	SPS1	General indication (binary input)	0	
Ind26	SPS1	General indication (binary input)	0	
Ind27	SPS1	General indication (binary input)	0	
Ind28	SPS1	General indication (binary input)	0	
Ind29	SPS1	General indication (binary input)	0	
Ind30	SPS1	General indication (binary input)	0	
Ind31	SPS1	General indication (binary input)	0	
Ind32	SPS1	General indication (binary input)	0	



## 2.3.6 GGIO3

Attribute Name	Attribute Type	Explanation	T, M/O/C/E	Remarks
<b>GGIO class</b>				
GGIO	GGIO3	Generic process I/O		
<b>Data</b>				
<i>Common Mandatory Logical Node Information</i>				
Mod	INC_Mod2	Mode	M	Status-only
Beh	INS_Beh2	Behaviour	M	
Health	INS_Health	Health	M	
NamPlt	LPL1	Name plate	M	
<i>Status Information</i>				
Ind1	SPS1	General indication (binary input)	O	
Ind2	SPS1	General indication (binary input)	O	
Ind3	SPS1	General indication (binary input)	O	
Ind4	SPS1	General indication (binary input)	O	
Ind5	SPS1	General indication (binary input)	O	
Ind6	SPS1	General indication (binary input)	O	
Ind7	SPS1	General indication (binary input)	O	
Ind8	SPS1	General indication (binary input)	O	
Ind9	SPS1	General indication (binary input)	O	
Ind10	SPS1	General indication (binary input)	O	
Ind11	SPS1	General indication (binary input)	O	
Ind12	SPS1	General indication (binary input)	O	
Ind13	SPS1	General indication (binary input)	O	
Ind14	SPS1	General indication (binary input)	O	
Ind15	SPS1	General indication (binary input)	O	
Ind16	SPS1	General indication (binary input)	O	
Ind17	SPS1	General indication (binary input)	O	
Ind18	SPS1	General indication (binary input)	O	
Ind19	SPS1	General indication (binary input)	O	
Ind20	SPS1	General indication (binary input)	O	
Ind21	SPS1	General indication (binary input)	O	
Ind22	SPS1	General indication (binary input)	O	
Ind23	SPS1	General indication (binary input)	O	
Ind24	SPS1	General indication (binary input)	O	
Ind25	SPS1	General indication (binary input)	O	
Ind26	SPS1	General indication (binary input)	O	

Attribute Name	Attribute Type	Explanation	T, M/O/C/E	Remarks
Ind27	SPS1	General indication (binary input)	O	
Ind28	SPS1	General indication (binary input)	O	
Ind29	SPS1	General indication (binary input)	O	
Ind30	SPS1	General indication (binary input)	O	
Ind31	SPS1	General indication (binary input)	O	
Ind32	SPS1	General indication (binary input)	O	

## 2.3.7 GGIO4

Attribute Name	Attribute Type	Explanation	T, M/O/C/E	Remarks
<b>GGIO class</b>				
GGIO	GGIO4	Generic process I/O		
<b>Data</b>				
<i>Common Mandatory Logical Node Information</i>				
Mod	INC_Mod2	Mode	M	Status-only
Beh	INS_Beh2	Behaviour	M	
Health	INS_Health	Health	M	
NamPlt	LPL1	Name plate	M	
<i>Controls</i>				
SPCSO1	SPC2	Single point controllable status output	O	
SPCSO2	SPC2	Single point controllable status output	O	
SPCSO3	SPC2	Single point controllable status output	O	
SPCSO4	SPC2	Single point controllable status output	O	
SPCSO5	SPC2	Single point controllable status output	O	
SPCSO6	SPC2	Single point controllable status output	O	
SPCSO7	SPC2	Single point controllable status output	O	
SPCSO8	SPC2	Single point controllable status output	O	
SPCSO9	SPC2	Single point controllable status output	O	
SPCSO10	SPC2	Single point controllable status output	O	
SPCSO11	SPC2	Single point controllable status output	O	
SPCSO12	SPC2	Single point controllable status output	O	
SPCSO13	SPC2	Single point controllable status output	O	
SPCSO14	SPC2	Single point controllable status output	O	
SPCSO15	SPC2	Single point controllable status output	O	
SPCSO16	SPC2	Single point controllable status output	O	

Attribute Name	Attribute Type	Explanation	T, M/O/C/E	Remarks
SPCSO17	SPC2	Single point controllable status output	O	
SPCSO18	SPC2	Single point controllable status output	O	
SPCSO19	SPC2	Single point controllable status output	O	
SPCSO20	SPC2	Single point controllable status output	O	
SPCSO21	SPC2	Single point controllable status output	O	
SPCSO22	SPC2	Single point controllable status output	O	
SPCSO23	SPC2	Single point controllable status output	O	
SPCSO24	SPC2	Single point controllable status output	O	
SPCSO25	SPC2	Single point controllable status output	O	
SPCSO26	SPC2	Single point controllable status output	O	
SPCSO27	SPC2	Single point controllable status output	O	
SPCSO28	SPC2	Single point controllable status output	O	
SPCSO29	SPC2	Single point controllable status output	O	
SPCSO30	SPC2	Single point controllable status output	O	
SPCSO31	SPC2	Single point controllable status output	O	
SPCSO32	SPC2	Single point controllable status output	O	

## 2.3.8 GGIO6

Attribute Name	Attribute Type	Explanation	T, M/O/C/E	Remarks
<b>GGIO class</b>				
GGIO	GGIO6	Generic process I/O		
<b>Data</b>				
<i>Common Mandatory Logical Node Information</i>				
Mod	INC_Mod2	Mode	M	Status-only
Beh	INS_Beh2	Behaviour	M	
Health	INS_Health	Health	M	
NamPlt	LPL1	Name plate	M	
<i>Status Information</i>				
Ind1	SPS1	General indication (binary input)	O	
Ind2	SPS1	General indication (binary input)	O	
Ind3	SPS1	General indication (binary input)	O	
Ind4	SPS1	General indication (binary input)	O	

## 2.3.9 GGIO7

Attribute Name	Attribute Type	Explanation	T, M/O/C/E	Remarks
<b>GGIO class</b>				
GGIO	GGIO7	Generic process I/O		
<b>Data</b>				
<i>Common Mandatory Logical Node Information</i>				
Mod	INC_Mod1	Mode	M	Status-only
Beh	INS_Beh1	Behaviour	M	
Health	INS_Health	Health	M	
NamPlt	LPL1	Name plate	M	
<i>Status Information</i>				
Ind1	SPS1	General indication (binary input)	O	
Ind2	SPS1	General indication (binary input)	O	
Ind3	SPS1	General indication (binary input)	O	
Ind4	SPS1	General indication (binary input)	O	
Ind5	SPS1	General indication (binary input)	O	
Ind6	SPS1	General indication (binary input)	O	
Ind7	SPS1	General indication (binary input)	O	
Ind8	SPS1	General indication (binary input)	O	
Ind9	SPS1	General indication (binary input)	O	
Ind10	SPS1	General indication (binary input)	O	
Ind11	SPS1	General indication (binary input)	O	
Ind12	SPS1	General indication (binary input)	O	
Ind13	SPS1	General indication (binary input)	O	
Ind14	SPS1	General indication (binary input)	O	
Ind15	SPS1	General indication (binary input)	O	
Ind16	SPS1	General indication (binary input)	O	

## 2.3.10 IHMI1

Attribute Name	Attribute Type	Explanation	T, M/O/C/E	Remarks
<b>IHMI class</b>				
IHMI	IHMI1	Human machine interface		
<b>Data</b>				
<i>Common Mandatory Logical Node Information</i>				

Attribute Name	Attribute Type	Explanation	T, M/O/C/E	Remarks
Mod	INC_Mod2	Mode	M	Status-only
Beh	INS_Beh2	Behaviour	M	
Health	INS_Health	Health	M	
NamPlt	LPL1	Name plate	M	

### 2.3.11 ITPC1 - (Extension)

Attribute Name	Attribute Type	Explanation	T, M/O/C/E	Remarks
<b>ITPC class</b>				
ITPC	ITPC1			
<b>Data</b>				
<i>Extensions</i>				
Mod	INC_Mod1	Mode	E	Status-only
Beh	INS_Beh1	Behaviour	E	
Health	INS_Health	Health	E	
NamPlt	LPL1	Name plate	E	
SynOk	SPS1	Measuring systems is synchronized with Remote device	E	
FrSyn	SPS1	Frames Synchronization	E	
TmSyn	SPS1	Time Synchronization	E	

### 2.3.12 LLN0CON

Attribute Name	Attribute Type	Explanation	T, M/O/C/E	Remarks
<b>LLN0 class</b>				
LLN0	LLN0CON	Logical node zero		
<b>Data</b>				
<i>Common Mandatory Logical Node Information</i>				
Mod	INC_Mod2	Mode	M	Status-only
Beh	INS_Beh2	Behaviour	M	
Health	INS_Health	Health	M	
NamPlt	LPL2	Name plate	M	

### 2.3.13 LLN0EXT

Attribute Name	Attribute Type	Explanation	T, M/O/C/E	Remarks
<b>LLN0 class</b>				
LLN0	LLN0EXT	Logical node zero		
<b>Data</b>				
<i>Common Mandatory Logical Node Information</i>				
Mod	INC_Mod2	Mode	M	Status-only
Beh	INS_Beh2	Behaviour	M	
Health	INS_Health	Health	M	
NamPlt	LPL2	Name plate	M	

### 2.3.14 LLN0MEA

Attribute Name	Attribute Type	Explanation	T, M/O/C/E	Remarks
<b>LLN0 class</b>				
LLN0	LLN0MEA	Logical node zero		
<b>Data</b>				
<i>Common Mandatory Logical Node Information</i>				
Mod	INC_Mod2	Mode	M	Status-only
Beh	INS_Beh2	Behaviour	M	
Health	INS_Health	Health	M	
NamPlt	LPL2	Name plate	M	

### 2.3.15 LLN0PRO

Attribute Name	Attribute Type	Explanation	T, M/O/C/E	Remarks
<b>LLN0 class</b>				
LLN0	LLN0PRO	Logical node zero		
<b>Data</b>				
<i>Common Mandatory Logical Node Information</i>				
Mod	INC_Mod2	Mode	M	Status-only
Beh	INS_Beh2	Behaviour	M	
Health	INS_Health	Health	M	

Attribute Name	Attribute Type	Explanation	T, M/O/C/E	Remarks
NamPlt	LPL2	Name plate	M	

### 2.3.16 LLNOREC

Attribute Name	Attribute Type	Explanation	T, M/O/C/E	Remarks
<b>LLN0 class</b>				
LLN0	LLNOREC	Logical node zero		
<b>Data</b>				
<i>Common Mandatory Logical Node Information</i>				
Mod	INC_Mod2	Mode	M	Status-only
Beh	INS_Beh2	Behaviour	M	
Health	INS_Health	Health	M	
NamPlt	LPL2	Name plate	M	

### 2.3.17 LLNOSYS

Attribute Name	Attribute Type	Explanation	T, M/O/C/E	Remarks
<b>LLN0 class</b>				
LLN0	LLNOSYS	Logical node zero		
<b>Data</b>				
<i>Common Mandatory Logical Node Information</i>				
Mod	INC_Mod2	Mode	M	Status-only
Beh	INS_Beh2	Behaviour	M	
Health	INS_Health	Health	M	
NamPlt	LPL2	Name plate	M	

### 2.3.18 LPHDCON

Attribute Name	Attribute Type	Explanation	T, M/O/C/E	Remarks
<b>LPHD class</b>				
LPHD	LPHDCON	Physical device information		
<b>Data</b>				

Attribute Name	Attribute Type	Explanation	T, M/O/C/E	Remarks
PhyNam	DPL1	Physical device name plate	M	
PhyHealth	INS_Health	Physical device health	M	
Proxy	SPS1	Indicates if this LN is a proxy	M	

### 2.3.19 LPHDEXT

Attribute Name	Attribute Type	Explanation	T, M/O/C/E	Remarks
<b>LPHD class</b>				
LPHD	LPHDEXT	Physical device information		
<b>Data</b>				
PhyNam	DPL1	Physical device name plate	M	
PhyHealth	INS_Health	Physical device health	M	
Proxy	SPS1	Indicates if this LN is a proxy	M	

### 2.3.20 LPHDMEA

Attribute Name	Attribute Type	Explanation	T, M/O/C/E	Remarks
<b>LPHD class</b>				
LPHD	LPHDMEA	Physical device information		
<b>Data</b>				
PhyNam	DPL1	Physical device name plate	M	
PhyHealth	INS_Health	Physical device health	M	
Proxy	SPS1	Indicates if this LN is a proxy	M	

### 2.3.21 LPHDPRO

Attribute Name	Attribute Type	Explanation	T, M/O/C/E	Remarks
<b>LPHD class</b>				
LPHD	LPHDPRO	Physical device information		
<b>Data</b>				
PhyNam	DPL1	Physical device name plate	M	
PhyHealth	INS_Health	Physical device health	M	



Attribute Name	Attribute Type	Explanation	T, M/O/C/E	Remarks
Proxy	SPS1	Indicates if this LN is a proxy	M	

### 2.3.22 LPHDREC

Attribute Name	Attribute Type	Explanation	T, M/O/C/E	Remarks
<b>LPHD class</b>				
LPHD	LPHDREC	Physical device information		
<b>Data</b>				
PhyNam	DPL1	Physical device name plate	M	
PhyHealth	INS_Health	Physical device health	M	
Proxy	SPS1	Indicates if this LN is a proxy	M	

### 2.3.23 LPHDSYS

Attribute Name	Attribute Type	Explanation	T, M/O/C/E	Remarks
<b>LPHD class</b>				
LPHD	LPHDSYS	Physical device information		
<b>Data</b>				
PhyNam	DPL1	Physical device name plate	M	
PhyHealth	INS_Health	Physical device health	M	
Proxy	SPS1	Indicates if this LN is a proxy	M	

### 2.3.24 MMTR1

Attribute Name	Attribute Type	Explanation	T, M/O/C/E	Remarks
<b>MMTR class</b>				
MMTR	MMTR1	Metering		
<b>Data</b>				
<i>Common Mandatory Logical Node Information</i>				
Mod	INC_Mod2	Mode	M	Status-only
Beh	INS_Beh2	Behaviour	M	
Health	INS_Health	Health	M	

## 2 Logical Nodes

### 2.3.25 MMXU1

Attribute Name	Attribute Type	Explanation	T, M/O/C/E	Remarks
NamPlt	LPL1	Name plate	M	
<i>Metered Values</i>				
SupWh	BCR1	Consumed Active Energy	O	
DmdWh	BCR1	Fed Active Energy	O	
SupVARh	BCR1	Consumed Reactive Energy	O	
DmdVARh	BCR1	Fed Reactive Energy	O	
TotWh	BCR1	Absolute Active Power Hours	O	
TotVARh	BCR1	Absolute Reactive Power Hours	O	
TotVAh	BCR1	Absolute Apparent Power Hours	O	

### 2.3.25 MMXU1

Attribute Name	Attribute Type	Explanation	T, M/O/C/E	Remarks
<b>MMXU class</b>				
MMXU	MMXU1	Measurement		
<b>Data</b>				
<i>Common Mandatory Logical Node Information</i>				
Mod	INC_Mod2	Mode	M	Status-only
Beh	INS_Beh2	Behaviour	M	
Health	INS_Health	Health	M	
NamPlt	LPL1	Name plate	M	
<i>Measured values</i>				
TotW	MV1	Total Active Power (Total P)	O	
TotVAr	MV1	Total Reactive Power (Total Q)	O	
TotVA	MV1	Total Apparent Power (Total S)	O	
TotPF	MV1	Average Power factor (Total PF)	O	

### 2.3.26 MMXU2

Attribute Name	Attribute Type	Explanation	T, M/O/C/E	Remarks
<b>MMXU class</b>				
MMXU	MMXU2	Measurement		
<b>Data</b>				
<i>Common Mandatory Logical Node Information</i>				

Attribute Name	Attribute Type	Explanation	T, M/O/C/E	Remarks
Mod	INC_Mod2	Mode	M	Status-only
Beh	INS_Beh2	Behaviour	M	
Health	INS_Health	Health	M	
NamPlt	LPL1	Name plate	M	
<i>Measured values</i>				
PPV	DEL1	Phase to phase voltages (UL12, UL23, UL31)	O	
PhV	WYE1	Phase to ground voltages (UL1, UL2, UL3)	O	
Hz	MV1	frequency	O	

### 2.3.27 MMXU3

Attribute Name	Attribute Type	Explanation	T, M/O/C/E	Remarks
<b>MMXU class</b>				
MMXU	MMXU3	Measurement		
<b>Data</b>				
<i>Common Mandatory Logical Node Information</i>				
Mod	INC_Mod2	Mode	M	Status-only
Beh	INS_Beh2	Behaviour	M	
Health	INS_Health	Health	M	
NamPlt	LPL1	Name plate	M	
<i>Measured values</i>				
A	WYE1	Phase currents (IL1, IL2, IL3)	O	

### 2.3.28 MMXU8

Attribute Name	Attribute Type	Explanation	T, M/O/C/E	Remarks
<b>MMXU class</b>				
MMXU	MMXU8	Measurement		
<b>Data</b>				
<i>Common Mandatory Logical Node Information</i>				
Mod	INC_Mod2	Mode	M	Status-only
Beh	INS_Beh2	Behaviour	M	
Health	INS_Health	Health	M	
NamPlt	LPL1	Name plate	M	

Attribute Name	Attribute Type	Explanation	T, M/O/C/E	Remarks
<i>Measured values</i>				
A	WYE2	Phase currents (IL1, IL2, IL3)	O	

### 2.3.29 MSTA1

Attribute Name	Attribute Type	Explanation	T, M/O/C/E	Remarks
<b>MSTA class</b>				
MSTA	MSTA1	Metering Statistics		
<b>Data</b>				
<i>Common Mandatory Logical Node Information</i>				
Mod	INC_Mod2	Mode	M	Status-only
Beh	INS_Beh2	Behaviour	M	
Health	INS_Health	Health	M	
NamPlt	LPL1	Name plate	M	
<i>Extensions</i>				
AvAPhsA	MV1	Average current IL1	E	
AvAPhsB	MV1	Average current IL2	E	
AvAPhsC	MV1	Average current IL3	E	
MaxAPhsA	MV1	Maximum current IL1	E	
MaxAPhsB	MV1	Maximum current IL2	E	
MaxAPhsC	MV1	Maximum current IL3	E	
MinAPhsA	MV1	Minimum current IL1	E	
MinAPhsB	MV1	Minimum current IL2	E	
MinAPhsC	MV1	Minimum current IL3	E	

### 2.3.30 MSTA2

Attribute Name	Attribute Type	Explanation	T, M/O/C/E	Remarks
<b>MSTA class</b>				
MSTA	MSTA2	Metering Statistics		
<b>Data</b>				
<i>Common Mandatory Logical Node Information</i>				
Mod	INC_Mod2	Mode	M	Status-only
Beh	INS_Beh2	Behaviour	M	

Attribute Name	Attribute Type	Explanation	T, M/O/C/E	Remarks
Health	INS_Health	Health	M	
NamPlt	LPL1	Name plate	M	
<i>Extensions</i>				
AvVPhsAB	MV1	Average voltage UL12	E	
AvVPhsBC	MV1	Average voltage UL23	E	
AvVPhsCA	MV1	Average voltage UL31	E	
MaxVPhsAB	MV1	Maximum voltage UL12	E	
MaxVPhsBC	MV1	Maximum voltage UL23	E	
MaxVPhsCA	MV1	Maximum voltage UL31	E	
MinVPhsAB	MV1	Minimum voltage UL12	E	
MinVPhsBC	MV1	Minimum voltage UL23	E	
MinVPhsCA	MV1	Minimum voltage UL31	E	
AvVPhsA	MV1	Average voltage UL1	E	
AvVPhsB	MV1	Average voltage UL2	E	
AvVPhsC	MV1	Average voltage UL3	E	
MaxVPhsA	MV1	Maximum voltage UL1	E	
MaxVPhsB	MV1	Maximum voltage UL2	E	
MaxVPhsC	MV1	Maximum voltage UL3	E	
MinVPhsA	MV1	Minimum voltage UL1	E	
MinVPhsB	MV1	Minimum voltage UL2	E	
MinVPhsC	MV1	Minimum voltage UL3	E	

### 2.3.31 MSTA3

Attribute Name	Attribute Type	Explanation	T, M/O/C/E	Remarks
<b>MSTA class</b>				
MSTA	MSTA3	Metering Statistics		
<b>Data</b>				
<i>Common Mandatory Logical Node Information</i>				
Mod	INC_Mod2	Mode	M	Status-only
Beh	INS_Beh2	Behaviour	M	
Health	INS_Health	Health	M	
NamPlt	LPL1	Name plate	M	
<i>Metered Values</i>				
AvVA	MV1	Average apparent power	O	

## 2 Logical Nodes

### 2.3.32 PDIF1

Attribute Name	Attribute Type	Explanation	T, M/O/C/E	Remarks
MaxVA	MV1	Maximum apparent power	O	
MinVA	MV1	Minimum apparent power	O	
AvW	MV1	Average real power	O	
MaxW	MV1	Maximum real power	O	
MinW	MV1	Minimum real power	O	
AvVAr	MV1	Average reactive power	O	
MaxVAr	MV1	Maximum reactive power	O	
MinVAr	MV1	Minimum reactive power	O	

### 2.3.32 PDIF1

Attribute Name	Attribute Type	Explanation	T, M/O/C/E	Remarks
<b>PDIF class</b>				
PDIF	PDIF1	Differential		
<b>Data</b>				
<i>Common Mandatory Logical Node Information</i>				
Mod	INC_Mod1	Mode	M	Status-only
Beh	INS_Beh1	Behaviour	M	
Health	INS_Health	Health	M	
NamPlt	LPL1	Name plate	M	
<i>Status Information</i>				
Str	ACD1	Start	O	
Op	ACT1	Operate	M	

### 2.3.33 PDIF2

Attribute Name	Attribute Type	Explanation	T, M/O/C/E	Remarks
<b>PDIF class</b>				
PDIF	PDIF2	Differential		
<b>Data</b>				
<i>Common Mandatory Logical Node Information</i>				
Mod	INC_Mod1	Mode	M	Status-only
Beh	INS_Beh1	Behaviour	M	
Health	INS_Health	Health	M	

Attribute Name	Attribute Type	Explanation	T, M/O/C/E	Remarks
NamPlt	LPL1	Name plate	M	
<i>Status Information</i>				
Str	ACD1	Start	O	
Op	ACT1	Operate	M	

### 2.3.34 PDIF3

Attribute Name	Attribute Type	Explanation	T, M/O/C/E	Remarks
<b>PDIF class</b>				
PDIF	PDIF3	Differential		
<b>Data</b>				
<i>Common Mandatory Logical Node Information</i>				
Mod	INC_Mod1	Mode	M	Status-only
Beh	INS_Beh1	Behaviour	M	
Health	INS_Health	Health	M	
NamPlt	LPL1	Name plate	M	
<i>Status Information</i>				
Str	ACD1	Start	O	
Op	ACT1	Operate	M	

### 2.3.35 PDIF4

Attribute Name	Attribute Type	Explanation	T, M/O/C/E	Remarks
<b>PDIF class</b>				
PDIF	PDIF4	Differential		
<b>Data</b>				
<i>Common Mandatory Logical Node Information</i>				
Mod	INC_Mod1	Mode	M	Status-only
Beh	INS_Beh1	Behaviour	M	
Health	INS_Health	Health	M	
NamPlt	LPL1	Name plate	M	
<i>Status Information</i>				
Str	ACD1	Start	O	

Attribute Name	Attribute Type	Explanation	T, M/O/C/E	Remarks
Op	ACT1	Operate	M	

### 2.3.36 PDOP1

Attribute Name	Attribute Type	Explanation	T, M/O/C/E	Remarks
<b>PDOP class</b>				
PDOP	PDOP1	Directional overpower		
<b>Data</b>				
<i>Common Mandatory Logical Node Information</i>				
Mod	INC_Mod1	Mode	M	Status-only
Beh	INS_Beh1	Behaviour	M	
Health	INS_Health	Health	M	
NamPlt	LPL1	Name plate	M	
<i>Status Information</i>				
Str	ACD1	Start	M	
Op	ACT1	Operate	M	

### 2.3.37 PDUP1

Attribute Name	Attribute Type	Explanation	T, M/O/C/E	Remarks
<b>PDUP class</b>				
PDUP	PDUP1	Directional underpower		
<b>Data</b>				
<i>Common Mandatory Logical Node Information</i>				
Mod	INC_Mod1	Mode	M	Status-only
Beh	INS_Beh1	Behaviour	M	
Health	INS_Health	Health	M	
NamPlt	LPL1	Name plate	M	
<i>Status Information</i>				
Str	ACD1	Start	M	
Op	ACT1	Operate	M	



### 2.3.38 PFRC1

Attribute Name	Attribute Type	Explanation	T, M/O/C/E	Remarks
<b>PFRC class</b>				
PFRC	PFRC1	Rate of change of frequency		
<b>Data</b>				
<i>Common Mandatory Logical Node Information</i>				
Mod	INC_Mod1	Mode	M	Status-only
Beh	INS_Beh1	Behaviour	M	
Health	INS_Health	Health	M	
NamPlt	LPL1	Name plate	M	
<i>Status Information</i>				
Str	ACD1	Start	M	
Op	ACT1	Operate	M	

### 2.3.39 PFRC2

Attribute Name	Attribute Type	Explanation	T, M/O/C/E	Remarks
<b>PFRC class</b>				
PFRC	PFRC2	Rate of change of frequency		
<b>Data</b>				
<i>Common Mandatory Logical Node Information</i>				
Mod	INC_Mod1	Mode	M	Status-only
Beh	INS_Beh1	Behaviour	M	
Health	INS_Health	Health	M	
NamPlt	LPL1	Name plate	M	
<i>Status Information</i>				
Str	ACD1	Start	M	
Op	ACT1	Operate	M	

### 2.3.40 PHAR1

Attribute Name	Attribute Type	Explanation	T, M/O/C/E	Remarks
<b>PHAR class</b>				
PHAR	PHAR1	Harmonic restraint		

Attribute Name	Attribute Type	Explanation	T, M/O/C/E	Remarks
<b>Data</b>				
<i>Common Mandatory Logical Node Information</i>				
Mod	INC_Mod1	Mode	M	Status-only
Beh	INS_Beh1	Behaviour	M	
Health	INS_Health	Health	M	
NamPlt	LPL1	Name plate	M	
<i>Status Information</i>				
Str	ACD1	Start	M	

### 2.3.41 PPAM1

Attribute Name	Attribute Type	Explanation	T, M/O/C/E	Remarks
<b>PPAM class</b>				
PPAM	PPAM1	Phase angle measuring		
<b>Data</b>				
<i>Common Mandatory Logical Node Information</i>				
Mod	INC_Mod1	Mode	M	Status-only
Beh	INS_Beh1	Behaviour	M	
Health	INS_Health	Health	M	
NamPlt	LPL1	Name plate	M	
<i>Status Information</i>				
Str	ACD1	Start	M	
Op	ACT1	Operate	M	

### 2.3.42 PRTT1 - (Extension)

Attribute Name	Attribute Type	Explanation	T, M/O/C/E	Remarks
<b>PRTT class</b>				
PRTT	PRTT1			
<b>Data</b>				
<i>Extensions</i>				
Mod	INC_Mod1	Mode	E	Status-only
Beh	INS_Beh1	Behaviour	E	
Health	INS_Health	Health	E	

Attribute Name	Attribute Type	Explanation	T, M/O/C/E	Remarks
NamPlt	LPL1	Name plate	E	
Op	ACT1	Trip	E	
PerTr1	SPS1	Permissive for Rx.Trip	E	
PerTr2	SPS1	Permissive for Rx.Trip	E	
PerTr3	SPS1	Permissive for Rx.Trip	E	
PerTr4	SPS1	Permissive for Rx.Trip	E	
RemTr1	SPS1	Trip from remote	E	
RemTr2	SPS1	Trip from remote	E	
RemTr3	SPS1	Trip from remote	E	
RemTr4	SPS1	Trip from remote	E	

### 2.3.43 PSDE1

Attribute Name	Attribute Type	Explanation	T, M/O/C/E	Remarks
<b>PSDE class</b>				
PSDE	PSDE1	Sensitive directional earthfault		
<b>Data</b>				
<i>Common Mandatory Logical Node Information</i>				
Mod	INC_Mod1	Mode	M	Status-only
Beh	INS_Beh1	Behaviour	M	
Health	INS_Health	Health	M	
NamPlt	LPL1	Name plate	M	
<i>Status Information</i>				
Str	ACD1	Start	M	

### 2.3.44 PSDE2

Attribute Name	Attribute Type	Explanation	T, M/O/C/E	Remarks
<b>PSDE class</b>				
PSDE	PSDE2	Sensitive directional earthfault		
<b>Data</b>				
<i>Common Mandatory Logical Node Information</i>				
Mod	INC_Mod1	Mode	M	Status-only
Beh	INS_Beh1	Behaviour	M	

## 2 Logical Nodes

### 2.3.45 PSOF1 - (Extension)

Attribute Name	Attribute Type	Explanation	T, M/O/C/E	Remarks
Health	INS_Health	Health	M	
NamPlt	LPL1	Name plate	M	
<i>Status Information</i>				
Str	ACD1	Start	M	

### 2.3.45 PSOF1 - (Extension)

Attribute Name	Attribute Type	Explanation	T, M/O/C/E	Remarks
<b>PSOF class</b>				
PSOF	PSOF1	Switch onto fault		
<b>Data</b>				
<i>Extensions</i>				
Mod	INC_Mod1	Mode	E	Status-only
Beh	INS_Beh1	Behaviour	E	
Health	INS_Health	Health	E	
NamPlt	LPL3	Name plate	E	
Str	ACD1	Start	E	

### 2.3.46 PTOC1

Attribute Name	Attribute Type	Explanation	T, M/O/C/E	Remarks
<b>PTOC class</b>				
PTOC	PTOC1	Time overcurrent		
<b>Data</b>				
<i>Common Mandatory Logical Node Information</i>				
Mod	INC_Mod1	Mode	M	Status-only
Beh	INS_Beh1	Behaviour	M	
Health	INS_Health	Health	M	
NamPlt	LPL1	Name plate	M	
<i>Status Information</i>				
Str	ACD1	Start	M	
Op	ACT1	Operate	M	

### 2.3.47 PTOC2

Attribute Name	Attribute Type	Explanation	T, M/O/C/E	Remarks
<b>PTOC class</b>				
PTOC	PTOC2	Time overcurrent		
<b>Data</b>				
<i>Common Mandatory Logical Node Information</i>				
Mod	INC_Mod1	Mode	M	Status-only
Beh	INS_Beh1	Behaviour	M	
Health	INS_Health	Health	M	
NamPlt	LPL1	Name plate	M	
<i>Status Information</i>				
Str	ACD1	Start	M	
Op	ACT1	Operate	M	

### 2.3.48 PTOC3

Attribute Name	Attribute Type	Explanation	T, M/O/C/E	Remarks
<b>PTOC class</b>				
PTOC	PTOC3	Time overcurrent		
<b>Data</b>				
<i>Common Mandatory Logical Node Information</i>				
Mod	INC_Mod1	Mode	M	Status-only
Beh	INS_Beh1	Behaviour	M	
Health	INS_Health	Health	M	
NamPlt	LPL1	Name plate	M	
<i>Status Information</i>				
Str	ACD1	Start	M	
Op	ACT1	Operate	M	

### 2.3.49 PTOF1

Attribute Name	Attribute Type	Explanation	T, M/O/C/E	Remarks
<b>PTOF class</b>				
PTOF	PTOF1	Overfrequency		

2 Logical Nodes  
2.3.50 PTOV1

Attribute Name	Attribute Type	Explanation	T, M/O/C/E	Remarks
<b>Data</b>				
<i>Common Mandatory Logical Node Information</i>				
Mod	INC_Mod1	Mode	M	Status-only
Beh	INS_Beh1	Behaviour	M	
Health	INS_Health	Health	M	
NamPlt	LPL1	Name plate	M	
<i>Status Information</i>				
Str	ACD1	Start	M	
Op	ACT1	Operate	M	

### 2.3.50 PTOV1

Attribute Name	Attribute Type	Explanation	T, M/O/C/E	Remarks
<b>PTOV class</b>				
PTOV	PTOV1	Overvoltage		
<b>Data</b>				
<i>Common Mandatory Logical Node Information</i>				
Mod	INC_Mod1	Mode	M	Status-only
Beh	INS_Beh1	Behaviour	M	
Health	INS_Health	Health	M	
NamPlt	LPL1	Name plate	M	
<i>Status Information</i>				
Str	ACD1	Start	M	
Op	ACT1	Operate	O	

### 2.3.51 PTOV2

Attribute Name	Attribute Type	Explanation	T, M/O/C/E	Remarks
<b>PTOV class</b>				
PTOV	PTOV2	Overvoltage		
<b>Data</b>				
<i>Common Mandatory Logical Node Information</i>				
Mod	INC_Mod1	Mode	M	Status-only
Beh	INS_Beh1	Behaviour	M	

Attribute Name	Attribute Type	Explanation	T, M/O/C/E	Remarks
Health	INS_Health	Health	M	
NamPlt	LPL1	Name plate	M	
<i>Status Information</i>				
Str	ACD1	Start	M	
Op	ACT1	Operate	O	

## 2.3.52 PTOV3

Attribute Name	Attribute Type	Explanation	T, M/O/C/E	Remarks
<b>PTOV class</b>				
PTOV	PTOV3	Overvoltage		
<b>Data</b>				
<i>Common Mandatory Logical Node Information</i>				
Mod	INC_Mod1	Mode	M	Status-only
Beh	INS_Beh1	Behaviour	M	
Health	INS_Health	Health	M	
NamPlt	LPL1	Name plate	M	
<i>Status Information</i>				
Str	ACD1	Start	M	
Op	ACT1	Operate	O	

## 2.3.53 PTRC1

Attribute Name	Attribute Type	Explanation	T, M/O/C/E	Remarks
<b>PTRC class</b>				
PTRC	PTRC1	Protection trip conditioning		
<b>Data</b>				
<i>Common Mandatory Logical Node Information</i>				
Mod	INC_Mod2	Mode	M	Status-only
Beh	INS_Beh2	Behaviour	M	
Health	INS_Health	Health	M	
NamPlt	LPL1	Name plate	M	
<i>Status Information</i>				

Attribute Name	Attribute Type	Explanation	T, M/O/C/E	Remarks
Op	ACT1	Operate	C	

### 2.3.54 PTRC2

Attribute Name	Attribute Type	Explanation	T, M/O/C/E	Remarks
<b>PTRC class</b>				
PTRC	PTRC2	Protection trip conditioning		
<b>Data</b>				
<i>Common Mandatory Logical Node Information</i>				
Mod	INC_Mod1	Mode	M	Status-only
Beh	INS_Beh1	Behaviour	M	
Health	INS_Health	Health	M	
NamPlt	LPL1	Name plate	M	
<i>Status Information</i>				
Str	ACD1	Start	O	
Op	ACT1	Operate	C	

### 2.3.55 PTTR1

Attribute Name	Attribute Type	Explanation	T, M/O/C/E	Remarks
<b>PTTR class</b>				
PTTR	PTTR1	Thermal overload		
<b>Data</b>				
<i>Common Mandatory Logical Node Information</i>				
Mod	INC_Mod1	Mode	M	Status-only
Beh	INS_Beh1	Behaviour	M	
Health	INS_Health	Health	M	
NamPlt	LPL1	Name plate	M	
<i>Status Information</i>				
Op	ACT1	Operate	M	



## 2.3.56 PTUF1

Attribute Name	Attribute Type	Explanation	T, M/O/C/E	Remarks
<b>PTUF class</b>				
PTUF	PTUF1	Underfrequency		
<b>Data</b>				
<i>Common Mandatory Logical Node Information</i>				
Mod	INC_Mod1	Mode	M	Status-only
Beh	INS_Beh1	Behaviour	M	
Health	INS_Health	Health	M	
NamPlt	LPL1	Name plate	M	
<i>Status Information</i>				
Str	ACD1	Start	M	
Op	ACT1	Operate	M	

## 2.3.57 PTUV1

Attribute Name	Attribute Type	Explanation	T, M/O/C/E	Remarks
<b>PTUV class</b>				
PTUV	PTUV1	Undervoltage		
<b>Data</b>				
<i>Common Mandatory Logical Node Information</i>				
Mod	INC_Mod1	Mode	M	Status-only
Beh	INS_Beh1	Behaviour	M	
Health	INS_Health	Health	M	
NamPlt	LPL1	Name plate	M	
<i>Status Information</i>				
Str	ACD1	Start	M	
Op	ACT1	Operate	M	

## 2.3.58 PTUV2

Attribute Name	Attribute Type	Explanation	T, M/O/C/E	Remarks
<b>PTUV class</b>				
PTUV	PTUV2	Undervoltage		

Attribute Name	Attribute Type	Explanation	T, M/O/C/E	Remarks
<b>Data</b>				
<i>Common Mandatory Logical Node Information</i>				
Mod	INC_Mod1	Mode	M	Status-only
Beh	INS_Beh1	Behaviour	M	
Health	INS_Health	Health	M	
NamPlt	LPL1	Name plate	M	
<i>Status Information</i>				
Str	ACD1	Start	M	
Op	ACT1	Operate	M	

### 2.3.59 PTUV3

Attribute Name	Attribute Type	Explanation	T, M/O/C/E	Remarks
<b>PTUV class</b>				
PTUV	PTUV3	Undervoltage		
<b>Data</b>				
<i>Common Mandatory Logical Node Information</i>				
Mod	INC_Mod1	Mode	M	Status-only
Beh	INS_Beh1	Behaviour	M	
Health	INS_Health	Health	M	
NamPlt	LPL1	Name plate	M	
<i>Status Information</i>				
Str	ACD1	Start	M	
Op	ACT1	Operate	M	

### 2.3.60 PTUV4

Attribute Name	Attribute Type	Explanation	T, M/O/C/E	Remarks
<b>PTUV class</b>				
PTUV	PTUV4	Undervoltage		
<b>Data</b>				
<i>Common Mandatory Logical Node Information</i>				
Mod	INC_Mod1	Mode	M	Status-only
Beh	INS_Beh1	Behaviour	M	

Attribute Name	Attribute Type	Explanation	T, M/O/C/E	Remarks
Health	INS_Health	Health	M	
NamPlt	LPL1	Name plate	M	
<i>Status Information</i>				
Str	ACD1	Start	M	
Op	ACT1	Operate	M	

### 2.3.61 PTUV5

Attribute Name	Attribute Type	Explanation	T, M/O/C/E	Remarks
<b>PTUV class</b>				
PTUV	PTUV5	Undervoltage		
<b>Data</b>				
<i>Common Mandatory Logical Node Information</i>				
Mod	INC_Mod1	Mode	M	Status-only
Beh	INS_Beh1	Behaviour	M	
Health	INS_Health	Health	M	
NamPlt	LPL1	Name plate	M	
<i>Status Information</i>				
Str	ACD1	Start	M	
Op	ACT1	Operate	M	

### 2.3.62 PUPF1

Attribute Name	Attribute Type	Explanation	T, M/O/C/E	Remarks
<b>PUPF class</b>				
PUPF	PUPF1	Underpower factor		
<b>Data</b>				
<i>Common Mandatory Logical Node Information</i>				
Mod	INC_Mod1	Mode	M	Status-only
Beh	INS_Beh1	Behaviour	M	
Health	INS_Health	Health	M	
NamPlt	LPL1	Name plate	M	
<i>Status Information</i>				
Str	ACD1	Start	M	

Attribute Name	Attribute Type	Explanation	T, M/O/C/E	Remarks
Op	ACT1	Operate	M	

### 2.3.63 PVPH1

Attribute Name	Attribute Type	Explanation	T, M/O/C/E	Remarks
<b>PVPH class</b>				
PVPH	PVPH1	Volts per Hz		
<b>Data</b>				
<i>Common Mandatory Logical Node Information</i>				
Mod	INC_Mod1	Mode	M	Status-only
Beh	INS_Beh1	Behaviour	M	
Health	INS_Health	Health	M	
NamPlt	LPL1	Name plate	M	
<i>Status Information</i>				
Str	ACD1	Start	M	
Op	ACT1	Operate	M	

### 2.3.64 RBRF1

Attribute Name	Attribute Type	Explanation	T, M/O/C/E	Remarks
<b>RBRF class</b>				
RBRF	RBRF1	Breaker failure		
<b>Data</b>				
<i>Common Mandatory Logical Node Information</i>				
Mod	INC_Mod1	Mode	M	Status-only
Beh	INS_Beh1	Behaviour	M	
Health	INS_Health	Health	M	
NamPlt	LPL1	Name plate	M	
<i>Status Information</i>				
Str	ACD1	Start	O	
OpEx	ACT1	Breaker failure trip	C	

## 2.3.65 RDRE1

Attribute Name	Attribute Type	Explanation	T, M/O/C/E	Remarks
<b>RDRE class</b>				
RDRE	RDRE1	Disturbance recorder function		
<b>Data</b>				
<i>Common Mandatory Logical Node Information</i>				
Mod	INC_Mod2	Mode	M	Status-only
Beh	INS_Beh2	Behaviour	M	
Health	INS_Health	Health	M	
NamPlt	LPL1	Name plate	M	
<i>Status Information</i>				
RcdMade	SPS1	Recording made	M	
FltNum	INS1	Fault Number	M	
GriFltNum	INS1	Grid Fault Number	O	
RcdStr	SPS1	Recording started	O	

## 2.3.66 RREC1

Attribute Name	Attribute Type	Explanation	T, M/O/C/E	Remarks
<b>RREC class</b>				
RREC	RREC1	Autoreclosing		
<b>Data</b>				
<i>Common Mandatory Logical Node Information</i>				
Mod	INC_Mod1	Mode	M	Status-only
Beh	INS_Beh1	Behaviour	M	
Health	INS_Health	Health	M	
NamPlt	LPL1	Name plate	M	
<i>Status Information</i>				
Op	ACT1	Operate	M	
AutoRecSt	INS_AutoRecSt	Auto Reclosing Status	M	

### 2.3.67 RSYN1

Attribute Name	Attribute Type	Explanation	T, M/O/C/E	Remarks
<b>RSYN class</b>				
RSYN	RSYN1	Synchronism-check or synchronising		
<b>Data</b>				
<i>Common Mandatory Logical Node Information</i>				
Mod	INC_Mod1	Mode	M	Status-only
Beh	INS_Beh1	Behaviour	M	
Health	INS_Health	Health	M	
NamPlt	LPL1	Name plate	M	
<i>Status Information</i>				
Rel	SPS1	Ready to Close	M	
AngInd	SPS1	Phase Angle difference too high	O	
HzInd	SPS1	Frequency difference too high	O	
VInd	SPS1	Voltage difference too high	O	
<i>Measured values</i>				
DifAngClc	MV1	Phase Angle difference value	O	
DifHzClc	MV1	Frequency difference value	O	
DifVClc	MV1	Voltage difference value	O	

### 2.3.68 SCBR1 - (Extension)

Attribute Name	Attribute Type	Explanation	T, M/O/C/E	Remarks
<b>SCBR class</b>				
SCBR	SCBR1	Circuit breaker supervision		
<b>Data</b>				
<i>Extensions</i>				
Mod	INC_Mod1	Mode	E	Status-only
Beh	INS_Beh1	Behaviour	E	
Health	INS_Health	Health	E	
NamPlt	LPL1	Name plate	E	
TrCctAlm	ACD1	Alarm signal	E	

## 2.3.69 XCBR1

Attribute Name	Attribute Type	Explanation	T, M/O/C/E	Remarks
<b>XCBR class</b>				
XCBR	XCBR1	Circuit breaker		
<b>Data</b>				
<i>Common Mandatory Logical Node Information</i>				
Mod	INC_Mod2	Mode	M	Status-only
Beh	INS_Beh2	Behaviour	M	
Health	INS_Health	Health	M	
NamPlt	LPL1	Name plate	M	
<i>Logical Node Information</i>				
Loc	SPS1	Local operation	M	
OpCnt	INS1	Operation counter	M	
<i>Controls</i>				
Pos	DPC1	Switch Position	M	
BlkOpn	SPC1	Block opening	M	
BlkCls	SPC1	Block closing	M	
<i>Status Information</i>				
CBOpCap	INS_CBOpCap	Circuit breaker operating capability	M	

## 2.3.70 XSWI1

Attribute Name	Attribute Type	Explanation	T, M/O/C/E	Remarks
<b>XSWI class</b>				
XSWI	XSWI1	Circuit switch		
<b>Data</b>				
<i>Common Mandatory Logical Node Information</i>				
Mod	INC_Mod2	Mode	M	Status-only
Beh	INS_Beh2	Behaviour	M	
Health	INS_Health	Health	M	
NamPlt	LPL1	Name plate	M	
<i>Logical Node Information</i>				
Loc	SPS1	Local operation	M	
OpCnt	INS1	Operation counter	M	
<i>Controls</i>				

## 2 Logical Nodes

### 2.3.70 XSWI1

<b>Attribute Name</b>	<b>Attribute Type</b>	<b>Explanation</b>	<b>T, M/O/C/E</b>	<b>Remarks</b>
Pos	DPC1	Switch Position	M	
BlkOpn	SPC1	Block opening	M	
BlkCls	SPC1	Block closing	M	
<i>Status Information</i>				
SwTyp	INS_CBOpCap	Switch type	M	
SwOpCap	INS_CBOpCap	Switch operating capability	M	



## 3 Common Data Class

### 3.1 Common Data Class Definitions

The following table contains the list of Common Data Classes implemented in the device:

CDC Type	CDC Class	Description
ACD1	ACD	Directional protection activation information
ACT1	ACT	Protection activation information
BCR1	BCR	Binary counter reading
CMV1	CMV	Complex measured value
Cancel1		
DEL1	DEL	Phase to phase related measured values of a three phase system
DPC1	DPC	Controllable double point
DPC2	DPC	Controllable double point
DPL1	DPL	Device name plate
INC_Mod1	INC	Controllable integer status
INC_Mod2	INC	Controllable integer status
INS1	INS	Integer status
INS_AutoRecSt	INS	Integer status
INS_Beh1	INS	Integer status
INS_Beh2	INS	Integer status
INS_CBOpCap	INS	Integer status
INS_Health	INS	Integer status
LPL1	LPL	Logical node name plate
LPL2	LPL	Logical node name plate
LPL3	LPL	Logical node name plate
MV1	MV	Measured value
Oper1		
PulseConfig1		
SPC1	SPC	Controllable single point
SPC2	SPC	Controllable single point
SPS1	SPS	Single point status
WYE1	WYE	Phase to ground related measured values of a three phase system
WYE2	WYE	Phase to ground related measured values of a three phase system
analogValue1		
origin1		
units1		
vector1		

### 3.1.1 Data Objects Type Definitions

#### 3.1.1.1 ACD1

Attribute Name	Attribute Type	FC	TrgOp	Value / Value Range	M/O/C/E	Remarks
<b>ACD class</b> - Directional protection activation information						
status						
general	BOOLEAN	ST	dchg		M	
dirGeneral	Enum	ST	dchg	dir	M	
q	Quality	ST	qchg		M	
t	Timestamp	ST			M	

#### 3.1.1.2 ACT1

Attribute Name	Attribute Type	FC	TrgOp	Value / Value Range	M/O/C/E	Remarks
<b>ACT class</b> - Protection activation information						
status						
general	BOOLEAN	ST	dchg		M	
q	Quality	ST	qchg		M	
t	Timestamp	ST			M	

#### 3.1.1.3 BCR1

Attribute Name	Attribute Type	FC	TrgOp	Value / Value Range	M/O/C/E	Remarks
<b>BCR class</b> - Binary counter reading						
status						
actVal	INT64	ST	dchg		M	
q	Quality	ST	qchg		M	
t	Timestamp	ST			M	
configuration, description and extension						
pulsQty	FLOAT32	CF	dchg		M	
units	Struct	CF		units1	O	

**3.1.1.4 CMV1**

Attribute Name	Attribute Type	FC	TrgOp	Value / Value Range	M/O/C/E	Remarks
<b>CMV class</b> - Complex measured value						
measured attributes						
instCVal	Struct	MX		vector1	O	
cVal	Struct	MX	dchg dupd	vector1	M	
q	Quality	MX	qchg		M	
t	Timestamp	MX			M	
configuration, description and extension						
units	Struct	CF		units1	O	
db	INT32U	CF	dchg		O	
Extensions						
dbAng	INT32U	CF	dchg		E	

**3.1.1.5 DEL1**

Attribute Name	Attribute Type	FC	TrgOp	Value / Value Range	M/O/C/E	Remarks
<b>DEL class</b> - Phase to phase related measured values of a three phase system						
SubDataObject						
phsAB	CMV1				E	
phsBC	CMV1				E	
phsCA	CMV1				E	

**3.1.1.6 DPC1**

Attribute Name	Attribute Type	FC	TrgOp	Value / Value Range	M/O/C/E	Remarks
<b>DPC class</b> - Controllable double point						
control and status						
stVal	Dbpos	ST	dchg		M	
q	Quality	ST	qchg		M	
t	Timestamp	ST			M	
configuration, description and extension						

Attribute Name	Attribute Type	FC	TrgOp	Value / Value Range	M/O/C/E	Remarks
ctlModel	Enum	CF		ctlModel	M	

### 3.1.1.7 DPC2

Attribute Name	Attribute Type	FC	TrgOp	Value / Value Range	M/O/C/E	Remarks
<b>DPC class</b> - Controllable double point						
control and status						
origin	Struct	ST		origin1	C	
ctlNum	INT8U	ST			C	
stVal	Dbpos	ST	dchg		M	
q	Quality	ST	qchg		M	
t	Timestamp	ST			M	
stSeld	BOOLEAN	ST	dchg		C	
configuration, description and extension						
ctlModel	Enum	CF		ctlModel	M	
sboTimeout	INT32U	CF			C	
sboClass	Enum	CF		sboClass	C	
Extensions						
SBOw	Struct	CO		Oper1	E	
Oper	Struct	CO		Oper1	E	
Cancel	Struct	CO		Cancel1	E	
operTimeout	INT32U	CF			E	

### 3.1.1.8 DPL1

Attribute Name	Attribute Type	FC	TrgOp	Value / Value Range	M/O/C/E	Remarks
<b>DPL class</b> - Device name plate						
configuration, description and extension						
vendor	VisString255	DC			M	

**3.1.1.9 INC\_Mod1**

Attribute Name	Attribute Type	FC	TrgOp	Value / Value Range	M/O/C/E	Remarks
<b>INC class</b> – Controllable integer status						
control and status						
stVal	Enum	ST	dchg	Mod1	M	
q	Quality	ST	qchg		M	
t	Timestamp	ST			M	
configuration, description and extension						
ctlModel	Enum	CF		ctlModel	M	

**3.1.1.10 INC\_Mod2**

Attribute Name	Attribute Type	FC	TrgOp	Value / Value Range	M/O/C/E	Remarks
<b>INC class</b> – Controllable integer status						
control and status						
stVal	Enum	ST	dchg	Mod2	M	
q	Quality	ST	qchg		M	
t	Timestamp	ST			M	
configuration, description and extension						
ctlModel	Enum	CF		ctlModel	M	

**3.1.1.11 INS1**

Attribute Name	Attribute Type	FC	TrgOp	Value / Value Range	M/O/C/E	Remarks
<b>INS class</b> – Integer status						
status						
stVal	INT32	ST	dchg		M	
q	Quality	ST	qchg		M	
t	Timestamp	ST			M	

### 3.1.1.12 INS\_AutoRecSt

Attribute Name	Attribute Type	FC	TrgOp	Value / Value Range	M/O/C/E	Remarks
<b>INS class</b> - Integer status						
status						
stVal	Enum	ST	dchg	AutoRecSt	M	
q	Quality	ST	qchg		M	
t	Timestamp	ST			M	

### 3.1.1.13 INS\_Beh1

Attribute Name	Attribute Type	FC	TrgOp	Value / Value Range	M/O/C/E	Remarks
<b>INS class</b> - Integer status						
status						
stVal	Enum	ST	dchg	Beh1	M	
q	Quality	ST	qchg		M	
t	Timestamp	ST			M	

### 3.1.1.14 INS\_Beh2

Attribute Name	Attribute Type	FC	TrgOp	Value / Value Range	M/O/C/E	Remarks
<b>INS class</b> - Integer status						
status						
stVal	Enum	ST	dchg	Beh2	M	
q	Quality	ST	qchg		M	
t	Timestamp	ST			M	

### 3.1.1.15 INS\_CBOpCap

Attribute Name	Attribute Type	FC	TrgOp	Value / Value Range	M/O/C/E	Remarks
<b>INS class</b> - Integer status						
status						
stVal	Enum	ST	dchg	CBOpCap	M	
q	Quality	ST	qchg		M	

Attribute Name	Attribute Type	FC	TrgOp	Value / Value Range	M/O/C/E	Remarks
t	Timestamp	ST			M	

### 3.1.1.16 INS\_Health

Attribute Name	Attribute Type	FC	TrgOp	Value / Value Range	M/O/C/E	Remarks
<b>INS class</b> - Integer status						
status						
stVal	Enum	ST	dchg	Health	M	
q	Quality	ST	qchg		M	
t	Timestamp	ST			M	

### 3.1.1.17 LPL1

Attribute Name	Attribute Type	FC	TrgOp	Value / Value Range	M/O/C/E	Remarks
<b>LPL class</b> - Logical node name plate						
configuration, description and extension						
vendor	VisString255	DC			M	
swRev	VisString255	DC			M	
d	VisString255	DC			M	

### 3.1.1.18 LPL2

Attribute Name	Attribute Type	FC	TrgOp	Value / Value Range	M/O/C/E	Remarks
<b>LPL class</b> - Logical node name plate						
configuration, description and extension						
vendor	VisString255	DC			M	
swRev	VisString255	DC			M	
d	VisString255	DC			M	
ldNs	VisString255	EX			C	
configRev	VisString255	DC			C	

### 3.1.1.19 LPL3

Attribute Name	Attribute Type	FC	TrgOp	Value / Value Range	M/O/C/E	Remarks
<b>LPL class</b> – Logical node name plate						
configuration, description and extension						
vendor	VisString255	DC			M	
swRev	VisString255	DC			M	
d	VisString255	DC			M	
InNs	VisString255	EX			C	

### 3.1.1.20 MV1

Attribute Name	Attribute Type	FC	TrgOp	Value / Value Range	M/O/C/E	Remarks
<b>MV class</b> – Measured value						
measured attributes						
mag	Struct	MX	dchg dupd	analogValue1	M	
q	Quality	MX	qchg		M	
t	Timestamp	MX			M	
configuration, description and extension						
units	Struct	CF		units1	O	
db	INT32U	CF	dchg		O	
d	VisString255	DC			O	
dataNs	VisString255	EX			C	

### 3.1.1.21 SPC1

Attribute Name	Attribute Type	FC	TrgOp	Value / Value Range	M/O/C/E	Remarks
<b>SPC class</b> – Controllable single point						
control and status						
stVal	BOOLEAN	ST	dchg		C	
q	Quality	ST	qchg		C	
t	Timestamp	ST			C	
configuration, description and extension						



Attribute Name	Attribute Type	FC	TrgOp	Value / Value Range	M/O/C/E	Remarks
ctlModel	Enum	CF		<a href="#">ctlModel</a>	M	

### 3.1.1.22 SPC2

Attribute Name	Attribute Type	FC	TrgOp	Value / Value Range	M/O/C/E	Remarks
<b>SPC class</b> - Controllable single point						
control and status						
stVal	BOOLEAN	ST	dchg		C	
q	Quality	ST	qchg		C	
t	Timestamp	ST			C	
configuration, description and extension						
ctlModel	Enum	CF		<a href="#">ctlModel</a>	M	
pulseConfig	Struct	CF		<a href="#">PulseConfig1</a>	C	
Extensions						
Oper	Struct	CO		<a href="#">Oper1</a>	E	

### 3.1.1.23 SPS1

Attribute Name	Attribute Type	FC	TrgOp	Value / Value Range	M/O/C/E	Remarks
<b>SPS class</b> - Single point status						
status						
stVal	BOOLEAN	ST	dchg		M	
q	Quality	ST	qchg		M	
t	Timestamp	ST			M	

### 3.1.1.24 WYE1

Attribute Name	Attribute Type	FC	TrgOp	Value / Value Range	M/O/C/E	Remarks
<b>WYE class</b> - Phase to ground related measured values of a three phase system						
SubDataObject						
phsA	CMV1				E	
phsB	CMV1				E	
phsC	CMV1				E	

### 3 Common Data Class

#### 3.1.1.25 WYE2

Attribute Name	Attribute Type	FC	TrgOp	Value / Value Range	M/O/C/E	Remarks
neut	CMV1				E	

#### 3.1.1.25 WYE2

Attribute Name	Attribute Type	FC	TrgOp	Value / Value Range	M/O/C/E	Remarks
<b>WYE class</b> - Phase to ground related measured values of a three phase system						
SubDataObject						
phsA	CMV1				E	
phsB	CMV1				E	
phsC	CMV1				E	

## 3.2 Data Attributes Type Definitions

### 3.2.1 analogValue1

Attribute Name	Attribute Type	Value / Value Range
f	FLOAT32	

### 3.2.2 Cancel1

Attribute Name	Attribute Type	Value / Value Range
ctlVal	BOOLEAN	
origin	Struct	<a href="#">origin1</a>
ctlNum	INT8U	
T	Timestamp	
Test	BOOLEAN	

### 3.2.3 Oper1

Attribute Name	Attribute Type	Value / Value Range
ctlVal	BOOLEAN	
origin	Struct	<a href="#">origin1</a>
ctlNum	INT8U	
T	Timestamp	
Test	BOOLEAN	
Check	Check	

### 3.2.4 origin1

Attribute Name	Attribute Type	Value / Value Range
orCat	Enum	<a href="#">orCategory</a>
orIdent	Octet64	

### 3.2.5 PulseConfig1

Attribute Name	Attribute Type	Value / Value Range
cmdQual	Enum	cmdQual
onDur	INT32U	
offDur	INT32U	
numPls	INT32U	

### 3.2.6 units1

Attribute Name	Attribute Type	Value / Value Range
SIUnit	Enum	SIUnit
multiplier	Enum	multiplier

### 3.2.7 vector1

Attribute Name	Attribute Type	Value / Value Range
mag	Struct	analogValue1
ang	Struct	analogValue1

### 3.3 Enumerated Type Definitions

#### 3.3.1 AutoRecSt

Ordinal	Semantic
1	Ready
2	InProgress
3	Successful

#### 3.3.2 Beh1

Ordinal	Semantic
1	on
2	blocked
3	test
4	test/blocked
5	off

#### 3.3.3 Beh2

Ordinal	Semantic
1	on
3	test

#### 3.3.4 CBOpCap

Ordinal	Semantic
1	None
2	Open
3	Close-Open
4	Open-Close-Open
5	Close-Open-Close-Open

### 3.3.5 cmdQual

Ordinal	Semantic
0	pulse
1	persistent

### 3.3.6 ctlModel

Ordinal	Semantic
0	status-only
1	direct-with-normal-security
2	sbo-with-normal-security
3	direct-with-enhanced-security
4	sbo-with-enhanced-security

### 3.3.7 Dbpos

Ordinal	Semantic
0	intermediate
1	off
2	on
3	bad

### 3.3.8 dir

Ordinal	Semantic
0	unknown
1	forward
2	backward
3	both

### 3.3.9 Health

Ordinal	Semantic
1	Ok

Ordinal	Semantic
2	Warning
3	Alarm

### 3.3.10 Mod1

Ordinal	Semantic
1	on
2	blocked
3	test
4	test/blocked
5	off

### 3.3.11 Mod2

Ordinal	Semantic
1	on
3	test

### 3.3.12 multiplier

Ordinal	Semantic
-24	y
-21	z
-18	a
-15	f
-12	p
-9	n
-6	$\mu$
-3	m
-2	c
-1	d
0	
1	da

Ordinal	Semantic
2	h
3	k
6	M
9	G
12	T
15	P
18	E
21	Z
24	Y

### 3.3.13 orCategory

Ordinal	Semantic
0	not-supported
1	bay-control
2	station-control
3	remote-control
4	automatic-bay
5	automatic-station
6	automatic-remote
7	maintenance
8	process

### 3.3.14 sboClass

Ordinal	Semantic
0	operate-once
1	operate-many

### 3.3.15 SIUnit

Ordinal	Semantic
1	



Ordinal	Semantic
2	m
3	kg
4	s
5	A
6	K
7	mol
8	cd
9	deg
10	rad
11	sr
21	Gy
22	q
23	°C
24	Sv
25	F
26	C
27	S
28	H
29	V
30	ohm
31	J
32	N
33	Hz
34	lx
35	Lm
36	Wb
37	T
38	W
39	Pa
41	m <sup>2</sup>
42	m <sup>3</sup>
43	m/s

Ordinal	Semantic
44	$m/s^2$
45	$m^3/s$
46	$m/m^3$
47	M
48	$kg/m^3$
49	$m^2/s$
50	W/m K
51	J/K
52	ppm
53	1/s
54	rad/s
61	VA
62	Watts
63	VAr
64	phi
65	$\cos(\text{phi})$
66	Vs
67	$V^2$
68	As
69	$A^2$
70	$A^2t$
71	VAh
72	Wh
73	VArh
74	V/Hz

## 4 Appendix

### 4.1 Register Maps

Legend: \* The Logical Node is dependent on the settings in the “Device planning”. (See [4.2 Device Planning Dependencies](#)).

#### 4.1.1 LDevice::CTRL

Logical Node	Data Object	Module ( - ANSI/IEEE Device Number ) . Name
<b>CILO1* (CILO1)</b>		
	Mod	
	Beh	
	Health	
	NamPlt	
	EnaOpn	»SG[1] . Interl OFF«
	EnaCls	»SG[1] . Interl ON«

Logical Node	Data Object	Module ( - ANSI/IEEE Device Number ) . Name
<b>CILO2* (CILO1)</b>		
	Mod	
	Beh	
	Health	
	NamPlt	
	EnaOpn	»SG[2] . Interl OFF«
	EnaCls	»SG[2] . Interl ON«

Logical Node	Data Object	Module ( - ANSI/IEEE Device Number ) . Name
<b>CILO3* (CILO1)</b>		
	Mod	
	Beh	
	Health	
	NamPlt	
	EnaOpn	»SG[3] . Interl OFF«
	EnaCls	»SG[3] . Interl ON«

Logical Node	Data Object	Module ( - ANSI/IEEE Device Number ) . Name
<b>CILO4* (CILO1)</b>		
	Mod	
	Beh	
	Health	

Logical Node	Data Object	Module ( - ANSI/IEEE Device Number ) . Name
<b>CILO4* (CILO1)</b>		
	NamPlt	
	EnaOpn	»SG[4] . Interl OFF«
	EnaCls	»SG[4] . Interl ON«

Logical Node	Data Object	Module ( - ANSI/IEEE Device Number ) . Name
<b>CILO5* (CILO1)</b>		
	Mod	
	Beh	
	Health	
	NamPlt	
	EnaOpn	»SG[5] . Interl OFF«
	EnaCls	»SG[5] . Interl ON«

Logical Node	Data Object	Module ( - ANSI/IEEE Device Number ) . Name
<b>CILO6* (CILO1)</b>		
	Mod	
	Beh	
	Health	
	NamPlt	
	EnaOpn	»SG[6] . Interl OFF«
	EnaCls	»SG[6] . Interl ON«

Logical Node	Data Object	Module ( - ANSI/IEEE Device Number ) . Name
<b>CSWI1* (CSWI1)</b>		
	Mod	
	Beh	
	Health	
	NamPlt	
	Loc	»Ctrl . Remote«
	Pos	»SG[1] . Pos« »SG[1] . t-Move ON« »SG[1] . t-Move OFF«

Logical Node	Data Object	Module ( - ANSI/IEEE Device Number ) . Name
<b>CSWI2* (CSWI1)</b>		
	Mod	
	Beh	

Logical Node	Data Object	Module ( - ANSI/IEEE Device Number ) . Name
<b>CSWI2* (CSWI1)</b>		
	Health	
	NamPlt	
	Loc	»Ctrl . Remote«
	Pos	»SG[2] . Pos« »SG[2] . t-Move ON« »SG[2] . t-Move OFF«

Logical Node	Data Object	Module ( - ANSI/IEEE Device Number ) . Name
<b>CSWI3* (CSWI1)</b>		
	Mod	
	Beh	
	Health	
	NamPlt	
	Loc	»Ctrl . Remote«
	Pos	»SG[3] . Pos« »SG[3] . t-Move ON« »SG[3] . t-Move OFF«

Logical Node	Data Object	Module ( - ANSI/IEEE Device Number ) . Name
<b>CSWI4* (CSWI1)</b>		
	Mod	
	Beh	
	Health	
	NamPlt	
	Loc	»Ctrl . Remote«
	Pos	»SG[4] . Pos« »SG[4] . t-Move ON« »SG[4] . t-Move OFF«

Logical Node	Data Object	Module ( - ANSI/IEEE Device Number ) . Name
<b>CSWI5* (CSWI1)</b>		
	Mod	
	Beh	
	Health	
	NamPlt	
	Loc	»Ctrl . Remote«

Logical Node	Data Object	Module ( - ANSI/IEEE Device Number ) . Name
<b>CSWI5* (CSWI1)</b>		
	Pos	»SG[5] . Pos« »SG[5] . t-Move ON« »SG[5] . t-Move OFF«

Logical Node	Data Object	Module ( - ANSI/IEEE Device Number ) . Name
<b>CSWI6* (CSWI1)</b>		
	Mod	
	Beh	
	Health	
	NamPlt	
	Loc	»Ctrl . Remote«
	Pos	»SG[6] . Pos« »SG[6] . t-Move ON« »SG[6] . t-Move OFF«

Logical Node	Data Object	Module ( - ANSI/IEEE Device Number ) . Name
<b>LLN0 (LLN0CON)</b>		
	Mod	
	Beh	
	Health	
	NamPlt	

Logical Node	Data Object	Module ( - ANSI/IEEE Device Number ) . Name
<b>LPHD1 (LPHDCON)</b>		
	PhyNam	
	PhyHealth	
	Proxy	

Logical Node	Data Object	Module ( - ANSI/IEEE Device Number ) . Name
<b>TCSSCBR1 (SCBR1)</b>		
	Mod	»TCS . Active«
	Beh	
	Health	
	NamPlt	
	TrCctAlm	»TCS . Alarm«

Logical Node	Data Object	Module ( - ANSI/IEEE Device Number ) . Name
<b>XCBR1* (XCBR1)</b>		
	Mod	
	Beh	
	Health	
	NamPlt	
	Loc	»Ctrl . Remote«
	OpCnt	»SG[1] . TripCmd Cr«
	Pos	»SG[1] . Pos«
	BlkOpn	
	BlkCls	
	CBOpCap	

Logical Node	Data Object	Module ( - ANSI/IEEE Device Number ) . Name
<b>XCBR2* (XCBR1)</b>		
	Mod	
	Beh	
	Health	
	NamPlt	
	Loc	»Ctrl . Remote«
	OpCnt	»SG[2] . TripCmd Cr«
	Pos	»SG[2] . Pos«
	BlkOpn	
	BlkCls	
	CBOpCap	

Logical Node	Data Object	Module ( - ANSI/IEEE Device Number ) . Name
<b>XCBR3* (XCBR1)</b>		
	Mod	
	Beh	
	Health	
	NamPlt	
	Loc	»Ctrl . Remote«
	OpCnt	»SG[3] . TripCmd Cr«
	Pos	»SG[3] . Pos«
	BlkOpn	
	BlkCls	
	CBOpCap	

Logical Node	Data Object	Module ( - ANSI/IEEE Device Number ) . Name
<b>XCBR4* (XCBR1)</b>		
	Mod	
	Beh	
	Health	
	NamPlt	
	Loc	»Ctrl . Remote«
	OpCnt	»SG[4] . TripCmd Cr«
	Pos	»SG[4] . Pos«
	BlkOpn	
	BlkCls	
	CBOpCap	

Logical Node	Data Object	Module ( - ANSI/IEEE Device Number ) . Name
<b>XCBR5* (XCBR1)</b>		
	Mod	
	Beh	
	Health	
	NamPlt	
	Loc	»Ctrl . Remote«
	OpCnt	»SG[5] . TripCmd Cr«
	Pos	»SG[5] . Pos«
	BlkOpn	
	BlkCls	
	CBOpCap	

Logical Node	Data Object	Module ( - ANSI/IEEE Device Number ) . Name
<b>XCBR6* (XCBR1)</b>		
	Mod	
	Beh	
	Health	
	NamPlt	
	Loc	»Ctrl . Remote«
	OpCnt	»SG[6] . TripCmd Cr«
	Pos	»SG[6] . Pos«
	BlkOpn	
	BlkCls	
	CBOpCap	



Logical Node	Data Object	Module ( - ANSI/IEEE Device Number ) . Name
<b>XSWI1* (XSWI1)</b>		
	Mod	
	Beh	
	Health	
	NamPlt	
	Loc	»Ctrl . Remote«
	OpCnt	»SG[1] . TripCmd Cr«
	Pos	»SG[1] . Pos«
	BlkOpn	
	BlkCls	
	SwTyp	
	SwOpCap	

Logical Node	Data Object	Module ( - ANSI/IEEE Device Number ) . Name
<b>XSWI2* (XSWI1)</b>		
	Mod	
	Beh	
	Health	
	NamPlt	
	Loc	»Ctrl . Remote«
	OpCnt	»SG[2] . TripCmd Cr«
	Pos	»SG[2] . Pos«
	BlkOpn	
	BlkCls	
	SwTyp	
	SwOpCap	

Logical Node	Data Object	Module ( - ANSI/IEEE Device Number ) . Name
<b>XSWI3* (XSWI1)</b>		
	Mod	
	Beh	
	Health	
	NamPlt	
	Loc	»Ctrl . Remote«
	OpCnt	»SG[3] . TripCmd Cr«
	Pos	»SG[3] . Pos«
	BlkOpn	
	BlkCls	

Logical Node	Data Object	Module ( - ANSI/IEEE Device Number ) . Name
<b>XSWI3* (XSWI1)</b>		
	SwTyp	
	SwOpCap	

Logical Node	Data Object	Module ( - ANSI/IEEE Device Number ) . Name
<b>XSWI4* (XSWI1)</b>		
	Mod	
	Beh	
	Health	
	NamPlt	
	Loc	»Ctrl . Remote«
	OpCnt	»SG[4] . TripCmd Cr«
	Pos	»SG[4] . Pos«
	BlkOpn	
	BlkCls	
	SwTyp	
	SwOpCap	

Logical Node	Data Object	Module ( - ANSI/IEEE Device Number ) . Name
<b>XSWI5* (XSWI1)</b>		
	Mod	
	Beh	
	Health	
	NamPlt	
	Loc	»Ctrl . Remote«
	OpCnt	»SG[5] . TripCmd Cr«
	Pos	»SG[5] . Pos«
	BlkOpn	
	BlkCls	
	SwTyp	
	SwOpCap	

Logical Node	Data Object	Module ( - ANSI/IEEE Device Number ) . Name
<b>XSWI6* (XSWI1)</b>		
	Mod	
	Beh	
	Health	
	NamPlt	

Logical Node	Data Object	Module ( - ANSI/IEEE Device Number ) . Name
<b>XSWI6* (XSWI1)</b>		
	Loc	»Ctrl . Remote«
	OpCnt	»SG[6] . TripCmd Cr«
	Pos	»SG[6] . Pos«
	BlkOpn	
	BlkCls	
	SwTyp	
	SwOpCap	

## 4.1.2 LDevice::DR

Logical Node	Data Object	Module ( - ANSI/IEEE Device Number ) . Name
<b>LLN0 (LLN0REC)</b>		
	Mod	
	Beh	
	Health	
	NamPlt	

Logical Node	Data Object	Module ( - ANSI/IEEE Device Number ) . Name
<b>LPHD1 (LPHDREC)</b>		
	PhyNam	
	PhyHealth	
	Proxy	

Logical Node	Data Object	Module ( - ANSI/IEEE Device Number ) . Name
<b>RDRE1 (RDRE1)</b>		
	Mod	
	Beh	
	Health	
	NamPlt	
	RcdMade	»Disturb rec . recording«
	FltNum	»Prot . Fault No.«
	GrifltNum	»Prot . No. of Grid Faults«
	RcdStr	»Disturb rec . recording«

### 4.1.3 LDevice::EXT

Logical Node	Data Object	Module ( - ANSI/IEEE Device Number ) . Name
<b>COUTGGIO1 (GGIO1)</b>		
	Mod	
	Beh	
	Health	
	NamPlt	
	Ind1	»IEC 61850 . COUTGGIO1.Ind1.stVal-I«
	Ind2	»IEC 61850 . COUTGGIO1.Ind2.stVal-I«
	Ind3	»IEC 61850 . COUTGGIO1.Ind3.stVal-I«
	Ind4	»IEC 61850 . COUTGGIO1.Ind4.stVal-I«
	Ind5	»IEC 61850 . COUTGGIO1.Ind5.stVal-I«
	Ind6	»IEC 61850 . COUTGGIO1.Ind6.stVal-I«
	Ind7	»IEC 61850 . COUTGGIO1.Ind7.stVal-I«
	Ind8	»IEC 61850 . COUTGGIO1.Ind8.stVal-I«
	Ind9	»IEC 61850 . COUTGGIO1.Ind9.stVal-I«
	Ind10	»IEC 61850 . COUTGGIO1.Ind10.stVal-I«
	Ind11	»IEC 61850 . COUTGGIO1.Ind11.stVal-I«
	Ind12	»IEC 61850 . COUTGGIO1.Ind12.stVal-I«
	Ind13	»IEC 61850 . COUTGGIO1.Ind13.stVal-I«
	Ind14	»IEC 61850 . COUTGGIO1.Ind14.stVal-I«
	Ind15	»IEC 61850 . COUTGGIO1.Ind15.stVal-I«
	Ind16	»IEC 61850 . COUTGGIO1.Ind16.stVal-I«
	Ind17	»IEC 61850 . COUTGGIO1.Ind17.stVal-I«
	Ind18	»IEC 61850 . COUTGGIO1.Ind18.stVal-I«
	Ind19	»IEC 61850 . COUTGGIO1.Ind19.stVal-I«
	Ind20	»IEC 61850 . COUTGGIO1.Ind20.stVal-I«
	Ind21	»IEC 61850 . COUTGGIO1.Ind21.stVal-I«
	Ind22	»IEC 61850 . COUTGGIO1.Ind22.stVal-I«
	Ind23	»IEC 61850 . COUTGGIO1.Ind23.stVal-I«
	Ind24	»IEC 61850 . COUTGGIO1.Ind24.stVal-I«
	Ind25	»IEC 61850 . COUTGGIO1.Ind25.stVal-I«
	Ind26	»IEC 61850 . COUTGGIO1.Ind26.stVal-I«
	Ind27	»IEC 61850 . COUTGGIO1.Ind27.stVal-I«
	Ind28	»IEC 61850 . COUTGGIO1.Ind28.stVal-I«
	Ind29	»IEC 61850 . COUTGGIO1.Ind29.stVal-I«
	Ind30	»IEC 61850 . COUTGGIO1.Ind30.stVal-I«
	Ind31	»IEC 61850 . COUTGGIO1.Ind31.stVal-I«

Logical Node	Data Object	Module ( - ANSI/IEEE Device Number ) . Name
<b>COUTGGIO1 (GGIO1)</b>		
	Ind32	»IEC 61850 . COUTGGIO1.Ind32.stVal-I«

Logical Node	Data Object	Module ( - ANSI/IEEE Device Number ) . Name
<b>COUTGGIO2 (GGIO1)</b>		
	Mod	
	Beh	
	Health	
	NamPlt	
	Ind1	»IEC 61850 . COUTGGIO2.Ind1.stVal-I«
	Ind2	»IEC 61850 . COUTGGIO2.Ind2.stVal-I«
	Ind3	»IEC 61850 . COUTGGIO2.Ind3.stVal-I«
	Ind4	»IEC 61850 . COUTGGIO2.Ind4.stVal-I«
	Ind5	»IEC 61850 . COUTGGIO2.Ind5.stVal-I«
	Ind6	»IEC 61850 . COUTGGIO2.Ind6.stVal-I«
	Ind7	»IEC 61850 . COUTGGIO2.Ind7.stVal-I«
	Ind8	»IEC 61850 . COUTGGIO2.Ind8.stVal-I«
	Ind9	»IEC 61850 . COUTGGIO2.Ind9.stVal-I«
	Ind10	»IEC 61850 . COUTGGIO2.Ind10.stVal-I«
	Ind11	»IEC 61850 . COUTGGIO2.Ind11.stVal-I«
	Ind12	»IEC 61850 . COUTGGIO2.Ind12.stVal-I«
	Ind13	»IEC 61850 . COUTGGIO2.Ind13.stVal-I«
	Ind14	»IEC 61850 . COUTGGIO2.Ind14.stVal-I«
	Ind15	»IEC 61850 . COUTGGIO2.Ind15.stVal-I«
	Ind16	»IEC 61850 . COUTGGIO2.Ind16.stVal-I«
	Ind17	»IEC 61850 . COUTGGIO2.Ind17.stVal-I«
	Ind18	»IEC 61850 . COUTGGIO2.Ind18.stVal-I«
	Ind19	»IEC 61850 . COUTGGIO2.Ind19.stVal-I«
	Ind20	»IEC 61850 . COUTGGIO2.Ind20.stVal-I«
	Ind21	»IEC 61850 . COUTGGIO2.Ind21.stVal-I«
	Ind22	»IEC 61850 . COUTGGIO2.Ind22.stVal-I«
	Ind23	»IEC 61850 . COUTGGIO2.Ind23.stVal-I«
	Ind24	»IEC 61850 . COUTGGIO2.Ind24.stVal-I«
	Ind25	»IEC 61850 . COUTGGIO2.Ind25.stVal-I«
	Ind26	»IEC 61850 . COUTGGIO2.Ind26.stVal-I«
	Ind27	»IEC 61850 . COUTGGIO2.Ind27.stVal-I«
	Ind28	»IEC 61850 . COUTGGIO2.Ind28.stVal-I«
	Ind29	»IEC 61850 . COUTGGIO2.Ind29.stVal-I«

Logical Node	Data Object	Module ( - ANSI/IEEE Device Number ) . Name
<b>COUTGGIO2 (GGIO1)</b>		
	Ind30	»IEC 61850 . COUTGGIO2.Ind30.stVal-I«
	Ind31	»IEC 61850 . COUTGGIO2.Ind31.stVal-I«
	Ind32	»IEC 61850 . COUTGGIO2.Ind32.stVal-I«

Logical Node	Data Object	Module ( - ANSI/IEEE Device Number ) . Name
<b>CTLGGIO1 (GGIO4)</b>		
	Mod	
	Beh	
	Health	
	NamPlt	
	SPCSO1	»IEC 61850 . CTLGGIO1.SPCSO1.stVal«
	SPCSO2	»IEC 61850 . CTLGGIO1.SPCSO2.stVal«
	SPCSO3	»IEC 61850 . CTLGGIO1.SPCSO3.stVal«
	SPCSO4	»IEC 61850 . CTLGGIO1.SPCSO4.stVal«
	SPCSO5	»IEC 61850 . CTLGGIO1.SPCSO5.stVal«
	SPCSO6	»IEC 61850 . CTLGGIO1.SPCSO6.stVal«
	SPCSO7	»IEC 61850 . CTLGGIO1.SPCSO7.stVal«
	SPCSO8	»IEC 61850 . CTLGGIO1.SPCSO8.stVal«
	SPCSO9	»IEC 61850 . CTLGGIO1.SPCSO9.stVal«
	SPCSO10	»IEC 61850 . CTLGGIO1.SPCSO10.stVal«
	SPCSO11	»IEC 61850 . CTLGGIO1.SPCSO11.stVal«
	SPCSO12	»IEC 61850 . CTLGGIO1.SPCSO12.stVal«
	SPCSO13	»IEC 61850 . CTLGGIO1.SPCSO13.stVal«
	SPCSO14	»IEC 61850 . CTLGGIO1.SPCSO14.stVal«
	SPCSO15	»IEC 61850 . CTLGGIO1.SPCSO15.stVal«
	SPCSO16	»IEC 61850 . CTLGGIO1.SPCSO16.stVal«
	SPCSO17	»IEC 61850 . CTLGGIO1.SPCSO17.stVal«
	SPCSO18	»IEC 61850 . CTLGGIO1.SPCSO18.stVal«
	SPCSO19	»IEC 61850 . CTLGGIO1.SPCSO19.stVal«
	SPCSO20	»IEC 61850 . CTLGGIO1.SPCSO20.stVal«
	SPCSO21	»IEC 61850 . CTLGGIO1.SPCSO21.stVal«
	SPCSO22	»IEC 61850 . CTLGGIO1.SPCSO22.stVal«
	SPCSO23	»IEC 61850 . CTLGGIO1.SPCSO23.stVal«
	SPCSO24	»IEC 61850 . CTLGGIO1.SPCSO24.stVal«
	SPCSO25	»IEC 61850 . CTLGGIO1.SPCSO25.stVal«
	SPCSO26	»IEC 61850 . CTLGGIO1.SPCSO26.stVal«
	SPCSO27	»IEC 61850 . CTLGGIO1.SPCSO27.stVal«

Logical Node	Data Object	Module ( - ANSI/IEEE Device Number ) . Name
<b>CTLGGIO1 (GGIO4)</b>		
	SPCSO28	»IEC 61850 . CTLGGIO1.SPCSO28.stVal«
	SPCSO29	»IEC 61850 . CTLGGIO1.SPCSO29.stVal«
	SPCSO30	»IEC 61850 . CTLGGIO1.SPCSO30.stVal«
	SPCSO31	»IEC 61850 . CTLGGIO1.SPCSO31.stVal«
	SPCSO32	»IEC 61850 . CTLGGIO1.SPCSO32.stVal«

Logical Node	Data Object	Module ( - ANSI/IEEE Device Number ) . Name
<b>EPGAPC1 (GAPC1)</b>		
	Mod	»Intertripping . Active« »Intertripping . Blo TripCmd« »Intertripping . ExBlo TripCmd«
	Beh	
	Health	
	NamPlt	
	Str	»Intertripping . Alarm«
	Op	»Intertripping . Trip«

Logical Node	Data Object	Module ( - ANSI/IEEE Device Number ) . Name
<b>EPGAPC10 (GAPC1)</b>		
	Mod	»ExtTempSuperv[3] . Active« »ExtTempSuperv[3] . Blo TripCmd« »ExtTempSuperv[3] . ExBlo TripCmd«
	Beh	
	Health	
	NamPlt	
	Str	»ExtTempSuperv[3] . Alarm«
	Op	»ExtTempSuperv[3] . Trip«

Logical Node	Data Object	Module ( - ANSI/IEEE Device Number ) . Name
<b>EPGAPC2 (GAPC1)</b>		
	Mod	»Exp[1] . Active« »Exp[1] . Blo TripCmd« »Exp[1] . ExBlo TripCmd«
	Beh	
	Health	
	NamPlt	

Logical Node	Data Object	Module ( - ANSI/IEEE Device Number ) . Name
<b>EPGAPC2 (GAPC1)</b>		
	Str	»Exp[1] . Alarm«
	Op	»Exp[1] . Trip«

Logical Node	Data Object	Module ( - ANSI/IEEE Device Number ) . Name
<b>EPGAPC3 (GAPC1)</b>		
	Mod	»Exp[2] . Active« »Exp[2] . Blo TripCmd« »Exp[2] . ExBlo TripCmd«
	Beh	
	Health	
	NamPlt	
	Str	»Exp[2] . Alarm«
	Op	»Exp[2] . Trip«

Logical Node	Data Object	Module ( - ANSI/IEEE Device Number ) . Name
<b>EPGAPC4 (GAPC1)</b>		
	Mod	»Exp[3] . Active« »Exp[3] . Blo TripCmd« »Exp[3] . ExBlo TripCmd«
	Beh	
	Health	
	NamPlt	
	Str	»Exp[3] . Alarm«
	Op	»Exp[3] . Trip«

Logical Node	Data Object	Module ( - ANSI/IEEE Device Number ) . Name
<b>EPGAPC5 (GAPC1)</b>		
	Mod	»Exp[4] . Active« »Exp[4] . Blo TripCmd« »Exp[4] . ExBlo TripCmd«
	Beh	
	Health	
	NamPlt	
	Str	»Exp[4] . Alarm«
	Op	»Exp[4] . Trip«



Logical Node	Data Object	Module ( - ANSI/IEEE Device Number ) . Name
<b>EPGAPC6 (GAPC1)</b>		
	Mod	»Ext Sudd Press . Active« »Ext Sudd Press . Blo TripCmd« »Ext Sudd Press . ExBlo TripCmd«
	Beh	
	Health	
	NamPlt	
	Str	»Ext Sudd Press . Alarm«
	Op	»Ext Sudd Press . Trip«

Logical Node	Data Object	Module ( - ANSI/IEEE Device Number ) . Name
<b>EPGAPC7 (GAPC1)</b>		
	Mod	»Ext Oil Temp . Active« »Ext Oil Temp . Blo TripCmd« »Ext Oil Temp . ExBlo TripCmd«
	Beh	
	Health	
	NamPlt	
	Str	»Ext Oil Temp . Alarm«
	Op	»Ext Oil Temp . Trip«

Logical Node	Data Object	Module ( - ANSI/IEEE Device Number ) . Name
<b>EPGAPC8 (GAPC1)</b>		
	Mod	»ExtTempSuperv[1] . Active« »ExtTempSuperv[1] . Blo TripCmd« »ExtTempSuperv[1] . ExBlo TripCmd«
	Beh	
	Health	
	NamPlt	
	Str	»ExtTempSuperv[1] . Alarm«
	Op	»ExtTempSuperv[1] . Trip«

Logical Node	Data Object	Module ( - ANSI/IEEE Device Number ) . Name
<b>EPGAPC9 (GAPC1)</b>		
	Mod	»ExtTempSuperv[2] . Active« »ExtTempSuperv[2] . Blo TripCmd« »ExtTempSuperv[2] . ExBlo TripCmd«

Logical Node	Data Object	Module ( - ANSI/IEEE Device Number ) . Name
<b>EPGAPC9 (GAPC1)</b>		
	Beh	
	Health	
	NamPlt	
	Str	»ExtTempSuperv[2] . Alarm«
	Op	»ExtTempSuperv[2] . Trip«

Logical Node	Data Object	Module ( - ANSI/IEEE Device Number ) . Name
<b>GOSINGGIO1 (GGIO3)</b>		
	Mod	
	Beh	
	Health	
	NamPlt	
	Ind1	
	Ind2	
	Ind3	
	Ind4	
	Ind5	
	Ind6	
	Ind7	
	Ind8	
	Ind9	
	Ind10	
	Ind11	
	Ind12	
	Ind13	
	Ind14	
	Ind15	
	Ind16	
	Ind17	
	Ind18	
	Ind19	
	Ind20	
	Ind21	
	Ind22	
	Ind23	
	Ind24	
	Ind25	

Logical Node	Data Object	Module ( - ANSI/IEEE Device Number ) . Name
<b>GOSINGGIO1 (GGIO3)</b>		
	Ind26	
	Ind27	
	Ind28	
	Ind29	
	Ind30	
	Ind31	
	Ind32	

Logical Node	Data Object	Module ( - ANSI/IEEE Device Number ) . Name
<b>GOSINGGIO2 (GGIO2)</b>		
	Mod	
	Beh	
	Health	
	NamPlt	
	Ind1	
	Ind2	
	Ind3	
	Ind4	
	Ind5	
	Ind6	
	Ind7	
	Ind8	
	Ind9	
	Ind10	
	Ind11	
	Ind12	
	Ind13	
	Ind14	
	Ind15	
	Ind16	
	Ind17	
	Ind18	
	Ind19	
	Ind20	
	Ind21	
	Ind22	
	Ind23	

Logical Node	Data Object	Module ( - ANSI/IEEE Device Number ) . Name
<b>GOSINGGIO2 (GGIO2)</b>		
	Ind24	
	Ind25	
	Ind26	
	Ind27	
	Ind28	
	Ind29	
	Ind30	
	Ind31	
	Ind32	

Logical Node	Data Object	Module ( - ANSI/IEEE Device Number ) . Name
<b>LLN0 (LLN0EXT)</b>		
	Mod	
	Beh	
	Health	
	NamPlt	

Logical Node	Data Object	Module ( - ANSI/IEEE Device Number ) . Name
<b>LPHD1 (LPHD1EXT)</b>		
	PhyNam	
	PhyHealth	
	Proxy	

Logical Node	Data Object	Module ( - ANSI/IEEE Device Number ) . Name
<b>TSGGIO1 (GGIO7)</b>		
	Mod	»Sig-Trans . Active« »Sig-Trans . ExBlo« »Sig-Trans . ExBlo«
	Beh	
	Health	
	NamPlt	
	Ind1	»Sig-Trans . Rx.Signal1«
	Ind2	»Sig-Trans . Rx.Signal2«
	Ind3	»Sig-Trans . Rx.Signal3«
	Ind4	»Sig-Trans . Rx.Signal4«
	Ind5	»Sig-Trans . Rx.Signal5«
	Ind6	»Sig-Trans . Rx.Signal6«

Logical Node	Data Object	Module ( - ANSI/IEEE Device Number ) . Name
<b>TSGGIO1 (GGIO7)</b>		
	Ind7	»Sig-Trans . Rx.Signal7«
	Ind8	»Sig-Trans . Rx.Signal8«
	Ind9	»Sig-Trans . Rx.Signal9«
	Ind10	»Sig-Trans . Rx.Signal10«
	Ind11	»Sig-Trans . Rx.Signal11«
	Ind12	»Sig-Trans . Rx.Signal12«
	Ind13	»Sig-Trans . Rx.Signal13«
	Ind14	»Sig-Trans . Rx.Signal14«
	Ind15	»Sig-Trans . Rx.Signal15«
	Ind16	»Sig-Trans . Rx.Signal16«

Logical Node	Data Object	Module ( - ANSI/IEEE Device Number ) . Name
<b>TTGGIO1 (GGIO6)</b>		
	Mod	
	Beh	
	Health	
	NamPlt	
	Ind1	»Trip-Trans . Rx.Trip1.Input«
	Ind2	»Trip-Trans . Rx.Trip2.Input«
	Ind3	»Trip-Trans . Rx.Trip3.Input«
	Ind4	»Trip-Trans . Rx.Trip4.Input«

#### 4.1.4 LDevice::MEAS

Logical Node	Data Object	Module ( - ANSI/IEEE Device Number ) . Name
<b>CMMXU1 (MMXU3)</b>		
	Mod	
	Beh	
	Health	
	NamPlt	
	A	»CT Local . IL1 RMS« »CT Local . phi IL1« »CT Local . IL2 RMS« »CT Local . phi IL2« »CT Local . IL3 RMS« »CT Local . phi IL3« »CT Local . IG meas RMS«

Logical Node	Data Object	Module ( - ANSI/IEEE Device Number ) . Name
<b>CMMXU1 (MMXU3)</b>		
		»CT Local . phi IG meas«
		»CT Local . IG calc RMS«
		»CT Local . phi IG calc«

Logical Node	Data Object	Module ( - ANSI/IEEE Device Number ) . Name
<b>CMSTA1 (MSTA1)</b>		
	Mod	
	Beh	
	Health	
	NamPlt	
	AvAPhsA	»CT Local . IL1 avg «
	AvAPhsB	»CT Local . IL2 avg «
	AvAPhsC	»CT Local . IL3 avg «
	MaxAPhsA	»CT Local . IL1 max «
	MaxAPhsB	»CT Local . IL2 max «
	MaxAPhsC	»CT Local . IL3 max «
	MinAPhsA	»CT Local . IL1 min «
	MinAPhsB	»CT Local . IL2 min «
	MinAPhsC	»CT Local . IL3 min «

Logical Node	Data Object	Module ( - ANSI/IEEE Device Number ) . Name
<b>ECMMTR1 (MMTR1)</b>		
	Mod	
	Beh	
	Health	
	NamPlt	
	SupWh	»PQSCR . Wp+«
	DmdWh	»PQSCR . Wp-«
	SupVARh	»PQSCR . Wq+«
	DmdVARh	»PQSCR . Wq-«
	TotWh	»PQSCR . Wp Net«
	TotVARh	»PQSCR . Wq Net«
	TotVAh	»PQSCR . Ws Net«

Logical Node	Data Object	Module ( - ANSI/IEEE Device Number ) . Name
<b>LLNO (LLN0MEA)</b>		
	Mod	

Logical Node	Data Object	Module ( - ANSI/IEEE Device Number ) . Name
<b>LLN0 (LLN0MEA)</b>		
	Beh	
	Health	
	NamPlt	

Logical Node	Data Object	Module ( - ANSI/IEEE Device Number ) . Name
<b>LPHD1 (LPHDMEA)</b>		
	PhyNam	
	PhyHealth	
	Proxy	

Logical Node	Data Object	Module ( - ANSI/IEEE Device Number ) . Name
<b>PMMXU1 (MMXU1)</b>		
	Mod	
	Beh	
	Health	
	NamPlt	
	TotW	»PQSCr . P RMS«
	TotVAr	»PQSCr . Q «
	TotVA	»PQSCr . S RMS«
	TotPF	»PQSCr . cos phi RMS«

Logical Node	Data Object	Module ( - ANSI/IEEE Device Number ) . Name
<b>PMSTA1 (MSTA3)</b>		
	Mod	
	Beh	
	Health	
	NamPlt	
	AvVA	»PQSCr . S avg (Demand)«
	MaxVA	»PQSCr . S max«
	MinVA	»PQSCr . S min«
	AvW	»PQSCr . P avg«
	MaxW	»PQSCr . P max«
	MinW	»PQSCr . P min«
	AvVAr	»PQSCr . Q avg (Demand)«
	MaxVAr	»PQSCr . Q max«
	MinVAr	»PQSCr . Q min«

Logical Node	Data Object	Module ( - ANSI/IEEE Device Number ) . Name
<b>RCMMXU1 (MMXU8)</b>		
	Mod	
	Beh	
	Health	
	NamPlt	
	A	»CT Remote . IL1 « »CT Remote . phi IL1« »CT Remote . IL2 « »CT Remote . phi IL2« »CT Remote . IL3 « »CT Remote . phi IL3«

Logical Node	Data Object	Module ( - ANSI/IEEE Device Number ) . Name
<b>VMMXU1 (MMXU2)</b>		
	Mod	
	Beh	
	Health	
	NamPlt	
	PPV	»VT . VL12 RMS« »VT . phi VL12« »VT . VL23 RMS« »VT . phi VL23« »VT . VL31 RMS« »VT . phi VL31«
	PhV	»VT . VL1 RMS« »VT . phi VL1« »VT . VL2 RMS« »VT . phi VL2« »VT . VL3 RMS« »VT . phi VL3« »VT . VX meas RMS« »VT . phi VX meas« »VT . VG calc RMS« »VT . phi VG calc«
	Hz	»VT . f«



Logical Node	Data Object	Module ( - ANSI/IEEE Device Number ) . Name
<b>VMSTA1 (MSTA2)</b>		
	Mod	
	Beh	
	Health	
	NamPlt	
	AvVPhsAB	»VT . VL12 avg «
	AvVPhsBC	»VT . VL23 avg «
	AvVPhsCA	»VT . VL31 avg «
	MaxVPhsAB	»VT . VL12 max «
	MaxVPhsBC	»VT . VL23 max «
	MaxVPhsCA	»VT . VL31 max «
	MinVPhsAB	»VT . VL12 min «
	MinVPhsBC	»VT . VL23 min «
	MinVPhsCA	»VT . VL31 min «
	AvVPhsA	»VT . VL1 avg «
	AvVPhsB	»VT . VL2 avg «
	AvVPhsC	»VT . VL3 avg «
	MaxVPhsA	»VT . VL1 max «
	MaxVPhsB	»VT . VL2 max «
	MaxVPhsC	»VT . VL3 max «
	MinVPhsA	»VT . VL1 min «
	MinVPhsB	»VT . VL2 min «
	MinVPhsC	»VT . VL3 min «

#### 4.1.5 LDevice::PROT

Logical Node	Data Object	Module ( - ANSI/IEEE Device Number ) . Name
<b>GFPTOC1 (PTOC2)</b>		
	Mod	»IG[1] . Active« »IG[1] . Blo TripCmd« »IG[1] . ExBlo TripCmd«
	Beh	
	Health	
	NamPlt	
	Str	»IG[1] . Alarm«
	Op	»IG[1] . Trip«

Logical Node	Data Object	Module ( - ANSI/IEEE Device Number ) . Name
<b>GFPTOC2 (PTOC2)</b>		
	Mod	»IG[2] . Active« »IG[2] . Blo TripCmd« »IG[2] . ExBlo TripCmd«
	Beh	
	Health	
	NamPlt	
	Str	»IG[2] . Alarm«
	Op	»IG[2] . Trip«

Logical Node	Data Object	Module ( - ANSI/IEEE Device Number ) . Name
<b>GFPTOC3 (PTOC2)</b>		
	Mod	»IG[3] . Active« »IG[3] . Blo TripCmd« »IG[3] . ExBlo TripCmd«
	Beh	
	Health	
	NamPlt	
	Str	»IG[3] . Alarm«
	Op	»IG[3] . Trip«

Logical Node	Data Object	Module ( - ANSI/IEEE Device Number ) . Name
<b>GFPTOC4 (PTOC2)</b>		
	Mod	»IG[4] . Active« »IG[4] . Blo TripCmd« »IG[4] . ExBlo TripCmd«
	Beh	
	Health	
	NamPlt	
	Str	»IG[4] . Alarm«
	Op	»IG[4] . Trip«

Logical Node	Data Object	Module ( - ANSI/IEEE Device Number ) . Name
<b>GPDIF1 (PDIF3)</b>		
	Mod	»IdGH . Active« »IdGH . Blo TripCmd« »IdGH . ExBlo TripCmd«

Logical Node	Data Object	Module ( - ANSI/IEEE Device Number ) . Name
<b>GPDIF1 (PDIF3)</b>		
	Beh	
	Health	
	NamPlt	
	Str	»IdGH . Alarm«
	Op	»IdGH . TripCmd«

Logical Node	Data Object	Module ( - ANSI/IEEE Device Number ) . Name
<b>HRGPDIF1 (PDIF4)</b>		
	Mod	»IdH . Active« »IdH . Blo TripCmd« »IdH . ExBlo TripCmd«
	Beh	
	Health	
	NamPlt	
	Str	»IdH . Alarm«
	Op	»IdH . TripCmd«

Logical Node	Data Object	Module ( - ANSI/IEEE Device Number ) . Name
<b>HSPPDIF1 (PDIF2)</b>		
	Mod	»IdG . Active« »IdG . Blo TripCmd« »IdG . ExBlo TripCmd«
	Beh	
	Health	
	NamPlt	
	Str	»IdG . Alarm«
	Op	»IdG . Trip«

Logical Node	Data Object	Module ( - ANSI/IEEE Device Number ) . Name
<b>IHMI1 (IHM11)</b>		
	Mod	
	Beh	
	Health	
	NamPlt	

Logical Node	Data Object	Module ( - ANSI/IEEE Device Number ) . Name
<b>INRPHAR1 (PHAR1)</b>		
	Mod	»IH2 . Active«
	Beh	
	Health	
	NamPlt	
	Str	»IH2 . 3-ph Blo«

Logical Node	Data Object	Module ( - ANSI/IEEE Device Number ) . Name
<b>ITPC1 (ITPC1)</b>		
	Mod	»ProtCom . Active« »ProtCom . Inactive« »ProtCom . ExBlo«
	Beh	
	Health	
	NamPlt	
	SynOk	»ProtCom . Comm.Ok«
	FrSyn	»ProtCom . FrameSync«
	TmSyn	»ProtCom . TimeSync«

Logical Node	Data Object	Module ( - ANSI/IEEE Device Number ) . Name
<b>LLN0 (LLN0PRO)</b>		
	Mod	
	Beh	
	Health	
	NamPlt	

Logical Node	Data Object	Module ( - ANSI/IEEE Device Number ) . Name
<b>LPHD1 (LPHDPRO)</b>		
	PhyNam	
	PhyHealth	
	Proxy	

Logical Node	Data Object	Module ( - ANSI/IEEE Device Number ) . Name
<b>LSPFDPFRC1 (PFRC2)</b>		
	Mod	»UFLS . Active« »UFLS . ExBlo« »UFLS . Fuse Fail VT Blo«
	Beh	

Logical Node	Data Object	Module ( - ANSI/IEEE Device Number ) . Name
<b>LSPFDPFRC1 (PFRC2)</b>		
	Health	
	NamPlt	
	Str	»UFLS . Alarm«
	Op	»UFLS . Trip«

Logical Node	Data Object	Module ( - ANSI/IEEE Device Number ) . Name
<b>LVRTPTUV1 (PTUV4)</b>		
	Mod	»LVRT[1] . Active« »LVRT[1] . Blo TripCmd« »LVRT[1] . ExBlo TripCmd«
	Beh	
	Health	
	NamPlt	
	Str	»LVRT[1] . Alarm«
	Op	»LVRT[1] . Trip«

Logical Node	Data Object	Module ( - ANSI/IEEE Device Number ) . Name
<b>LVRTPTUV2 (PTUV4)</b>		
	Mod	»LVRT[2] . Active« »LVRT[2] . Blo TripCmd« »LVRT[2] . ExBlo TripCmd«
	Beh	
	Health	
	NamPlt	
	Str	»LVRT[2] . Alarm«
	Op	»LVRT[2] . Trip«

Logical Node	Data Object	Module ( - ANSI/IEEE Device Number ) . Name
<b>OEPVPH1* (PVPH1)</b>		
	Mod	»V/f>[1] . Active« »V/f>[1] . Blo TripCmd« »V/f>[1] . ExBlo TripCmd«
	Beh	
	Health	
	NamPlt	
	Str	»V/f>[1] . Alarm«

Logical Node	Data Object	Module ( - ANSI/IEEE Device Number ) . Name
<b>OEVPVPH1* (PVPH1)</b>		
	Op	»V/f>[1] . Trip«

Logical Node	Data Object	Module ( - ANSI/IEEE Device Number ) . Name
<b>OEVPVPH2* (PVPH1)</b>		
	Mod	»V/f>[2] . Active« »V/f>[2] . Blo TripCmd« »V/f>[2] . ExBlo TripCmd«
	Beh	
	Health	
	NamPlt	
	Str	»V/f>[2] . Alarm«
	Op	»V/f>[2] . Trip«

Logical Node	Data Object	Module ( - ANSI/IEEE Device Number ) . Name
<b>PDOP1* (PDOP1)</b>		
	Mod	»P . Active« »P . Blo TripCmd« »P . ExBlo TripCmd«
	Beh	
	Health	
	NamPlt	
	Str	»P . Alarm«
	Op	»P . Trip«

Logical Node	Data Object	Module ( - ANSI/IEEE Device Number ) . Name
<b>PDOP2* (PDOP1)</b>		
	Mod	»Q . Active« »Q . Blo TripCmd« »Q . ExBlo TripCmd«
	Beh	
	Health	
	NamPlt	
	Str	»Q . Alarm«
	Op	»Q . Trip«

Logical Node	Data Object	Module ( - ANSI/IEEE Device Number ) . Name
<b>PDOP3* (PDOP1)</b>		
	Mod	»PQS[1] . Active« »PQS[1] . Blo TripCmd« »PQS[1] . ExBlo TripCmd«
	Beh	
	Health	
	NamPlt	
	Str	»PQS[1] . Alarm«
	Op	»PQS[1] . Trip«

Logical Node	Data Object	Module ( - ANSI/IEEE Device Number ) . Name
<b>PDOP4* (PDOP1)</b>		
	Mod	»PQS[2] . Active« »PQS[2] . Blo TripCmd« »PQS[2] . ExBlo TripCmd«
	Beh	
	Health	
	NamPlt	
	Str	»PQS[2] . Alarm«
	Op	»PQS[2] . Trip«

Logical Node	Data Object	Module ( - ANSI/IEEE Device Number ) . Name
<b>PDOP5* (PDOP1)</b>		
	Mod	»PQS[3] . Active« »PQS[3] . Blo TripCmd« »PQS[3] . ExBlo TripCmd«
	Beh	
	Health	
	NamPlt	
	Str	»PQS[3] . Alarm«
	Op	»PQS[3] . Trip«

Logical Node	Data Object	Module ( - ANSI/IEEE Device Number ) . Name
<b>PDOP6* (PDOP1)</b>		
	Mod	»PQS[4] . Active« »PQS[4] . Blo TripCmd« »PQS[4] . ExBlo TripCmd«

Logical Node	Data Object	Module ( - ANSI/IEEE Device Number ) . Name
<b>PDOP6* (PDOP1)</b>		
	Beh	
	Health	
	NamPlt	
	Str	»PQS[4] . Alarm«
	Op	»PQS[4] . Trip«

Logical Node	Data Object	Module ( - ANSI/IEEE Device Number ) . Name
<b>PDOP7* (PDOP1)</b>		
	Mod	»PQS[5] . Active« »PQS[5] . Blo TripCmd« »PQS[5] . ExBlo TripCmd«
	Beh	
	Health	
	NamPlt	
	Str	»PQS[5] . Alarm«
	Op	»PQS[5] . Trip«

Logical Node	Data Object	Module ( - ANSI/IEEE Device Number ) . Name
<b>PDOP8* (PDOP1)</b>		
	Mod	»PQS[6] . Active« »PQS[6] . Blo TripCmd« »PQS[6] . ExBlo TripCmd«
	Beh	
	Health	
	NamPlt	
	Str	»PQS[6] . Alarm«
	Op	»PQS[6] . Trip«

Logical Node	Data Object	Module ( - ANSI/IEEE Device Number ) . Name
<b>PDUP3* (PDUP1)</b>		
	Mod	»PQS[1] . Active« »PQS[1] . Blo TripCmd« »PQS[1] . ExBlo TripCmd«
	Beh	
	Health	
	NamPlt	



Logical Node	Data Object	Module ( - ANSI/IEEE Device Number ) . Name
<b>PDUP3* (PDUP1)</b>		
	Str	»PQS[1] . Alarm«
	Op	»PQS[1] . Trip«

Logical Node	Data Object	Module ( - ANSI/IEEE Device Number ) . Name
<b>PDUP4* (PDUP1)</b>		
	Mod	»PQS[2] . Active« »PQS[2] . Blo TripCmd« »PQS[2] . ExBlo TripCmd«
	Beh	
	Health	
	NamPlt	
	Str	»PQS[2] . Alarm«
	Op	»PQS[2] . Trip«

Logical Node	Data Object	Module ( - ANSI/IEEE Device Number ) . Name
<b>PDUP5* (PDUP1)</b>		
	Mod	»PQS[3] . Active« »PQS[3] . Blo TripCmd« »PQS[3] . ExBlo TripCmd«
	Beh	
	Health	
	NamPlt	
	Str	»PQS[3] . Alarm«
	Op	»PQS[3] . Trip«

Logical Node	Data Object	Module ( - ANSI/IEEE Device Number ) . Name
<b>PDUP6* (PDUP1)</b>		
	Mod	»PQS[4] . Active« »PQS[4] . Blo TripCmd« »PQS[4] . ExBlo TripCmd«
	Beh	
	Health	
	NamPlt	
	Str	»PQS[4] . Alarm«
	Op	»PQS[4] . Trip«

Logical Node	Data Object	Module ( - ANSI/IEEE Device Number ) . Name
<b>PDUP7* (PDUP1)</b>		
	Mod	»PQS[5] . Active« »PQS[5] . Blo TripCmd« »PQS[5] . ExBlo TripCmd«
	Beh	
	Health	
	NamPlt	
	Str	»PQS[5] . Alarm«
	Op	»PQS[5] . Trip«

Logical Node	Data Object	Module ( - ANSI/IEEE Device Number ) . Name
<b>PDUP8* (PDUP1)</b>		
	Mod	»PQS[6] . Active« »PQS[6] . Blo TripCmd« »PQS[6] . ExBlo TripCmd«
	Beh	
	Health	
	NamPlt	
	Str	»PQS[6] . Alarm«
	Op	»PQS[6] . Trip«

Logical Node	Data Object	Module ( - ANSI/IEEE Device Number ) . Name
<b>PFRC1* (PFRC1)</b>		
	Mod	»df/dt . Active« »df/dt . Blo TripCmd« »df/dt . ExBlo TripCmd«
	Beh	
	Health	
	NamPlt	
	Str	»df/dt . Alarm«
	Op	»df/dt . Trip«

Logical Node	Data Object	Module ( - ANSI/IEEE Device Number ) . Name
<b>PFRC3* (PFRC1)</b>		
	Mod	»f[1] . Active« »f[1] . Blo TripCmd« »f[1] . ExBlo TripCmd«

Logical Node	Data Object	Module ( - ANSI/IEEE Device Number ) . Name
<b>PFRC3* (PFRC1)</b>		
	Beh	
	Health	
	NamPlt	
	Str	»f[1] . Alarm«
	Op	»f[1] . Trip«

Logical Node	Data Object	Module ( - ANSI/IEEE Device Number ) . Name
<b>PFRC4* (PFRC1)</b>		
	Mod	»f[2] . Active« »f[2] . Blo TripCmd« »f[2] . ExBlo TripCmd«
	Beh	
	Health	
	NamPlt	
	Str	»f[2] . Alarm«
	Op	»f[2] . Trip«

Logical Node	Data Object	Module ( - ANSI/IEEE Device Number ) . Name
<b>PFRC5* (PFRC1)</b>		
	Mod	»f[3] . Active« »f[3] . Blo TripCmd« »f[3] . ExBlo TripCmd«
	Beh	
	Health	
	NamPlt	
	Str	»f[3] . Alarm«
	Op	»f[3] . Trip«

Logical Node	Data Object	Module ( - ANSI/IEEE Device Number ) . Name
<b>PFRC6* (PFRC1)</b>		
	Mod	»f[4] . Active« »f[4] . Blo TripCmd« »f[4] . ExBlo TripCmd«
	Beh	
	Health	
	NamPlt	

Logical Node	Data Object	Module ( - ANSI/IEEE Device Number ) . Name
<b>PFRC6* (PFRC1)</b>		
	Str	»f[4] . Alarm«
	Op	»f[4] . Trip«

Logical Node	Data Object	Module ( - ANSI/IEEE Device Number ) . Name
<b>PFRC7* (PFRC1)</b>		
	Mod	»f[5] . Active« »f[5] . Blo TripCmd« »f[5] . ExBlo TripCmd«
	Beh	
	Health	
	NamPlt	
	Str	»f[5] . Alarm«
	Op	»f[5] . Trip«

Logical Node	Data Object	Module ( - ANSI/IEEE Device Number ) . Name
<b>PFRC8* (PFRC1)</b>		
	Mod	»f[6] . Active« »f[6] . Blo TripCmd« »f[6] . ExBlo TripCmd«
	Beh	
	Health	
	NamPlt	
	Str	»f[6] . Alarm«
	Op	»f[6] . Trip«

Logical Node	Data Object	Module ( - ANSI/IEEE Device Number ) . Name
<b>PPAM2* (PPAM1)</b>		
	Mod	»delta phi . Active« »delta phi . Blo TripCmd« »delta phi . ExBlo TripCmd«
	Beh	
	Health	
	NamPlt	
	Str	»delta phi . Alarm«
	Op	»delta phi . Trip«

Logical Node	Data Object	Module ( - ANSI/IEEE Device Number ) . Name
<b>PPAM3* (PPAM1)</b>		
	Mod	»f[1] . Active« »f[1] . Blo TripCmd« »f[1] . ExBlo TripCmd«
	Beh	
	Health	
	NamPlt	
	Str	»f[1] . Alarm«
	Op	»f[1] . Trip«

Logical Node	Data Object	Module ( - ANSI/IEEE Device Number ) . Name
<b>PPAM4* (PPAM1)</b>		
	Mod	»f[2] . Active« »f[2] . Blo TripCmd« »f[2] . ExBlo TripCmd«
	Beh	
	Health	
	NamPlt	
	Str	»f[2] . Alarm«
	Op	»f[2] . Trip«

Logical Node	Data Object	Module ( - ANSI/IEEE Device Number ) . Name
<b>PPAM5* (PPAM1)</b>		
	Mod	»f[3] . Active« »f[3] . Blo TripCmd« »f[3] . ExBlo TripCmd«
	Beh	
	Health	
	NamPlt	
	Str	»f[3] . Alarm«
	Op	»f[3] . Trip«

Logical Node	Data Object	Module ( - ANSI/IEEE Device Number ) . Name
<b>PPAM6* (PPAM1)</b>		
	Mod	»f[4] . Active« »f[4] . Blo TripCmd« »f[4] . ExBlo TripCmd«

Logical Node	Data Object	Module ( - ANSI/IEEE Device Number ) . Name
<b>PPAM6* (PPAM1)</b>		
	Beh	
	Health	
	NamPlt	
	Str	»f[4] . Alarm«
	Op	»f[4] . Trip«

Logical Node	Data Object	Module ( - ANSI/IEEE Device Number ) . Name
<b>PPAM7* (PPAM1)</b>		
	Mod	»f[5] . Active« »f[5] . Blo TripCmd« »f[5] . ExBlo TripCmd«
	Beh	
	Health	
	NamPlt	
	Str	»f[5] . Alarm«
	Op	»f[5] . Trip«

Logical Node	Data Object	Module ( - ANSI/IEEE Device Number ) . Name
<b>PPAM8* (PPAM1)</b>		
	Mod	»f[6] . Active« »f[6] . Blo TripCmd« »f[6] . ExBlo TripCmd«
	Beh	
	Health	
	NamPlt	
	Str	»f[6] . Alarm«
	Op	»f[6] . Trip«

Logical Node	Data Object	Module ( - ANSI/IEEE Device Number ) . Name
<b>PPDIF1 (PDIF1)</b>		
	Mod	»Id . Active« »Id . Blo TripCmd« »Id . ExBlo TripCmd«
	Beh	
	Health	
	NamPlt	

Logical Node	Data Object	Module ( - ANSI/IEEE Device Number ) . Name
<b>PPDIF1 (PDIF1)</b>		
	Str	»Id . Alarm«
	Op	»Id . TripCmd«

Logical Node	Data Object	Module ( - ANSI/IEEE Device Number ) . Name
<b>PROTPTRC1 (PTRC2)</b>		
	Mod	»Prot . Active« »Prot . Blo TripCmd« »Prot . ExBlo TripCmd«
	Beh	
	Health	
	NamPlt	
	Str	»Prot . Alarm«
	Op	»Prot . Trip«

Logical Node	Data Object	Module ( - ANSI/IEEE Device Number ) . Name
<b>PRTT1 (PRTT1)</b>		
	Mod	»Trip-Trans . Active« »Trip-Trans . Blo TripCmd« »Trip-Trans . ExBlo TripCmd«
	Beh	
	Health	
	NamPlt	
	Op	»Trip-Trans . Trip«
	PerTr1	»Trip-Trans . Rx.Trip1.Permissive«
	PerTr2	»Trip-Trans . Rx.Trip2.Permissive«
	PerTr3	»Trip-Trans . Rx.Trip3.Permissive«
	PerTr4	»Trip-Trans . Rx.Trip4.Permissive«
	RemTr1	»Trip-Trans . Rx.Trip1«
	RemTr2	»Trip-Trans . Rx.Trip2«
	RemTr3	»Trip-Trans . Rx.Trip3«
	RemTr4	»Trip-Trans . Rx.Trip4«

Logical Node	Data Object	Module ( - ANSI/IEEE Device Number ) . Name
<b>PSDE1 (PSDE1)</b>		
	Mod	»VT . IG meas dir sin/cos«
	Beh	
	Health	

Logical Node	Data Object	Module ( - ANSI/IEEE Device Number ) . Name
<b>PSDE1 (PSDE1)</b>		
	NamPlt	
	Str	»Prot . IG meas dir fwd« »Prot . IG meas dir rev«

Logical Node	Data Object	Module ( - ANSI/IEEE Device Number ) . Name
<b>PSDE2 (PSDE2)</b>		
	Mod	»VT . IG calc dir sin/cos«
	Beh	
	Health	
	NamPlt	
	Str	»Prot . IG calc dir fwd« »Prot . IG calc dir rev«

Logical Node	Data Object	Module ( - ANSI/IEEE Device Number ) . Name
<b>PSOF1 (PSOF1)</b>		
	Mod	»SOTF . Active« »SOTF . ExBlo« »SOTF . Ex rev Interl«
	Beh	
	Health	
	NamPlt	
	Str	»SOTF . enabled«

Logical Node	Data Object	Module ( - ANSI/IEEE Device Number ) . Name
<b>PTOC1 (PTOC1)</b>		
	Mod	»I[1] . Active« »I[1] . Blo TripCmd« »I[1] . ExBlo TripCmd«
	Beh	
	Health	
	NamPlt	
	Str	»I[1] . Alarm«
	Op	»I[1] . Trip«



Logical Node	Data Object	Module ( - ANSI/IEEE Device Number ) . Name
<b>PTOC2 (PTOC1)</b>		
	Mod	»I[2] . Active« »I[2] . Blo TripCmd« »I[2] . ExBlo TripCmd«
	Beh	
	Health	
	NamPlt	
	Str	»I[2] . Alarm«
	Op	»I[2] . Trip«

Logical Node	Data Object	Module ( - ANSI/IEEE Device Number ) . Name
<b>PTOC3 (PTOC1)</b>		
	Mod	»I[3] . Active« »I[3] . Blo TripCmd« »I[3] . ExBlo TripCmd«
	Beh	
	Health	
	NamPlt	
	Str	»I[3] . Alarm«
	Op	»I[3] . Trip«

Logical Node	Data Object	Module ( - ANSI/IEEE Device Number ) . Name
<b>PTOC4 (PTOC1)</b>		
	Mod	»I[4] . Active« »I[4] . Blo TripCmd« »I[4] . ExBlo TripCmd«
	Beh	
	Health	
	NamPlt	
	Str	»I[4] . Alarm«
	Op	»I[4] . Trip«

Logical Node	Data Object	Module ( - ANSI/IEEE Device Number ) . Name
<b>PTOC5 (PTOC1)</b>		
	Mod	»I[5] . Active« »I[5] . Blo TripCmd« »I[5] . ExBlo TripCmd«

Logical Node	Data Object	Module ( - ANSI/IEEE Device Number ) . Name
<b>PTOC5 (PTOC1)</b>		
	Beh	
	Health	
	NamPlt	
	Str	»I[5] . Alarm«
	Op	»I[5] . Trip«

Logical Node	Data Object	Module ( - ANSI/IEEE Device Number ) . Name
<b>PTOC6 (PTOC1)</b>		
	Mod	»I[6] . Active« »I[6] . Blo TripCmd« »I[6] . ExBlo TripCmd«
	Beh	
	Health	
	NamPlt	
	Str	»I[6] . Alarm«
	Op	»I[6] . Trip«

Logical Node	Data Object	Module ( - ANSI/IEEE Device Number ) . Name
<b>PTOF3* (PTOF1)</b>		
	Mod	»f[1] . Active« »f[1] . Blo TripCmd« »f[1] . ExBlo TripCmd«
	Beh	
	Health	
	NamPlt	
	Str	»f[1] . Alarm«
	Op	»f[1] . Trip«

Logical Node	Data Object	Module ( - ANSI/IEEE Device Number ) . Name
<b>PTOF4* (PTOF1)</b>		
	Mod	»f[2] . Active« »f[2] . Blo TripCmd« »f[2] . ExBlo TripCmd«
	Beh	
	Health	
	NamPlt	

Logical Node	Data Object	Module ( - ANSI/IEEE Device Number ) . Name
<b>PTOF4* (PTOF1)</b>		
	Str	»f[2] . Alarm«
	Op	»f[2] . Trip«

Logical Node	Data Object	Module ( - ANSI/IEEE Device Number ) . Name
<b>PTOF5* (PTOF1)</b>		
	Mod	»f[3] . Active« »f[3] . Blo TripCmd« »f[3] . ExBlo TripCmd«
	Beh	
	Health	
	NamPlt	
	Str	»f[3] . Alarm«
	Op	»f[3] . Trip«

Logical Node	Data Object	Module ( - ANSI/IEEE Device Number ) . Name
<b>PTOF6* (PTOF1)</b>		
	Mod	»f[4] . Active« »f[4] . Blo TripCmd« »f[4] . ExBlo TripCmd«
	Beh	
	Health	
	NamPlt	
	Str	»f[4] . Alarm«
	Op	»f[4] . Trip«

Logical Node	Data Object	Module ( - ANSI/IEEE Device Number ) . Name
<b>PTOF7* (PTOF1)</b>		
	Mod	»f[5] . Active« »f[5] . Blo TripCmd« »f[5] . ExBlo TripCmd«
	Beh	
	Health	
	NamPlt	
	Str	»f[5] . Alarm«
	Op	»f[5] . Trip«

Logical Node	Data Object	Module ( - ANSI/IEEE Device Number ) . Name
<b>PTOF8* (PTOF1)</b>		
	Mod	»f[6] . Active« »f[6] . Blo TripCmd« »f[6] . ExBlo TripCmd«
	Beh	
	Health	
	NamPlt	
	Str	»f[6] . Alarm«
	Op	»f[6] . Trip«

Logical Node	Data Object	Module ( - ANSI/IEEE Device Number ) . Name
<b>PTOV1* (PTOV2)</b>		
	Mod	»V[1] . Active« »V[1] . Blo TripCmd« »V[1] . ExBlo TripCmd«
	Beh	
	Health	
	NamPlt	
	Str	»V[1] . Alarm«
	Op	»V[1] . Trip«

Logical Node	Data Object	Module ( - ANSI/IEEE Device Number ) . Name
<b>PTOV2* (PTOV2)</b>		
	Mod	»V[2] . Active« »V[2] . Blo TripCmd« »V[2] . ExBlo TripCmd«
	Beh	
	Health	
	NamPlt	
	Str	»V[2] . Alarm«
	Op	»V[2] . Trip«

Logical Node	Data Object	Module ( - ANSI/IEEE Device Number ) . Name
<b>PTOV3* (PTOV2)</b>		
	Mod	»V[3] . Active« »V[3] . Blo TripCmd« »V[3] . ExBlo TripCmd«

Logical Node	Data Object	Module ( - ANSI/IEEE Device Number ) . Name
<b>PTOV3* (PTOV2)</b>		
	Beh	
	Health	
	NamPlt	
	Str	»V[3] . Alarm«
	Op	»V[3] . Trip«

Logical Node	Data Object	Module ( - ANSI/IEEE Device Number ) . Name
<b>PTOV4* (PTOV2)</b>		
	Mod	»V[4] . Active« »V[4] . Blo TripCmd« »V[4] . ExBlo TripCmd«
	Beh	
	Health	
	NamPlt	
	Str	»V[4] . Alarm«
	Op	»V[4] . Trip«

Logical Node	Data Object	Module ( - ANSI/IEEE Device Number ) . Name
<b>PTOV5* (PTOV2)</b>		
	Mod	»V[5] . Active« »V[5] . Blo TripCmd« »V[5] . ExBlo TripCmd«
	Beh	
	Health	
	NamPlt	
	Str	»V[5] . Alarm«
	Op	»V[5] . Trip«

Logical Node	Data Object	Module ( - ANSI/IEEE Device Number ) . Name
<b>PTOV6* (PTOV2)</b>		
	Mod	»V[6] . Active« »V[6] . Blo TripCmd« »V[6] . ExBlo TripCmd«
	Beh	
	Health	
	NamPlt	

Logical Node	Data Object	Module ( - ANSI/IEEE Device Number ) . Name
<b>PTOV6* (PTOV2)</b>		
	Str	»V[6] . Alarm«
	Op	»V[6] . Trip«

Logical Node	Data Object	Module ( - ANSI/IEEE Device Number ) . Name
<b>PTRC1* (PTRC1)</b>		
	Mod	
	Beh	
	Health	
	NamPlt	
	Op	»SG[1] . TripCmd«

Logical Node	Data Object	Module ( - ANSI/IEEE Device Number ) . Name
<b>PTRC2* (PTRC1)</b>		
	Mod	
	Beh	
	Health	
	NamPlt	
	Op	»SG[2] . TripCmd«

Logical Node	Data Object	Module ( - ANSI/IEEE Device Number ) . Name
<b>PTRC3* (PTRC1)</b>		
	Mod	
	Beh	
	Health	
	NamPlt	
	Op	»SG[3] . TripCmd«

Logical Node	Data Object	Module ( - ANSI/IEEE Device Number ) . Name
<b>PTRC4* (PTRC1)</b>		
	Mod	
	Beh	
	Health	
	NamPlt	
	Op	»SG[4] . TripCmd«

Logical Node	Data Object	Module ( - ANSI/IEEE Device Number ) . Name
<b>PTRC5* (PTRC1)</b>		
	Mod	

Logical Node	Data Object	Module ( - ANSI/IEEE Device Number ) . Name
<b>PTRC5* (PTRC1)</b>		
	Beh	
	Health	
	NamPlt	
	Op	»SG[5] . TripCmd«

Logical Node	Data Object	Module ( - ANSI/IEEE Device Number ) . Name
<b>PTRC6* (PTRC1)</b>		
	Mod	
	Beh	
	Health	
	NamPlt	
	Op	»SG[6] . TripCmd«

Logical Node	Data Object	Module ( - ANSI/IEEE Device Number ) . Name
<b>PTUF3* (PTUF1)</b>		
	Mod	»f[1] . Active« »f[1] . Blo TripCmd« »f[1] . ExBlo TripCmd«
	Beh	
	Health	
	NamPlt	
	Str	»f[1] . Alarm«
	Op	»f[1] . Trip«

Logical Node	Data Object	Module ( - ANSI/IEEE Device Number ) . Name
<b>PTUF4* (PTUF1)</b>		
	Mod	»f[2] . Active« »f[2] . Blo TripCmd« »f[2] . ExBlo TripCmd«
	Beh	
	Health	
	NamPlt	
	Str	»f[2] . Alarm«
	Op	»f[2] . Trip«

Logical Node	Data Object	Module ( - ANSI/IEEE Device Number ) . Name
<b>PTUF5* (PTUF1)</b>		
	Mod	»f[3] . Active« »f[3] . Blo TripCmd« »f[3] . ExBlo TripCmd«
	Beh	
	Health	
	NamPlt	
	Str	»f[3] . Alarm«
	Op	»f[3] . Trip«

Logical Node	Data Object	Module ( - ANSI/IEEE Device Number ) . Name
<b>PTUF6* (PTUF1)</b>		
	Mod	»f[4] . Active« »f[4] . Blo TripCmd« »f[4] . ExBlo TripCmd«
	Beh	
	Health	
	NamPlt	
	Str	»f[4] . Alarm«
	Op	»f[4] . Trip«

Logical Node	Data Object	Module ( - ANSI/IEEE Device Number ) . Name
<b>PTUF7* (PTUF1)</b>		
	Mod	»f[5] . Active« »f[5] . Blo TripCmd« »f[5] . ExBlo TripCmd«
	Beh	
	Health	
	NamPlt	
	Str	»f[5] . Alarm«
	Op	»f[5] . Trip«

Logical Node	Data Object	Module ( - ANSI/IEEE Device Number ) . Name
<b>PTUF8* (PTUF1)</b>		
	Mod	»f[6] . Active« »f[6] . Blo TripCmd« »f[6] . ExBlo TripCmd«



Logical Node	Data Object	Module ( - ANSI/IEEE Device Number ) . Name
<b>PTUF8* (PTUF1)</b>		
	Beh	
	Health	
	NamPlt	
	Str	»f[6] . Alarm«
	Op	»f[6] . Trip«

Logical Node	Data Object	Module ( - ANSI/IEEE Device Number ) . Name
<b>PTUV1* (PTUV2)</b>		
	Mod	»V[1] . Active« »V[1] . Blo TripCmd« »V[1] . ExBlo TripCmd«
	Beh	
	Health	
	NamPlt	
	Str	»V[1] . Alarm«
	Op	»V[1] . Trip«

Logical Node	Data Object	Module ( - ANSI/IEEE Device Number ) . Name
<b>PTUV2* (PTUV2)</b>		
	Mod	»V[2] . Active« »V[2] . Blo TripCmd« »V[2] . ExBlo TripCmd«
	Beh	
	Health	
	NamPlt	
	Str	»V[2] . Alarm«
	Op	»V[2] . Trip«

Logical Node	Data Object	Module ( - ANSI/IEEE Device Number ) . Name
<b>PTUV3* (PTUV2)</b>		
	Mod	»V[3] . Active« »V[3] . Blo TripCmd« »V[3] . ExBlo TripCmd«
	Beh	
	Health	
	NamPlt	

Logical Node	Data Object	Module ( - ANSI/IEEE Device Number ) . Name
<b>PTUV3* (PTUV2)</b>		
	Str	»V[3] . Alarm«
	Op	»V[3] . Trip«

Logical Node	Data Object	Module ( - ANSI/IEEE Device Number ) . Name
<b>PTUV4* (PTUV2)</b>		
	Mod	»V[4] . Active« »V[4] . Blo TripCmd« »V[4] . ExBlo TripCmd«
	Beh	
	Health	
	NamPlt	
	Str	»V[4] . Alarm«
	Op	»V[4] . Trip«

Logical Node	Data Object	Module ( - ANSI/IEEE Device Number ) . Name
<b>PTUV5* (PTUV2)</b>		
	Mod	»V[5] . Active« »V[5] . Blo TripCmd« »V[5] . ExBlo TripCmd«
	Beh	
	Health	
	NamPlt	
	Str	»V[5] . Alarm«
	Op	»V[5] . Trip«

Logical Node	Data Object	Module ( - ANSI/IEEE Device Number ) . Name
<b>PTUV6* (PTUV2)</b>		
	Mod	»V[6] . Active« »V[6] . Blo TripCmd« »V[6] . ExBlo TripCmd«
	Beh	
	Health	
	NamPlt	
	Str	»V[6] . Alarm«
	Op	»V[6] . Trip«

Logical Node	Data Object	Module ( - ANSI/IEEE Device Number ) . Name
<b>PUPF1 (PUPF1)</b>		
	Mod	»PF[1] . Active« »PF[1] . Blo TripCmd« »PF[1] . ExBlo TripCmd«
	Beh	
	Health	
	NamPlt	
	Str	»PF[1] . Alarm«
	Op	»PF[1] . Trip«

Logical Node	Data Object	Module ( - ANSI/IEEE Device Number ) . Name
<b>PUPF2 (PUPF1)</b>		
	Mod	»PF[2] . Active« »PF[2] . Blo TripCmd« »PF[2] . ExBlo TripCmd«
	Beh	
	Health	
	NamPlt	
	Str	»PF[2] . Alarm«
	Op	»PF[2] . Trip«

Logical Node	Data Object	Module ( - ANSI/IEEE Device Number ) . Name
<b>QVPTUV1 (PTUV5)</b>		
	Mod	»Q->&V< . Active« »Q->&V< . ExBlo« »Q->&V< . Fuse Fail VT Blo«
	Beh	
	Health	
	NamPlt	
	Str	»Q->&V< . Alarm«
	Op	»Q->&V< . Decoupling Gen.«

Logical Node	Data Object	Module ( - ANSI/IEEE Device Number ) . Name
<b>RBRF1 (RBRF1)</b>		
	Mod	»CBF . Active« »CBF . ExBlo« »CBF . ExBlo«

Logical Node	Data Object	Module ( - ANSI/IEEE Device Number ) . Name
<b>RBRF1 (RBRF1)</b>		
	Beh	
	Health	
	NamPlt	
	Str	»CBF . running«
	OpEx	»CBF . Alarm«

Logical Node	Data Object	Module ( - ANSI/IEEE Device Number ) . Name
<b>RREC1 (RREC1)</b>		
	Mod	»AR . Active« »AR . ExBlo« »AR . ExBlo«
	Beh	
	Health	
	NamPlt	
	Op	»AR . CB ON Cmd«
	AutoRecSt	»AR . ARRecCState«

Logical Node	Data Object	Module ( - ANSI/IEEE Device Number ) . Name
<b>RSYN1 (RSYN1)</b>		
	Mod	»Sync . Active« »Sync . ExBlo« »Sync . ExBlo«
	Beh	
	Health	
	NamPlt	
	Rel	»Sync . Ready to Close«
	Anglnd	»Sync . AngleDiffTooHigh«
	Hlznd	»Sync . SlipTooHigh«
	Vlnd	»Sync . VDiffTooHigh«
	DifAngClc	»Sync . Angle Diff«
	DifHzClc	»Sync . Slip Freq«
	DifVClc	»Sync . Volt Diff«

Logical Node	Data Object	Module ( - ANSI/IEEE Device Number ) . Name
<b>TRPTR1 (PTR1)</b>		
	Mod	»ThR . Active« »ThR . Blo TripCmd«

Logical Node	Data Object	Module ( - ANSI/IEEE Device Number ) . Name
<b>TRPTTR1 (PTTR1)</b>		
		»ThR . ExBlo TripCmd«
	Beh	
	Health	
	NamPlt	
	Op	»ThR . Trip«

Logical Node	Data Object	Module ( - ANSI/IEEE Device Number ) . Name
<b>ULPTOC1 (PTOC3)</b>		
	Mod	»I2>[1] . Active« »I2>[1] . Blo TripCmd« »I2>[1] . ExBlo TripCmd«
	Beh	
	Health	
	NamPlt	
	Str	»I2>[1] . Alarm«
	Op	»I2>[1] . Trip«

Logical Node	Data Object	Module ( - ANSI/IEEE Device Number ) . Name
<b>ULPTOC2 (PTOC3)</b>		
	Mod	»I2>[2] . Active« »I2>[2] . Blo TripCmd« »I2>[2] . ExBlo TripCmd«
	Beh	
	Health	
	NamPlt	
	Str	»I2>[2] . Alarm«
	Op	»I2>[2] . Trip«

Logical Node	Data Object	Module ( - ANSI/IEEE Device Number ) . Name
<b>VAPTOV1* (PTOV3)</b>		
	Mod	»V012[1] . Active« »V012[1] . Blo TripCmd« »V012[1] . ExBlo TripCmd«
	Beh	
	Health	
	NamPlt	

Logical Node	Data Object	Module ( - ANSI/IEEE Device Number ) . Name
<b>VAPTOV1* (PTOV3)</b>		
	Str	»V012[1] . Alarm«
	Op	»V012[1] . Trip«

Logical Node	Data Object	Module ( - ANSI/IEEE Device Number ) . Name
<b>VAPTOV2* (PTOV3)</b>		
	Mod	»V012[2] . Active« »V012[2] . Blo TripCmd« »V012[2] . ExBlo TripCmd«
	Beh	
	Health	
	NamPlt	
	Str	»V012[2] . Alarm«
	Op	»V012[2] . Trip«

Logical Node	Data Object	Module ( - ANSI/IEEE Device Number ) . Name
<b>VAPTOV3* (PTOV3)</b>		
	Mod	»V012[3] . Active« »V012[3] . Blo TripCmd« »V012[3] . ExBlo TripCmd«
	Beh	
	Health	
	NamPlt	
	Str	»V012[3] . Alarm«
	Op	»V012[3] . Trip«

Logical Node	Data Object	Module ( - ANSI/IEEE Device Number ) . Name
<b>VAPTOV4* (PTOV3)</b>		
	Mod	»V012[4] . Active« »V012[4] . Blo TripCmd« »V012[4] . ExBlo TripCmd«
	Beh	
	Health	
	NamPlt	
	Str	»V012[4] . Alarm«
	Op	»V012[4] . Trip«

Logical Node	Data Object	Module ( - ANSI/IEEE Device Number ) . Name
<b>VAPTOV5* (PTOV3)</b>		
	Mod	»V012[5] . Active« »V012[5] . Blo TripCmd« »V012[5] . ExBlo TripCmd«
	Beh	
	Health	
	NamPlt	
	Str	»V012[5] . Alarm«
	Op	»V012[5] . Trip«

Logical Node	Data Object	Module ( - ANSI/IEEE Device Number ) . Name
<b>VAPTOV6* (PTOV3)</b>		
	Mod	»V012[6] . Active« »V012[6] . Blo TripCmd« »V012[6] . ExBlo TripCmd«
	Beh	
	Health	
	NamPlt	
	Str	»V012[6] . Alarm«
	Op	»V012[6] . Trip«

Logical Node	Data Object	Module ( - ANSI/IEEE Device Number ) . Name
<b>VAPTUV1* (PTUV3)</b>		
	Mod	»V012[1] . Active« »V012[1] . Blo TripCmd« »V012[1] . ExBlo TripCmd«
	Beh	
	Health	
	NamPlt	
	Str	»V012[1] . Alarm«
	Op	»V012[1] . Trip«

Logical Node	Data Object	Module ( - ANSI/IEEE Device Number ) . Name
<b>VAPTUV2* (PTUV3)</b>		
	Mod	»V012[2] . Active« »V012[2] . Blo TripCmd« »V012[2] . ExBlo TripCmd«

Logical Node	Data Object	Module ( - ANSI/IEEE Device Number ) . Name
<b>VAPTUV2* (PTUV3)</b>		
	Beh	
	Health	
	NamPlt	
	Str	»V012[2] . Alarm«
	Op	»V012[2] . Trip«

Logical Node	Data Object	Module ( - ANSI/IEEE Device Number ) . Name
<b>VAPTUV3* (PTUV3)</b>		
	Mod	»V012[3] . Active« »V012[3] . Blo TripCmd« »V012[3] . ExBlo TripCmd«
	Beh	
	Health	
	NamPlt	
	Str	»V012[3] . Alarm«
	Op	»V012[3] . Trip«

Logical Node	Data Object	Module ( - ANSI/IEEE Device Number ) . Name
<b>VAPTUV4* (PTUV3)</b>		
	Mod	»V012[4] . Active« »V012[4] . Blo TripCmd« »V012[4] . ExBlo TripCmd«
	Beh	
	Health	
	NamPlt	
	Str	»V012[4] . Alarm«
	Op	»V012[4] . Trip«

Logical Node	Data Object	Module ( - ANSI/IEEE Device Number ) . Name
<b>VAPTUV5* (PTUV3)</b>		
	Mod	»V012[5] . Active« »V012[5] . Blo TripCmd« »V012[5] . ExBlo TripCmd«
	Beh	
	Health	
	NamPlt	



Logical Node	Data Object	Module ( - ANSI/IEEE Device Number ) . Name
<b>VAPTUV5* (PTUV3)</b>		
	Str	»V012[5] . Alarm«
	Op	»V012[5] . Trip«

Logical Node	Data Object	Module ( - ANSI/IEEE Device Number ) . Name
<b>VAPTUV6* (PTUV3)</b>		
	Mod	»V012[6] . Active« »V012[6] . Blo TripCmd« »V012[6] . ExBlo TripCmd«
	Beh	
	Health	
	NamPlt	
	Str	»V012[6] . Alarm«
	Op	»V012[6] . Trip«

Logical Node	Data Object	Module ( - ANSI/IEEE Device Number ) . Name
<b>VSPTOV1* (PTOV1)</b>		
	Mod	»VG[1] . Active« »VG[1] . Blo TripCmd« »VG[1] . ExBlo TripCmd«
	Beh	
	Health	
	NamPlt	
	Str	»VG[1] . Alarm«
	Op	»VG[1] . Trip«

Logical Node	Data Object	Module ( - ANSI/IEEE Device Number ) . Name
<b>VSPTOV2* (PTOV1)</b>		
	Mod	»VG[2] . Active« »VG[2] . Blo TripCmd« »VG[2] . ExBlo TripCmd«
	Beh	
	Health	
	NamPlt	
	Str	»VG[2] . Alarm«
	Op	»VG[2] . Trip«

Logical Node	Data Object	Module ( - ANSI/IEEE Device Number ) . Name
<b>VSPTUV1* (PTUV1)</b>		
	Mod	»VG[1] . Active« »VG[1] . Blo TripCmd« »VG[1] . ExBlo TripCmd«
	Beh	
	Health	
	NamPlt	
	Str	»VG[1] . Alarm«
	Op	»VG[1] . Trip«

Logical Node	Data Object	Module ( - ANSI/IEEE Device Number ) . Name
<b>VSPTUV2* (PTUV1)</b>		
	Mod	»VG[2] . Active« »VG[2] . Blo TripCmd« »VG[2] . ExBlo TripCmd«
	Beh	
	Health	
	NamPlt	
	Str	»VG[2] . Alarm«
	Op	»VG[2] . Trip«

## 4.2 Device Planning Dependencies

The availability of Logical Node instances in the generated ICD file depends on the settings in the “Device planning” menu.

The following list gives an overview about those settings for every module that have an effect on the availability of a Logical Node.

Module ( - ANSI/IEEE Device Number ) . Name	Value
<b>XSWI1</b>	
»SG[1] . SwitchgearType«	“Monitored SG”
	“Controlled SG”
<b>XCBR1</b>	
»SG[1] . SwitchgearType«	“Monitored Make Break SG”
	“Controlled Make Break SG”
<b>XSWI2</b>	
»SG[2] . SwitchgearType«	“Monitored SG”
	“Controlled SG”
<b>XCBR2</b>	
»SG[2] . SwitchgearType«	“Monitored Make Break SG”
	“Controlled Make Break SG”
<b>XSWI3</b>	
»SG[3] . SwitchgearType«	“Monitored SG”
	“Controlled SG”
<b>XCBR3</b>	
»SG[3] . SwitchgearType«	“Monitored Make Break SG”
	“Controlled Make Break SG”
<b>XSWI4</b>	
»SG[4] . SwitchgearType«	“Monitored SG”
	“Controlled SG”
<b>XCBR4</b>	
»SG[4] . SwitchgearType«	“Monitored Make Break SG”
	“Controlled Make Break SG”
<b>XSWI5</b>	
»SG[5] . SwitchgearType«	“Monitored SG”
	“Controlled SG”
<b>XCBR5</b>	
»SG[5] . SwitchgearType«	“Monitored Make Break SG”
	“Controlled Make Break SG”
<b>XSWI6</b>	

<b>Module ( - ANSI/IEEE Device Number ) . Name</b>	<b>Value</b>
»SG[6] . SwitchgearType«	“Monitored SG”
	“Controlled SG”
<b>XCBR6</b>	
»SG[6] . SwitchgearType«	“Monitored Make Break SG”
	“Controlled Make Break SG”
<b>CSWI1</b>	
»SG[1] . SwitchgearType«	“Controlled SG”
	“Controlled Make Break SG”
<b>CILO1</b>	
»SG[1] . SwitchgearType«	“Controlled SG”
	“Controlled Make Break SG”
<b>CSWI2</b>	
»SG[2] . SwitchgearType«	“Controlled SG”
	“Controlled Make Break SG”
<b>CILO2</b>	
»SG[2] . SwitchgearType«	“Controlled SG”
	“Controlled Make Break SG”
<b>CSWI3</b>	
»SG[3] . SwitchgearType«	“Controlled SG”
	“Controlled Make Break SG”
<b>CILO3</b>	
»SG[3] . SwitchgearType«	“Controlled SG”
	“Controlled Make Break SG”
<b>CSWI4</b>	
»SG[4] . SwitchgearType«	“Controlled SG”
	“Controlled Make Break SG”
<b>CILO4</b>	
»SG[4] . SwitchgearType«	“Controlled SG”
	“Controlled Make Break SG”
<b>CSWI5</b>	
»SG[5] . SwitchgearType«	“Controlled SG”
	“Controlled Make Break SG”
<b>CILO5</b>	
»SG[5] . SwitchgearType«	“Controlled SG”
	“Controlled Make Break SG”
<b>CSWI6</b>	
»SG[6] . SwitchgearType«	“Controlled SG”

Module ( - ANSI/IEEE Device Number ) . Name	Value
	"Controlled Make Break SG"
<b>CILO6</b>	
»SG[6] . SwitchgearType«	"Controlled SG"
	"Controlled Make Break SG"
<b>PTRC1</b>	
»SG[1] . SwitchgearType«	"Monitored Make Break SG"
	"Controlled Make Break SG"
<b>PTUV1</b>	
»V[1] . Mode«	"V<"
	"use"
<b>PTOV1</b>	
»V[1] . Mode«	"V>"
<b>PFRC1</b>	
»df/dt . Mode«	"f< and df/dt"
	"f> and df/dt"
	"f< and DF/DT"
	"f> and DF/DT"
	"df/dt"
	"use"
<b>PDOPI</b>	
»P . Mode«	"P>"
	"Pr>"
	"Q>"
	"Qr>"
	"S>"
	"P>"
	"Pr>"
	"Q>"
	"Qr>"
	"PAV,E P1>"
	"PAV,E P1r>"
	"PAV,E P1<"
	"PAV,E P1r<"
<b>VSPTOV1</b>	
»VG[1] . Mode«	"V>"
<b>VSPTUV1</b>	
»VG[1] . Mode«	"V<"

Module ( - ANSI/IEEE Device Number ) . Name	Value
	"use"
<b>VAPTUV1</b>	
»V012[1] . Mode«	"V1<"
<b>VAPTOV1</b>	
»V012[1] . Mode«	"V1>"
	"V2>"
	"use"
<b>OEVPVPH1</b>	
»V/f>[1] . Mode«	"use"
<b>PTRC2</b>	
»SG[2] . SwitchgearType«	"Monitored Make Break SG"
	"Controlled Make Break SG"
<b>PTUV2</b>	
»V[2] . Mode«	"V<"
	"use"
<b>PTOV2</b>	
»V[2] . Mode«	"V>"
<b>PPAM2</b>	
»delta phi . Mode«	"delta phi"
	"use"
<b>PDOP2</b>	
»Q . Mode«	"P>"
	"Pr>"
	"Q>"
	"Qr>"
	"S>"
	"P>"
	"Pr>"
	"Q>"
	"Qr>"
	"PAV,E P1>"
	"PAV,E P1r>"
	"PAV,E P1<"
	"PAV,E P1r<"
<b>VSPTOV2</b>	
»VG[2] . Mode«	"V>"
<b>VSPTUV2</b>	

Module ( - ANSI/IEEE Device Number ) . Name	Value
»VG[2] . Mode«	"V<"
	"use"
<b>VAPTUV2</b>	
»V012[2] . Mode«	"V1<"
<b>VAPTOV2</b>	
»V012[2] . Mode«	"V1>"
	"V2>"
	"use"
<b>OEPPH2</b>	
»V/f>[2] . Mode«	"use"
<b>PTRC3</b>	
»SG[3] . SwitchgearType«	"Monitored Make Break SG"
	"Controlled Make Break SG"
<b>PTUV3</b>	
»V[3] . Mode«	"V<"
	"use"
<b>PTOV3</b>	
»V[3] . Mode«	"V>"
<b>VAPTUV3</b>	
»V012[3] . Mode«	"V1<"
<b>VAPTOV3</b>	
»V012[3] . Mode«	"V1>"
	"V2>"
	"use"
<b>PTOF3</b>	
»f[1] . Mode«	"f>"
<b>PTUF3</b>	
»f[1] . Mode«	"f<"
<b>PFRC3</b>	
»f[1] . Mode«	"f< and df/dt"
	"f> and df/dt"
	"f< and DF/DT"
	"f> and DF/DT"
	"df/dt"
	"use"
<b>PPAM3</b>	
»f[1] . Mode«	"delta phi"

Module ( - ANSI/IEEE Device Number ) . Name	Value
	"use"
<b>PDUP3</b>	
»PQS[1] . Mode«	"P<"
	"Pr<"
	"Q<"
	"Qr<"
	"S<"
	"P<"
	"Pr<"
	"Q<"
	"Qr<"
	"PAV,E P1>"
	"PAV,E P1r>"
	"PAV,E P1<"
	"PAV,E P1r<"
<b>PDOP3</b>	
»PQS[1] . Mode«	"P>"
	"Pr>"
	"Q>"
	"Qr>"
	"S>"
	"P>"
	"Pr>"
	"Q>"
	"Qr>"
	"PAV,E P1>"
	"PAV,E P1r>"
	"PAV,E P1<"
	"PAV,E P1r<"
<b>PTRC4</b>	
»SG[4] . SwitchgearType«	"Monitored Make Break SG"
	"Controlled Make Break SG"
<b>PTUV4</b>	
»V[4] . Mode«	"V<"
	"use"
<b>PTOV4</b>	
»V[4] . Mode«	"V>"



Module (- ANSI/IEEE Device Number ) . Name	Value
<b>VAPTUV4</b>	
»V012[4] . Mode«	"V1<"
<b>VAPTOV4</b>	
»V012[4] . Mode«	"V1>"
	"V2>"
	"use"
<b>PTOF4</b>	
»f[2] . Mode«	"f>"
<b>PTUF4</b>	
»f[2] . Mode«	"f<"
<b>PFRC4</b>	
»f[2] . Mode«	"f< and df/dt"
	"f> and df/dt"
	"f< and DF/DT"
	"f> and DF/DT"
	"df/dt"
	"use"
<b>PPAM4</b>	
»f[2] . Mode«	"delta phi"
	"use"
<b>PDUP4</b>	
»PQS[2] . Mode«	"P<"
	"Pr<"
	"Q<"
	"Qr<"
	"S<"
	"P<"
	"Pr<"
	"Q<"
	"Qr<"
	"PAV,E P1>"
	"PAV,E P1r>"
	"PAV,E P1<"
	"PAV,E P1r<"
<b>PDOP4</b>	
»PQS[2] . Mode«	"P>"
	"Pr>"

Module ( - ANSI/IEEE Device Number ) . Name	Value
	"Q>"
	"Qr>"
	"S>"
	"P>"
	"Pr>"
	"Q>"
	"Qr>"
	"PAV,E P1>"
	"PAV,E P1r>"
	"PAV,E P1<"
	"PAV,E P1r<"
<b>PTRC5</b>	
»SG[5] . SwitchgearType«	"Monitored Make Break SG"
	"Controlled Make Break SG"
<b>PTUV5</b>	
»V[5] . Mode«	"V<"
	"use"
<b>PTOV5</b>	
»V[5] . Mode«	"V>"
<b>VAPTUV5</b>	
»V012[5] . Mode«	"V1<"
<b>VAPTOV5</b>	
»V012[5] . Mode«	"V1>"
	"V2>"
	"use"
<b>PTOF5</b>	
»f[3] . Mode«	"f>"
<b>PTUF5</b>	
»f[3] . Mode«	"f<"
<b>PFRC5</b>	
»f[3] . Mode«	"f< and df/dt"
	"f> and df/dt"
	"f< and DF/DT"
	"f> and DF/DT"
	"df/dt"
	"use"
<b>PPAM5</b>	

Module ( - ANSI/IEEE Device Number ) . Name	Value
»f[3] . Mode«	"delta phi"
	"use"
<b>PDUP5</b>	
»PQS[3] . Mode«	"P<"
	"Pr<"
	"Q<"
	"Qr<"
	"S<"
	"P<"
	"Pr<"
	"Q<"
	"Qr<"
	"PAV,E P1>"
	"PAV,E P1r>"
	"PAV,E P1<"
	"PAV,E P1r<"
<b>PDOP5</b>	
»PQS[3] . Mode«	"P>"
	"Pr>"
	"Q>"
	"Qr>"
	"S>"
	"P>"
	"Pr>"
	"Q>"
	"Qr>"
	"PAV,E P1>"
	"PAV,E P1r>"
	"PAV,E P1<"
	"PAV,E P1r<"
<b>PTRC6</b>	
»SG[6] . SwitchgearType«	"Monitored Make Break SG"
	"Controlled Make Break SG"
<b>PTUV6</b>	
»V[6] . Mode«	"V<"
	"use"
<b>PTOV6</b>	

Module ( - ANSI/IEEE Device Number ) . Name	Value
»V[6] . Mode«	"V>"
<b>VAPTUV6</b>	
»V012[6] . Mode«	"V1<"
<b>VAPTOV6</b>	
»V012[6] . Mode«	"V1>"
	"V2>"
	"use"
<b>PTOF6</b>	
»f[4] . Mode«	"f>"
<b>PTUF6</b>	
»f[4] . Mode«	"f<"
<b>PFRC6</b>	
»f[4] . Mode«	"f< and df/dt"
	"f> and df/dt"
	"f< and DF/DT"
	"f> and DF/DT"
	"df/dt"
	"use"
<b>PPAM6</b>	
»f[4] . Mode«	"delta phi"
	"use"
<b>PDUP6</b>	
»PQS[4] . Mode«	"P<"
	"Pr<"
	"Q<"
	"Qr<"
	"S<"
	"P<"
	"Pr<"
	"Q<"
	"Qr<"
	"PAV,E P1>"
	"PAV,E P1r>"
	"PAV,E P1<"
	"PAV,E P1r<"
<b>PDOP6</b>	
»PQS[4] . Mode«	"P>"

Module ( - ANSI/IEEE Device Number ) . Name	Value
	"Pr>"
	"Q>"
	"Qr>"
	"S>"
	"P>"
	"Pr>"
	"Q>"
	"Qr>"
	"PAV,E P1>"
	"PAV,E P1r>"
	"PAV,E P1<"
	"PAV,E P1r<"
<b>PTOF7</b>	
»f[5] . Mode«	"f>"
<b>PTUF7</b>	
»f[5] . Mode«	"f<"
<b>PFRC7</b>	
»f[5] . Mode«	"f< and df/dt"
	"f> and df/dt"
	"f< and DF/DT"
	"f> and DF/DT"
	"df/dt"
	"use"
<b>PPAM7</b>	
»f[5] . Mode«	"delta phi"
	"use"
<b>PDUP7</b>	
»PQS[5] . Mode«	"P<"
	"Pr<"
	"Q<"
	"Qr<"
	"S<"
	"P<"
	"Pr<"
	"Q<"
	"Qr<"
	"PAV,E P1>"

Module ( - ANSI/IEEE Device Number ) . Name	Value
	"PAV,E P1r>"
	"PAV,E P1<"
	"PAV,E P1r<"
<b>PDOP7</b>	
»PQS[5] . Mode«	"P>"
	"Pr>"
	"Q>"
	"Qr>"
	"S>"
	"P>"
	"Pr>"
	"Q>"
	"Qr>"
	"PAV,E P1>"
	"PAV,E P1r>"
	"PAV,E P1<"
	"PAV,E P1r<"
<b>PTOF8</b>	
»f[6] . Mode«	"f>"
<b>PTUF8</b>	
»f[6] . Mode«	"f<"
<b>PFRC8</b>	
»f[6] . Mode«	"f< and df/dt"
	"f> and df/dt"
	"f< and DF/DT"
	"f> and DF/DT"
	"df/dt"
	"use"
<b>PPAM8</b>	
»f[6] . Mode«	"delta phi"
	"use"
<b>PDUP8</b>	
»PQS[6] . Mode«	"P<"
	"Pr<"
	"Q<"
	"Qr<"
	"S<"


Module ( - ANSI/IEEE Device Number ) . Name	Value
	"P<"
	"Pr<"
	"Q<"
	"Qr<"
	"PAV,E P1>"
	"PAV,E P1r>"
	"PAV,E P1<"
	"PAV,E P1r<"
<b>PDOP8</b>	
»PQS[6] . Mode«	"P>"
	"Pr>"
	"Q>"
	"Qr>"
	"S>"
	"P>"
	"Pr>"
	"Q>"
	"Qr>"
	"PAV,E P1>"
	"PAV,E P1r>"
	"PAV,E P1<"
	"PAV,E P1r<"

High **PROTEC**

**MCDLV4**

IEC 61850 (Edition 1) — MICS

[docs.SEGelectronics.de/HighPROTEC](https://docs.SEGelectronics.de/HighPROTEC)



SEG Electronics GmbH reserves the right to update any portion of this publication at any time.  
Information provided by SEG Electronics GmbH is believed to be correct and reliable.  
However, SEG Electronics GmbH assumes no responsibility  
unless otherwise expressly undertaken.



SEG Electronics GmbH  
Krefelder Weg 47 • D-47906 Kempen (Germany)  
Telephone: +49 (0) 21 52 145 0

Internet: [www.SEGelectronics.de](http://www.SEGelectronics.de)

Sales  
Telephone: +49 (0) 21 52 145 331  
Fax: +49 (0) 21 52 145 354  
E-mail: [sales@SEGelectronics.de](mailto:sales@SEGelectronics.de)

Service  
Telephone: +49 (0) 21 52 145 600  
Fax: +49 (0) 21 52 145 354  
E-mail: [support@SEGelectronics.de](mailto:support@SEGelectronics.de)