



High **PRO**TEC

MRDT4-3.7-EN-IEC61850-MICS

MRDT4

Transformer Differential Protection

IEC 61850 - MICS

Model Implementation Conformance Statement (MICS)

UCA International Users Group Testing Sub Committee

Version: 3.7

Original document · English

Revision: - 47547 · © 2020

Woodward Kempen GmbH

Krefelder Weg 47 • D-47906 Kempen (Germany)

Postfach 10 07 55 (P.O.Box) • D-47884 Kempen (Germany)

Telephone: +49 (0) 21 52 145 1

Internet: www.woodward.com

Sales

Telephone: +49 (0) 21 52 145 331

Fax: +49 (0) 21 52 145 354

Email: SalesPGD_EMEA@woodward.com

Service

Telephone: +49 (0) 21 52 145 614

Fax: +49 (0) 21 52 145 354

Email: industrial.support@woodward.com

© 2020 Woodward Kempen GmbH

Table of Contents

1	Introduction	6
2	Logical Nodes	7
2.1	Logical Nodes List	7
2.2	Logical Node Definitions	9
2.3	WW_CILO1	11
2.4	WW_CSWI1	11
2.5	WW_GAPC1	11
2.6	WW_GGIO4	12
2.7	WW_GGIO10	13
2.8	WW_GGIO11	14
2.9	WW_GGIO14	16
2.10	WW_IHMI1	17
2.11	WW_LLN0CON	17
2.12	WW_LLN0MEA	18
2.13	WW_LLN0PRO	18
2.14	WW_LLN0REC	19
2.15	WW_LLN0SYS	19
2.16	WW_LPHDCON	19
2.17	WW_LPHDMEA	20
2.18	WW_LPHDPRO	20
2.19	WW_LPHDREC	20
2.20	WW_LPHDSYS	21
2.21	WW_MMXU7	21
2.22	WW_MSTA1	21
2.23	WW_PDIF1	22
2.24	WW_PDIF2	22
2.25	WW_PDIF3	23
2.26	WW_PDIF4	23
2.27	WW_PHAR1	24
2.28	WW_PSOF1	24

Table of Contents

2.29	WW_PTOC1	25
2.30	WW_PTOC3	25
2.31	WW_PTOC4	25
2.32	WW_PTTR3	26
2.33	WW_PTTR4	26
2.34	WW_RBRF1	27
2.35	WW_RDRE1	27
2.36	WW_SCBR1	28
2.37	WW_XCBR2	28
2.38	WW_XSWI1	29
3	Common Data Class	30
3.1	Common Data Class Definitions	30
3.1.1	WW_ACD1	31
3.1.2	WW_ACT1	31
3.1.3	WW_CMV2	31
3.1.4	WW_DPC1	31
3.1.5	WW_DPC2	32
3.1.6	WW_DPL1	32
3.1.7	WW_INC1	32
3.1.8	WW_INS1	33
3.1.9	WW_INS2	33
3.1.10	WW_INS3	33
3.1.11	WW_INS5	34
3.1.12	WW_LPL1	34
3.1.13	WW_LPL2	34
3.1.14	WW_LPL3	34
3.1.15	WW_MV1	35
3.1.16	WW_SPC1	35
3.1.17	WW_SPC2	35
3.1.18	WW_SPS1	36
3.1.19	WW_WYE2	36
3.2	Common Data Attributes Type Definitions	37

3.2.1	WW_analogValue1	37
3.2.2	WW_Cancel1	37
3.2.3	WW_Oper1	37
3.2.4	WW_origin1	37
3.2.5	WW_units1	38
3.2.6	WW_vector1	38
3.3	Enumerated type definitions	39
3.3.1	AutoRecSt	39
3.3.2	Beh	39
3.3.3	CBOpCap	39
3.3.4	ctlModel	39
3.3.5	Dbpos	40
3.3.6	ACDdir	40
3.3.7	Health	40
3.3.8	Mod	40
3.3.9	MotorCycle	41
3.3.10	multiplier	41
3.3.11	orCategory	42
3.3.12	sboClass	42
3.3.13	SIUnit	42
4	Appendix	45
4.1	Register Maps	45
4.2	Device Planning Dependencies	66

1 Introduction

This model implementation conformance statement is applicable to the MRDT4 version 3.7.

This MICS document specifies the modelling extensions compared to IEC 61850 edition 1.

Clause 2 contains the list of implemented logical nodes.

Clause 3 describes the new and extended logical nodes.

Clause 4 describes the existing common data classes.

Clause 5 describes the existing enum types.

2 Logical Nodes

2.1 Logical Nodes List

The following table contains the list of logical nodes implemented in the device:

L: System Logical Nodes
LLNO (Logical Node device)
LPHD (Physical device)
P: Logical Nodes for protection functions
PDIF (Differential)
PHAR (Harmonic restraint)
PSOF (Switch Onto Fault)
PTOC (Time overcurrent)
PTTR (Thermal overload protection)
R: Logical Nodes for protection related functions
RBRF (Breaker failure)
RDRE (Disturbance recorder function)
G: Logical Nodes for generic references
GAPC (Generic automatic process control)
GGIO (Generic process I/O)
M: Logical Nodes for metering and measurement
MMXU (Measurement)
MSTA (Metering Statistics)
X: Logical Nodes for switchgear
XCBR (Circuit Breaker)
XSWI (Circuit Switch)
C: Logical Nodes for control
CILO (Interlocking)
CSWI (Switch controller)
I: Logical Nodes for interfacing and archiving
IHMI (Human machine interface)

2 Logical Nodes

2.1 Logical Nodes List

S: Logical Nodes for sensors and monitoring

SCBR (Circuit breaker monitoring)

2.2 Logical Node Definitions

Abbreviations used in the following table:

- **M**: Data is mandatory in the IEC 61850-7-4.
- **O**: Data is optional in the IEC 61850-7-4 and is used in the device.
- **E**: Data is an extension to the IEC 61850-7-4.

LN Type	LN Class	Description
WW_CILO1	CILO	Interlocking
WW_CSWI1	CSWI	Switch controller
WW_GAPC1	GAPC	Generic automatic process control
WW_GGIO10	GGIO	Generic process I/O
WW_GGIO11	GGIO	Generic process I/O
WW_GGIO14	GGIO	Generic process I/O
WW_GGIO4	GGIO	Generic process I/O
WW_IHMI1	IHMI	Human machine interface
WW_LLNOCON	LLNO	Logical Node device
WW_LLNAMEA	LLNO	Logical Node device
WW_LLNOPRO	LLNO	Logical Node device
WW_LLNOREC	LLNO	Logical Node device
WW_LLNOSYS	LLNO	Logical Node device
WW_LPHDCON	LPHD	Physical device
WW_LPHDMEA	LPHD	Physical device
WW_LPHDPRO	LPHD	Physical device
WW_LPHDREC	LPHD	Physical device
WW_LPHDSYS	LPHD	Physical device
WW_MMXU7	MMXU	Measurement
WW_MSTA1	MSTA	Metering Statistics
WW_PDIF1	PDIF	Differential
WW_PDIF2	PDIF	Differential
WW_PDIF3	PDIF	Differential
WW_PDIF4	PDIF	Differential
WW_PHAR1	PHAR	Harmonic restraint
WW_PSOF1	PSOF	Switch Onto Fault
WW_PTOC1	PTOC	Time overcurrent
WW_PTOC3	PTOC	Time overcurrent
WW_PTOC4	PTOC	Time overcurrent
WW_PTTR3	PTTR	Thermal overload protection
WW_PTTR4	PTTR	Thermal overload protection

2 Logical Nodes

2.2 Logical Node Definitions

LN Type	LN Class	Description
WW_RBRF1	RBRF	Breaker failure
WW_RDRE1	RDRE	Disturbance recorder function
WW_SCBR1	SCBR	Circuit breaker monitoring
WW_XCBR2	XCBR	Circuit Breaker
WW_XSWI1	XSWI	Circuit Switch

2.3 WW_CILO1

Attribute	Attribute	Explanation	M/O/E	Remarks
Name	Type			
CILO class				
CILO	WW_CILO1	Interlocking		
Data				
<i>Common Logical Node Information</i>				
Mod	WW_INC1	Mode	M	Status-only
Beh	WW_INS1	Behavior	M	
Health	WW_INS3	Health	M	
NamPlt	WW_LPL1	Name plate	M	
<i>Status Information</i>				
EnaOpn	WW_SPS1	Enable Open	M	
EnaCls	WW_SPS1	Enable Close	M	

2.4 WW_CSWI1

Attribute	Attribute	Explanation	M/O/E	Remarks
Name	Type			
CSWI class				
CSWI	WW_CSWI1	Switch Controller		
Data				
<i>Common Logical Node Information</i>				
Mod	WW_INC1	Mode	M	Status-only
Beh	WW_INS1	Behaviour	M	
Health	WW_INS3	Health	M	
NamPlt	WW_LPL1	Name plate	M	
Loc	WW_SPS1	Local operation	O	
<i>Controls</i>				
Pos	WW_DPC2	Switch position	M	

2.5 WW_GAPC1

Attribute	Attribute	Explanation	M/O/E	Remarks
Name	Type			
GAPC class				
GAPC	WW_GAPC1	Generic automatic process control		

2 Logical Nodes

2.6 WW_GGIO4

Attribute	Attribute	Explanation	M/O/E	Remarks			
Name	Type						
Data							
<i>Common Logical Node Information</i>							
Mod	WW_INC1	Mode	M	Status-only			
Beh	WW_INS1	Behaviour	M				
Health	WW_INS3	Health	M				
NamPlt	WW_LPL1	Name plate	M				
Loc	WW_SPS1	Local operation	O				
<i>Status Information</i>							
Str	WW_ACD1	Start	M				
Op	WW_ACT1	Operate	M				

2.6 WW_GGIO4

Attribute	Attribute	Explanation	M/O/E	Remarks
Name	Type			
GGIO class				
GGIO	WW_GGIO4	Generic process I/O		
Data				
<i>Common Logical Node Information</i>				
Mod	WW_INC1	Mode	M	Status-only
Beh	WW_INS1	Behaviour	M	
Health	WW_INS3	Health	M	
NamPlt	WW_LPL1	Name plate	M	
<i>Status Information</i>				
Ind1	WW_SPS1	General indication (binary input)	O	
Ind2	WW_SPS1	General indication (binary input)	O	
Ind3	WW_SPS1	General indication (binary input)	O	
Ind4	WW_SPS1	General indication (binary input)	O	
Ind5	WW_SPS1	General indication (binary input)	O	
Ind6	WW_SPS1	General indication (binary input)	O	
Ind7	WW_SPS1	General indication (binary input)	O	
Ind8	WW_SPS1	General indication (binary input)	O	
Ind9	WW_SPS1	General indication (binary input)	O	
Ind10	WW_SPS1	General indication (binary input)	O	
Ind11	WW_SPS1	General indication (binary input)	O	
Ind12	WW_SPS1	General indication (binary input)	O	

Attribute	Attribute	Explanation	M/O/E	Remarks
Name	Type			
Ind13	WW_SPS1	General indication (binary input)	O	
Ind14	WW_SPS1	General indication (binary input)	O	
Ind15	WW_SPS1	General indication (binary input)	O	
Ind16	WW_SPS1	General indication (binary input)	O	
Ind17	WW_SPS1	General indication (binary input)	O	
Ind18	WW_SPS1	General indication (binary input)	O	
Ind19	WW_SPS1	General indication (binary input)	O	
Ind20	WW_SPS1	General indication (binary input)	O	
Ind21	WW_SPS1	General indication (binary input)	O	
Ind22	WW_SPS1	General indication (binary input)	O	
Ind23	WW_SPS1	General indication (binary input)	O	
Ind24	WW_SPS1	General indication (binary input)	O	
Ind25	WW_SPS1	General indication (binary input)	O	
Ind26	WW_SPS1	General indication (binary input)	O	
Ind27	WW_SPS1	General indication (binary input)	O	
Ind28	WW_SPS1	General indication (binary input)	O	
Ind29	WW_SPS1	General indication (binary input)	O	
Ind30	WW_SPS1	General indication (binary input)	O	
Ind31	WW_SPS1	General indication (binary input)	O	
Ind32	WW_SPS1	General indication (binary input)	O	

2.7 WW_GGIO10

Attribute	Attribute	Explanation	M/O/E	Remarks
Name	Type			
GGIO class				
GGIO	WW_GGI10	Generic process I/O		
Data				
<i>Common Logical Node Information</i>				
Mod	WW_INC1	Mode	M	Status-only
Beh	WW_INS1	Behaviour	M	
Health	WW_INS3	Health	M	
NamPlt	WW_LPL1	Name plate	M	
<i>Status Information</i>				
Ind1	WW_SPS1	General indication (binary input)	O	
Ind2	WW_SPS1	General indication (binary input)	O	

2 Logical Nodes

2.8 WW_GGIO11

Attribute	Attribute	Explanation	M/O/E	Remarks
Name	Type			
Ind3	WW_SPS1	General indication (binary input)	O	
Ind4	WW_SPS1	General indication (binary input)	O	
Ind5	WW_SPS1	General indication (binary input)	O	
Ind6	WW_SPS1	General indication (binary input)	O	
Ind7	WW_SPS1	General indication (binary input)	O	
Ind8	WW_SPS1	General indication (binary input)	O	
Ind9	WW_SPS1	General indication (binary input)	O	
Ind10	WW_SPS1	General indication (binary input)	O	
Ind11	WW_SPS1	General indication (binary input)	O	
Ind12	WW_SPS1	General indication (binary input)	O	
Ind13	WW_SPS1	General indication (binary input)	O	
Ind14	WW_SPS1	General indication (binary input)	O	
Ind15	WW_SPS1	General indication (binary input)	O	
Ind16	WW_SPS1	General indication (binary input)	O	
Ind17	WW_SPS1	General indication (binary input)	O	
Ind18	WW_SPS1	General indication (binary input)	O	
Ind19	WW_SPS1	General indication (binary input)	O	
Ind20	WW_SPS1	General indication (binary input)	O	
Ind21	WW_SPS1	General indication (binary input)	O	
Ind22	WW_SPS1	General indication (binary input)	O	
Ind23	WW_SPS1	General indication (binary input)	O	
Ind24	WW_SPS1	General indication (binary input)	O	
Ind25	WW_SPS1	General indication (binary input)	O	
Ind26	WW_SPS1	General indication (binary input)	O	
Ind27	WW_SPS1	General indication (binary input)	O	
Ind28	WW_SPS1	General indication (binary input)	O	
Ind29	WW_SPS1	General indication (binary input)	O	
Ind30	WW_SPS1	General indication (binary input)	O	
Ind31	WW_SPS1	General indication (binary input)	O	
Ind32	WW_SPS1	General indication (binary input)	O	

2.8 WW_GGIO11

Attribute	Attribute	Explanation	M/O/E	Remarks
Name	Type			
GGIO class				

Attribute	Attribute	Explanation	M/O/E	Remarks
Name	Type			
GGIO	WW_GGI11	Generic process I/O		
Data				
<i>Common Logical Node Information</i>				
Mod	WW_INC1	Mode	M	Status-only
Beh	WW_INS1	Behaviour	M	
Health	WW_INS3	Health	M	
NamPlt	WW_LPL1	Name plate	M	
<i>Status Information</i>				
Ind1	WW_SPS1	General indication (binary input)	O	
Ind2	WW_SPS1	General indication (binary input)	O	
Ind3	WW_SPS1	General indication (binary input)	O	
Ind4	WW_SPS1	General indication (binary input)	O	
Ind5	WW_SPS1	General indication (binary input)	O	
Ind6	WW_SPS1	General indication (binary input)	O	
Ind7	WW_SPS1	General indication (binary input)	O	
Ind8	WW_SPS1	General indication (binary input)	O	
Ind9	WW_SPS1	General indication (binary input)	O	
Ind10	WW_SPS1	General indication (binary input)	O	
Ind11	WW_SPS1	General indication (binary input)	O	
Ind12	WW_SPS1	General indication (binary input)	O	
Ind13	WW_SPS1	General indication (binary input)	O	
Ind14	WW_SPS1	General indication (binary input)	O	
Ind15	WW_SPS1	General indication (binary input)	O	
Ind16	WW_SPS1	General indication (binary input)	O	
Ind17	WW_SPS1	General indication (binary input)	O	
Ind18	WW_SPS1	General indication (binary input)	O	
Ind19	WW_SPS1	General indication (binary input)	O	
Ind20	WW_SPS1	General indication (binary input)	O	
Ind21	WW_SPS1	General indication (binary input)	O	
Ind22	WW_SPS1	General indication (binary input)	O	
Ind23	WW_SPS1	General indication (binary input)	O	
Ind24	WW_SPS1	General indication (binary input)	O	
Ind25	WW_SPS1	General indication (binary input)	O	
Ind26	WW_SPS1	General indication (binary input)	O	
Ind27	WW_SPS1	General indication (binary input)	O	
Ind28	WW_SPS1	General indication (binary input)	O	

Attribute	Attribute	Explanation	M/O/E	Remarks
Name	Type			
Ind29	WW_SPS1	General indication (binary input)	O	
Ind30	WW_SPS1	General indication (binary input)	O	
Ind31	WW_SPS1	General indication (binary input)	O	
Ind32	WW_SPS1	General indication (binary input)	O	

2.9 WW_GGIO14

Attribute	Attribute	Explanation	M/O/E	Remarks
Name	Type			
GGIO class				
GGIO	WW_GGI14	Generic process I/O		
Data				
<i>Common Logical Node Information</i>				
Mod	WW_INC1	Mode	M	Status-only
Beh	WW_INS1	Behaviour	M	
Health	WW_INS3	Health	M	
NamPlt	WW_LPL1	Name plate	M	
<i>Status Information</i>				
SPCSO1	WW_SPC2	Single point controllable status output	O	
SPCSO2	WW_SPC2	Single point controllable status output	O	
SPCSO3	WW_SPC2	Single point controllable status output	O	
SPCSO4	WW_SPC2	Single point controllable status output	O	
SPCSO5	WW_SPC2	Single point controllable status output	O	
SPCSO6	WW_SPC2	Single point controllable status output	O	
SPCSO7	WW_SPC2	Single point controllable status output	O	
SPCSO8	WW_SPC2	Single point controllable status output	O	
SPCSO9	WW_SPC2	Single point controllable status output	O	
SPCSO10	WW_SPC2	Single point controllable status output	O	
SPCSO11	WW_SPC2	Single point controllable status output	O	
SPCSO12	WW_SPC2	Single point controllable status output	O	
SPCSO13	WW_SPC2	Single point controllable status output	O	
SPCSO14	WW_SPC2	Single point controllable status output	O	
SPCSO15	WW_SPC2	Single point controllable status output	O	
SPCSO16	WW_SPC2	Single point controllable status output	O	
SPCSO17	WW_SPC2	Single point controllable status output	O	
SPCSO18	WW_SPC2	Single point controllable status output	O	

Attribute	Attribute	Explanation	M/O/E	Remarks
Name	Type			
SPCSO19	WW_SPC2	Single point controllable status output	O	
SPCSO20	WW_SPC2	Single point controllable status output	O	
SPCSO21	WW_SPC2	Single point controllable status output	O	
SPCSO22	WW_SPC2	Single point controllable status output	O	
SPCSO23	WW_SPC2	Single point controllable status output	O	
SPCSO24	WW_SPC2	Single point controllable status output	O	
SPCSO25	WW_SPC2	Single point controllable status output	O	
SPCSO26	WW_SPC2	Single point controllable status output	O	
SPCSO27	WW_SPC2	Single point controllable status output	O	
SPCSO28	WW_SPC2	Single point controllable status output	O	
SPCSO29	WW_SPC2	Single point controllable status output	O	
SPCSO30	WW_SPC2	Single point controllable status output	O	
SPCSO31	WW_SPC2	Single point controllable status output	O	
SPCSO32	WW_SPC2	Single point controllable status output	O	

2.10 WW_IHMI1

Attribute	Attribute	Explanation	M/O/E	Remarks
Name	Type			
IHMI class				
IHMI	WW_IHMI1	Human machine interface		
Data				
<i>Common Logical Node Information</i>				
Mod	WW_INC1	Mode	M	Status-only
Beh	WW_INS1	Behaviour	M	
Health	WW_INS3	Health	M	
NamPlt	WW_LPL1	Name plate	M	

2.11 WW_LLNOCON

Attribute	Attribute	Explanation	M/O/E	Remarks
Name	Type			
LLNO class				
LLNO	WW_LLNOCON	Logical Node device		
Data				
<i>Common Logical Node Information</i>				

2 Logical Nodes

2.12 WW_LLN0MEA

Attribute	Attribute	Explanation	M/O/E	Remarks
Name	Type			
Mod	WW_INC1	Mode	M	Status-only
Beh	WW_INS1	Behaviour	M	
Health	WW_INS3	Health	M	
NamPlt	WW_LPL2	Name plate	M	

2.12 WW_LLN0MEA

Attribute	Attribute	Explanation	M/O/E	Remarks
Name	Type			
LLN0 class				
LLN0	WW_LLN0MEA	Logical Node device		
Data				
<i>Common Logical Node Information</i>				
Mod	WW_INC1	Mode	M	Status-only
Beh	WW_INS1	Behaviour	M	
Health	WW_INS3	Health	M	
NamPlt	WW_LPL2	Name plate	M	

2.13 WW_LLN0PRO

Attribute	Attribute	Explanation	M/O/E	Remarks
Name	Type			
LLN0 class				
LLN0	WW_LLN0PRO	Logical Node device		
Data				
<i>Common Logical Node Information</i>				
Mod	WW_INC1	Mode	M	Status-only
Beh	WW_INS1	Behaviour	M	
Health	WW_INS3	Health	M	
NamPlt	WW_LPL2	Name plate	M	

2.14 WW_LLN0REC

Attribute	Attribute	Explanation	M/O/E	Remarks
Name	Type			
LLN0 class				
LLN0	WW_LLN0REC	Logical Node device		
Data				
<i>Common Logical Node Information</i>				
Mod	WW_INC1	Mode	M	Status-only
Beh	WW_INS1	Behaviour	M	
Health	WW_INS3	Health	M	
NamPlt	WW_LPL2	Name plate	M	

2.15 WW_LLN0SYS

Attribute	Attribute	Explanation	M/O/E	Remarks
Name	Type			
LLN0 class				
LLN0	WW_LLN0SYS	Logical Node device		
Data				
<i>Common Logical Node Information</i>				
Mod	WW_INC1	Mode	M	Status-only
Beh	WW_INS1	Behaviour	M	
Health	WW_INS3	Health	M	
NamPlt	WW_LPL2	Name plate	M	

2.16 WW_LPHDCON

Attribute	Attribute	Explanation	M/O/E	Remarks
Name	Type			
LPHD class				
LPHD	WW_LPHDCON	Physical device information		
Data				
<i>Common Logical Node Information</i>				
PhyNam	WW_DPL1	Physical device name plate	M	
PhyHealth	WW_INS3	Physical Device Health	M	
Proxy	WW_SPS1	Indicates if this LN is a proxy	M	

2.17 WW_LPHDMEA

Attribute	Attribute	Explanation	M/O/E	Remarks
Name	Type			
LPHD class				
LPHD	WW_LPHDMEA	Physical device information		
Data				
<i>Common Logical Node Information</i>				
PhyNam	WW_DPL1	Physical device name plate	M	
PhyHealth	WW_INS3	Physical Device Health	M	
Proxy	WW_SPS1	Indicates if this LN is a proxy	M	

2.18 WW_LPHDPRO

Attribute	Attribute	Explanation	M/O/E	Remarks
Name	Type			
LPHD class				
LPHD	WW_LPHDPRO	Physical device information		
Data				
<i>Common Logical Node Information</i>				
PhyNam	WW_DPL1	Physical device name plate	M	
PhyHealth	WW_INS3	Physical Device Health	M	
Proxy	WW_SPS1	Indicates if this LN is a proxy	M	

2.19 WW_LPHDREC

Attribute	Attribute	Explanation	M/O/E	Remarks
Name	Type			
LPHD class				
LPHD	WW_LPHDREC	Physical device information		
Data				
<i>Common Logical Node Information</i>				
PhyNam	WW_DPL1	Physical device name plate	M	
PhyHealth	WW_INS3	Physical Device Health	M	
Proxy	WW_SPS1	Indicates if this LN is a proxy	M	

2.20 WW_LPHDSYS

Attribute	Attribute	Explanation	M/O/E	Remarks
Name	Type			
LPHD class				
LPHD	WW_LPHDSYS	Physical device information		
Data				
<i>Common Logical Node Information</i>				
PhyNam	WW_DPL1	Physical device name plate	M	
PhyHealth	WW_INS3	Physical Device Health	M	
Proxy	WW_SPS1	Indicates if this LN is a proxy	M	

2.21 WW_MMXU7

Attribute	Attribute	Explanation	M/O/E	Remarks
Name	Type			
MMXU class				
MMXU	WW_MMXU7	Measurement		
Data				
<i>Common Logical Node Information</i>				
Mod	WW_INC1	Mode	M	Status-only
Beh	WW_INS1	Behaviour	M	
Health	WW_INS3	Health	M	
NamPlt	WW_LPL1	Name plate	M	
<i>Measured values</i>				
A	WW_WYE2	Phase currents (IL1, IL2, IL3)	O	

2.22 WW_MSTA1

Attribute	Attribute	Explanation	M/O/E	Remarks
Name	Type			
MSTA class				
MSTA	WW_MSTA1	Metering Statistics		
Data				
<i>Common Logical Node Information</i>				
Mod	WW_INC1	Mode	M	Status-only
Beh	WW_INS1	Behaviour	M	
Health	WW_INS3	Health	M	

2 Logical Nodes

2.23 WW_PDIF1

Attribute	Attribute	Explanation	M/O/E	Remarks
Name	Type			
NamPlt	WW_LPL1	Name plate	M	
<i>Metered values</i>				
AvAPhA	WW_MV1	Average current IL1	E	
AvAPhB	WW_MV1	Average current IL2	E	
AvAPhC	WW_MV1	Average current IL3	E	
MaxAPhA	WW_MV1	Maximum current IL1	E	
MaxAPhB	WW_MV1	Maximum current IL2	E	
MaxAPhC	WW_MV1	Maximum current IL3	E	
MinAPhA	WW_MV1	Minimum current IL1	E	
MinAPhB	WW_MV1	Minimum current IL2	E	
MinAPhC	WW_MV1	Minimum current IL3	E	

2.23 WW_PDIF1

Attribute	Attribute	Explanation	M/O/E	Remarks
Name	Type			
PDIF class				
PDIF	WW_PDIF1	Differential		
Data				
<i>Common Logical Node Information</i>				
Mod	WW_INC1	Mode	M	Status-only
Beh	WW_INS1	Behaviour	M	
Health	WW_INS3	Health	M	
NamPlt	WW_LPL1	Name plate	M	
<i>Status Information</i>				
Str	WW_ACD1	Start	M	
Op	WW_ACT1	Operate	M	

2.24 WW_PDIF2

Attribute	Attribute	Explanation	M/O/E	Remarks
Name	Type			
PDIF class				
PDIF	WW_PDIF2	Differential		
Data				
<i>Common Logical Node Information</i>				

Attribute	Attribute	Explanation	M/O/E	Remarks
Name	Type			
Mod	WW_INC1	Mode	M	Status-only
Beh	WW_INS1	Behaviour	M	
Health	WW_INS3	Health	M	
NamPlt	WW_LPL1	Name plate	M	
<i>Status Information</i>				
Str	WW_ACD1	Start	M	
Op	WW_ACT1	Operate	M	

2.25 WW_PDIF3

Attribute	Attribute	Explanation	M/O/E	Remarks
Name	Type			
PDIF class				
PDIF	WW_PDIF3	Differential		
Data				
<i>Common Logical Node Information</i>				
Mod	WW_INC1	Mode	M	Status-only
Beh	WW_INS1	Behaviour	M	
Health	WW_INS3	Health	M	
NamPlt	WW_LPL1	Name plate	M	
<i>Status Information</i>				
Str	WW_ACD1	Start	M	
Op	WW_ACT1	Operate	M	

2.26 WW_PDIF4

Attribute	Attribute	Explanation	M/O/E	Remarks
Name	Type			
PDIF class				
PDIF	WW_PDIF4	Differential		
Data				
<i>Common Logical Node Information</i>				
Mod	WW_INC1	Mode	M	Status-only
Beh	WW_INS1	Behaviour	M	
Health	WW_INS3	Health	M	
NamPlt	WW_LPL1	Name plate	M	

Attribute	Attribute	Explanation	M/O/E	Remarks
Name	Type			
<i>Status Information</i>				
Str	WW_ACD1	Start	M	
Op	WW_ACT1	Operate	M	

2.27 WW_PHAR1

Attribute	Attribute	Explanation	M/O/E	Remarks
Name	Type			
PHAR class				
PHAR	WW_PHAR1	Harmonic restraint		
Data				
<i>Common Logical Node Information</i>				
Mod	WW_INC1	Mode	M	Status-only
Beh	WW_INS1	Behaviour	M	
Health	WW_INS3	Health	M	
NamPlt	WW_LPL1	Name plate	M	
<i>Status Information</i>				
Str	WW_ACD1	Start	M	

2.28 WW_PSOF1

Attribute	Attribute	Explanation	M/O/E	Remarks
Name	Type			
PSOF class				
PSOF	WW_PSOF1	Protection Switch Onto fault		
Data				
<i>Common Logical Node Information</i>				
Mod	WW_INC1	Mode	M	Status-only
Beh	WW_INS1	Behaviour	M	
Health	WW_INS3	Health	M	
NamPlt	WW_LPL3	Name plate	M	
<i>Status Information</i>				
Str	WW_ACD1	Start	M	

2.29 WW_PTOC1

Attribute	Attribute	Explanation	M/O/E	Remarks
Name	Type			
PTOC class				
PTOC	WW_PTOC1	Time overcurrent		
Data				
<i>Common Logical Node Information</i>				
Mod	WW_INC1	Mode	M	Status-only
Beh	WW_INS1	Behaviour	M	
Health	WW_INS3	Health	M	
NamPlt	WW_LPL1	Name plate	M	
<i>Status Information</i>				
Str	WW_ACD1	Start	M	
Op	WW_ACT1	Operate	M	

2.30 WW_PTOC3

Attribute	Attribute	Explanation	M/O/E	Remarks
Name	Type			
PTOC class				
PTOC	WW_PTOC3	Time overcurrent		
Data				
<i>Common Logical Node Information</i>				
Mod	WW_INC1	Mode	M	Status-only
Beh	WW_INS1	Behaviour	M	
Health	WW_INS3	Health	M	
NamPlt	WW_LPL1	Name plate	M	
<i>Status Information</i>				
Str	WW_ACD1	Start	M	
Op	WW_ACT1	Operate	M	

2.31 WW_PTOC4

Attribute	Attribute	Explanation	M/O/E	Remarks
Name	Type			
PTOC class				
PTOC	WW_PTOC4	Time overcurrent		

2 Logical Nodes

2.32 WW_PTTR3

Attribute	Attribute	Explanation	M/O/E	Remarks
Name	Type			
Data				
<i>Common Logical Node Information</i>				
Mod	WW_INC1	Mode	M	Status-only
Beh	WW_INS1	Behaviour	M	
Health	WW_INS3	Health	M	
NamPlt	WW_LPL1	Name plate	M	
<i>Status Information</i>				
Str	WW_ACD1	Start	M	
Op	WW_ACT1	Operate	M	

2.32 WW_PTTR3

Attribute	Attribute	Explanation	M/O/E	Remarks
Name	Type			
PTTR class				
PTTR	WW_PTTR3	Thermal overload		
Data				
<i>Common Logical Node Information</i>				
Mod	WW_INC1	Mode	M	Status-only
Beh	WW_INS1	Behaviour	M	
Health	WW_INS3	Health	M	
NamPlt	WW_LPL1	Name plate	M	
<i>Status Information</i>				
Op	WW_ACT1	Operate	M	

2.33 WW_PTTR4

Attribute	Attribute	Explanation	M/O/E	Remarks
Name	Type			
PTTR class				
PTTR	WW_PTTR4	Thermal overload		
Data				
<i>Common Logical Node Information</i>				
Mod	WW_INC1	Mode	M	Status-only
Beh	WW_INS1	Behaviour	M	
Health	WW_INS3	Health	M	

Attribute	Attribute	Explanation	M/O/E	Remarks
Name	Type			
NamPlt	WW_LPL1	Name plate	M	
<i>Status Information</i>				
Op	WW_ACT1	Operate	M	

2.34 WW_RBRF1

Attribute	Attribute	Explanation	M/O/E	Remarks
Name	Type			
RBRF class				
RBRF	WW_RBRF1	Breaker failure		
Data				
<i>Common Logical Node Information</i>				
Mod	WW_INC1	Mode	M	Status-only
Beh	WW_INS1	Behaviour	M	
Health	WW_INS3	Health	M	
NamPlt	WW_LPL1	Name plate	M	
<i>Status Information</i>				
Str	WW_ACD1	Start	M	
OpEx	WW_ACT1	Breaker failure trip	M	

2.35 WW_RDRE1

Attribute	Attribute	Explanation	M/O/E	Remarks
Name	Type			
RDRE class				
RDRE	WW_RDRE1	Disturbance recorder function		
Data				
<i>Common Logical Node Information</i>				
Mod	WW_INC1	Mode	M	Status-only
Beh	WW_INS1	Behaviour	M	
Health	WW_INS3	Health	M	
NamPlt	WW_LPL1	Name plate	M	
<i>Status Information</i>				
RcdMade	WW_SPS1	Recording made	M	
FltNum	WW_INS2	Fault Number	M	
GriFltNum	WW_INS2	Grid Fault Number	O	

2 Logical Nodes

2.36 WW_SCBR1

Attribute	Attribute	Explanation	M/O/E	Remarks
Name	Type			
RcdStr	WW_SPS1	Recording started	O	

2.36 WW_SCBR1

Attribute	Attribute	Explanation	M/O/E	Remarks
Name	Type			
RBRF class				
SCBR	WW_SCBR1	Circuit breaker monitoring		
Data				
<i>Common Logical Node Information</i>				
Mod	WW_INC1	Mode	M	Status-only
Beh	WW_INS1	Behaviour	M	
Health	WW_INS3	Health	M	
NamPlt	WW_LPL1	Name plate	M	
<i>Status Information</i>				
TrCctAlm	WW_ACD1	Alarm signal	E	

2.37 WW_XCBR2

Attribute	Attribute	Explanation	M/O/E	Remarks
Name	Type			
XCBR class				
XCBR	WW_XCBR2	Circuit Breaker		
Data				
<i>Common Logical Node Information</i>				
Mod	WW_INC1	Mode	M	Status-only
Beh	WW_INS1	Behaviour	M	
Health	WW_INS3	Health	M	
NamPlt	WW_LPL1	Name plate	M	
Loc	WW_SPS1	Local operation	M	
OpCnt	WW_INS2	Operation counter	M	
<i>Status Information</i>				
CBOpCap	WW_INS5	Circuit breaker operating capability	M	
Controls				
Pos	WW_DPC1	Switch position	M	
BlkOpn	WW_SPC1	Block opening	M	

Attribute	Attribute	Explanation	M/O/E	Remarks
Name	Type			
BlkCl1	WW_SPC1	Block closing	M	

2.38 WW_XSWI1

Attribute	Attribute	Explanation	M/O/E	Remarks
Name	Type			
XSWI class				
XSWI	WW_XSWI1	Circuit switch		
Data				
<i>Common Logical Node Information</i>				
Mod	WW_INC1	Mode	M	Status-only
Beh	WW_INS1	Behaviour	M	
Health	WW_INS3	Health	M	
NamPlt	WW_LPL1	Name plate	M	
Loc	WW_SPS1	Local operation	M	
OpCnt	WW_INS2	Operation counter	M	
<i>Status Information</i>				
SwTyp	WW_INS5	Switch type	M	
SwOpCap	WW_INS5	Switch operating capability	M	
<i>Controls</i>				
Pos	WW_DPC1	Switch position	M	
BlkOpn	WW_SPC1	Block opening	M	
BlkCl1	WW_SPC1	Block closing	M	

3 Common Data Class

3.1 Common Data Class Definitions

The following table contains the list of Common Data Classes implemented in the device:

CDC Type	CDC Class	Description
WW_ACD1	ACD	Directional Protection activation information
WW_ACT1	ACT	Protection Activation Information
WW_analogValue1	analogValue	Analogue value
WW_Cancel1	Cancel	Cancel operating
WW_CMV2	CMV	Complex measured value
WW_DPC1	DPC	Controllable Double Point
WW_DPC2	DPC	Controllable Double Point
WW_DPL1	DPL	Device name plate
WW_INC1	INC	Controllable Integer Status
WW_INS1	INS	Integer Status
WW_INS2	INS	Integer Status
WW_INS3	INS	Integer Status
WW_INS5	INS	Integer Status
WW_LPL1	LPL	Logical node name plate
WW_LPL2	LPL	Logical node name plate
WW_LPL3	LPL	Logical node name plate
WW_MV1	MV	Measured Value
WW_Oper1	Oper	Start>Select operating
WW_origin1	origin	Originator
WW_SPC1	SPC	Controllable Single Point
WW_SPC2	SPC	Controllable Single Point
WW_SPS1	SPS	Single Point Status
WW_units1	units	Unit definition
WW_vector1	vector	Vector definition
WW_WYE2	WYE	Phase to ground related measured values of a three phase system

3.1.1 WW_ACD1

Attribute Name	Attribute Type	FC	TrgOp	Value / Value Range	M/O/E	Remarks
ACD class						
General	BOOLEAN	ST	dchg		M	
dirGeneral	Enum	ST	dchg	ACDdir	M	
q	Quality	ST	qchg		M	
t	Timestamp	ST			M	

3.1.2 WW_ACT1

Attribute Name	Attribute Type	FC	TrgOp	Value / Value Range	M/O/E	Remarks
ACT class						
General	BOOLEAN	ST	dchg		M	
q	Quality	ST	qchg		M	
t	Timestamp	ST			M	

3.1.3 WW_CMV2

Attribute Name	Attribute Type	FC	TrgOp	Value / Value Range	M/O/E	Remarks
CMV class						
cVal	Struct	MX		WW_vector1	M	
q	Quality	ST	qchg		M	
t	Timestamp	ST			M	
instCVal	Struct	MX		WW_vector1	O	
units	Struct	CF		WW_units1	O	
db	INT32U	CF			O	
dbAng	INT32U	CF			E	

3.1.4 WW_DPC1

Attribute Name	Attribute Type	FC	TrgOp	Value / Value Range	M/O/E	Remarks
DPC class						
stVal	Dbpos	ST	dchg	Dbpos	M	

3 Common Data Class

3.1.5 WW_DPC2

Attribute	Attribute	FC	TrgOp	Value / Value Range	M/O/E	Remarks
Name	Type					
q	Quality	ST	qchg		M	
t	Timestamp	ST			M	
ctlModel	Enum	CF		ctlModel	M	

3.1.5 WW_DPC2

Attribute	Attribute	FC	TrgOp	Value / Value Range	M/O/E	Remarks
Name	Type					
DPC class						
origin	Struct	ST		WW_origin1	O	
ctlNum	INT8U	ST			O	
stVal	Dbpos	ST	dchg	Dbpos	M	
q	Quality	ST	qchg		M	
t	Timestamp	ST			M	
stSeld	BOOLEAN	ST	dchg		O	
ctlModel	Enum	CF		ctlModel	M	
sboTimeout	INT32U	CF			O	
sboClass	Enum	CF		sboClass	O	
cdcNs	VisString255	EX			O	
Oper	Struct	CO		WW_Oper1		
SBOw	Struct	CO		WW_Oper1		
Cancel	Struct	CO		WW_Cancel1		

3.1.6 WW_DPL1

Attribute	Attribute	FC	TrgOp	Value / Value Range	M/O/E	Remarks
Name	Type					
DPL class						
vendor	VisString255	DC			M	

3.1.7 WW_INC1

Attribute	Attribute	FC	TrgOp	Value / Value Range	M/O/E	Remarks
Name	Type					
INC class						

Attribute	Attribute	FC	TrgOp	Value / Value Range	M/O/E	Remarks
Name	Type					
stVal	Enum	ST	dchg	Mode	M	
q	Quality	ST	qchg		M	
t	Timestamp	ST			M	
ctlModel	Enum	CF		ctlModel	M	

3.1.8 WW_INS1

Attribute	Attribute	FC	TrgOp	Value / Value Range	M/O/E	Remarks
Name	Type					
INS class						
stVal	Enum	ST	dchg	Behaviour	M	
q	Quality	ST	qchg		M	
t	Timestamp	ST			M	

3.1.9 WW_INS2

Attribute	Attribute	FC	TrgOp	Value / Value Range	M/O/E	Remarks
Name	Type					
INS class						
stVal	INT32	ST	dchg		M	
q	Quality	ST	qchg		M	
t	Timestamp	ST			M	

3.1.10 WW_INS3

Attribute	Attribute	FC	TrgOp	Value / Value Range	M/O/E	Remarks
Name	Type					
INS class						
stVal	Enum	ST	dchg	AutoRecSt	M	
q	Quality	ST	qchg		M	
t	Timestamp	ST			M	

3 Common Data Class

3.1.11 WW_INS5

Attribute	Attribute	FC	TrgOp	Value / Value Range	M/O/E	Remarks
Name	Type					
INS class						
stVal	Enum	ST	dchg	CBOpCap	M	
q	Quality	ST	qchg		M	
t	Timestamp	ST			M	

3.1.12 WW_LPL1

Attribute	Attribute	FC	TrgOp	Value / Value Range	M/O/E	Remarks
Name	Type					
LPL class						
vendor	visString255	DC			M	
swRev	visString255	DC			M	
d	visString255	DC			M	

3.1.13 WW_LPL2

Attribute	Attribute	FC	TrgOp	Value / Value Range	M/O/E	Remarks
Name	Type					
LPL class						
vendor	visString255	DC			M	
swRev	visString255	DC			M	
d	visString255	DC			M	
ldNs	visString255	EX				

3.1.14 WW_LPL3

Attribute	Attribute	FC	TrgOp	Value / Value Range	M/O/E	Remarks
Name	Type					
LPL class						
vendor	visString255	DC			M	
swRev	visString255	DC			M	
d	visString255	DC			M	

Attribute	Attribute	FC	TrgOp	Value / Value Range	M/O/E	Remarks
Name	Type					
LnNS	visString255	EX				

3.1.15 WW_MV1

Attribute	Attribute	FC	TrgOp	Value / Value Range	M/O/E	Remarks
Name	Type					
MV class						
mag	Struct	MX		WW_analogValue1	M	
q	Quality	ST	qchg		M	
t	Timestamp	ST			M	
units	Struct	CF		WW_units1	O	
db	INT32U	CF			O	
d	visString255	DC			O	
dataNs	visString255	DC			O	

3.1.16 WW_SPC1

Attribute	Attribute	FC	TrgOp	Value / Value Range	M/O/E	Remarks
Name	Type					
SPC class						
stVal	BOOLEAN	ST	dchg		M	
q	Quality	ST	dchg		M	
t	Timestamp	ST			M	
ctlModel	Enum	CF		ctlModel	M	

3.1.17 WW_SPC2

Attribute	Attribute	FC	TrgOp	Value / Value Range	M/O/E	Remarks
Name	Type					
SPC class						
Oper	Struct	CO		WW_Oper1		
stVal	BOOLEAN	ST	dchg		M	
q	Quality	ST	dchg		M	
t	Timestamp	ST			M	

3 Common Data Class

3.1.18 WW_SPS1

Attribute	Attribute	FC	TrgOp	Value / Value Range	M/O/E	Remarks
Name	Type					
ctlModel	Enum	CF		ctlModel	M	

3.1.18 WW_SPS1

Attribute	Attribute	FC	TrgOp	Value / Value Range	M/O/E	Remarks
Name	Type					
SPS class						
stVal	BOOLEAN	ST	dchg		M	
q	Quality	ST	qchg		M	
t	Timestamp	ST			M	

3.1.19 WW_WYE2

Attribute	Attribute	FC	TrgOp	Value / Value Range	M/O/E	Remarks
Name	Type					
WYE class						
phsAB	WW_CMV2					
phsBC	WW_CMV2					
phsCA	WW_CMV2					
neut	WW_CMV2					

3.2 Common Data Attributes Type Definitions

3.2.1 WW_analogValue1

Attribute	Attribute	FC	TrgOp	Value / Value Range	M/O/E	Remarks
Name	Type					
analogValue class						
f	FLOAT32	MX			M	

3.2.2 WW_Cancel1

Attribute	Attribute	FC	TrgOp	Value / Value Range	M/O/E	Remarks
Name	Type					
Cancel class						
ctlval	BOOLEAN	CO			M	
origin	Struct	ST		WW_origin1	O	
ctlNum	INT8U	ST			O	
T	Timestamp	CO			O	
Test	BOOLEAN	CO			O	

3.2.3 WW_Oper1

Attribute	Attribute	FC	TrgOp	Value / Value Range	M/O/E	Remarks
Name	Type					
Oper class						
ctlval	BOOLEAN	CO			M	
origin	Struct	ST		WW_origin1	O	
ctlNum	INT8U	ST			O	
T	Timestamp	CO			O	
Test	BOOLEAN	CO			O	
Check	Check	CO			O	

3.2.4 WW_origin1

Attribute	Attribute	FC	TrgOp	Value / Value Range	M/O/E	Remarks
Name	Type					
origin class						
orCat	Enum	ST		orCategory	M	

3 Common Data Class

3.2.5 WW_units1

Attribute	Attribute	FC	TrgOp	Value / Value Range	M/O/E	Remarks
Name	Type					
orldent	Octet64	ST			M	

3.2.5 WW_units1

Attribute	Attribute	FC	TrgOp	Value / Value Range	M/O/E	Remarks
Name	Type					
unit class						
SIUnit	Enum			SIUnit	M	
multiplier	Enum			multiplier	O	

3.2.6 WW_vector1

Attribute	Attribute	FC	TrgOp	Value / Value Range	M/O/E	Remarks
Name	Type					
vector class						
mag	Struct			WW_analogValue1	M	
ang	Struct			WW_analogValue1	O	

3.3 Enumerated type definitions

3.3.1 AutoRecSt

Ordinal	Semantic
1	Ready
2	InProgress
3	Successful

3.3.2 Beh

Ordinal	Semantic
1	on
2	blocked
3	test
4	test/blocked
5	off

3.3.3 CBOpCap

Ordinal	Semantic
1	None
2	Open
3	Close-Open
4	Open-Close-Open
5	Close-Open-Close-Open

3.3.4 ctlModel

Ordinal	Semantic
1	status-only
2	direct-with-normal-security
3	sbo-with-normal-security
4	direct-with-enhanced-security

Ordinal	Semantic
5	sbo-with-enhanced-security

3.3.5 Dbpos

Ordinal	Semantic
1	intermediate
2	off
3	on
4	bad

3.3.6 ACDdir

Ordinal	Semantic
0	unknown
1	forward
2	backward
3	both

3.3.7 Health

Ordinal	Semantic
1	Ok
2	Warning
3	Alarm

3.3.8 Mod

Ordinal	Semantic
1	on
2	blocked
3	test
4	test/block

Ordinal	Semantic
5	off

3.3.9 MotorCycle

Ordinal	Semantic
0	Trip/Off
1	Stop
2	Start
3	Run

3.3.10 multiplier

Ordinal	Semantic
-24	y
-21	z
-18	a
-15	f
-12	p
-9	n
-6	μ
-3	m
-2	c
-1	d
0	
1	da
2	h
3	k
6	M
9	G
12	T
15	P
18	E

Ordinal	Semantic
21	Z
24	Y

3.3.11 orCategory

Ordinal	Semantic
0	not-supported
1	bay-control
2	station-control
3	remote-control
4	automatic-bay
5	automatic-station
6	automatic-remote
7	maintenance
8	process

3.3.12 sboClass

Ordinal	Semantic
0	operate-once
1	operate-many

3.3.13 SIUnit

Ordinal	Semantic
1	none
2	m
3	kg
4	s
5	A
6	K
7	mol
8	cd

Ordinal	Semantic
9	deg
10	rad
11	sr
21	Gy
22	q
23	°C
24	Sv
25	F
26	C
27	S
28	H
29	V
30	ohm
31	J
32	N
33	Hz
34	lx
35	Lm
36	Wb
37	T
38	W
39	Pa
41	m ²
42	m ³
43	m/s
44	m/s ²
45	m ³ /s
46	m/m ³
47	M
48	kg/m ³
49	m ² /s
50	W/m K

Ordinal	Semantic
51	J/K
52	ppm
53	1/s
54	rad/s
61	VA
62	Watts
63	VAr
64	phi
65	cos(phi)
66	Vs
67	V ²
68	As
69	A ²
70	A ² t
71	VAh
72	Wh
73	VArh
74	V/Hz

4 Appendix

4.1 Register Maps

Legend: * The Logical Node is dependent on the settings in the “Device planning”. (See  “4.2 Device Planning Dependencies”).

LDevice::CTRL

Logical Node	Data Object	Module (- ANSI/IEEE Device Number) . Name
CILO1* (WW_CILO1)		
	Mod	
	Beh	
	Health	
	NamPlt	
	EnaOpn	SG[1] . Interl OFF
	EnaCls	SG[1] . Interl ON

Logical Node	Data Object	Module (- ANSI/IEEE Device Number) . Name
CILO2* (WW_CILO1)		
	Mod	
	Beh	
	Health	
	NamPlt	
	EnaOpn	SG[2] . Interl OFF
	EnaCls	SG[2] . Interl ON

Logical Node	Data Object	Module (- ANSI/IEEE Device Number) . Name
CSWI1* (WW_CSWI1)		
	Mod	
	Beh	
	Health	
	NamPlt	
	Loc	
	Pos	SG[1] . Pos

Logical Node	Data Object	Module (- ANSI/IEEE Device Number) . Name
CSWI2* (WW_CSWI1)		
	Mod	
	Beh	
	Health	

4 Appendix

4.1 Register Maps

Logical Node	Data Object	Module (- ANSI/IEEE Device Number) . Name
CSWI2* (WW_CSWI1)		
	NamPlt	
	Loc	
	Pos	SG[2] . Pos

Logical Node	Data Object	Module (- ANSI/IEEE Device Number) . Name
LLN0 (WW_LLNOCON)		
	Mod	
	Beh	
	Health	
	NamPlt	

Logical Node	Data Object	Module (- ANSI/IEEE Device Number) . Name
LPHD1 (WW_LPHDCON)		
	PhyNam	
	PhyHealth	
	Proxy	

Logical Node	Data Object	Module (- ANSI/IEEE Device Number) . Name
TCSSCBR1 (WW_SCBR1)		
	Mod	TCS[1] - 74TC . active
	Beh	
	Health	
	NamPlt	
	TrCctAlm	TCS[1] - 74TC . Alarm

Logical Node	Data Object	Module (- ANSI/IEEE Device Number) . Name
TCSSCBR2 (WW_SCBR1)		
	Mod	TCS[2] - 74TC . active
	Beh	
	Health	
	NamPlt	
	TrCctAlm	TCS[2] - 74TC . Alarm

Logical Node	Data Object	Module (- ANSI/IEEE Device Number) . Name
XCBR1* (WW_XCBR2)		
	Mod	
	Beh	
	Health	

Logical Node	Data Object	Module (- ANSI/IEEE Device Number) . Name
XCBR1* (WW_XCBR2)		
	NamPlt	
	Loc	
	OpCnt	
	Pos	SG[1] . Pos
	BlkOpn	
	BlkClIs	
	CBOpCap	

Logical Node	Data Object	Module (- ANSI/IEEE Device Number) . Name
XCBR2* (WW_XCBR2)		
	Mod	
	Beh	
	Health	
	NamPlt	
	Loc	
	OpCnt	
	Pos	SG[2] . Pos
	BlkOpn	
	BlkClIs	
	CBOpCap	

Logical Node	Data Object	Module (- ANSI/IEEE Device Number) . Name
XSWI1* (WW_XSWI1)		
	Mod	
	Beh	
	Health	
	NamPlt	
	Loc	
	OpCnt	
	Pos	SG[1] . Pos
	BlkOpn	
	BlkClIs	
	SwTyp	
	SwOpCap	

4 Appendix

4.1 Register Maps

Logical Node	Data Object	Module (- ANSI/IEEE Device Number) . Name
XSWI2* (WW_XSWI1)		
	Mod	
	Beh	
	Health	
	NamPlt	
	Loc	
	OpCnt	
	Pos	SG[2] . Pos
	BlkOpn	
	BlkClis	
	SwTyp	
	SwOpCap	

LDevice::DR

Logical Node	Data Object	Module (- ANSI/IEEE Device Number) . Name
LLN0 (WW_LLNOREC)		
	Mod	
	Beh	
	Health	
	NamPlt	

Logical Node	Data Object	Module (- ANSI/IEEE Device Number) . Name
LPHD1 (WW_LPHDREC)		
	PhyNam	
	PhyHealth	
	Proxy	

Logical Node	Data Object	Module (- ANSI/IEEE Device Number) . Name
RDRE1 (WW_RDRE1)		
	Mod	
	Beh	
	Health	
	NamPlt	
	RcdMade	Disturb rec . recording
	FiltNum	
	GriFiltNum	
	RcdStr	Disturb rec . recording

LDevice::EXT

Logical Node	Data Object	Module (- ANSI/IEEE Device Number) . Name
COUTGGIO1 (WW_GGIO4)		
	Mod	
	Beh	
	Health	
	NamPlt	
	Ind1	IEC 61850 . COUTGGIO1.Ind1.stVal-I
	Ind2	IEC 61850 . COUTGGIO1.Ind2.stVal-I
	Ind3	IEC 61850 . COUTGGIO1.Ind3.stVal-I
	Ind4	IEC 61850 . COUTGGIO1.Ind4.stVal-I
	Ind5	IEC 61850 . COUTGGIO1.Ind5.stVal-I
	Ind6	IEC 61850 . COUTGGIO1.Ind6.stVal-I
	Ind7	IEC 61850 . COUTGGIO1.Ind7.stVal-I
	Ind8	IEC 61850 . COUTGGIO1.Ind8.stVal-I
	Ind9	IEC 61850 . COUTGGIO1.Ind9.stVal-I
	Ind10	IEC 61850 . COUTGGIO1.Ind10.stVal-I
	Ind11	IEC 61850 . COUTGGIO1.Ind11.stVal-I
	Ind12	IEC 61850 . COUTGGIO1.Ind12.stVal-I
	Ind13	IEC 61850 . COUTGGIO1.Ind13.stVal-I
	Ind14	IEC 61850 . COUTGGIO1.Ind14.stVal-I
	Ind15	IEC 61850 . COUTGGIO1.Ind15.stVal-I
	Ind16	IEC 61850 . COUTGGIO1.Ind16.stVal-I
	Ind17	IEC 61850 . COUTGGIO1.Ind17.stVal-I
	Ind18	IEC 61850 . COUTGGIO1.Ind18.stVal-I
	Ind19	IEC 61850 . COUTGGIO1.Ind19.stVal-I
	Ind20	IEC 61850 . COUTGGIO1.Ind20.stVal-I
	Ind21	IEC 61850 . COUTGGIO1.Ind21.stVal-I
	Ind22	IEC 61850 . COUTGGIO1.Ind22.stVal-I
	Ind23	IEC 61850 . COUTGGIO1.Ind23.stVal-I
	Ind24	IEC 61850 . COUTGGIO1.Ind24.stVal-I
	Ind25	IEC 61850 . COUTGGIO1.Ind25.stVal-I
	Ind26	IEC 61850 . COUTGGIO1.Ind26.stVal-I
	Ind27	IEC 61850 . COUTGGIO1.Ind27.stVal-I
	Ind28	IEC 61850 . COUTGGIO1.Ind28.stVal-I
	Ind29	IEC 61850 . COUTGGIO1.Ind29.stVal-I
	Ind30	IEC 61850 . COUTGGIO1.Ind30.stVal-I
	Ind31	IEC 61850 . COUTGGIO1.Ind31.stVal-I

4 Appendix

4.1 Register Maps

Logical Node	Data Object	Module (- ANSI/IEEE Device Number) . Name
COUTGGIO1 (WW_GGIO4)		
	Ind32	IEC 61850 . COUTGGIO1.Ind32.stVal-I
COUTGGIO2 (WW_GGIO4)		
	Mod	
	Beh	
	Health	
	NamPlt	
	Ind1	IEC 61850 . COUTGGIO2.Ind1.stVal-I
	Ind2	IEC 61850 . COUTGGIO2.Ind2.stVal-I
	Ind3	IEC 61850 . COUTGGIO2.Ind3.stVal-I
	Ind4	IEC 61850 . COUTGGIO2.Ind4.stVal-I
	Ind5	IEC 61850 . COUTGGIO2.Ind5.stVal-I
	Ind6	IEC 61850 . COUTGGIO2.Ind6.stVal-I
	Ind7	IEC 61850 . COUTGGIO2.Ind7.stVal-I
	Ind8	IEC 61850 . COUTGGIO2.Ind8.stVal-I
	Ind9	IEC 61850 . COUTGGIO2.Ind9.stVal-I
	Ind10	IEC 61850 . COUTGGIO2.Ind10.stVal-I
	Ind11	IEC 61850 . COUTGGIO2.Ind11.stVal-I
	Ind12	IEC 61850 . COUTGGIO2.Ind12.stVal-I
	Ind13	IEC 61850 . COUTGGIO2.Ind13.stVal-I
	Ind14	IEC 61850 . COUTGGIO2.Ind14.stVal-I
	Ind15	IEC 61850 . COUTGGIO2.Ind15.stVal-I
	Ind16	IEC 61850 . COUTGGIO2.Ind16.stVal-I
	Ind17	IEC 61850 . COUTGGIO2.Ind17.stVal-I
	Ind18	IEC 61850 . COUTGGIO2.Ind18.stVal-I
	Ind19	IEC 61850 . COUTGGIO2.Ind19.stVal-I
	Ind20	IEC 61850 . COUTGGIO2.Ind20.stVal-I
	Ind21	IEC 61850 . COUTGGIO2.Ind21.stVal-I
	Ind22	IEC 61850 . COUTGGIO2.Ind22.stVal-I
	Ind23	IEC 61850 . COUTGGIO2.Ind23.stVal-I
	Ind24	IEC 61850 . COUTGGIO2.Ind24.stVal-I
	Ind25	IEC 61850 . COUTGGIO2.Ind25.stVal-I
	Ind26	IEC 61850 . COUTGGIO2.Ind26.stVal-I
	Ind27	IEC 61850 . COUTGGIO2.Ind27.stVal-I
	Ind28	IEC 61850 . COUTGGIO2.Ind28.stVal-I
	Ind29	IEC 61850 . COUTGGIO2.Ind29.stVal-I

Logical Node	Data Object	Module (- ANSI/IEEE Device Number) . Name
COUTGGIO2 (WW_GGIO4)		
	Ind30	IEC 61850 . COUTGGIO2.Ind30.stVal-I
	Ind31	IEC 61850 . COUTGGIO2.Ind31.stVal-I
	Ind32	IEC 61850 . COUTGGIO2.Ind32.stVal-I

Logical Node	Data Object	Module (- ANSI/IEEE Device Number) . Name
CTLGGIO1 (WW_GGIO14)		
	Mod	
	Beh	
	Health	
	NamPlt	
	SPCS01	
	SPCS02	
	SPCS03	
	SPCS04	
	SPCS05	
	SPCS06	
	SPCS07	
	SPCS08	
	SPCS09	
	SPCS010	
	SPCS011	
	SPCS012	
	SPCS013	
	SPCS014	
	SPCS015	
	SPCS016	
	SPCS017	
	SPCS018	
	SPCS019	
	SPCS020	
	SPCS021	
	SPCS022	
	SPCS023	
	SPCS024	
	SPCS025	
	SPCS026	
	SPCS027	

4 Appendix

4.1 Register Maps

Logical Node	Data Object	Module (- ANSI/IEEE Device Number) . Name
CTLGGIO1 (WW_GGIO14)		
	SPCSO28	
	SPCSO29	
	SPCSO30	
	SPCSO31	
	SPCSO32	

Logical Node	Data Object	Module (- ANSI/IEEE Device Number) . Name
EPGAPC1 (WW_GAPC1)		
	Mod	ExP[1] . active ExP[1] . Blo TripCmd ExP[1] . ExBlo TripCmd
	Beh	
	Health	
	NamPlt	
	Str	ExP[1] . Alarm
	Op	ExP[1] . Trip

Logical Node	Data Object	Module (- ANSI/IEEE Device Number) . Name
EPGAPC2 (WW_GAPC1)		
	Mod	ExP[2] . active ExP[2] . Blo TripCmd ExP[2] . ExBlo TripCmd
	Beh	
	Health	
	NamPlt	
	Str	ExP[2] . Alarm
	Op	ExP[2] . Trip

Logical Node	Data Object	Module (- ANSI/IEEE Device Number) . Name
EPGAPC3 (WW_GAPC1)		
	Mod	ExP[3] . active ExP[3] . Blo TripCmd ExP[3] . ExBlo TripCmd
	Beh	
	Health	
	NamPlt	
	Str	ExP[3] . Alarm
	Op	ExP[3] . Trip

Logical Node	Data Object	Module (- ANSI/IEEE Device Number) . Name
EPGAPC4 (WW_GAPC1)		
	Mod	ExP[4] . active ExP[4] . Blo TripCmd ExP[4] . ExBlo TripCmd
	Beh	

Logical Node	Data Object	Module (- ANSI/IEEE Device Number) . Name
EPGAPC4 (WW_GAPC1)		
	Health	
	NamPlt	
	Str	ExP[4] . Alarm
	Op	ExP[4] . Trip

Logical Node	Data Object	Module (- ANSI/IEEE Device Number) . Name
EPGAPC5 (WW_GAPC1)		
	Mod	Ext Sudd Press . active Ext Sudd Press . Blo TripCmd Ext Sudd Press . ExBlo TripCmd
	Beh	
	Health	
	NamPlt	
	Str	Ext Sudd Press . Alarm
	Op	Ext Sudd Press . Trip

Logical Node	Data Object	Module (- ANSI/IEEE Device Number) . Name
EPGAPC6 (WW_GAPC1)		
	Mod	Ext Oil Temp . active Ext Oil Temp . Blo TripCmd Ext Oil Temp . ExBlo TripCmd
	Beh	
	Health	
	NamPlt	
	Str	Ext Oil Temp . Alarm
	Op	Ext Oil Temp . Trip

Logical Node	Data Object	Module (- ANSI/IEEE Device Number) . Name
EPGAPC7 (WW_GAPC1)		
	Mod	Ext Temp Superv[1] . active Ext Temp Superv[1] . Blo TripCmd Ext Temp Superv[1] . ExBlo TripCmd
	Beh	
	Health	
	NamPlt	
	Str	Ext Temp Superv[1] . Alarm
	Op	Ext Temp Superv[1] . Trip

Logical Node	Data Object	Module (- ANSI/IEEE Device Number) . Name
EPGAPC8 (WW_GAPC1)		
	Mod	Ext Temp Superv[2] . active Ext Temp Superv[2] . Blo TripCmd Ext Temp Superv[2] . ExBlo TripCmd

4 Appendix

4.1 Register Maps

Logical Node	Data Object	Module (- ANSI/IEEE Device Number) . Name
EPGAPC8 (WW_GAPC1)		
	Beh	
	Health	
	NamPlt	
	Str	Ext Temp Superv[2] . Alarm
	Op	Ext Temp Superv[2] . Trip

Logical Node	Data Object	Module (- ANSI/IEEE Device Number) . Name
EPGAPC9 (WW_GAPC1)		
	Mod	Ext Temp Superv[3] . active Ext Temp Superv[3] . Blo TripCmd Ext Temp Superv[3] . ExBlo TripCmd
	Beh	
	Health	
	NamPlt	
	Str	Ext Temp Superv[3] . Alarm
	Op	Ext Temp Superv[3] . Trip

Logical Node	Data Object	Module (- ANSI/IEEE Device Number) . Name
GOSINGGIO1 (WW_GGIO11)		
	Mod	
	Beh	
	Health	
	NamPlt	
	Ind1	
	Ind2	
	Ind3	
	Ind4	
	Ind5	
	Ind6	
	Ind7	
	Ind8	
	Ind9	
	Ind10	
	Ind11	
	Ind12	
	Ind13	
	Ind14	
	Ind15	
	Ind16	

Logical Node	Data Object	Module (- ANSI/IEEE Device Number) . Name
GOSINGGIO1 (WW_GGIO11)		
	Ind17	
	Ind18	
	Ind19	
	Ind20	
	Ind21	
	Ind22	
	Ind23	
	Ind24	
	Ind25	
	Ind26	
	Ind27	
	Ind28	
	Ind29	
	Ind30	
	Ind31	
	Ind32	

Logical Node	Data Object	Module (- ANSI/IEEE Device Number) . Name
GOSINGGIO2 (WW_GGIO10)		
	Mod	
	Beh	
	Health	
	NamPlt	
	Ind1	
	Ind2	
	Ind3	
	Ind4	
	Ind5	
	Ind6	
	Ind7	
	Ind8	
	Ind9	
	Ind10	
	Ind11	
	Ind12	
	Ind13	
	Ind14	

Logical Node	Data Object	Module (- ANSI/IEEE Device Number) . Name
GOSINGGIO2 (WW_GGIO10)		
	Ind15	
	Ind16	
	Ind17	
	Ind18	
	Ind19	
	Ind20	
	Ind21	
	Ind22	
	Ind23	
	Ind24	
	Ind25	
	Ind26	
	Ind27	
	Ind28	
	Ind29	
	Ind30	
	Ind31	
	Ind32	

Logical Node	Data Object	Module (- ANSI/IEEE Device Number) . Name
LLN0 (WW_LLNOSYS)		
	Mod	
	Beh	
	Health	
	NamPlt	

Logical Node	Data Object	Module (- ANSI/IEEE Device Number) . Name
LPHD1 (WW_LPHDSYS)		
	PhyNam	
	PhyHealth	
	Proxy	

LDevice::MEAS

Logical Node	Data Object	Module (- ANSI/IEEE Device Number) . Name
CMMXU1 (WW_MMXU7)		
	Mod	
	Beh	

Logical Node	Data Object	Module (- ANSI/IEEE Device Number) . Name
CMMXU1 (WW_MMXU7)		
	Health	
	NamPlt	
	A	CT W1 . IL1 RMS CT W1 . phi IL1 CT W1 . IL2 RMS CT W1 . phi IL2 CT W1 . IL3 RMS CT W1 . phi IL3 CT W1 . IG meas RMS CT W1 . phi IG meas CT W1 . IG calc RMS CT W1 . phi IG calc

Logical Node	Data Object	Module (- ANSI/IEEE Device Number) . Name
CMMXU2 (WW_MMXU7)		
	Mod	
	Beh	
	Health	
	NamPlt	
	A	CT W2 . IL1 RMS CT W2 . phi IL1 CT W2 . IL2 RMS CT W2 . phi IL2 CT W2 . IL3 RMS CT W2 . phi IL3 CT W2 . IG meas RMS CT W2 . phi IG meas CT W2 . IG calc RMS CT W2 . phi IG calc

Logical Node	Data Object	Module (- ANSI/IEEE Device Number) . Name
CMSTA1 (WW_MSTA1)		
	Mod	
	Beh	
	Health	
	NamPlt	
	AvAPhsA	CT W1 . IL1 avg
	AvAPhsB	CT W1 . IL2 avg
	AvAPhsC	CT W1 . IL3 avg
	MaxAPhsA	CT W1 . IL1 max
	MaxAPhsB	CT W1 . IL2 max
	MaxAPhsC	CT W1 . IL3 max
	MinAPhsA	CT W1 . IL1 min
	MinAPhsB	CT W1 . IL2 min
	MinAPhsC	CT W1 . IL3 min

Logical Node	Data Object	Module (- ANSI/IEEE Device Number) . Name
CMSTA2 (WW_MSTA1)		
	Mod	
	Beh	
	Health	
	NamPlt	

4 Appendix

4.1 Register Maps

Logical Node	Data Object	Module (- ANSI/IEEE Device Number) . Name
CMSTA2 (WW_MSTA1)		
	AvAPhsA	CT W2 . IL1 avg
	AvAPhsB	CT W2 . IL2 avg
	AvAPhsC	CT W2 . IL3 avg
	MaxAPhsA	CT W2 . IL1 max
	MaxAPhsB	CT W2 . IL2 max
	MaxAPhsC	CT W2 . IL3 max
	MinAPhsA	CT W2 . IL1 min
	MinAPhsB	CT W2 . IL2 min
	MinAPhsC	CT W2 . IL3 min

Logical Node	Data Object	Module (- ANSI/IEEE Device Number) . Name
LLN0 (WW_LLNAMEA)		
	Mod	
	Beh	
	Health	
	NamPlt	

Logical Node	Data Object	Module (- ANSI/IEEE Device Number) . Name
LPHD1 (WW_LPHDMEA)		
	PhyNam	
	PhyHealth	
	Proxy	

LDevice::PROT

Logical Node	Data Object	Module (- ANSI/IEEE Device Number) . Name
GFPTOC1 (WW_PTOC3)		
	Mod	IG[1] - 50N, 51N . active IG[1] - 50N, 51N . Blo TripCmd IG[1] - 50N, 51N . ExBlo TripCmd
	Beh	
	Health	
	NamPlt	
	Str	IG[1] - 50N, 51N . Alarm
	Op	IG[1] - 50N, 51N . Trip

Logical Node	Data Object	Module (- ANSI/IEEE Device Number) . Name
GFPTOC2 (WW_PTOC3)		
	Mod	IG[2] - 50N, 51N . active IG[2] - 50N, 51N . Blo TripCmd IG[2] - 50N, 51N . ExBlo TripCmd

Logical Node	Data Object	Module (- ANSI/IEEE Device Number) . Name
GFPTOC2 (WW_PTOC3)		
	Beh	
	Health	
	NamPlt	
	Str	IG[2] - 50N, 51N . Alarm
	Op	IG[2] - 50N, 51N . Trip

Logical Node	Data Object	Module (- ANSI/IEEE Device Number) . Name
GFPTOC3 (WW_PTOC3)		
	Mod	IG[3] - 50N, 51N . active IG[3] - 50N, 51N . Blo TripCmd IG[3] - 50N, 51N . ExBlo TripCmd
	Beh	
	Health	
	NamPlt	
	Str	IG[3] - 50N, 51N . Alarm
	Op	IG[3] - 50N, 51N . Trip

Logical Node	Data Object	Module (- ANSI/IEEE Device Number) . Name
GFPTOC4 (WW_PTOC3)		
	Mod	IG[4] - 50N, 51N . active IG[4] - 50N, 51N . Blo TripCmd IG[4] - 50N, 51N . ExBlo TripCmd
	Beh	
	Health	
	NamPlt	
	Str	IG[4] - 50N, 51N . Alarm
	Op	IG[4] - 50N, 51N . Trip

Logical Node	Data Object	Module (- ANSI/IEEE Device Number) . Name
GPDIF1 (WW_PDFI3)		
	Mod	IdGH[1] - 87N . active IdGH[1] - 87N . Blo TripCmd IdGH[1] - 87N . ExBlo TripCmd
	Beh	
	Health	
	NamPlt	
	Str	IdGH[1] - 87N . Alarm
	Op	IdGH[1] - 87N . TripCmd

4 Appendix

4.1 Register Maps

Logical Node	Data Object	Module (- ANSI/IEEE Device Number) . Name
GPDIF2 (WW_PDIF3)		
	Mod	IdGH[2] - 87N . active IdGH[2] - 87N . Blo TripCmd IdGH[2] - 87N . ExBlo TripCmd
	Beh	
	Health	
	NamPlt	
	Str	IdGH[2] - 87N . Alarm
	Op	IdGH[2] - 87N . TripCmd

Logical Node	Data Object	Module (- ANSI/IEEE Device Number) . Name
HRGPDIF1 (WW_PDIF4)		
	Mod	IdH - 87 . active IdH - 87 . Blo TripCmd IdH - 87 . ExBlo TripCmd
	Beh	
	Health	
	NamPlt	
	Str	IdH - 87 . Alarm
	Op	IdH - 87 . TripCmd

Logical Node	Data Object	Module (- ANSI/IEEE Device Number) . Name
HSPPDIF1 (WW_PDIF2)		
	Mod	IdG[1] - 87N . active IdG[1] - 87N . Blo TripCmd IdG[1] - 87N . ExBlo TripCmd
	Beh	
	Health	
	NamPlt	
	Str	IdG[1] - 87N . Alarm
	Op	IdG[1] - 87N . Trip

Logical Node	Data Object	Module (- ANSI/IEEE Device Number) . Name
HSPPDIF2 (WW_PDIF2)		
	Mod	IdG[2] - 87N . active IdG[2] - 87N . Blo TripCmd IdG[2] - 87N . ExBlo TripCmd
	Beh	
	Health	
	NamPlt	
	Str	IdG[2] - 87N . Alarm
	Op	IdG[2] - 87N . Trip

Logical Node	Data Object	Module (- ANSI/IEEE Device Number) . Name
IHM1 (WW_IHM1)		
	Mod	
	Beh	
	Health	
	NamPlt	

Logical Node	Data Object	Module (- ANSI/IEEE Device Number) . Name
INRPHAR1 (WW_PHAR1)		
	Mod	IH2[1] . active
	Beh	
	Health	
	NamPlt	
	Str	IH2[1] . 3-ph Blo

Logical Node	Data Object	Module (- ANSI/IEEE Device Number) . Name
INRPHAR2 (WW_PHAR1)		
	Mod	IH2[2] . active
	Beh	
	Health	
	NamPlt	
	Str	IH2[2] . 3-ph Blo

Logical Node	Data Object	Module (- ANSI/IEEE Device Number) . Name
LLN0 (WW_LLNOPRO)		
	Mod	
	Beh	
	Health	
	NamPlt	

Logical Node	Data Object	Module (- ANSI/IEEE Device Number) . Name
LPHD1 (WW_LPHDPRO)		
	PhyNam	
	PhyHealth	
	Proxy	

Logical Node	Data Object	Module (- ANSI/IEEE Device Number) . Name
PPDIF1 (WW_PDIF1)		
	Mod	Id - 87 . active Id - 87 . Blo TripCmd Id - 87 . ExBlo TripCmd
	Beh	

4 Appendix

4.1 Register Maps

Logical Node	Data Object	Module (- ANSI/IEEE Device Number) . Name
PPDIF1 (WW_PDIF1)		
	Health	
	NamPlt	
	Str	Id - 87 . Alarm
	Op	Id - 87 . TripCmd

Logical Node	Data Object	Module (- ANSI/IEEE Device Number) . Name
PSOF1 (WW_PSOF1)		
	Mod	SOTF . active SOTF . ExBlo SOTF . Ex rev Interl
	Beh	
	Health	
	NamPlt	
	Str	SOTF . enabled

Logical Node	Data Object	Module (- ANSI/IEEE Device Number) . Name
PTOC1 (WW_PTOC1)		
	Mod	I[1] - 50, 51 . active I[1] - 50, 51 . Blo TripCmd I[1] - 50, 51 . ExBlo TripCmd
	Beh	
	Health	
	NamPlt	
	Str	I[1] - 50, 51 . Alarm
	Op	I[1] - 50, 51 . Trip

Logical Node	Data Object	Module (- ANSI/IEEE Device Number) . Name
PTOC2 (WW_PTOC1)		
	Mod	I[2] - 50, 51 . active I[2] - 50, 51 . Blo TripCmd I[2] - 50, 51 . ExBlo TripCmd
	Beh	
	Health	
	NamPlt	
	Str	I[2] - 50, 51 . Alarm
	Op	I[2] - 50, 51 . Trip

Logical Node	Data Object	Module (- ANSI/IEEE Device Number) . Name
PTOC3 (WW_PTOC1)		
	Mod	I[3] - 50, 51 . active I[3] - 50, 51 . Blo TripCmd I[3] - 50, 51 . ExBlo TripCmd
	Beh	
	Health	

Logical Node	Data Object	Module (- ANSI/IEEE Device Number) . Name
PTOC3 (WW_PTOC1)		
	NamPlt	
	Str	I[3] - 50, 51 . Alarm
	Op	I[3] - 50, 51 . Trip

Logical Node	Data Object	Module (- ANSI/IEEE Device Number) . Name
PTOC4 (WW_PTOC1)		
	Mod	I[4] - 50, 51 . active I[4] - 50, 51 . Blo TripCmd I[4] - 50, 51 . ExBlo TripCmd
	Beh	
	Health	
	NamPlt	
	Str	I[4] - 50, 51 . Alarm
	Op	I[4] - 50, 51 . Trip

Logical Node	Data Object	Module (- ANSI/IEEE Device Number) . Name
PTOC5 (WW_PTOC1)		
	Mod	I[5] - 50, 51 . active I[5] - 50, 51 . Blo TripCmd I[5] - 50, 51 . ExBlo TripCmd
	Beh	
	Health	
	NamPlt	
	Str	I[5] - 50, 51 . Alarm
	Op	I[5] - 50, 51 . Trip

Logical Node	Data Object	Module (- ANSI/IEEE Device Number) . Name
PTOC6 (WW_PTOC1)		
	Mod	I[6] - 50, 51 . active I[6] - 50, 51 . Blo TripCmd I[6] - 50, 51 . ExBlo TripCmd
	Beh	
	Health	
	NamPlt	
	Str	I[6] - 50, 51 . Alarm
	Op	I[6] - 50, 51 . Trip

Logical Node	Data Object	Module (- ANSI/IEEE Device Number) . Name
RBRF1 (WW_RBRF1)		
	Mod	CBF[1] - 50BF, 62BF . active CBF[1] - 50BF, 62BF . ExBlo CBF[1] - 50BF, 62BF . ExBlo
	Beh	

4 Appendix

4.1 Register Maps

Logical Node	Data Object	Module (- ANSI/IEEE Device Number) . Name
RBRF1 (WW_RBRF1)		
	Health	
	NamPlt	
	Str	CBF[1] - 50BF, 62BF . running
	OpEx	CBF[1] - 50BF, 62BF . Alarm
RBRF2 (WW_RBRF1)		
	Mod	CBF[2] - 50BF, 62BF . active CBF[2] - 50BF, 62BF . ExBlo CBF[2] - 50BF, 62BF . ExBlo
	Beh	
	Health	
	NamPlt	
	Str	CBF[2] - 50BF, 62BF . running
	OpEx	CBF[2] - 50BF, 62BF . Alarm
RTDPTTR1 (WW_PTTR4)		
	Mod	RTD . active RTD . Blo TripCmd RTD . ExBlo TripCmd
	Beh	
	Health	
	NamPlt	
	Op	RTD . Trip
TRPTTR1 (WW_PTTR3)		
	Mod	ThR - 49 . active ThR - 49 . Blo TripCmd ThR - 49 . ExBlo TripCmd
	Beh	
	Health	
	NamPlt	
	Op	ThR - 49 . Trip
ULPTOC1 (WW_PTOC4)		
	Mod	I2>[1] - 46 . active I2>[1] - 46 . Blo TripCmd I2>[1] - 46 . ExBlo TripCmd
	Beh	
	Health	
	NamPlt	

Logical Node	Data Object	Module (- ANSI/IEEE Device Number) . Name
ULPTOC1 (WW_PTOC4)		
	Str	I2>[1] - 46 . Alarm
	Op	I2>[1] - 46 . Trip

Logical Node	Data Object	Module (- ANSI/IEEE Device Number) . Name
ULPTOC2 (WW_PTOC4)		
	Mod	I2>[2] - 46 . active I2>[2] - 46 . Blo TripCmd I2>[2] - 46 . ExBlo TripCmd
	Beh	
	Health	
	NamPlt	
	Str	I2>[2] - 46 . Alarm
	Op	I2>[2] - 46 . Trip

4.2 Device Planning Dependencies

The availability of Logical Node instances in the generated ICD file depends on the settings in the “Device planning” menu.

The following list gives an overview about those settings for every module that have an effect on the availability of a Logical Node.

Module (- ANSI/IEEE Device Number) . Name	Value
CILO1	
SG[1] . SwitchgearType	Controlled SG
SG[1] . SwitchgearType	Controlled Make Break SG
CILO2	
SG[2] . SwitchgearType	Controlled SG
SG[2] . SwitchgearType	Controlled Make Break SG
CSWI1	
SG[1] . SwitchgearType	Controlled SG
SG[1] . SwitchgearType	Controlled Make Break SG
CSWI2	
SG[2] . SwitchgearType	Controlled SG
SG[2] . SwitchgearType	Controlled Make Break SG
XCBR1	
SG[1] . SwitchgearType	Monitored Make Break SG
SG[1] . SwitchgearType	Controlled Make Break SG
XCBR2	
SG[2] . SwitchgearType	Monitored Make Break SG
SG[2] . SwitchgearType	Controlled Make Break SG
XSWI1	
SG[1] . SwitchgearType	Monitored SG
SG[1] . SwitchgearType	Controlled SG
XSWI2	
SG[2] . SwitchgearType	Monitored SG
SG[2] . SwitchgearType	Controlled SG

We appreciate your comments about the content of our publications.

Send comments to: kemp.doc@woodward.com

Please reference publication MRDT4-3.7-EN-IEC61850-MICS

https://wss.woodward.com/manuals/Library/Protection_Relays/HighPROTEC



Woodward Kempen GmbH reserves the right to update any portion of this publication at any time. Information provided by Woodward Kempen GmbH is believed to be correct and reliable. However, Woodward Kempen GmbH assumes no responsibility unless otherwise expressly undertaken.



Woodward Kempen GmbH
Krefelder Weg 47 • D-47906 Kempen (Germany)
Postfach 10 07 55 (P.O.Box) • D-47884 Kempen (Germany)
Telephone: : +49 (0) 21 52 145 1

Internet: — www.woodward.com

Sales

Telephone: : +49 (0) 21 52 145 331
Fax: : +49 (0) 21 52 145 354
Email: : SalesPGD_EMEA@woodward.com

Service

Telephone: : +49 (0) 21 52 145 614
Fax: : +49 (0) 21 52 145 354
Email: : industrial.support@woodward.com

Woodward has company-owned plants, subsidiaries, and branches, as well as authorized distributors and other authorized service and sales facilities throughout the world.

Complete address / phone / fax / email information for all locations is available on our website.