



## MRM4

### Motor Protection

**Version: 3.6.b (Build 41481)**

**Original document · English**

**Revision: - (Build 42251)**

© 2019

Original reference manual

Woodward Kempen GmbH

Krefelder Weg 47 • D-47906 Kempen (Germany)

Postfach 10 07 55 (P.O.Box) • D-47884 Kempen (Germany)

Telephone: +49 (0) 21 52 145 1

© 2019 Woodward Kempen GmbH

# Table of Contents

<b>1</b>	<b>About This Reference Manual</b> .....	<b>9</b>
<b>2</b>	<b>Hardware</b> .....	<b>12</b>
2.1	Device Configuration .....	12
2.2	Digital Inputs .....	14
2.2.1	DI Slot X1 (“DI8-X1”) .....	14
2.2.2	DI Slot X1 (“DI4-X1”) .....	15
2.3	Binary Outputs .....	16
2.3.1	BO Slot X2 (6 Binary Outputs) .....	16
2.3.2	BO Slot X2 (4 Binary Outputs) .....	26
2.4	Analog Outputs .....	33
2.4.1	AnOut[1] .....	33
2.5	LEDs .....	34
2.5.1	LED 1 .....	34
2.5.2	LED 2 .....	37
2.5.3	LED 3 .....	40
2.5.4	LED 4 .....	43
2.5.5	LED 5 .....	46
2.5.6	LED 6 .....	49
2.5.7	LED 7 .....	52
2.6	HMI .....	55
2.6.1	HMI: Global Parameters .....	55
2.6.2	HMI: Direct Controls .....	56
2.6.3	HMI: Values .....	56
<b>3</b>	<b>Security</b> .....	<b>57</b>
<b>4</b>	<b>Field settings</b> .....	<b>59</b>
4.1	Field Para: Global Parameters .....	59
4.2	CT .....	60
4.2.1	CT: Global Parameters .....	60
4.2.2	CT: Signals (Output States) .....	61
4.2.3	CT: Values .....	62
4.2.4	CT: Statistical Values .....	65
<b>5</b>	<b>System</b> .....	<b>67</b>
5.1	Sys: Global Parameters .....	67
5.2	Sys: Direct Controls .....	69
5.3	Sys: Input States .....	70
5.4	Sys: Signals (Output States) .....	71
5.5	Sys: Values .....	73
<b>6</b>	<b>Measured Values</b> .....	<b>75</b>

<b>7</b>	<b>Statistics</b> .....	<b>76</b>
7.1	Statistics: Global Parameters .....	76
7.2	Statistics: Direct Controls .....	77
7.3	Statistics: Input States .....	78
7.4	Statistics: Signals (Output States) .....	78
7.5	Statistics: Counters .....	78
<b>8</b>	<b>Communication</b> .....	<b>80</b>
8.1	Scada: Device Planning Parameters .....	80
8.2	Scada: Signals (Output States) .....	80
8.3	Tcplp .....	81
8.3.1	Tcplp: Global Parameters .....	81
8.4	DNP3 .....	82
8.4.1	DNP3: Global Parameters .....	82
8.4.2	DNP3: Direct Controls .....	87
8.4.3	DNP3: Input States .....	87
8.4.4	DNP3: Signals (Output States) .....	88
8.4.5	DNP3: Counters .....	88
8.5	Modbus .....	90
8.5.1	Modbus: Global Parameters .....	90
8.5.2	Modbus: Direct Controls .....	93
8.5.3	Modbus: Input States .....	93
8.5.4	Modbus: Signals (Output States) .....	93
8.5.5	Modbus: Values .....	94
8.5.6	Modbus: Counters .....	95
8.6	IEC 61850 .....	97
8.6.1	IEC 61850: Global Parameters .....	97
8.6.2	IEC 61850: Direct Controls .....	97
8.6.3	IEC 61850: Signals (Output States) .....	97
8.6.4	IEC 61850: Values .....	98
8.6.5	IEC 61850: Counters .....	99
8.6.6	IEC 61850 - Virt.Outp. ....	101
8.7	IEC103 .....	102
8.7.1	IEC103: Global Parameters .....	102
8.7.2	IEC103: Direct Controls .....	104
8.7.3	IEC103: Signals (Output States) .....	105
8.7.4	IEC103: Counters .....	105
8.8	IEC104 .....	107
8.8.1	IEC104: Global Parameters .....	107
8.8.2	IEC104: Direct Controls .....	110
8.8.3	IEC104: Signals (Output States) .....	110
8.8.4	IEC104: Values .....	110
8.8.5	IEC104: Counters .....	111
8.9	Profibus .....	112

8.9.1	Profibus: Global Parameters . . . . .	112
8.9.2	Profibus: Direct Controls . . . . .	112
8.9.3	Profibus: Input States . . . . .	113
8.9.4	Profibus: Signals (Output States) . . . . .	113
8.9.5	Profibus: Values . . . . .	114
8.9.6	Profibus: Counters . . . . .	115
8.10	IRIG-B . . . . .	116
8.10.1	IRIG-B: Device Planning Parameters . . . . .	116
8.10.2	IRIG-B: Global Parameters . . . . .	116
8.10.3	IRIG-B: Direct Controls . . . . .	116
8.10.4	IRIG-B: Signals (Output States) . . . . .	117
8.10.5	IRIG-B: Counters . . . . .	117
8.11	SNTP . . . . .	118
8.11.1	SNTP: Device Planning Parameters . . . . .	118
8.11.2	SNTP: Global Parameters . . . . .	118
8.11.3	SNTP: Direct Controls . . . . .	119
8.11.4	SNTP: Signals (Output States) . . . . .	119
8.11.5	SNTP: Values . . . . .	119
8.11.6	SNTP: Counters . . . . .	120
8.12	TimeSync . . . . .	122
8.12.1	TimeSync: Global Parameters . . . . .	122
8.12.2	TimeSync: Signals (Output States) . . . . .	124
<b>9</b>	<b>Protection Parameter . . . . .</b>	<b>125</b>
9.1	Prot: Global Parameters . . . . .	125
9.2	Prot: Direct Controls . . . . .	126
9.3	Prot: Input States . . . . .	126
9.4	Prot: Signals (Output States) . . . . .	126
9.5	MStart . . . . .	129
9.5.1	MStart: Global Parameters . . . . .	129
9.5.2	MStart: Setting Group Parameters . . . . .	134
9.5.3	MStart: Direct Controls . . . . .	135
9.5.4	MStart: Input States . . . . .	135
9.5.5	MStart: Signals (Output States) . . . . .	136
9.5.6	MStart: Values . . . . .	140
9.5.7	MStart: Statistical Values . . . . .	140
9.5.8	MStart: Counters . . . . .	141
9.6	I[1] . . . . . I[6] . . . . .	144
9.6.1	I[1]: Device Planning Parameters . . . . .	144
9.6.2	I[1]: Global Parameters . . . . .	144
9.6.3	I[1]: Setting Group Parameters . . . . .	145
9.6.4	I[1]: Input States . . . . .	148
9.6.5	I[1]: Signals (Output States) . . . . .	149
9.6.6	I[1]: Counters . . . . .	150

9.7	IG[1] ... IG[4] . . . . .	152
9.7.1	IG[1]: Device Planning Parameters . . . . .	152
9.7.2	IG[1]: Global Parameters . . . . .	152
9.7.3	IG[1]: Setting Group Parameters . . . . .	154
9.7.4	IG[1]: Input States . . . . .	156
9.7.5	IG[1]: Signals (Output States) . . . . .	157
9.7.6	IG[1]: Counters . . . . .	159
9.8	ThR . . . . .	160
9.8.1	ThR: Global Parameters . . . . .	160
9.8.2	ThR: Setting Group Parameters . . . . .	161
9.8.3	ThR: Direct Controls . . . . .	163
9.8.4	ThR: Input States . . . . .	163
9.8.5	ThR: Signals (Output States) . . . . .	163
9.8.6	ThR: Counters . . . . .	165
9.9	Jam[1] ... Jam[2] . . . . .	166
9.9.1	Jam[1]: Device Planning Parameters . . . . .	166
9.9.2	Jam[1]: Global Parameters . . . . .	166
9.9.3	Jam[1]: Setting Group Parameters . . . . .	167
9.9.4	Jam[1]: Input States . . . . .	168
9.9.5	Jam[1]: Signals (Output States) . . . . .	168
9.9.6	Jam[1]: Counters . . . . .	169
9.10	I<[1] ... I<[3] . . . . .	170
9.10.1	I<[1]: Device Planning Parameters . . . . .	170
9.10.2	I<[1]: Global Parameters . . . . .	170
9.10.3	I<[1]: Setting Group Parameters . . . . .	171
9.10.4	I<[1]: Input States . . . . .	172
9.10.5	I<[1]: Signals (Output States) . . . . .	172
9.10.6	I<[1]: Counters . . . . .	173
9.11	MLS . . . . .	174
9.11.1	MLS: Device Planning Parameters . . . . .	174
9.11.2	MLS: Global Parameters . . . . .	174
9.11.3	MLS: Setting Group Parameters . . . . .	174
9.11.4	MLS: Input States . . . . .	175
9.11.5	MLS: Signals (Output States) . . . . .	175
9.12	I2>[1] ... I2>[2] . . . . .	177
9.12.1	I2>[1]: Device Planning Parameters . . . . .	177
9.12.2	I2>[1]: Global Parameters . . . . .	177
9.12.3	I2>[1]: Setting Group Parameters . . . . .	178
9.12.4	I2>[1]: Input States . . . . .	179
9.12.5	I2>[1]: Signals (Output States) . . . . .	180
9.12.6	I2>[1]: Counters . . . . .	181
9.13	ExP[1] ... ExP[4] . . . . .	182
9.13.1	ExP[1]: Device Planning Parameters . . . . .	182
9.13.2	ExP[1]: Global Parameters . . . . .	182

9.13.3	Exp[1]: Setting Group Parameters . . . . .	183
9.13.4	Exp[1]: Input States . . . . .	184
9.13.5	Exp[1]: Signals (Output States) . . . . .	184
9.13.6	Exp[1]: Counters . . . . .	185
9.14	URTD . . . . .	186
9.14.1	URTD: Global Parameters . . . . .	186
9.14.2	URTD: Direct Controls . . . . .	186
9.14.3	URTD: Signals (Output States) . . . . .	190
9.14.4	URTD: Values . . . . .	191
9.14.5	URTD: Statistical Values . . . . .	192
9.15	RTD . . . . .	194
9.15.1	RTD: Device Planning Parameters . . . . .	194
9.15.2	RTD: Global Parameters . . . . .	194
9.15.3	RTD: Setting Group Parameters . . . . .	195
9.15.4	RTD: Input States . . . . .	209
9.15.5	RTD: Signals (Output States) . . . . .	209
9.15.6	RTD: Counters . . . . .	218
9.16	Supervision . . . . .	220
9.16.1	CBF . . . . .	220
9.16.2	TCS . . . . .	224
9.16.3	CTS . . . . .	227
<b>10</b>	<b>Control . . . . .</b>	<b>230</b>
10.1	Ctrl: Device Planning Parameters . . . . .	230
10.2	Ctrl: Global Parameters . . . . .	230
10.3	Ctrl: Direct Controls . . . . .	230
10.4	Ctrl: Input States . . . . .	231
10.5	Ctrl: Signals (Output States) . . . . .	231
10.6	Ctrl: Values . . . . .	232
10.7	SG[1] . . . . .	233
10.7.1	SG[1]: Global Parameters . . . . .	233
10.7.2	SG[1]: Direct Controls . . . . .	237
10.7.3	SG[1]: Input States . . . . .	237
10.7.4	SG[1]: Signals (Output States) . . . . .	238
10.7.5	Breaker Wear . . . . .	242
<b>11</b>	<b>System Alarms . . . . .</b>	<b>248</b>
11.1	SysA: Device Planning Parameters . . . . .	248
11.2	SysA: Global Parameters . . . . .	248
11.3	SysA: Input States . . . . .	249
11.4	SysA: Signals (Output States) . . . . .	249
<b>12</b>	<b>Records . . . . .</b>	<b>251</b>
12.1	Event rec . . . . .	251
12.1.1	Event rec: Direct Controls . . . . .	251

12.1.2	Event rec: Signals (Output States) . . . . .	251
12.2	Disturb rec . . . . .	252
12.2.1	Disturb rec: Global Parameters . . . . .	252
12.2.2	Disturb rec: Direct Controls . . . . .	253
12.2.3	Disturb rec: Input States . . . . .	253
12.2.4	Disturb rec: Signals (Output States) . . . . .	253
12.2.5	Disturb rec: Values . . . . .	254
12.3	Fault rec . . . . .	255
12.3.1	Fault rec: Global Parameters . . . . .	255
12.3.2	Fault rec: Direct Controls . . . . .	255
12.3.3	Fault rec: Signals (Output States) . . . . .	255
12.4	Trend rec . . . . .	256
12.4.1	Trend rec: Global Parameters . . . . .	256
12.4.2	Trend rec: Direct Controls . . . . .	258
12.4.3	Trend rec: Signals (Output States) . . . . .	258
12.4.4	Trend rec: Counters . . . . .	258
12.5	Start rec . . . . .	259
12.5.1	Start rec: Global Parameters . . . . .	259
12.5.2	Start rec: Direct Controls . . . . .	259
12.5.3	Start rec: Signals (Output States) . . . . .	260
<b>13</b>	<b>Logic . . . . .</b>	<b>261</b>
13.1	Logics . . . . .	261
13.1.1	Logics: Device Planning Parameters . . . . .	261
13.1.2	Logics . . . Logics . . . . .	262
<b>14</b>	<b>Self-Supervision . . . . .</b>	<b>265</b>
14.1	SSV: Direct Controls . . . . .	265
14.2	SSV: Signals (Output States) . . . . .	265
14.3	SSV: Counters . . . . .	265
<b>15</b>	<b>Service . . . . .</b>	<b>266</b>
15.1	Sgen . . . . .	267
15.1.1	Sgen: Device Planning Parameters . . . . .	267
15.1.2	Sgen: Global Parameters . . . . .	267
15.1.3	Sgen: Direct Controls . . . . .	268
15.1.4	Sgen: Input States . . . . .	268
15.1.5	Sgen: Signals (Output States) . . . . .	269
15.1.6	Sgen: Values . . . . .	270
15.1.7	Sgen . . . . .	271
<b>16</b>	<b>Selection Lists . . . . .</b>	<b>275</b>
<b>17</b>	<b>Index . . . . .</b>	<b>459</b>



# 1 About This Reference Manual

This document is a reference of all the Setting Values, Direct Commands and Signals of the MRM4. In other words, it lists all parameters that are available (or can be made available) with the (optionally) full featured versions of the MRM4 protection device.

## CAUTION!



This document does not intend to give long and/or detailed description, nor does it intend to replace the full Technical Manual in any way. Only a quite short description is given for each parameter.

This document is a reference of all the Setting Values, Direct Commands and Signals of the MRM4.

Every HighPROTEC protection device operates using a lot of digital values of various types. Throughout our Technical Documentation, we are talking of “settings” (or “parameters”) or “signals” or “(measured) values”, depending on the type.

Please consult the Technical Manual, in particular Chapter “Modules, Settings, Signals and Values”, for details of the existing data types.

### Modules

The firmware of every HighPROTEC protection device can be thought of being sub-divided in several independent function blocks, the so-called “modules”. Every protection function, for example, is a module of its own. But one of the fundamental concepts of a HighPROTEC protection device is to implement this with great consequence: The functionality of calculating statistical data is a module (named »Statistics«), every communication protocol is a module, the control of switchgear devices is a module (named »Ctrl«), but the properties of the switchgear itself is part of another module. There is even a general protection module (named »Prot«) that interacts all specific protection modules.

Every parameter, every value and every signal is therefore a member of some module.

But note that the settings dialogs (on the panel (HMI) or in the *Smart view* operating software) often omit the module name whenever it is clear from the menu branch. This means the parameters are often displayed only with their individual parameter names, i. e. simply »Function« instead of the full-blown »I[1] . Function«. This increases the overview and simplifies all configuration and operation work; however, it is good to know that the writing »Function« is just an abbreviation. In fact, **every** parameter **always** belongs to a module, and therefore – to make this concept absolutely clear – the reference tables have always the module name added in front of every parameter name

Especially for protection functions it is often required to have several instances active. For example, overcurrent protection usually has several “stages”, and all of these are running at the same time (using their individual setting values). Therefore it is an important feature of every HighPROTEC protection device that a lot of modules exist in several “instances”, which are numbered (in brackets): For the overcurrent protection, for example: »I[1]«, I[2]«, ...

In the reference tables, usually every module has its own dedicated chapter, which lists the available number of instances at the beginning. Then, however, in the sub-chapters listing the various parameter types, only the first instance (e. g. »I[1]«) is mentioned, because all the other instances are identical anyway.









### Structure of a Reference Table

Since (almost) every module can be activated or deactivated independently of the other modules and all parameters of an inactive module disappear from the menu branch it would not be helpful if this Reference Manual would list parameters sorted according to the menu structure. Instead, we list categories of modules (e. g. "Protection Functions") and all the modules within a category.

For each parameter, there is a table with its properties, looking like this:

Module . Parameter	[Menu Path to This Parameter]	
Default Value	Value Range	Perm.
For some parameters:		
<ul style="list-style-type: none"> <li>• Availability restrictions</li> </ul>		
Type <i>Short descriptive text explaining the functionality of this parameter.</i>		

"Type" is the data type of the parameter, which is denoted by a small icon. The following types are possible:



-  Setting Parameter
-  Direct Control
-  Input State
-  Signal (Output State)
-  Statistical Value
-  Counter
-  (Measuring) Value
-  Dialog — Such a dialog can feature several data objects using a special representation and/or functionality.


"Perm." means "permission", i. e. the access level and password that is required to modify the parameter. (Please refer to the "Security" chapter in the full Technical Manual for details.)

" Adapt. Param." means that this parameter supports Adaptive Parameter Sets. (See the "Adaptive Parameter Sets" section in the User Manual.)

For some parameter types (e. g. Input and Output States), the second row (default, value range, permission) is useless and therefore omitted.

Example of a parameter:

I[1] . Mode	[Device planning]	
non directional	Selection List  Mode: -, non directional, forward, reverse	S.3
 <i>general operation mode</i>		

This means that one can find the parameter in the menu [Device planning], and its values are picked from a selection list named “Mode”. The “” arrow indicates a cross-reference (hyperlink) into the “Selection Lists” chapter, and a click takes you to a table that lists all available choices. The access level “S.3” means the access level “Supervisor-Lv3”, which is required to modify the parameter.

### **Audience of This Manual**

The manual serves as working basis for:

- Engineers in the protection field,
- commissioning engineers,
- people dealing with setting, testing and maintenance of protection and control devices,
- as well as trained personnel for electrical installations and power stations.

All functions concerning the MRM4 are listed. Should there be a description of any functions, parameters or inputs/outputs which do not apply to the device in use, please ignore that information.

This manual describes the (optionally) full featured versions of the devices.

All technical information and data included in this manual reflect their state at the time this document was issued. We reserve the right to carry out technical modifications in line with further development without changing this manual and without previous notice. Hence no claim can be brought based on the information and descriptions this manual includes.

We do not accept any liability for damage and operational failures caused by operating errors or disregarding the directions of this manual.

No part of this manual is allowed to be reproduced or passed on to others in any form, unless *Woodward* have approved in writing.

This Reference Manual is part of the delivery scope when purchasing the device. In case the device is passed on (sold) to a third party, the manual has to be handed over as well.

### **Information Concerning Liability and Warranty**

*Woodward* does not accept any liability for damage resulting from conversions or changes carried out on the device or planning (projecting) work, parameter setting or adjustment changes done by the customer.

The warranty expires after a device has been opened by others than *Woodward* specialists.

Warranty and liability conditions stated in *Woodward* General Terms and Conditions are not supplemented by the above mentioned explanations.

## 2 Hardware


### 2.1 Device Configuration


<b>Motor Protection</b>						
<b>MRM4</b>	<b>-2</b>	<b>#</b>	<b>#</b>	<b>#</b>	<b>#</b>	<b>#</b>
<b>Hardware Variant 1</b>						
8 digital inputs   6 binary output relays   IRIG-B	<b>A</b>					
4 DI, 2 NO, 2 Changeover, 1 AnOut, IRIG, URTD	<b>B</b>					
<b>Hardware Variant 2</b>						
Phase Current 5A/1A, Ground Current 5A/1A	<b>0</b>					
Phase Current 5A/1A, Sensitive Ground Current 5A/1A	<b>1</b>					
<b>Housing</b>						
Flush mounting				<b>A</b>		
19 inch mounting (semi-flush)				<b>B</b>		
Customized Version 1				<b>H</b>		
Customized Version 2				<b>K</b>		
<b>Communication</b>						
Without					<b>A</b>	
RS 485: Modbus RTU   IEC 60870-5-103   DNP3 RTU					<b>B</b>	
Ethernet: Modbus TCP   DNP3 UDP/TCP   IEC 60870-5-104					<b>C</b>	
Fiber Optics: Profibus-DP					<b>D</b>	
D-SUB: Profibus-DP					<b>E</b>	
Fiber Optics: Modbus RTU   IEC 60870-5-103   DNP3 RTU					<b>F</b>	
RS 485/D-SUB: Modbus RTU   IEC 60870-5-103   DNP3 RTU					<b>G</b>	
Ethernet: IEC 61850 communication   Modbus TCP   DNP3 UDP/TCP   IEC 60870-5-104					<b>H</b>	
RS 485, Ethernet: Modbus TCP/RTU   IEC 60870-5-103   IEC 60870-5-104   DNP3 UDP/TCP/RTU					<b>I</b>	
Ethernet/Fiber Optics: IEC 61850 communication   Modbus TCP   DNP3 UDP/TCP   IEC 60870-5-104					<b>K</b>	
Ethernet/Fiber Optics: Modbus TCP   DNP3 UDP/TCP   IEC 60870-5-104					<b>L</b>	
RS 485, Ethernet: IEC 61850   Modbus TCP/RTU   IEC 60870-5-103   IEC 60870-5-104   DNP3 UDP/TCP/RTU					<b>T</b>	
<b>Printed Circuit Board</b>						


<b>Motor Protection</b>						
<b>MRM4</b>	<b>-2</b>	<b>#</b>	<b>#</b>	<b>#</b>	<b>#</b>	<b>#</b>
Standard						<b>A</b>
printed circuit boards are conformal coated						<b>B</b>


## 2.2 Digital Inputs

### 2.2.1 DI Slot X1 (“DI8-X1”)


DI Slot X1 . <b>Nom voltage</b>	[Device Para / Digital Inputs / DI Slot X1 / Group 1] [Device Para / Digital Inputs / DI Slot X1 / Group 2] [Device Para / Digital Inputs / DI Slot X1 / Group 3]	
24 VDC	24 VDC, 48 VDC, 60 VDC, 110 VDC, 230 VDC, 110 VAC, 230 VAC  ↳ <b>Nom voltage.</b>	S.3
 <i>Nominal voltage of the digital inputs</i>		


DI Slot X1 . <b>Inverting 1</b> ... DI Slot X1 . <b>Inverting 8</b>	[Device Para / Digital Inputs / DI Slot X1 / Group 1] [Device Para / Digital Inputs / DI Slot X1 / Group 2] [Device Para / Digital Inputs / DI Slot X1 / Group 3]	
inactive	inactive, active  ↳ <b>Mode.</b>	S.3
 <i>Inverting the input signals.</i>		


DI Slot X1 . <b>Debouncing time 1</b> ... DI Slot X1 . <b>Debouncing time 8</b>	[Device Para / Digital Inputs / DI Slot X1 / Group 1] [Device Para / Digital Inputs / DI Slot X1 / Group 2] [Device Para / Digital Inputs / DI Slot X1 / Group 3]	
no debouncing time	no debouncing time, 20 ms, 50 ms, 100 ms  ↳ <b>Debouncing time.</b>	S.3
 <i>A change of the state of a digital input will only be recognized after the debouncing time has expired (become effective). Thus, transient signals will not be misinterpreted.</i>		


DI Slot X1 . <b>DI 1</b> ... DI Slot X1 . <b>DI 8</b>	[Device Para / Digital Inputs / DI Slot X1 / Group 1] [Device Para / Digital Inputs / DI Slot X1 / Group 2] [Device Para / Digital Inputs / DI Slot X1 / Group 3]	
 <i>Signal: Digital Input</i>		

## 2.2.2 DI Slot X1 (“DI4-X1”)

DI Slot X1 . <b>Nom voltage</b>	[Device Para / Digital Inputs / DI Slot X1]	
24 VDC	24 VDC, 48 VDC, 60 VDC, 110 VDC, 230 VDC, 110 VAC, 230 VAC  ↳ Nom voltage.	S.3
 <i>Nominal voltage of the digital inputs</i>		


DI Slot X1 . <b>Inverting 1</b> ... DI Slot X1 . <b>Inverting 4</b>	[Device Para / Digital Inputs / DI Slot X1]	
inactive	inactive, active  ↳ Mode.	S.3
 <i>Inverting the input signals.</i>		


DI Slot X1 . <b>Debouncing time 1</b> ... DI Slot X1 . <b>Debouncing time 4</b>	[Device Para / Digital Inputs / DI Slot X1]	
no debouncing time	no debouncing time, 20 ms, 50 ms, 100 ms  ↳ Debouncing time.	S.3
 <i>A change of the state of a digital input will only be recognized after the debouncing time has expired (become effective). Thus, transient signals will not be misinterpreted.</i>		


DI Slot X1 . <b>DI 1</b> ... DI Slot X1 . <b>DI 4</b>	[Device Para / Digital Inputs / DI Slot X1]	
 <i>Signal: Digital Input</i>		


## 2.3 Binary Outputs


### 2.3.1 BO Slot X2 (6 Binary Outputs)


<b>BO Slot X2 . Operating Mode</b>		[Device Para / Binary Outputs / BO Slot X2 / BO 1]
Normally open (NO)	Normally open (NO), Normally closed (NC)	S.3
	↳ 1...n Operating Modes.	
 Operating Mode		

<b>BO Slot X2 . t-hold</b>		[Device Para / Binary Outputs / BO Slot X2 / BO 1]
0.00s	0.00s ... 300.00s	S.3
	<i>To clearly identify the state transition of a binary output relay, the "new state" is being hold, at least for the duration of the hold time.</i>	

<b>BO Slot X2 . t-Off Delay</b>		[Device Para / Binary Outputs / BO Slot X2 / BO 1]
0.00s	0.00s ... 300.00s	S.3
	<i>Switch Off Delay</i>	

<b>BO Slot X2 . Latched</b>		[Device Para / Binary Outputs / BO Slot X2 / BO 1]
active	inactive, active	S.3
	↳ Mode.	
	<i>Defines whether the Relay Output will be latched when it picks up.</i>	

<b>BO Slot X2 . Acknowledgement</b>		[Device Para / Binary Outputs / BO Slot X2 / BO 1]
"_"	"_" ... Sys . Internal test state	S.3
Only available if:	↳ 1..n, Assignment List.	
	• BO Slot X2 . Latched = active	
	<i>Acknowledgement Signal - An acknowledgement signal (that acknowledges the corresponding binary output relay) can be assigned to each output relay. The acknowledgement-signal is only effective if the parameter "Latched" is set to active.</i>	

<b>BO Slot X2 . Inverting</b>		[Device Para / Binary Outputs / BO Slot X2 / BO 1]
inactive	inactive, active	S.3
	↳ Mode.	
	<i>Inverting of the collective signal (OR-gate/disjunction). In combination with inverted input signals an AND-gate can be programmed (Conjunction).</i>	



BO Slot X2 . <b>Assignment 1</b>	[Device Para / Binary Outputs / BO Slot X2 / BO 1]	
SG[1] . TripCmd	"-" ... Sys . Internal test state  ↳ 1..n, Assignment List.	S.3
🔗 <i>Assignment</i>		


BO Slot X2 . <b>Inverting 1</b>	[Device Para / Binary Outputs / BO Slot X2 / BO 1]	
...		
BO Slot X2 . <b>Inverting 7</b>		
inactive	inactive, active  ↳ Mode.	S.3
🔗 <i>Inverting of the state of the assigned signal.</i>		


BO Slot X2 . <b>Assignment 2</b>	[Device Para / Binary Outputs / BO Slot X2 / BO 1]	
...		
BO Slot X2 . <b>Assignment 7</b>		
"_"	"_" ... Sys . Internal test state  ↳ 1..n, Assignment List.	S.3
🔗 <i>Assignment</i>		


BO Slot X2 . <b>Operating Mode</b>	[Device Para / Binary Outputs / BO Slot X2 / BO 2]	
Normally open (NO)	Normally open (NO), Normally closed (NC)  ↳ 1...n Operating Modes.	S.3
🔗 <i>Operating Mode</i>		


BO Slot X2 . <b>t-hold</b>	[Device Para / Binary Outputs / BO Slot X2 / BO 2]	
0.00s	0.00s ... 300.00s	S.3
🔗 <i>To clearly identify the state transition of a binary output relay, the "new state" is being hold, at least for the duration of the hold time.</i>		


BO Slot X2 . <b>t-Off Delay</b>	[Device Para / Binary Outputs / BO Slot X2 / BO 2]	
0.00s	0.00s ... 300.00s	S.3
🔗 <i>Switch Off Delay</i>		


<b>BO Slot X2 . Latched</b>	[Device Para / Binary Outputs / BO Slot X2 / BO 2]	
inactive	inactive, active  ↳ Mode.	S.3
	<i>Defines whether the Relay Output will be latched when it picks up.</i>	


<b>BO Slot X2 . Acknowledgement</b>	[Device Para / Binary Outputs / BO Slot X2 / BO 2]	
"_"	"_" ... Sys . Internal test state	S.3
Only available if:	↳ 1..n, Assignment List.	
• BO Slot X2 . Latched = active		
	<i>Acknowledgement Signal - An acknowledgement signal (that acknowledges the corresponding binary output relay) can be assigned to each output relay. The acknowledgement-signal is only effective if the parameter "Latched" is set to active.</i>	


<b>BO Slot X2 . Inverting</b>	[Device Para / Binary Outputs / BO Slot X2 / BO 2]	
inactive	inactive, active  ↳ Mode.	S.3
	<i>Inverting of the collective signal (OR-gate/disjunction). In combination with inverted input signals an AND-gate can be programmed (Conjunction).</i>	


<b>BO Slot X2 . Assignment 1</b>	[Device Para / Binary Outputs / BO Slot X2 / BO 2]	
Prot . Alarm	"_" ... Sys . Internal test state	S.3
	↳ 1..n, Assignment List.	
	<i>Assignment</i>	


<b>BO Slot X2 . Inverting 1</b>	[Device Para / Binary Outputs / BO Slot X2 / BO 2]	
...		
<b>BO Slot X2 . Inverting 7</b>		
inactive	inactive, active  ↳ Mode.	S.3
	<i>Inverting of the state of the assigned signal.</i>	


BO Slot X2 . <b>Assignment 2</b>	[Device Para / Binary Outputs / BO Slot X2 / BO 2]	
...		
BO Slot X2 . <b>Assignment 7</b>		
"_"	"_" ... Sys . Internal test state  ↳ 1..n, Assignment List.	S.3
 Assignment		


BO Slot X2 . <b>Operating Mode</b>	[Device Para / Binary Outputs / BO Slot X2 / BO 3]	
Normally open (NO)	Normally open (NO), Normally closed (NC)  ↳ 1...n Operating Modes.	S.3
 Operating Mode		


BO Slot X2 . <b>t-hold</b>	[Device Para / Binary Outputs / BO Slot X2 / BO 3]	
0.00s	0.00s ... 300.00s	S.3
 To clearly identify the state transition of a binary output relay, the "new state" is being hold, at least for the duration of the hold time.		


BO Slot X2 . <b>t-Off Delay</b>	[Device Para / Binary Outputs / BO Slot X2 / BO 3]	
0.00s	0.00s ... 300.00s	S.3
 Switch Off Delay		


BO Slot X2 . <b>Latched</b>	[Device Para / Binary Outputs / BO Slot X2 / BO 3]	
inactive	inactive, active  ↳ Mode.	S.3
 Defines whether the Relay Output will be latched when it picks up.		


BO Slot X2 . <b>Acknowledgement</b>	[Device Para / Binary Outputs / BO Slot X2 / BO 3]	
"_"	"_" ... Sys . Internal test state	S.3
Only available if:	↳ 1..n, Assignment List.	
• BO Slot X2 . Latched = active		
 Acknowledgement Signal - An acknowledgement signal (that acknowledges the corresponding binary output relay) can be assigned to each output relay. The acknowledgement-signal is only effective if the parameter "Latched" is set to active.		


<b>BO Slot X2 . Inverting</b>		[Device Para / Binary Outputs / BO Slot X2 / BO 3]
inactive	inactive, active	S.3
		↳ Mode.
 <i>Inverting of the collective signal (OR-gate/disjunction). In combination with inverted input signals an AND-gate can be programmed (Conjunction).</i>		


<b>BO Slot X2 . Assignment 1</b>		[Device Para / Binary Outputs / BO Slot X2 / BO 3]
SG[1] . ON Cmd	"-" ... Sys . Internal test state	S.3
		↳ 1..n, Assignment List.
 <i>Assignment</i>		



<b>BO Slot X2 . Inverting 1</b>		[Device Para / Binary Outputs / BO Slot X2 / BO 3]
...		
<b>BO Slot X2 . Inverting 7</b>		
inactive	inactive, active	S.3
		↳ Mode.
 <i>Inverting of the state of the assigned signal.</i>		



<b>BO Slot X2 . Assignment 2</b>		[Device Para / Binary Outputs / BO Slot X2 / BO 3]
...		
<b>BO Slot X2 . Assignment 7</b>		
"-"	"-" ... Sys . Internal test state	S.3
		↳ 1..n, Assignment List.
 <i>Assignment</i>		



<b>BO Slot X2 . Operating Mode</b>		[Device Para / Binary Outputs / BO Slot X2 / BO 4]
Normally open (NO)	Normally open (NO), Normally closed (NC)	S.3
		↳ 1...n Operating Modes.
 <i>Operating Mode</i>		



<b>BO Slot X2 . t-hold</b>		[Device Para / Binary Outputs / BO Slot X2 / BO 4]
0.00s	0.00s ... 300.00s	S.3
	<i>To clearly identify the state transition of a binary output relay, the "new state" is being hold, at least for the duration of the hold time.</i>	



<b>BO Slot X2 . t-Off Delay</b>		[Device Para / Binary Outputs / BO Slot X2 / BO 4]
0.00s	0.00s ... 300.00s	S.3
	<i>Switch Off Delay</i>	



<b>BO Slot X2 . Latched</b>		[Device Para / Binary Outputs / BO Slot X2 / BO 4]
inactive	inactive, active  Mode.	S.3
	<i>Defines whether the Relay Output will be latched when it picks up.</i>	



<b>BO Slot X2 . Acknowledgement</b>		[Device Para / Binary Outputs / BO Slot X2 / BO 4]
"-"	"-" ... Sys . Internal test state  1..n, Assignment List.	S.3
<i>Only available if:</i>		
<ul style="list-style-type: none"> <li>• BO Slot X2 . Latched = active</li> </ul>		
	<i>Acknowledgement Signal - An acknowledgement signal (that acknowledges the corresponding binary output relay) can be assigned to each output relay. The acknowledgement-signal is only effective if the parameter "Latched" is set to active.</i>	


<b>BO Slot X2 . Inverting</b>		[Device Para / Binary Outputs / BO Slot X2 / BO 4]
inactive	inactive, active  Mode.	S.3
	<i>Inverting of the collective signal (OR-gate/disjunction). In combination with inverted input signals an AND-gate can be programmed (Conjunction).</i>	

<b>BO Slot X2 . Assignment 1</b>		[Device Para / Binary Outputs / BO Slot X2 / BO 4]
SG[1] . OFF Cmd	"-" ... Sys . Internal test state  1..n, Assignment List.	S.3
	<i>Assignment</i>	



BO Slot X2 . <b>Inverting 1</b>	[Device Para / Binary Outputs / BO Slot X2 / BO 4]	
...		
BO Slot X2 . <b>Inverting 7</b>		
inactive	inactive, active  Mode.	S.3
	<i>Inverting of the state of the assigned signal.</i>	


BO Slot X2 . <b>Assignment 2</b>	[Device Para / Binary Outputs / BO Slot X2 / BO 4]	
...		
BO Slot X2 . <b>Assignment 7</b>		
"_"	"_" ... Sys . Internal test state  1..n, Assignment List.	S.3
	<i>Assignment</i>	


BO Slot X2 . <b>Operating Mode</b>	[Device Para / Binary Outputs / BO Slot X2 / BO 5]	
Normally open (NO)	Normally open (NO), Normally closed (NC)  1...n Operating Modes.	S.3
	<i>Operating Mode</i>	


BO Slot X2 . <b>t-hold</b>	[Device Para / Binary Outputs / BO Slot X2 / BO 5]	
0.00s	0.00s ... 300.00s	S.3
	<i>To clearly identify the state transition of a binary output relay, the "new state" is being hold, at least for the duration of the hold time.</i>	


BO Slot X2 . <b>t-Off Delay</b>	[Device Para / Binary Outputs / BO Slot X2 / BO 5]	
0.00s	0.00s ... 300.00s	S.3
	<i>Switch Off Delay</i>	


BO Slot X2 . <b>Latched</b>	[Device Para / Binary Outputs / BO Slot X2 / BO 5]	
inactive	inactive, active  Mode.	S.3
	<i>Defines whether the Relay Output will be latched when it picks up.</i>	

<b>BO Slot X2 . Acknowledgement</b>		[Device Para / Binary Outputs / BO Slot X2 / BO 5]
"_"		"-" ... Sys . Internal test state
Only available if:		↳ 1..n, Assignment List.
<ul style="list-style-type: none"> <li>• BO Slot X2 . Latched = active</li> </ul>		
	<i>Acknowledgement Signal - An acknowledgement signal (that acknowledges the corresponding binary output relay) can be assigned to each output relay. The acknowledgement-signal is only effective if the parameter "Latched" is set to active.</i>	


<b>BO Slot X2 . Inverting</b>		[Device Para / Binary Outputs / BO Slot X2 / BO 5]
inactive		inactive, active
		↳ Mode.
	<i>Inverting of the collective signal (OR-gate/disjunction). In combination with inverted input signals an AND-gate can be programmed (Conjunction).</i>	


<b>BO Slot X2 . Assignment 1</b>		[Device Para / Binary Outputs / BO Slot X2 / BO 5]
MStart . Blo		"-" ... Sys . Internal test state
		↳ 1..n, Assignment List.
	<i>Assignment</i>	


<b>BO Slot X2 . Inverting 1</b>		[Device Para / Binary Outputs / BO Slot X2 / BO 5]
...		
<b>BO Slot X2 . Inverting 7</b>		
inactive		inactive, active
		↳ Mode.
	<i>Inverting of the state of the assigned signal.</i>	


<b>BO Slot X2 . Assignment 2</b>		[Device Para / Binary Outputs / BO Slot X2 / BO 5]
...		
<b>BO Slot X2 . Assignment 7</b>		
"_"		"-" ... Sys . Internal test state
		↳ 1..n, Assignment List.
	<i>Assignment</i>	

**2.3.1.1 BO Slot X2: Service**



BO Slot X2 . <b>DISARMED Ctrl</b>		[Service / Test (Prot inhibit) / DISARMED / BO Slot X2]
inactive	inactive, active	S.3
		↳ active/inactive.
	<i>Enables and disables the disarming of the relay outputs. This is the first step of a two step process, to inhibit the operation or the relay outputs. Please refer to "DISARMED" for the second step.</i>	


BO Slot X2 . <b>Disarm Mode</b>		[Service / Test (Prot inhibit) / DISARMED / BO Slot X2]
permanent	permanent, timeout	S.3
		↳ Mode.
	<i>CAUTION! RELAYS DISARMED in order to safely perform maintenance while eliminating the risk of taking an entire process off-line. (Note: The Supervision Contact cannot be disarmed). YOU MUST ENSURE that the relays are ARMED AGAIN after maintenance.</i>	



BO Slot X2 . <b>t-Timeout DISARM</b>		[Service / Test (Prot inhibit) / DISARMED / BO Slot X2]
0.03s	0.00s ... 300.00s	S.3
<i>Only available if:</i>		
<ul style="list-style-type: none"> <li>• BO Slot X2 . Disarm Mode = timeout</li> </ul>		
	<i>The relays will be armed again after expiring of this time.</i>	



BO Slot X2 . <b>DISARMED</b>		[Service / Test (Prot inhibit) / DISARMED / BO Slot X2]
inactive	inactive, active	S.3
		↳ active/inactive.
	<i>This is the second step, after the "DISARMED Ctrl" has been activated, that is required to DISARM the relay outputs. This will DISARM those output relays that are currently not latched and that are not on "hold" by a pending minimum hold time. CAUTION! RELAYS DISARMED in order to safely perform maintenance while eliminating the risk of taking an entire process off-line. (Note: Zone Interlocking and Supervision Contact cannot be disarmed). YOU MUST ENSURE that the relays are ARMED AGAIN after maintenance.</i>	




<b>BO Slot X2 . Force Mode</b>	[Service / Test (Prot inhibit) / Force OR / BO Slot X2]	
permanent	permanent, timeout  Mode.	S.3
	<i>By means of this function the normal Output Relay States can be overwritten (forced) in case that the Relay is not in a disarmed state. The relays can be set from normal operation (relay works according to the assigned signals) to "force energized" or "force de-energized" state.</i>	


<b>BO Slot X2 . t-Timeout Force</b>	[Service / Test (Prot inhibit) / Force OR / BO Slot X2]	
0.03s	0.00s ... 300.00s	S.3
Only available if:		
<ul style="list-style-type: none"> <li>• BO Slot X2 . Force Mode = timeout</li> </ul>		
	<i>The Output State will be set by force for the duration of this time. That means for the duration of this time the Output Relay does not show the state of the signals that are assigned on it.</i>	


<b>BO Slot X2 . Force all Outs</b>	[Service / Test (Prot inhibit) / Force OR / BO Slot X2]	
Normal	Normal, De-Energized, Energized  Relay operating modes.	S.3
	<i>By means of this function the normal Output Relay State can be overwritten (forced). The relay can be set from normal operation (relay works according to the assigned signals) to "force energized" or "force de-energized" state. Forcing all outputs relays of an entire assembly group is superior to forcing a single output relay.</i>	


<b>BO Slot X2 . Force OR1</b>	[Service / Test (Prot inhibit) / Force OR / BO Slot X2]	
...		
<b>BO Slot X2 . Force OR5</b>		
Normal	Normal, De-Energized, Energized  Relay operating modes.	S.3
	<i>By means of this function the normal Output Relay State can be overwritten (forced). The relay can be set from normal operation (relay works according to the assigned signals) to "force energized" or "force de-energized" state.</i>	


### 2.3.2 BO Slot X2 (4 Binary Outputs)


<b>BO Slot X2 . Operating Mode</b>		[Device Para / Binary Outputs / BO Slot X2 / BO 1]
Normally open (NO)	Normally open (NO), Normally closed (NC)	S.3
	↳ 1...n Operating Modes.	
 <i>Operating Mode</i>		

<b>BO Slot X2 . t-hold</b>		[Device Para / Binary Outputs / BO Slot X2 / BO 1]
0.00s	0.00s ... 300.00s	S.3
 <i>To clearly identify the state transition of a binary output relay, the "new state" is being hold, at least for the duration of the hold time.</i>		

<b>BO Slot X2 . t-Off Delay</b>		[Device Para / Binary Outputs / BO Slot X2 / BO 1]
0.00s	0.00s ... 300.00s	S.3
 <i>Switch Off Delay</i>		

<b>BO Slot X2 . Latched</b>		[Device Para / Binary Outputs / BO Slot X2 / BO 1]
active	inactive, active	S.3
	↳ Mode.	
 <i>Defines whether the Relay Output will be latched when it picks up.</i>		

<b>BO Slot X2 . Acknowledgement</b>		[Device Para / Binary Outputs / BO Slot X2 / BO 1]
"_"	"_" ... Sys . Internal test state	S.3
<i>Only available if:</i>	↳ 1..n, Assignment List.	
<ul style="list-style-type: none"> <li>• BO Slot X2 . Latched = active</li> </ul>		
 <i>Acknowledgement Signal - An acknowledgement signal (that acknowledges the corresponding binary output relay) can be assigned to each output relay. The acknowledgement-signal is only effective if the parameter "Latched" is set to active.</i>		

<b>BO Slot X2 . Inverting</b>		[Device Para / Binary Outputs / BO Slot X2 / BO 1]
inactive	inactive, active	S.3
	↳ Mode.	
 <i>Inverting of the collective signal (OR-gate/disjunction). In combination with inverted input signals an AND-gate can be programmed (Conjunction).</i>		

BO Slot X2 . <b>Assignment 1</b>	[Device Para / Binary Outputs / BO Slot X2 / BO 1]	
SG[1] . TripCmd	"-" ... Sys . Internal test state  ↳ 1..n, Assignment List.	S.3
🔗 <i>Assignment</i>		


BO Slot X2 . <b>Inverting 1</b>	[Device Para / Binary Outputs / BO Slot X2 / BO 1]	
...		
BO Slot X2 . <b>Inverting 7</b>		
inactive	inactive, active  ↳ Mode.	S.3
🔗 <i>Inverting of the state of the assigned signal.</i>		


BO Slot X2 . <b>Assignment 2</b>	[Device Para / Binary Outputs / BO Slot X2 / BO 1]	
...		
BO Slot X2 . <b>Assignment 7</b>		
"_"	"_" ... Sys . Internal test state  ↳ 1..n, Assignment List.	S.3
🔗 <i>Assignment</i>		


BO Slot X2 . <b>Operating Mode</b>	[Device Para / Binary Outputs / BO Slot X2 / BO 2]	
Normally open (NO)	Normally open (NO), Normally closed (NC)  ↳ 1...n Operating Modes.	S.3
🔗 <i>Operating Mode</i>		


BO Slot X2 . <b>t-hold</b>	[Device Para / Binary Outputs / BO Slot X2 / BO 2]	
0.00s	0.00s ... 300.00s	S.3
🔗 <i>To clearly identify the state transition of a binary output relay, the "new state" is being hold, at least for the duration of the hold time.</i>		


BO Slot X2 . <b>t-Off Delay</b>	[Device Para / Binary Outputs / BO Slot X2 / BO 2]	
0.00s	0.00s ... 300.00s	S.3
🔗 <i>Switch Off Delay</i>		


<b>BO Slot X2 . Latched</b>	[Device Para / Binary Outputs / BO Slot X2 / BO 2]	
inactive	inactive, active  ↳ Mode.	S.3
	<i>Defines whether the Relay Output will be latched when it picks up.</i>	


<b>BO Slot X2 . Acknowledgement</b>	[Device Para / Binary Outputs / BO Slot X2 / BO 2]	
"_"	"_" ... Sys . Internal test state	S.3
Only available if:	↳ 1..n, Assignment List.	
• BO Slot X2 . Latched = active		
	<i>Acknowledgement Signal - An acknowledgement signal (that acknowledges the corresponding binary output relay) can be assigned to each output relay. The acknowledgement-signal is only effective if the parameter "Latched" is set to active.</i>	


<b>BO Slot X2 . Inverting</b>	[Device Para / Binary Outputs / BO Slot X2 / BO 2]	
inactive	inactive, active  ↳ Mode.	S.3
	<i>Inverting of the collective signal (OR-gate/disjunction). In combination with inverted input signals an AND-gate can be programmed (Conjunction).</i>	


<b>BO Slot X2 . Assignment 1</b>	[Device Para / Binary Outputs / BO Slot X2 / BO 2]	
SG[1] . ON Cmd	"_" ... Sys . Internal test state	S.3
	↳ 1..n, Assignment List.	
	<i>Assignment</i>	


<b>BO Slot X2 . Inverting 1</b>	[Device Para / Binary Outputs / BO Slot X2 / BO 2]	
...		
<b>BO Slot X2 . Inverting 7</b>		
inactive	inactive, active  ↳ Mode.	S.3
	<i>Inverting of the state of the assigned signal.</i>	


BO Slot X2 . <b>Assignment 2</b>	[Device Para / Binary Outputs / BO Slot X2 / BO 2]	
...		
BO Slot X2 . <b>Assignment 7</b>		
"_"	"_" ... Sys . Internal test state  ↳ 1..n, Assignment List.	S.3
 Assignment		


BO Slot X2 . <b>Operating Mode</b>	[Device Para / Binary Outputs / BO Slot X2 / BO 3]	
Normally open (NO)	Normally open (NO), Normally closed (NC)  ↳ 1...n Operating Modes.	S.3
 Operating Mode		


BO Slot X2 . <b>t-hold</b>	[Device Para / Binary Outputs / BO Slot X2 / BO 3]	
0.00s	0.00s ... 300.00s	S.3
 To clearly identify the state transition of a binary output relay, the "new state" is being hold, at least for the duration of the hold time.		


BO Slot X2 . <b>t-Off Delay</b>	[Device Para / Binary Outputs / BO Slot X2 / BO 3]	
0.00s	0.00s ... 300.00s	S.3
 Switch Off Delay		


BO Slot X2 . <b>Latched</b>	[Device Para / Binary Outputs / BO Slot X2 / BO 3]	
inactive	inactive, active  ↳ Mode.	S.3
 Defines whether the Relay Output will be latched when it picks up.		

BO Slot X2 . <b>Acknowledgement</b>	[Device Para / Binary Outputs / BO Slot X2 / BO 3]	
"_"	"_" ... Sys . Internal test state	S.3
Only available if:	↳ 1..n, Assignment List.	
<ul style="list-style-type: none"> <li>BO Slot X2 . Latched = active</li> </ul>		
 Acknowledgement Signal - An acknowledgement signal (that acknowledges the corresponding binary output relay) can be assigned to each output relay. The acknowledgement-signal is only effective if the parameter "Latched" is set to active.		


<b>BO Slot X2 . Inverting</b>		[Device Para / Binary Outputs / BO Slot X2 / BO 3]
inactive	inactive, active	S.3
		↳ Mode.
 <i>Inverting of the collective signal (OR-gate/disjunction). In combination with inverted input signals an AND-gate can be programmed (Conjunction).</i>		


<b>BO Slot X2 . Assignment 1</b>		[Device Para / Binary Outputs / BO Slot X2 / BO 3]
SG[1] . OFF Cmd	"-" ... Sys . Internal test state	S.3
		↳ 1..n, Assignment List.
 <i>Assignment</i>		


<b>BO Slot X2 . Inverting 1</b>		[Device Para / Binary Outputs / BO Slot X2 / BO 3]
...		
<b>BO Slot X2 . Inverting 7</b>		
inactive	inactive, active	S.3
		↳ Mode.
 <i>Inverting of the state of the assigned signal.</i>		


<b>BO Slot X2 . Assignment 2</b>		[Device Para / Binary Outputs / BO Slot X2 / BO 3]
...		
<b>BO Slot X2 . Assignment 7</b>		
"-"	"-" ... Sys . Internal test state	S.3
		↳ 1..n, Assignment List.
 <i>Assignment</i>		





### 2.3.2.1 BO Slot X2: Service

<b>BO Slot X2 . DISARMED Ctrl</b>		[Service / Test (Prot inhibit) / DISARMED / BO Slot X2]
inactive	inactive, active	S.3
	↳ active/inactive.	
	<i>Enables and disables the disarming of the relay outputs. This is the first step of a two step process, to inhibit the operation or the relay outputs. Please refer to "DISARMED" for the second step.</i>	

<b>BO Slot X2 . Disarm Mode</b>		[Service / Test (Prot inhibit) / DISARMED / BO Slot X2]
permanent	permanent, timeout	S.3
	↳ Mode.	
	<i>CAUTION! RELAYS DISARMED in order to safely perform maintenance while eliminating the risk of taking an entire process off-line. (Note: The Supervision Contact cannot be disarmed). YOU MUST ENSURE that the relays are ARMED AGAIN after maintenance.</i>	

<b>BO Slot X2 . t-Timeout DISARM</b>		[Service / Test (Prot inhibit) / DISARMED / BO Slot X2]
0.03s	0.00s ... 300.00s	S.3
<i>Only available if:</i>		
<ul style="list-style-type: none"> <li>• BO Slot X2 . Disarm Mode = timeout</li> </ul>		
	<i>The relays will be armed again after expiring of this time.</i>	


<b>BO Slot X2 . DISARMED</b>		[Service / Test (Prot inhibit) / DISARMED / BO Slot X2]
inactive	inactive, active	S.3
	↳ active/inactive.	
	<i>This is the second step, after the "DISARMED Ctrl" has been activated, that is required to DISARM the relay outputs. This will DISARM those output relays that are currently not latched and that are not on "hold" by a pending minimum hold time. CAUTION! RELAYS DISARMED in order to safely perform maintenance while eliminating the risk of taking an entire process off-line. (Note: Zone Interlocking and Supervision Contact cannot be disarmed). YOU MUST ENSURE that the relays are ARMED AGAIN after maintenance.</i>	


<b>BO Slot X2 . Force Mode</b>		[Service / Test (Prot inhibit) / Force OR / BO Slot X2]
permanent	permanent, timeout	S.3
	↳ Mode.	
<p> By means of this function the normal Output Relay States can be overwritten (forced) in case that the Relay is not in a disarmed state. The relays can be set from normal operation (relay works according to the assigned signals) to "force energized" or "force de-energized" state.</p>		
<b>BO Slot X2 . t-Timeout Force</b>		[Service / Test (Prot inhibit) / Force OR / BO Slot X2]
0.03s	0.00s ... 300.00s	S.3
<p>Only available if:</p> <ul style="list-style-type: none"> <li>• BO Slot X2 . Force Mode = timeout</li> </ul>		
<p> The Output State will be set by force for the duration of this time. That means for the duration of this time the Output Relay does not show the state of the signals that are assigned on it.</p>		
<b>BO Slot X2 . Force all Outs</b>		[Service / Test (Prot inhibit) / Force OR / BO Slot X2]
Normal	Normal, De-Energized, Energized	S.3
	↳ Relay operating modes.	
<p> By means of this function the normal Output Relay State can be overwritten (forced). The relay can be set from normal operation (relay works according to the assigned signals) to "force energized" or "force de-energized" state. Forcing all outputs relays of an entire assembly group is superior to forcing a single output relay.</p>		
<b>BO Slot X2 . Force OR1</b>	[Service / Test (Prot inhibit) / Force OR / BO Slot X2]	
<b>BO Slot X2 . Force OR2</b>		
<b>BO Slot X2 . Force OR3</b>		
Normal	Normal, De-Energized, Energized	S.3
	↳ Relay operating modes.	
<p> By means of this function the normal Output Relay State can be overwritten (forced). The relay can be set from normal operation (relay works according to the assigned signals) to "force energized" or "force de-energized" state.</p>		





## 2.4 Analog Outputs

### 2.4.1 AnOut[1]

<b>AnOut[1] . Assignment</b>		[Device Para / Analog Outputs / AnOut[1]]
“-”	“-” ... RTD . Hottest MotBearTemp	S.3
	↳ 1..n, AnalogOutputList.	
	<i>Assignment</i>	


<b>AnOut[1] . Range</b>		[Device Para / Analog Outputs / AnOut[1]]
0...20mA	0...20mA, 4...20mA	S.3
	↳ Type of Output.	
	<i>Adjustable range</i>	


<b>AnOut[1] . Range max</b>		[Device Para / Analog Outputs / AnOut[1]]
1.00°C	-999999.00°C ... 999999.00°C	S.3
	<i>Adjustable range maximum.</i>	


<b>AnOut[1] . Range min</b>		[Device Para / Analog Outputs / AnOut[1]]
0.00°C	-999999.00°C ... 999999.00°C	S.3
	<i>Adjustable range minimum.</i>	


## 2.5 LEDs


### 2.5.1 LED 1


LEDs group A . <b>Latched</b>		[Device Para / LEDs / LED 1]
active	inactive, active, active, ack. by alarm	S.3
	↳ Mode.	
 Defines whether the LED will be latched when it picks up.		



LEDs group A . <b>Ack signal</b>		[Device Para / LEDs / LED 1]
"-"	"-" ... Sys . Internal test state	S.3
	↳ 1..n, Assignment List.	
 Acknowledgement signal for the LED. If latching is set to active the LED can only be acknowledged if those signals that initiated the setting are no longer present.		



LEDs group A . <b>LED active color</b>		[Device Para / LEDs / LED 1]
red	green, red, red flash, green flash, "-"	S.3
	↳ LED active color.	
 The LED lights up in this color if the state of the OR-assignment of the signals is true.		



LEDs group A . <b>LED inactive color</b>		[Device Para / LEDs / LED 1]
"-"	green, red, red flash, green flash, "-"	S.3
	↳ LED active color.	
 The LED lights up in this color if the state of the OR-assignment of the signals is untrue.		



LEDs group A . <b>Assignment 1</b>		[Device Para / LEDs / LED 1]
SG[1] . TripCmd	"-" ... Sys . Internal test state	S.3
	↳ 1..n, Assignment List.	
 Assignment		



LEDs group A . <b>Inverting 1</b>		[Device Para / LEDs / LED 1]
inactive	inactive, active	S.3
	↳ Mode.	
 Inverting of the state of the assigned signal.		



LEDs group A . <b>Assignment 2</b>		[Device Para / LEDs / LED 1]
"_"	"_" ... Sys . Internal test state  1..n, Assignment List.	S.3
	<i>Assignment</i>	


LEDs group A . <b>Inverting 2</b>		[Device Para / LEDs / LED 1]
inactive	inactive, active  Mode.	S.3
	<i>Inverting of the state of the assigned signal.</i>	


LEDs group A . <b>Assignment 3</b>		[Device Para / LEDs / LED 1]
"_"	"_" ... Sys . Internal test state  1..n, Assignment List.	S.3
	<i>Assignment</i>	

LEDs group A . <b>Inverting 3</b>		[Device Para / LEDs / LED 1]
inactive	inactive, active  Mode.	S.3
	<i>Inverting of the state of the assigned signal.</i>	


LEDs group A . <b>Assignment 4</b>		[Device Para / LEDs / LED 1]
"_"	"_" ... Sys . Internal test state  1..n, Assignment List.	S.3
	<i>Assignment</i>	


LEDs group A . <b>Inverting 4</b>		[Device Para / LEDs / LED 1]
inactive	inactive, active  Mode.	S.3
	<i>Inverting of the state of the assigned signal.</i>	


LEDs group A . <b>Assignment 5</b>		[Device Para / LEDs / LED 1]	
"_"	"-" ... Sys . Internal test state		S.3
	↳ 1..n, Assignment List.		
	<i>Assignment</i>		


LEDs group A . <b>Inverting 5</b>		[Device Para / LEDs / LED 1]	
inactive	inactive, active		S.3
	↳ Mode.		
	<i>Inverting of the state of the assigned signal.</i>		


## 2.5.2 LED 2


LEDs group A . <b>Latched</b>		[Device Para / LEDs / LED 2]
active	inactive, active, active, ack. by alarm	S.3
	↳ Mode.	
	<i>Defines whether the LED will be latched when it picks up.</i>	


LEDs group A . <b>Ack signal</b>		[Device Para / LEDs / LED 2]
"-"	"-" ... Sys . Internal test state	S.3
	↳ 1..n, Assignment List.	
	<i>Acknowledgement signal for the LED. If latching is set to active the LED can only be acknowledged if those signals that initiated the setting are no longer present.</i>	


LEDs group A . <b>LED active color</b>		[Device Para / LEDs / LED 2]
red	green, red, red flash, green flash, "-"	S.3
	↳ LED active color.	
	<i>The LED lights up in this color if the state of the OR-assignment of the signals is true.</i>	


LEDs group A . <b>LED inactive color</b>		[Device Para / LEDs / LED 2]
"-"	green, red, red flash, green flash, "-"	S.3
	↳ LED active color.	
	<i>The LED lights up in this color if the state of the OR-assignment of the signals is untrue.</i>	


LEDs group A . <b>Assignment 1</b>		[Device Para / LEDs / LED 2]
Prot . Alarm	"-" ... Sys . Internal test state	S.3
	↳ 1..n, Assignment List.	
	<i>Assignment</i>	


LEDs group A . <b>Inverting 1</b>		[Device Para / LEDs / LED 2]
inactive	inactive, active	S.3
	↳ Mode.	
	<i>Inverting of the state of the assigned signal.</i>	


<b>LEDs group A . Assignment 2</b>		[Device Para / LEDs / LED 2]
"_"	"_" ... Sys . Internal test state ↳ 1..n, Assignment List.	S.3
 <i>Assignment</i>		



<b>LEDs group A . Inverting 2</b>		[Device Para / LEDs / LED 2]
inactive	inactive, active ↳ Mode.	S.3
 <i>Inverting of the state of the assigned signal.</i>		



<b>LEDs group A . Assignment 3</b>		[Device Para / LEDs / LED 2]
"_"	"_" ... Sys . Internal test state ↳ 1..n, Assignment List.	S.3
 <i>Assignment</i>		

<b>LEDs group A . Inverting 3</b>		[Device Para / LEDs / LED 2]
inactive	inactive, active ↳ Mode.	S.3
 <i>Inverting of the state of the assigned signal.</i>		


<b>LEDs group A . Assignment 4</b>		[Device Para / LEDs / LED 2]
"_"	"_" ... Sys . Internal test state ↳ 1..n, Assignment List.	S.3
 <i>Assignment</i>		


<b>LEDs group A . Inverting 4</b>		[Device Para / LEDs / LED 2]
inactive	inactive, active ↳ Mode.	S.3
 <i>Inverting of the state of the assigned signal.</i>		


LEDs group A . <b>Assignment 5</b>		[Device Para / LEDs / LED 2]	
“-”		“-” ... Sys . Internal test state  1..n, Assignment List.	S.3
	<i>Assignment</i>		


LEDs group A . <b>Inverting 5</b>		[Device Para / LEDs / LED 2]	
inactive		inactive, active  Mode.	S.3
	<i>Inverting of the state of the assigned signal.</i>		


### 2.5.3 LED 3


LEDs group A . <b>Latched</b>		[Device Para / LEDs / LED 3]
active	inactive, active, active, ack. by alarm	S.3
	↳ Mode.	
	<i>Defines whether the LED will be latched when it picks up.</i>	

LEDs group A . <b>Ack signal</b>		[Device Para / LEDs / LED 3]
"-"	"-" ... Sys . Internal test state	S.3
	↳ 1..n, Assignment List.	
	<i>Acknowledgement signal for the LED. If latching is set to active the LED can only be acknowledged if those signals that initiated the setting are no longer present.</i>	



LEDs group A . <b>LED active color</b>		[Device Para / LEDs / LED 3]
red	green, red, red flash, green flash, "-"	S.3
	↳ LED active color.	
	<i>The LED lights up in this color if the state of the OR-assignment of the signals is true.</i>	



LEDs group A . <b>LED inactive color</b>		[Device Para / LEDs / LED 3]
"-"	green, red, red flash, green flash, "-"	S.3
	↳ LED active color.	
	<i>The LED lights up in this color if the state of the OR-assignment of the signals is untrue.</i>	



LEDs group A . <b>Assignment 1</b>		[Device Para / LEDs / LED 3]
ThR . Alarm	"-" ... Sys . Internal test state	S.3
	↳ 1..n, Assignment List.	
	<i>Assignment</i>	



LEDs group A . <b>Inverting 1</b>		[Device Para / LEDs / LED 3]
inactive	inactive, active	S.3
	↳ Mode.	
	<i>Inverting of the state of the assigned signal.</i>	







LEDs group A . <b>Assignment 2</b>		[Device Para / LEDs / LED 3]
I[1] . Alarm	"-" ... Sys . Internal test state  1..n, Assignment List.	S.3
 <i>Assignment</i>		



LEDs group A . <b>Inverting 2</b>		[Device Para / LEDs / LED 3]
inactive	inactive, active  Mode.	S.3
 <i>Inverting of the state of the assigned signal.</i>		



LEDs group A . <b>Assignment 3</b>		[Device Para / LEDs / LED 3]
"_"	"-" ... Sys . Internal test state  1..n, Assignment List.	S.3
 <i>Assignment</i>		

LEDs group A . <b>Inverting 3</b>		[Device Para / LEDs / LED 3]
inactive	inactive, active  Mode.	S.3
 <i>Inverting of the state of the assigned signal.</i>		


LEDs group A . <b>Assignment 4</b>		[Device Para / LEDs / LED 3]
"_"	"-" ... Sys . Internal test state  1..n, Assignment List.	S.3
 <i>Assignment</i>		


LEDs group A . <b>Inverting 4</b>		[Device Para / LEDs / LED 3]
inactive	inactive, active  Mode.	S.3
 <i>Inverting of the state of the assigned signal.</i>		


LEDs group A . <b>Assignment 5</b>		[Device Para / LEDs / LED 3]	
“-”		“-” ... Sys . Internal test state  1..n, Assignment List.	S.3
	<i>Assignment</i>		


LEDs group A . <b>Inverting 5</b>		[Device Para / LEDs / LED 3]	
inactive		inactive, active  Mode.	S.3
	<i>Inverting of the state of the assigned signal.</i>		


## 2.5.4 LED 4


LEDs group A . <b>Latched</b>		[Device Para / LEDs / LED 4]
active	inactive, active, active, ack. by alarm	S.3
	↳ Mode.	
 <i>Defines whether the LED will be latched when it picks up.</i>		


LEDs group A . <b>Ack signal</b>		[Device Para / LEDs / LED 4]
"-"	"-" ... Sys . Internal test state	S.3
	↳ 1..n, Assignment List.	
 <i>Acknowledgement signal for the LED. If latching is set to active the LED can only be acknowledged if those signals that initiated the setting are no longer present.</i>		


LEDs group A . <b>LED active color</b>		[Device Para / LEDs / LED 4]
red	green, red, red flash, green flash, "-"	S.3
	↳ LED active color.	
 <i>The LED lights up in this color if the state of the OR-assignment of the signals is true.</i>		


LEDs group A . <b>LED inactive color</b>		[Device Para / LEDs / LED 4]
"-"	green, red, red flash, green flash, "-"	S.3
	↳ LED active color.	
 <i>The LED lights up in this color if the state of the OR-assignment of the signals is untrue.</i>		


LEDs group A . <b>Assignment 1</b>		[Device Para / LEDs / LED 4]
MStart . Blo	"-" ... Sys . Internal test state	S.3
	↳ 1..n, Assignment List.	
 <i>Assignment</i>		


LEDs group A . <b>Inverting 1</b>		[Device Para / LEDs / LED 4]
inactive	inactive, active	S.3
	↳ Mode.	
 <i>Inverting of the state of the assigned signal.</i>		


<b>LEDs group A . Assignment 2</b>		[Device Para / LEDs / LED 4]
“-”	“-” ... Sys . Internal test state ↳ 1..n, Assignment List.	S.3
 <i>Assignment</i>		



<b>LEDs group A . Inverting 2</b>		[Device Para / LEDs / LED 4]
inactive	inactive, active ↳ Mode.	S.3
 <i>Inverting of the state of the assigned signal.</i>		



<b>LEDs group A . Assignment 3</b>		[Device Para / LEDs / LED 4]
“-”	“-” ... Sys . Internal test state ↳ 1..n, Assignment List.	S.3
 <i>Assignment</i>		

<b>LEDs group A . Inverting 3</b>		[Device Para / LEDs / LED 4]
inactive	inactive, active ↳ Mode.	S.3
 <i>Inverting of the state of the assigned signal.</i>		


<b>LEDs group A . Assignment 4</b>		[Device Para / LEDs / LED 4]
“-”	“-” ... Sys . Internal test state ↳ 1..n, Assignment List.	S.3
 <i>Assignment</i>		


<b>LEDs group A . Inverting 4</b>		[Device Para / LEDs / LED 4]
inactive	inactive, active ↳ Mode.	S.3
 <i>Inverting of the state of the assigned signal.</i>		


LEDs group A . <b>Assignment 5</b>		[Device Para / LEDs / LED 4]	
“-”		“-” ... Sys . Internal test state  1..n, Assignment List.	S.3
	<i>Assignment</i>		


LEDs group A . <b>Inverting 5</b>		[Device Para / LEDs / LED 4]	
inactive		inactive, active  Mode.	S.3
	<i>Inverting of the state of the assigned signal.</i>		


## 2.5.5 LED 5


LEDs group A . <b>Latched</b>		[Device Para / LEDs / LED 5]
inactive	inactive, active, active, ack. by alarm	S.3
	↳ Mode.	
 Defines whether the LED will be latched when it picks up.		



LEDs group A . <b>Ack signal</b>		[Device Para / LEDs / LED 5]
"-"	"-" ... Sys . Internal test state	S.3
	↳ 1..n, Assignment List.	
 Acknowledgement signal for the LED. If latching is set to active the LED can only be acknowledged if those signals that initiated the setting are no longer present.		



LEDs group A . <b>LED active color</b>		[Device Para / LEDs / LED 5]
red flash	green, red, red flash, green flash, "-"	S.3
	↳ LED active color.	
 The LED lights up in this color if the state of the OR-assignment of the signals is true.		



LEDs group A . <b>LED inactive color</b>		[Device Para / LEDs / LED 5]
"-"	green, red, red flash, green flash, "-"	S.3
	↳ LED active color.	
 The LED lights up in this color if the state of the OR-assignment of the signals is untrue.		



LEDs group A . <b>Assignment 1</b>		[Device Para / LEDs / LED 5]
MStart . Start	"-" ... Sys . Internal test state	S.3
	↳ 1..n, Assignment List.	
 Assignment		



LEDs group A . <b>Inverting 1</b>		[Device Para / LEDs / LED 5]
inactive	inactive, active	S.3
	↳ Mode.	
 Inverting of the state of the assigned signal.		



LEDs group A . <b>Assignment 2</b>		[Device Para / LEDs / LED 5]
"_"	"-" ... Sys . Internal test state  1..n, Assignment List.	S.3
	<i>Assignment</i>	


LEDs group A . <b>Inverting 2</b>		[Device Para / LEDs / LED 5]
inactive	inactive, active  Mode.	S.3
	<i>Inverting of the state of the assigned signal.</i>	


LEDs group A . <b>Assignment 3</b>		[Device Para / LEDs / LED 5]
"_"	"-" ... Sys . Internal test state  1..n, Assignment List.	S.3
	<i>Assignment</i>	

LEDs group A . <b>Inverting 3</b>		[Device Para / LEDs / LED 5]
inactive	inactive, active  Mode.	S.3
	<i>Inverting of the state of the assigned signal.</i>	

LEDs group A . <b>Assignment 4</b>		[Device Para / LEDs / LED 5]
"_"	"-" ... Sys . Internal test state  1..n, Assignment List.	S.3
	<i>Assignment</i>	


LEDs group A . <b>Inverting 4</b>		[Device Para / LEDs / LED 5]
inactive	inactive, active  Mode.	S.3
	<i>Inverting of the state of the assigned signal.</i>	


LEDs group A . <b>Assignment 5</b>		[Device Para / LEDs / LED 5]	
“-”		“-” ... Sys . Internal test state  ↳ 1..n, Assignment List.	S.3
	<i>Assignment</i>		


LEDs group A . <b>Inverting 5</b>		[Device Para / LEDs / LED 5]	
inactive		inactive, active  ↳ Mode.	S.3
	<i>Inverting of the state of the assigned signal.</i>		





## 2.5.6 LED 6


LEDs group A . <b>Latched</b>		[Device Para / LEDs / LED 6]
inactive	inactive, active, active, ack. by alarm	S.3
	↳ Mode.	
 Defines whether the LED will be latched when it picks up.		


LEDs group A . <b>Ack signal</b>		[Device Para / LEDs / LED 6]
"-"	"-" ... Sys . Internal test state	S.3
	↳ 1..n, Assignment List.	
 Acknowledgement signal for the LED. If latching is set to active the LED can only be acknowledged if those signals that initiated the setting are no longer present.		


LEDs group A . <b>LED active color</b>		[Device Para / LEDs / LED 6]
red	green, red, red flash, green flash, "-"	S.3
	↳ LED active color.	
 The LED lights up in this color if the state of the OR-assignment of the signals is true.		


LEDs group A . <b>LED inactive color</b>		[Device Para / LEDs / LED 6]
"-"	green, red, red flash, green flash, "-"	S.3
	↳ LED active color.	
 The LED lights up in this color if the state of the OR-assignment of the signals is untrue.		


LEDs group A . <b>Assignment 1</b>		[Device Para / LEDs / LED 6]
MStart . Run	"-" ... Sys . Internal test state	S.3
	↳ 1..n, Assignment List.	
 Assignment		


LEDs group A . <b>Inverting 1</b>		[Device Para / LEDs / LED 6]
inactive	inactive, active	S.3
	↳ Mode.	
 Inverting of the state of the assigned signal.		


<b>LEDs group A . Assignment 2</b>		[Device Para / LEDs / LED 6]
“-”	“-” ... Sys . Internal test state ↳ 1..n, Assignment List.	S.3
 <i>Assignment</i>		



<b>LEDs group A . Inverting 2</b>		[Device Para / LEDs / LED 6]
inactive	inactive, active ↳ Mode.	S.3
 <i>Inverting of the state of the assigned signal.</i>		



<b>LEDs group A . Assignment 3</b>		[Device Para / LEDs / LED 6]
“-”	“-” ... Sys . Internal test state ↳ 1..n, Assignment List.	S.3
 <i>Assignment</i>		

<b>LEDs group A . Inverting 3</b>		[Device Para / LEDs / LED 6]
inactive	inactive, active ↳ Mode.	S.3
 <i>Inverting of the state of the assigned signal.</i>		


<b>LEDs group A . Assignment 4</b>		[Device Para / LEDs / LED 6]
“-”	“-” ... Sys . Internal test state ↳ 1..n, Assignment List.	S.3
 <i>Assignment</i>		


<b>LEDs group A . Inverting 4</b>		[Device Para / LEDs / LED 6]
inactive	inactive, active ↳ Mode.	S.3
 <i>Inverting of the state of the assigned signal.</i>		


LEDs group A . <b>Assignment 5</b>		[Device Para / LEDs / LED 6]	
“-”		“-” ... Sys . Internal test state  1..n, Assignment List.	S.3
	<i>Assignment</i>		


LEDs group A . <b>Inverting 5</b>		[Device Para / LEDs / LED 6]	
inactive		inactive, active  Mode.	S.3
	<i>Inverting of the state of the assigned signal.</i>		


## 2.5.7 LED 7


LEDs group A . <b>Latched</b>		[Device Para / LEDs / LED 7]
inactive	inactive, active, active, ack. by alarm	S.3
	↳ Mode.	
 Defines whether the LED will be latched when it picks up.		



LEDs group A . <b>Ack signal</b>		[Device Para / LEDs / LED 7]
"-"	"-" ... Sys . Internal test state	S.3
	↳ 1..n, Assignment List.	
 Acknowledgement signal for the LED. If latching is set to active the LED can only be acknowledged if those signals that initiated the setting are no longer present.		



LEDs group A . <b>LED active color</b>		[Device Para / LEDs / LED 7]
green	green, red, red flash, green flash, "-"	S.3
	↳ LED active color.	
 The LED lights up in this color if the state of the OR-assignment of the signals is true.		



LEDs group A . <b>LED inactive color</b>		[Device Para / LEDs / LED 7]
"-"	green, red, red flash, green flash, "-"	S.3
	↳ LED active color.	
 The LED lights up in this color if the state of the OR-assignment of the signals is untrue.		



LEDs group A . <b>Assignment 1</b>		[Device Para / LEDs / LED 7]
MStart . Stop	"-" ... Sys . Internal test state	S.3
	↳ 1..n, Assignment List.	
 Assignment		



LEDs group A . <b>Inverting 1</b>		[Device Para / LEDs / LED 7]
inactive	inactive, active	S.3
	↳ Mode.	
 Inverting of the state of the assigned signal.		



LEDs group A . <b>Assignment 2</b>		[Device Para / LEDs / LED 7]
"_"	"_" ... Sys . Internal test state  1..n, Assignment List.	S.3
	<i>Assignment</i>	


LEDs group A . <b>Inverting 2</b>		[Device Para / LEDs / LED 7]
inactive	inactive, active  Mode.	S.3
	<i>Inverting of the state of the assigned signal.</i>	


LEDs group A . <b>Assignment 3</b>		[Device Para / LEDs / LED 7]
"_"	"_" ... Sys . Internal test state  1..n, Assignment List.	S.3
	<i>Assignment</i>	

LEDs group A . <b>Inverting 3</b>		[Device Para / LEDs / LED 7]
inactive	inactive, active  Mode.	S.3
	<i>Inverting of the state of the assigned signal.</i>	

LEDs group A . <b>Assignment 4</b>		[Device Para / LEDs / LED 7]
"_"	"_" ... Sys . Internal test state  1..n, Assignment List.	S.3
	<i>Assignment</i>	


LEDs group A . <b>Inverting 4</b>		[Device Para / LEDs / LED 7]
inactive	inactive, active  Mode.	S.3
	<i>Inverting of the state of the assigned signal.</i>	


LEDs group A . <b>Assignment 5</b>		[Device Para / LEDs / LED 7]	
“-”		“-” ... Sys . Internal test state ↳ 1..n, Assignment List.	S.3
	<i>Assignment</i>		

LEDs group A . <b>Inverting 5</b>		[Device Para / LEDs / LED 7]	
inactive		inactive, active ↳ Mode.	S.3
	<i>Inverting of the state of the assigned signal.</i>		


## 2.6 HMI


front-panel



<b>Password</b>	[Device Para / Security / Password]
 This item represents a special dialog. (See the Technical Manual for details.)	
	<i>Changing the password</i>


<b>Access Level</b>	[Device Para / Security / Access Level]
 This item represents a special dialog. (See the Technical Manual for details.)	
	<i>Access Level</i>

### 2.6.1 HMI: Global Parameters


<b>HMI . Display Off</b>	[Device Para / HMI]
180s	20s ... 3600s S.3
 <i>The display back light will be turned off when this timer has expired.</i>	

<b>HMI . Menu language</b>	[Device Para / HMI]
English	English ... Romanian S.3
	 Selection.
 <i>Selection of the language</i>	



<b>HMI . Display ANSI Device No.</b>	[Device Para / HMI]
active	inactive, active S.3
	 Mode.
 <i>Display ANSI Device Numbers</i>	

<b>HMI . t-max Edit/Access</b>	[Device Para / Security / General Settings]
180s	20s ... 3600s S.3
 <i>If no other key(s) is pressed at the panel, after expiration of this time, all cached (changed) parameters are canceled. The device access will be locked by falling back into Read-only level Lv0.</i>	

## 2.6.2 HMI: Direct Controls







<b>HMI . Contrast</b>		[Device Para / HMI]
50%	0% ... 100%	S.3
<input checked="" type="radio"/>	<i>Contrast</i>	
<b>HMI . Config. Device Reset</b>		[Device Para / Security / General Settings]
"Fact.def.", "PW rst"	"Fact.def.", "PW rst", Only "Fact.defaults", Reset deact.   <b>Config. Device Reset.</b>	S.3
<input checked="" type="radio"/>	<i>If the »C« key is pressed while the device is performing a cold restart a general Reset Dialog appears on the screen. Select which options shall be available with this dialog.</i>	



## 2.6.3 HMI: Values



<b>HMI . Config. Device Reset</b>		[Operation / Security / Security States]
"Fact.def.", "PW rst"	"Fact.def.", "PW rst", Only "Fact.defaults", Reset deact.   <b>Config. Device Reset.</b>	
	<i>If the »C« key is pressed while the device is performing a cold restart a general Reset Dialog appears on the screen. Select which options shall be available with this dialog.</i>	







### 3 Security

- Ctrl . Switching Authority:  Tab.
- HMI . Config. Device Reset:  Tab.
- HMI . t-max Edit/Access:  Tab.
- HMI . Config. Device Reset:  Tab.
- Password:  Tab.
- Access Level:  Tab.


<b>Sys . Smart view via USB</b>	[Operation / Security / Security States]
active	inactive, active  Mode.
 <i>Information whether or not the Smart view access via the USB interface is activated (allowed).</i>	



<b>Sys . Smart view via Eth</b>	[Operation / Security / Security States]
active <i>Avail. depends on HW</i>	inactive, active  Mode.
 <i>Information whether or not the Smart view access via the Ethernet interface is activated (allowed).</i>	



<b>Sys . Passw. for USB conn.</b>	[Operation / Security / Security States]
disabled	disabled, default, def. by user  Type of passw. def..
 <i>Type / Security-level of the connection password that is used for a USB connection.</i>	

<b>Sys . Passw.remote net.conn.</b>	[Operation / Security / Security States]
disabled <i>Avail. depends on HW</i>	disabled, default, def. by user  Type of passw. def..
 <i>Type / Security-level of the connection password that is used for a Smart view connection via some network interface.</i>	

<b>Sys . TLS Certificate</b>		[Operation / Security / Security States]
Device-specific	Device-specific, Basic, Corrupt  <a href="#">TLS Certificate.</a>	
	<i>Type of certificate that the device uses for the encrypted communication. This value is directly related to the security-level of the communication.</i>	

<b>Security Logger</b>		[Operation / Security / Security Logger]
	This item represents a special dialog. (See the Technical Manual for details.) <i>Security-related messages</i>	



<b>Sys . Smart view via USB</b>		[Device Para / Security / Communication]
active	inactive, active  <a href="#">Mode.</a>	S.3
	<i>Activate (allow) or inactivate (disallow) the Smart view access via the USB interface.</i>	



<b>Sys . Smart view via Eth</b>		[Device Para / Security / Communication]
active <i>Avail. depends on HW</i>	inactive, active  <a href="#">Mode.</a>	S.3
	<i>Activate (allow) or inactivate (disallow) the Smart view access via the Ethernet interface.</i>	

## 4 Field settings

Field settings

### 4.1 Field Para: Global Parameters


Field Para . <b>Phase Sequence</b>	[Field Para / General Settings]	
ABC	ABC, ACB  Phase Sequence.	S.3
 <i>Phase Sequence direction</i>		


Field Para . <b>f</b>	[Field Para / General Settings]	
50Hz	50Hz, 60Hz  fN.	S.3
 <i>Nominal frequency</i>		


## 4.2 CT


Current Transformer


### 4.2.1 CT: Global Parameters



<b>CT . IL1, IL2, IL3 Cutoff Level</b>	[Device Para / Measurment Display / Current]	
0.005In	0.0In ... 0.100In	S.3
	<i>The Current shown in the Display or within the PC Software will be displayed as zero, if the Current falls below this Cutoff Level. This parameter has no impact on recorders.</i>	



<b>CT . IG meas Cutoff Level</b>	[Device Para / Measurment Display / Current]	
0.005In	0.0In ... 0.100In	S.3
	<i>The measured Earth Current shown in the Display or within the PC Software will be displayed as zero, if the measured Earth Current falls below this Cutoff Level. This parameter has no impact on recorders.</i>	


<b>CT . IG calc Cutoff Level</b>	[Device Para / Measurment Display / Current]	
0.005In	0.0In ... 0.100In	S.3
	<i>The calculated Earth Current shown in the Display or within the PC Software will be displayed as zero, if the calculated Earth Current falls below this Cutoff Level. This parameter has no impact on recorders.</i>	



<b>CT . I012 Cutoff Level</b>	[Device Para / Measurment Display / Current]	
0.005In	0.0In ... 0.100In	S.3
	<i>The Symmetrical Component shown in the Display or within the PC Software will be displayed as zero, if the Symmetrical Component falls below this Cutoff Level. This parameter has no impact on recorders.</i>	



<b>CT . CT pri</b>	[Field Para / CT]	
10A	1A ... 50000A	S.3
	<i>Nominal current of the primary side of the current transformers.</i>	

<b>CT . CT sec</b>	[Field Para / CT]	
1A	1A, 5A	S.3
	 Ratio prim/sec.	
	<i>Nominal current of the secondary side of the current transformers.</i>	


CT . <b>CT dir</b>	[Field Para / CT]	
0°	0°, 180°  Polarity.	S.3
	<i>Protection functions with directional feature can only work properly if the connection of the current transformers is free of wiring errors. If all current transformers are connected to the device with an incorrect polarity, the wiring error can be compensated by this parameter. This parameter turns the current vectors by 180 degrees.</i>	

CT . <b>ECT pri</b>	[Field Para / CT]	
50A	1A ... 50000A	S.3
	<i>This parameter defines the primary nominal current of the connected earth current transformer. If the earth current is measured via the Holmgreen connection, the primary value of the phase current transformer must be entered here.</i>	











CT . <b>ECT sec</b>	[Field Para / CT]	
1A	1A, 5A  Ratio prim/sec.	S.3
	<i>This parameter defines the secondary nominal current of the connected earth current transformer. If the earth current is done via the Holmgreen connection, the primary value of the phase current transformer must be entered here.</i>	







CT . <b>ECT dir</b>	[Field Para / CT]	
0°	0°, 180°  Polarity.	S.3
	<i>Earth fault protection with directional feature depends also on the correct wiring of the earth current transformer. An incorrect polarity/wiring can be corrected by means of the settings "0°" or "180°". The operator has the possibility of turning the current vector by 180 degrees (change of sign) without modification of the wiring. This means, that - in terms of figures - the determined current indicator was turned by 180° by the device.</i>	

#### 4.2.2 CT: Signals (Output States)

CT . <b>Phase seq. wrong</b>	[Operation / Status Display / Supervision / Phase Sequence]	
	<i>Signal that the device has detected a phase sequence (L1-L2-L3 / L1-L3-L2) that is different from the one that had been set at [Field settings / General Settings] »Phase Sequence«.</i>	

### 4.2.3 CT: Values

CT . <b>IL1</b>	[Operation / Measured Values / Current ]
 Measured value: Phase current (fundamental)	
CT . <b>IL2</b>	[Operation / Measured Values / Current ]
 Measured value: Phase current (fundamental)	
CT . <b>IL3</b>	[Operation / Measured Values / Current ]
 Measured value: Phase current (fundamental)	
CT . <b>IG meas</b>	[Operation / Measured Values / Current ]
 Measured value (measured): IG (fundamental)	
CT . <b>IG calc</b>	[Operation / Measured Values / Current ]
 Measured value (calculated): IG (fundamental)	
CT . <b>I0</b>	[Operation / Measured Values / Current ]
 Measured value (calculated): Zero current (fundamental)	
CT . <b>I1</b>	[Operation / Measured Values / Current ]
 Measured value (calculated): Positive phase sequence current (fundamental)	
CT . <b>I2</b>	[Operation / Measured Values / Current ]
 Measured value (calculated): Unbalanced load current (fundamental)	
CT . <b>%(I2/I1)</b>	[Operation / Measured Values / Current ]
 Measured value (calculated): I2/I1, phase sequence will be taken into account automatically.	
CT . <b>phi IL1</b>	[Operation / Measured Values / Current ]
 Measured value (calculated): Angle of Phasor IL1	
	Reference phasor is required to calculate the angle. This is the first measured voltage (or current) channel with sufficiently high amplitude.

<b>CT . phi IL2</b>	[Operation / Measured Values / Current ]
	<p><i>Measured value (calculated): Angle of Phasor IL2</i></p> <p><i>Reference phasor is required to calculate the angle. This is the first measured voltage (or current) channel with sufficiently high amplitude.</i></p>
<b>CT . phi IL3</b>	[Operation / Measured Values / Current ]
	<p><i>Measured value (calculated): Angle of Phasor IL3</i></p> <p><i>Reference phasor is required to calculate the angle. This is the first measured voltage (or current) channel with sufficiently high amplitude.</i></p>
<b>CT . phi IG meas</b>	[Operation / Measured Values / Current ]
	<p><i>Measured value (calculated): Angle of Phasor IG meas</i></p> <p><i>Reference phasor is required to calculate the angle. This is the first measured voltage (or current) channel with sufficiently high amplitude.</i></p>
<b>CT . phi IG calc</b>	[Operation / Measured Values / Current ]
	<p><i>Measured value (calculated): Angle of Phasor IG calc</i></p> <p><i>Reference phasor is required to calculate the angle. This is the first measured voltage (or current) channel with sufficiently high amplitude.</i></p>
<b>CT . phi I0</b>	[Operation / Measured Values / Current ]
	<p><i>Measured value (calculated): Angle Zero Sequence System</i></p> <p><i>Reference phasor is required to calculate the angle. This is the first measured voltage (or current) channel with sufficiently high amplitude.</i></p>
<b>CT . phi I1</b>	[Operation / Measured Values / Current ]
	<p><i>Measured value (calculated): Angle of Positive Sequence System</i></p> <p><i>Reference phasor is required to calculate the angle. This is the first measured voltage (or current) channel with sufficiently high amplitude.</i></p>
<b>CT . phi I2</b>	[Operation / Measured Values / Current ]
	<p><i>Measured Value (calculated): Angle of Negative Sequence System</i></p> <p><i>Reference phasor is required to calculate the angle. This is the first measured voltage (or current) channel with sufficiently high amplitude.</i></p>

<b>CT . IL1 RMS</b>	[Operation / Measured Values / Current RMS]
 <i>Measured value: Phase current (RMS)</i>	
<b>CT . IL2 RMS</b>	[Operation / Measured Values / Current RMS]
 <i>Measured value: Phase current (RMS)</i>	
<b>CT . IL3 RMS</b>	[Operation / Measured Values / Current RMS]
 <i>Measured value: Phase current (RMS)</i>	
<b>CT . IG meas RMS</b>	[Operation / Measured Values / Current RMS]
 <i>Measured value (measured): IG (RMS)</i>	
<b>CT . IG calc RMS</b>	[Operation / Measured Values / Current RMS]
 <i>Measured value (calculated): IG (RMS)</i>	
<b>CT . %IL1 THD</b>	[Operation / Measured Values / Current RMS]
 <i>Measured value (calculated): IL1 Total Harmonic Distortion</i>	
<b>CT . %IL2 THD</b>	[Operation / Measured Values / Current RMS]
 <i>Measured value (calculated): IL2 Total Harmonic Distortion</i>	
<b>CT . %IL3 THD</b>	[Operation / Measured Values / Current RMS]
 <i>Measured value (calculated): IL3 Total Harmonic Distortion</i>	
<b>CT . IL1 THD</b>	[Operation / Measured Values / Current RMS]
 <i>Measured value (calculated): IL1 Total Harmonic Current</i>	
<b>CT . IL2 THD</b>	[Operation / Measured Values / Current RMS]
 <i>Measured value (calculated): IL2 Total Harmonic Current</i>	
<b>CT . IL3 THD</b>	[Operation / Measured Values / Current RMS]
 <i>Measured value (calculated): IL3 Total Harmonic Current</i>	



## 4.2.4 CT: Statistical Values




CT . <b>IL1 avg RMS</b>	[Operation / Statistics / Demand / Current Demand]
<input checked="" type="checkbox"/> <i>IL1 average value (RMS)</i>	
CT . <b>IL2 avg RMS</b>	[Operation / Statistics / Demand / Current Demand]
<input checked="" type="checkbox"/> <i>IL2 average value (RMS)</i>	
CT . <b>IL3 avg RMS</b>	[Operation / Statistics / Demand / Current Demand]
<input checked="" type="checkbox"/> <i>IL3 average value (RMS)</i>	
CT . <b>IL1 Peak demand</b>	[Operation / Statistics / Demand / Current Demand]
<input checked="" type="checkbox"/> <i>IL1 Peak value, RMS value</i>	
CT . <b>IL2 Peak demand</b>	[Operation / Statistics / Demand / Current Demand]
<input checked="" type="checkbox"/> <i>IL2 Peak value, RMS value</i>	
CT . <b>IL3 Peak demand</b>	[Operation / Statistics / Demand / Current Demand]
<input checked="" type="checkbox"/> <i>IL3 Peak value, RMS value</i>	
CT . <b>IL1 max RMS</b>	[Operation / Statistics / Max / Current]
<input checked="" type="checkbox"/> <i>IL1 maximum value (RMS)</i>	
CT . <b>IL2 max RMS</b>	[Operation / Statistics / Max / Current]
<input checked="" type="checkbox"/> <i>IL2 maximum value (RMS)</i>	
CT . <b>IL3 max RMS</b>	[Operation / Statistics / Max / Current]
<input checked="" type="checkbox"/> <i>IL3 maximum value (RMS)</i>	
CT . <b>IG meas max RMS</b>	[Operation / Statistics / Max / Current]
<input checked="" type="checkbox"/> <i>Measured value: IG maximum value (RMS)</i>	
CT . <b>IG calc max RMS</b>	[Operation / Statistics / Max / Current]
<input checked="" type="checkbox"/> <i>Measured value (calculated):IG maximum value (RMS)</i>	

<b>CT . I1 max</b>	[Operation / Statistics / Max / Current]
<input checked="" type="checkbox"/> <i>Maximum value positive phase sequence current (fundamental)</i>	
<b>CT . I2 max</b>	[Operation / Statistics / Max / Current]
<input checked="" type="checkbox"/> <i>Maximum value negative sequence current (fundamental)</i>	
<b>CT . %(I2/I1) max</b>	[Operation / Statistics / Max / Current]
<input checked="" type="checkbox"/> <i>Measured value (calculated): I2/I1 maximum value, phase sequence will be taken into account automatically</i>	
<b>CT . IL1 min RMS</b>	[Operation / Statistics / Min / Current]
<input checked="" type="checkbox"/> <i>IL1 minimum value (RMS)</i>	
<b>CT . IL2 min RMS</b>	[Operation / Statistics / Min / Current]
<input checked="" type="checkbox"/> <i>IL2 minimum value (RMS)</i>	
<b>CT . IL3 min RMS</b>	[Operation / Statistics / Min / Current]
<input checked="" type="checkbox"/> <i>IL3 minimum value (RMS)</i>	
<b>CT . IG meas min RMS</b>	[Operation / Statistics / Min / Current]
<input checked="" type="checkbox"/> <i>Measured value: IG minimum value (RMS)</i>	
<b>CT . IG calc min RMS</b>	[Operation / Statistics / Min / Current]
<input checked="" type="checkbox"/> <i>Measured value (calculated):IG minimum value (RMS)</i>	
<b>CT . I1 min</b>	[Operation / Statistics / Min / Current]
<input checked="" type="checkbox"/> <i>Minimum value positive phase sequence current (fundamental)</i>	
<b>CT . I2 min</b>	[Operation / Statistics / Min / Current]
<input checked="" type="checkbox"/> <i>Minimum value unbalanced load current (fundamental)</i>	
<b>CT . %(I2/I1) min</b>	[Operation / Statistics / Min / Current]
<input checked="" type="checkbox"/> <i>Measured value (calculated): I2/I1 minimum value, phase sequence will be taken into account automatically</i>	

## 5 System

System

### 5.1 Sys: Global Parameters

<b>Sys . Scaling</b>		[Device Para / Measurment Display / General Settings]
Per unit values	Per unit values, Primary values, Secondary values	S.3
	↳ Scaling.	
	<i>Display of the measured values as primary, secondary or per unit values</i>	
<b>Sys . Ack via »C« key</b>		[Device Para / Acknowledge]
Ack LEDs w/o passw.	Nothing, Ack LEDs w/o passw., Ack LEDs, Ack LEDs and relays, Ack Everything	P.2
	↳ Ack via »C« key.	
	<i>Select which acknowledgeable elements can be reset via pressing the »C« key.</i>	
<b>Sys . Remote Reset</b>		[Device Para / Acknowledge]
active	inactive, active	P.2
	↳ Mode.	
	<i>Enables or disables the option to acknowledge from external/remote via signals (assignments) and SCADA.</i>	
<b>Sys . Ack LED</b>		[Device Para / Acknowledge]
"-"	"-" ... Sys . Internal test state	S.3
Only available if:	↳ 1..n, Assignment List.	
• Sys . Remote Reset = active		
	<i>All acknowledgeable LEDs will be acknowledged if the state of the assigned signal becomes true.</i>	

<b>Sys . Ack BO</b>		[Device Para / Acknowledge]
"_"	"_" ... Sys . Internal test state	S.3
<i>Only available if:</i> <ul style="list-style-type: none"> <li>Sys . Remote Reset = active</li> </ul>		↳ 1..n, Assignment List.
	<i>All acknowledgeable binary output relays will be acknowledged if the state of the assigned signal becomes true.</i>	


<b>Sys . Ack Scada</b>		[Device Para / Acknowledge]
"_"	"_" ... Sys . Internal test state	S.3
<i>Only available if:</i> <ul style="list-style-type: none"> <li>Sys . Remote Reset = active</li> </ul>		↳ 1..n, Assignment List.
	<i>Latched SCADA signals are acknowledged if the state of the assigned signal becomes true.</i>	


<b>Sys . Program Mode</b>		[Field Para / General Settings]
Either Motor Stopped or Running	Either Motor Stopped or Running, Motor Stop	P.2
		↳ .
	<i>Program Mode</i>	


<b>Sys . PSet-Switch</b>		[Protection Para / PSet-Switch]
PS1	PS1, PS2, PS3, PS4, PSS via Inp fct, PSS via Scada	P.2
		↳ PSet-Switch.
	<i>Switching Parameter Set</i>	


<b>Sys . PS1: activated by</b>		[Protection Para / PSet-Switch]
...		
<b>Sys . PS4: activated by</b>		
"_"	"_" ... Logics . LE80.Out inverted	P.2
		↳ 1..n, PSS.
	<i>This Setting Group will be the active one if: The Parameter Setting Group Switch is set to "Switch via Input" and the other three input functions are inactive at the same time. In case that there is more than one input function active, no Parameter Setting Group Switch will be executed. In case all input functions are inactive, the device will keep working with the Setting Group that was activated lastly.</i>	


## 5.2 Sys: Direct Controls


<b>Sys . Ack BO LED Scd TCmd</b>	[Operation / Reset/Acknowledge / Acknowledge]	
inactive	inactive, active  Mode.	P.1
<input checked="" type="radio"/> <i>Reset the binary output relays, LEDs, SCADA and the Trip Command.</i>		

<b>Sys . Ack LED</b>	[Operation / Reset/Acknowledge / Acknowledge]	
inactive	inactive, active  Mode.	P.1
<input checked="" type="radio"/> <i>All acknowledgeable LEDs will be acknowledged.</i>		

<b>Sys . Ack BO</b>	[Operation / Reset/Acknowledge / Acknowledge]	
inactive	inactive, active  Mode.	P.1
<input checked="" type="radio"/> <i>All acknowledgeable binary output relays will be acknowledged.</i>		

<b>Sys . Ack Scada</b>	[Operation / Reset/Acknowledge / Acknowledge]	
inactive	inactive, active  Mode.	P.1
<input checked="" type="radio"/> <i>Latched SCADA signals are acknowledged.</i>		

<b>Sys . Res OperationsCr</b>	[Operation / Reset/Acknowledge / History]	
inactive	inactive, active  Mode.	P.1
<input checked="" type="radio"/> <i>Reset all counters in history group operations</i>		

<b>Sys . Res AlarmCr</b>	[Operation / Reset/Acknowledge / History]	
inactive	inactive, active  Mode.	P.1
<input checked="" type="radio"/> <i>Reset all counters in history group alarms</i>		

<b>Sys . Res TripCmdCr</b>	[Operation / Reset/Acknowledge / History]	
inactive	inactive, active ↳ Mode.	P.1
☉ <i>Reset all counters in history group trips</i>		

<b>Sys . Res TotalCr</b>	[Operation / Reset/Acknowledge / History]	
inactive	inactive, active ↳ Mode.	P.1
☉ <i>Reset all counters in history group total</i>		

<b>Sys . Res All</b>	[Operation / Reset/Acknowledge / History]	
inactive	inactive, active ↳ Mode.	P.1
☉ <i>Reset of all Counters</i>		

<b>Sys . Setting Lock Bypass</b>	[Field Para / General Settings]	
inactive	inactive, active ↳ Mode.	P.1
☉ <i>Short-period unlock of the Setting Lock</i>		

<b>Sys . Reboot</b>	[Service / General]	
no	no, yes ↳ yes/no.	S.3
☉ <i>Rebooting the device.</i>		

### 5.3 Sys: Input States

<b>Sys . Ack LED-I</b>	[Operation / Status Display / Sys]	
↳ <i>Module input state: LEDs acknowledgement by digital input</i>		

<b>Sys . Ack BO-I</b>	[Operation / Status Display / Sys]	
↳ <i>Module input state: Acknowledgement of the binary Output Relays</i>		

Sys . <b>Ack Scada-I</b>	[Operation / Status Display / Sys]
↓	<i>Module input state: Acknowledge latched SCADA signals.</i>
Sys . <b>PS1-I</b>	[Operation / Status Display / Sys]
...	
Sys . <b>PS4-I</b>	
↓	<i>State of the module input respectively of the signal, that should activate this Parameter Setting Group.</i>

## 5.4 Sys: Signals (Output States)

Sys . <b>Reboot</b>	[Operation / Status Display / Sys]
↓	<i>Signal: Rebooting the device.</i>
	<i>Device Start-up Codes: 1=Normal Start-up; 2=Reboot by the Operator; 3=Reboot by means of Super Reset; 4=outdated; 5=outdated; 6=Unknown Error Source; 7=Forced Reboot (initiated by the main processor); 8=Exceeded Time Limit of the Protection Cycle; 9= Forced Reboot (initiated by the digital signal processor); 10=Exceeded Time Limit of the Measured Value Processing; 11=Sags of the Supply Voltage; 12=Illegal Memory Access.</i>
Sys . <b>Act Set</b>	[Operation / Status Display / Sys] [Protection Para / PSet-Switch]
↓	<i>Signal: Active Parameter Set</i>
Sys . <b>PS 1</b>	[Operation / Status Display / Sys]
↓	<i>Signal: The currently active Parameter Set is PS 1</i>
Sys . <b>PS 2</b>	[Operation / Status Display / Sys]
↓	<i>Signal: The currently active Parameter Set is PS 2</i>
Sys . <b>PS 3</b>	[Operation / Status Display / Sys]
↓	<i>Signal: The currently active Parameter Set is PS 3</i>
Sys . <b>PS 4</b>	[Operation / Status Display / Sys]
↓	<i>Signal: The currently active Parameter Set is PS 4</i>


Sys . <b>PSS manual</b>	[Operation / Status Display / Sys]
↑	<i>Signal: Manual Switch over of a Parameter Set</i>
Sys . <b>PSS via Scada</b>	[Operation / Status Display / Sys]
↑	<i>Signal: Parameter Set Switch via Scada. Write into this output byte the integer of the parameter set that should become active (e.g. 4 =&gt; Switch onto parameter set 4).</i>
Sys . <b>PSS via Inp fct</b>	[Operation / Status Display / Sys]
↑	<i>Signal: Parameter Set Switch via input function</i>
Sys . <b>min 1 param changed</b>	[Operation / Status Display / Sys]
↑	<i>Signal: At least one parameter has been changed</i>
Sys . <b>Setting Lock Bypass</b>	[Operation / Status Display / Sys]
↑	<i>Signal: Short-period unlock of the Setting Lock</i>
Sys . <b>Ack LED</b>	[Operation / Status Display / Sys]
↑	<i>Signal: LEDs acknowledgement</i>
Sys . <b>Ack BO</b>	[Operation / Status Display / Sys]
↑	<i>Signal: Acknowledgement of the Binary Outputs</i>
Sys . <b>Ack Scada</b>	[Operation / Status Display / Sys]
↑	<i>Signal: Acknowledge latched SCADA signals</i>
Sys . <b>Ack TripCmd</b>	[Operation / Status Display / Sys]
↑	<i>Signal: Reset Trip Command</i>
Sys . <b>Ack LED-HMI</b>	[Operation / Status Display / Sys]
↑	<i>Signal: LEDs acknowledgement :HMI</i>
Sys . <b>Ack BO-HMI</b>	[Operation / Status Display / Sys]
↑	<i>Signal: Acknowledgement of the Binary Outputs :HMI</i>
Sys . <b>Ack Scada-HMI</b>	[Operation / Status Display / Sys]
↑	<i>Signal: Acknowledge latched SCADA signals :HMI</i>






Sys . <b>Ack TripCmd-HMI</b>	[Operation / Status Display / Sys]
⤴	<i>Signal: Reset Trip Command :HMI</i>
Sys . <b>Ack LED-Sca</b>	[Operation / Status Display / Sys]
⤴	<i>Signal: LEDs acknowledgement :SCADA</i>
Sys . <b>Ack BO-Sca</b>	[Operation / Status Display / Sys]
⤴	<i>Signal: Acknowledgement of the Binary Outputs :SCADA</i>
Sys . <b>Ack Counter-Sca</b>	[Operation / Status Display / Sys]
⤴	<i>Signal: Reset of all Counters :SCADA</i>
Sys . <b>Ack Scada-Sca</b>	[Operation / Status Display / Sys]
⤴	<i>Signal: Acknowledge latched SCADA signals :SCADA</i>
Sys . <b>Ack TripCmd-Sca</b>	[Operation / Status Display / Sys]
⤴	<i>Signal: Reset Trip Command :SCADA</i>
Sys . <b>Res OperationsCr</b>	[Operation / Status Display / Sys]
⤴	<i>Signal:: Res OperationsCr</i>
Sys . <b>Res AlarmCr</b>	[Operation / Status Display / Sys]
⤴	<i>Signal:: Res AlarmCr</i>
Sys . <b>Res TripCmdCr</b>	[Operation / Status Display / Sys]
⤴	<i>Signal:: Res TripCmdCr</i>
Sys . <b>Res TotalCr</b>	[Operation / Status Display / Sys]
⤴	<i>Signal:: Res TotalCr</i>


## 5.5 Sys: Values


Sys . <b>Hours Counter</b>	[Operation / History / TotalCr]
🔗	<i>Hours Counter</i>


<b>Sys . Operating hours Cr</b>	[Operation / Count and RevData / Sys]
 <i>Operating hours counter of the protective device</i>	


<b>Sys . DM version</b>	[Device Para / Version]
3.6.b	3.6.b 
 <i>Version of the device model</i>	


<b>Sys . SW version</b>	[Device Para / Version]
 <i>Version of the device firmware</i>	

<b>Sys . Build</b>	[Device Para / Version]
 <i>Build Number</i>	

<b>Sys . CAT No</b>	[Device Para / Version]
 <i>»CAT No.«, Order Code as printed on the nameplate of the device.</i>	

<b>Sys . REV.</b>	[Device Para / Version]
 <i>Revision (as printed on the nameplate of the device).</i>	




<b>Sys . S/N</b>	[Device Para / Version]
 <i>The serial number of the device.</i>	

<b>Sys . Bootloader Build</b>	[Device Para / Version]
 <i>Build number of the bootloader</i>	

## 6 Measured Values


- HMI: ↪ "HMI: Values"
- CT: ↪ "CT: Values"
- System: ↪ "Sys: Values"
- Modbus: ↪ "Modbus: Values"
- IEC 61850: ↪ "IEC 61850: Values"
- IEC104: ↪ "IEC104: Values"
- Profibus: ↪ "Profibus: Values"
- SNTP: ↪ "SNTP: Values"
- MStart: ↪ "MStart: Values"
- URTD: ↪ "URTD: Values"
- Control: ↪ "Ctrl: Values"
- Breaker Wear: ↪ "SG[1]: Values"
- Disturb rec: ↪ "Disturb rec: Values"
- Sgen: ↪ "Sgen: Values"


## 7 Statistics


- CT:  "CT: Statistical Values"
- MStart:  "MStart: Statistical Values"
- URTD:  "URTD: Statistical Values"

### 7.1 Statistics: Global Parameters


Statistics . <b>Start I Demand via:</b>		[Device Para / Statistics / Demand / Current Demand]
Duration	Duration, StartFct	S.3
	 Duration.	
	<i>Start Current demand by:</i>	
Statistics . <b>Start I Demand Fc</b>		[Device Para / Statistics / Demand / Current Demand]
"_"	"_" ... Sys . Internal test state	S.3
<i>Only available if:</i>	 1..n, Assignment List.	
<ul style="list-style-type: none"> <li>• Statistics . Start I Demand via: = StartFct</li> </ul>		
	<i>Start of the calculation, if the assigned signal becomes true.</i>	
Statistics . <b>ResFc I Demand</b>		[Device Para / Statistics / Demand / Current Demand]
"_"	"_" ... Sys . Internal test state	S.3
	 1..n, Assignment List.	
	<i>Resetting of Statistics - Current Demand (avg, peak avg)</i>	
Statistics . <b>Duration I Demand</b>		[Device Para / Statistics / Demand / Current Demand]
15 s	2 s ... 30 d	S.3
<i>Only available if:</i>	 Duration.	
<ul style="list-style-type: none"> <li>• Statistics . Start I Demand via: = Duration</li> </ul>		
	<i>Recording time</i>	


Statistics . <b>Window I Demand</b>		[Device Para / Statistics / Demand / Current Demand]
sliding	sliding, fixed	S.3
	↳ Window configuration.	
	<i>Window configuration</i>	


Statistics . <b>ResFc Max</b>		[Device Para / Statistics / Min / Max]
"_"	"_" ... Sys . Internal test state	S.3
	↳ 1..n, Assignment List.	
	<i>Resetting of all Maximum values</i>	



Statistics . <b>ResFc Min</b>		[Device Para / Statistics / Min / Max]
"_"	"_" ... Sys . Internal test state	S.3
	↳ 1..n, Assignment List.	
	<i>Resetting of all Minimum values</i>	

## 7.2 Statistics: Direct Controls


Statistics . <b>ResFc all</b>		[Operation / Reset/Acknowledge / Reset]
inactive	inactive, active	P.1
	↳ Mode.	
	<i>Resetting of all Statistic values (Current Demand, Power Demand, Min, Max)</i>	

Statistics . <b>ResFc Max</b>		[Operation / Reset/Acknowledge / Reset]
inactive	inactive, active	P.1
	↳ Mode.	
	<i>Resetting of all Maximum values</i>	


Statistics . <b>ResFc Min</b>		[Operation / Reset/Acknowledge / Reset]
inactive	inactive, active	P.1
	↳ Mode.	
	<i>Resetting of all Minimum values</i>	


Statistics . <b>ResFc I Demand</b>	[Operation / Reset/Acknowledge / Reset]	
inactive	inactive, active  Mode.	P.1
 <i>Resetting of Statistics - Current Demand (avg, peak avg)</i>		


### 7.3 Statistics: Input States


Statistics . <b>StartFc I Demand-I</b>	[Operation / Status Display / Statistics]
 <i>State of the module input: Start of the Statistics of the Current Demand</i>	

### 7.4 Statistics: Signals (Output States)


Statistics . <b>ResFc all</b>	[Operation / Status Display / Statistics]
 <i>Signal: Resetting of all Statistic values (Current Demand, Power Demand, Min, Max)</i>	


Statistics . <b>ResFc I Demand</b>	[Operation / Status Display / Statistics]
 <i>Signal: Resetting of Statistics - Current Demand (avg, peak avg)</i>	

Statistics . <b>ResFc Max</b>	[Operation / Status Display / Statistics]
 <i>Signal: Resetting of all Maximum values</i>	

Statistics . <b>ResFc Min</b>	[Operation / Status Display / Statistics]
 <i>Signal: Resetting of all Minimum values</i>	

### 7.5 Statistics: Counters

Statistics . <b>Res Cr I Demand</b>	[Operation / Statistics / Demand / Current Demand]
 <i>Number of resets since last booting. The timestamp shows date and time of the last reset.</i>	

Statistics . <b>Res Cr Max values</b>	[Operation / Statistics / Max / Current] [Operation / Statistics / Max / URTD]
 <i>Number of resets since last booting. The timestamp shows date and time of the last reset.</i>	

**Statistics . Res Cr Min values**



[Operation / Statistics / Min / Current]

# *Number of resets since last booting. The timestamp shows date and time of the last reset.*



## 8 Communication

Scada

### 8.1 Scada: Device Planning Parameters

Scada . <b>Protocol</b>	[Device planning]	
"_"	"-" ... Profibus  Used Protocol.	S.3
	<i>Select the SCADA protocol to be used.</i>	


### 8.2 Scada: Signals (Output States)

Scada . <b>SCADA connected</b>	[Operation / Status Display / Scada]
	<i>At least one SCADA System is connected to the device.</i>
Scada . <b>SCADA not connected</b>	[Operation / Status Display / Scada]
	<i>No SCADA System is connected to the device</i>





## 8.3 Tcplp


### Tcplp

<b>TCP/IP config</b>	[Device Para / TCP/IP / TCP/IP config]
	This item represents a special dialog. (See the Technical Manual for details.) <i>configuration of the TCP/IP protocol</i>

### 8.3.1 Tcplp: Global Parameters

<b>Tcplp . Keep Alive Time</b>	[Device Para / TCP/IP / Advanced Settings]
720s	1s ... 7200s S.3
	<i>Keep Alive Time is the duration between two keep alive transmissions in idle condition</i>


<b>Tcplp . Keep Alive Interval</b>	[Device Para / TCP/IP / Advanced Settings]
15s	1s ... 60s S.3
	<i>Keep Alive Interval is the duration between two successive keep alive retransmissions, if the acknowledgement to the previous keepalive transmission was not received.</i>


<b>Tcplp . Keep Alive Retry</b>	[Device Para / TCP/IP / Advanced Settings]
3	3 ... 3 S.3
	<i>Keep alive retry is the number of retransmissions to be carried out before declaring that the remote end is not available.</i>


## 8.4 DNP3

Distributed Network Protocol


### 8.4.1 DNP3: Global Parameters



DNP3 . <b>Function</b>	[Device Para / DNP3 / Communication]	
inactive	inactive, active ↳ Mode.	S.3
 <i>Permanent activation or deactivation of module/stage.</i>		



DNP3 . <b>IP Port Number</b>	[Device Para / DNP3 / Communication]	
20000	0 ... 65535	S.3
 <i>IP Port Number.</i>  <i>In general it is recommended to keep the default value. If this is not possible then select a number out of the private range 49152-52151 or 52164-65535 that is not yet in use within your network.</i>		


DNP3 . <b>Baud rate</b>	[Device Para / DNP3 / Communication]	
19200	1200 ... 115200 ↳ Baud rate.	S.3
 <i>Baud rate for communication</i>		


DNP3 . <b>Frame Layout</b>	[Device Para / DNP3 / Communication]	
8E1	8E1, 8O1, 8N1, 8N2 ↳ Byte Frame.	S.3
 <i>Frame Layout</i>		



DNP3 . <b>Optical rest position</b>	[Device Para / DNP3 / Communication]	
Light on <i>Avail. depends on HW</i>	Light off, Light on ↳ Optical rest position.	S.3
 <i>Optical rest position</i>		


<b>DNP3 . SelfAddress</b>	[Device Para / DNP3 / Communication]	
inactive	inactive, active  Mode.	S.3
	<i>Support of self (automatic) addresses</i>	


<b>DNP3 . DataLink confirm</b>	[Device Para / DNP3 / Communication]	
Never	Never, Always, On_Large  Communication Start Variants.	S.3
	<i>Enables or disables the data layer confirmation (ack).</i>	








<b>DNP3 . t-DataLink confirm</b>	[Device Para / DNP3 / Communication]	
1s	0.1s ... 10.0s	S.3
	<i>Data layer confirmation timeout</i>	



<b>DNP3 . DataLink num retries</b>	[Device Para / DNP3 / Communication]	
3	0 ... 255	S.3
	<i>Number of repetition of data link packet sending after failing</i>	


<b>DNP3 . Direction Bit</b>	[Device Para / DNP3 / Communication]	
inactive	inactive, active  Mode.	S.3
	<i>Enables Direction Bit functionality. The Direction Bit is 0 for SlaveStation and 1 for MasterStation</i>	



<b>DNP3 . Max Frame Size</b>	[Device Para / DNP3 / Communication]	
255	64 ... 255	S.3
	<i>This value is used to limit the net Frame Size</i>	


<b>DNP3 . Test Link Period</b>	[Device Para / DNP3 / Communication]	
0s	0.0s ... 120.0s	S.3
	<i>This value specifies the time period when to send a Test Link-Frame</i>	



<b>DNP3 . AppLink confirm</b>		[Device Para / DNP3 / Communication]
Always	Never, Always, Event	S.3
	↳ <code>_AL_ResponseType_k</code> .	
	<i>Determines if the device will request that the Application Layer response be confirmed or not</i>	
<b>DNP3 . t-AppLink confirm</b>		[Device Para / DNP3 / Communication]
5s	0.1s ... 10.0s	S.3
	<i>Application layer response timeout</i>	
<b>DNP3 . AppLink num retries</b>		[Device Para / DNP3 / Communication]
0	0 ... 255	S.3
	<i>The number of times the device will retransmit an Application Layer fragment</i>	
<b>DNP3 . Unsol Reporting</b>		[Device Para / DNP3 / Communication]
inactive	inactive, active	S.3
	↳ <code>Mode</code> .	
	<i>Enables unsolicited reporting. This is available only for DNP3 TCP connections, and for DNP3 RTU in case of a peer-to-peer connection.</i>	
<b>DNP3 . Unsol Reporting Timeout</b>		[Device Para / DNP3 / Communication]
10s	1.0s ... 60.0s	S.3
	<i>Set the amount of time that the outstation will wait for an Application Layer confirmation back from the master indicating that the master received the unsolicited response message.</i>	
<b>DNP3 . Unsol Reporting Retry</b>		[Device Para / DNP3 / Communication]
2	0 ... 255	S.3
	<i>Set the number of retries that an outstation transmits in each unsolicited response series if it does not receive confirmation back from the master.</i>	
<b>DNP3 . TestSeqNo</b>		[Device Para / DNP3 / Communication]
inactive	inactive, active	S.3
	↳ <code>Mode</code> .	
	<i>Test if sequence number of request is incremented. If it is not correctly incremented the request will be ignored. It is recommended to have it inactive but some older DNP implementations need it activated.</i>	


<b>DNP3 . TestSBO</b>		[Device Para / DNP3 / Communication]	
active	inactive, active		S.3
	 Mode.		
	<i>It enables a stricter comparing of SBO and operate command. For older DNP versions it is recommended to deactivated it.</i>		


<b>DNP3 . Timeout SBO</b>		[Device Para / DNP3 / Communication]	
30s	1.0s ... 60.0s		S.3
	<i>DNP Outputs can be controlled in a two stage procedure (SBO: Select Before Operate). These outputs are to be selected first by a Select command. After this the bit is reserved for this Operate request. This setting defines the timer for this reservation: After the timer has elapsed the bit is released.</i>		


<b>DNP3 . ColdRestart</b>		[Device Para / DNP3 / Communication]	
inactive	inactive, active		S.3
	 Mode.		
	<i>Enables support for Cold Restart function.</i>		


<b>DNP3 . Deadb integr time</b>		[Device Para / DNP3 / Communication]	
1	0 ... 300		S.3
	<i>Deadband integration time.</i>		


<b>DNP3 . BinaryInput 0</b>		[Device Para / DNP3 / Point map / Binary Inputs]	
...			
<b>DNP3 . BinaryInput 63</b>			
"_"	"_" ... Sys . Internal test state		S.3
	 1..n, Assignment List.		
	<i>Virtual Digital Input (DNP). This corresponds to a virtual binary output of the protective device.</i>		

DNP3 . <b>DoubleBitInput 0</b>	[Device Para / DNP3 / Point map / Double Bit Inputs]	
...		
DNP3 . <b>DoubleBitInput 5</b>		
"_"	"-", SG[1] . Pos  ↳ 1..n, Assignment List.	S.3
	<i>Double Bit Digital Input (DNP). This corresponds to a double bit binary output of the protective device.</i>	



DNP3 . <b>BinaryCounter 0</b>	[Device Para / DNP3 / Point map / BinaryCounter]	
...		
DNP3 . <b>BinaryCounter 7</b>		
"_"	"-" ... Sys . Hours Counter  ↳ 1..n, Assignment List.	S.3
	<i>Counter can be used to report counter values to the DNP master.</i>	


DNP3 . <b>Analog value 0</b>	[Device Para / DNP3 / Point map / Analog Input]	
...		
DNP3 . <b>Analog value 31</b>		
"_"	"-" ... RTD . Hottest Aux Temp  ↳ 1..n, TrendReclList.	S.3
	<i>Analog value can be used to report values to the master (DNP)</i>	


DNP3 . <b>Scale Factor 0</b>	[Device Para / DNP3 / Point map / Analog Input]	
...		
DNP3 . <b>Scale Factor 31</b>		
1	0.001 ... 1000000  ↳ Scale Factor.	S.3
	<i>The scale factor is used to convert the measured value in an integer format</i>	

DNP3 . <b>Dead Band 0</b>	[Device Para / DNP3 / Point map / Analog Input]	
...		
DNP3 . <b>Dead Band 31</b>		
1%	0.01% ... 100.00%	S.3
	<i>If a change of measured value is greater than the deadband value it will be reported to the master.</i>	


## 8.4.2 DNP3: Direct Controls

DNP3 . <b>Res all Diag Cr</b>	[Operation / Count and RevData / DNP3] [Operation / Reset/Acknowledge / Reset]	
inactive	inactive, active  Mode.	S.3
	<i>Reset all diagnosis counters</i>	

DNP3 . <b>Slave Id</b>	[Device Para / DNP3 / Communication]	
1	0 ... 65519	S.3
	<i>SlaveId defines the DNP3 address of this device (Outstation)</i>	

DNP3 . <b>Master Id</b>	[Device Para / DNP3 / Communication]	
65500	0 ... 65519	S.3
	<i>MasterId defines the DNP3 address of master (SCADA)</i>	

## 8.4.3 DNP3: Input States

DNP3 . <b>BinaryInput0-I</b>	[Operation / Status Display / DNP3 / Binary Inputs]	
...		
DNP3 . <b>BinaryInput63-I</b>		
	<i>Virtual Digital Input (DNP). This corresponds to a virtual binary output of the protective device.</i>	

DNP3 . <b>DoubleBitInput0-I</b>	[Operation / Status Display / DNP3 / Double Bit Inputs]
...	
DNP3 . <b>DoubleBitInput5-I</b>	
↓	<i>Double Bit Digital Input (DNP). This corresponds to a double bit binary output of the protective device.</i>

### 8.4.4 DNP3: Signals (Output States)

DNP3 . <b>busy</b>	[Operation / Status Display / DNP3 / State]
↓	<i>This message is set if the protocol is started. It will be reset if the protocol is shut down.</i>

DNP3 . <b>ready</b>	[Operation / Status Display / DNP3 / State]
↓	<i>The message will be set if the protocol is successfully started and ready for data exchange.</i>

DNP3 . <b>active</b>	[Operation / Status Display / DNP3 / State]
↓	<i>The communication with the Master (SCADA) is active.</i>
	<i>Note that for TCP/UDP, this state is permanently “Low” unless »DataLink confirm« is set to “Always”.</i>

### 8.4.5 DNP3: Counters

DNP3 . <b>NReceived</b>	[Operation / Count and RevData / DNP3]
#	<i>Diagnostic counter: Number of received characters</i>

DNP3 . <b>NSent</b>	[Operation / Count and RevData / DNP3]
#	<i>Diagnostic counter: Number of sent characters</i>

DNP3 . <b>NBadFramings</b>	[Operation / Count and RevData / DNP3]
#	<i>Diagnostic counter: Number of bad framings. A large number indicates a disturbed serial connection.</i>

DNP3 . <b>NBadParities</b>	[Operation / Count and RevData / DNP3]
#	<i>Diagnostic counter: Number of parity errors. A large number indicates a disturbed serial connection.</i>



**DNP3 . NBreakSignals**

[Operation / Count and RevData / DNP3]

# *Diagnostic counter: Number of break signals. A large number indicates a disturbed serial connection.*

**DNP3 . NBadChecksum**


[Operation / Count and RevData / DNP3]



# *Diagnostic counter: Number of frames received with bad checksum.*



## 8.5 Modbus



Modbus



### 8.5.1 Modbus: Global Parameters


<b>Modbus . t-call</b>	[Device Para / Modbus / Communication / General Settings]	
10s	1s ... 3600s	S.3
	<i>If there is no request telegram sent from Scada to the device after expiry of this time - the device concludes a communication failure within the Scada system.</i>	


<b>Modbus . Scada CmdBlo</b>	[Device Para / Modbus / Communication / General Settings]	
inactive	inactive, active	S.3
	 Mode.	
	<i>Activating (allowing)/ Deactivating (disallowing) the blocking of the Scada Commands</i>	


<b>Modbus . Disable Latching</b>	[Device Para / Modbus / Communication / General Settings]	
inactive	inactive, active	S.3
	 Mode.	
	<i>Disable Latching: If this parameter is active (true), none of the Modbus states will be latched. That means that trip signals wont be latched by Modbus.</i>	


<b>Modbus . AllowGap</b>	[Device Para / Modbus / Communication / General Settings]	
inactive	inactive, active	S.3
	 Mode.	
	<i>If this parameter is active (True), the user can request a set of modbus register without getting an exception, because of invalid address in the requested array. The invalid addresses have a special value 0xFAFA, but the user is responsible for ignoring invalid addresses. Attention: This special value can be valid, if address is valid.</i>	


<b>Modbus . Optical rest position</b>	[Device Para / Modbus / Communication / General Settings]	
Light on	Light off, Light on	S.3
Avail. depends on HW	 Optical rest position.	
	<i>Optical rest position</i>	


<b>Modbus . TCP Port Config</b>		[Device Para / Modbus / Communication / TCP]
Default	Default, Private	S.3
	↳ Port selection.	
	<i>TCP Port Configuration. This parameter needs to be set to "Private" only if another TCP Port than the default one shall be used.</i>	


<b>Modbus . Port</b>		[Device Para / Modbus / Communication / TCP]
502	If: Modbus . TCP Port Config = Default • 502 ... 502  If: Modbus . TCP Port Config = Private • 49152 ... 65535	S.3
	<i>IP Port Number.  In general it is recommended to keep the default value. if this is not possible then select a number out of the private range 49152-52151 or 52164-65535 that is not yet in use within your network.</i>	


<b>Modbus . t-timeout</b>		[Device Para / Modbus / Communication / RTU]
1s	0.01s ... 10.00s	S.3
	<i>Within this time the answer has to be received by the SCADA system, otherwise the request will be disregarded. In that case the Scada system detects a communication failure and the Scada System has to send a new request.</i>	


<b>Modbus . Baud rate</b>		[Device Para / Modbus / Communication / RTU]
19200	1200, 2400, 4800, 9600, 19200, 38400	S.3
	↳ Baud rate.	
	<i>Baud rate</i>	

<b>Modbus . Physical Settings</b>		[Device Para / Modbus / Communication / RTU]
8E1	8E1, 8O1, 8N1, 8N2	S.3
	↳ Byte Frame.	
	<i>Digit 1: Number of bits. Digit 2: E=even parity, O=odd parity, N=no parity. Digit 3: Number of stop bits. More information on the parity: It is possible that the last data bit is followed by a parity bit which is used for recognition of communication errors. The parity bit ensures that with even parity ("EVEN") always an even number of bits with valence "1" or with odd parity ("ODD") an odd number of "1" valence bits are transmitted. But it is also possible to transmit no parity bits (here the setting is "Parity = None"). More information on the stop-bits: The end of a data byte is terminated by the stop-bits.</i>	


Modbus . <b>Config Bin Inp1</b> ... Modbus . <b>Config Bin Inp32</b>	[Device Para / Modbus / Configb Registers / States]	
"-"	"-" ... Sys . Internal test state ↳ 1..n, Assignment List.	S.3
 <i>Virtual Digital Input. This corresponds to a virtual binary output of the protective device.</i>		

Modbus . <b>Latched Config Bin Inp1</b> ... Modbus . <b>Latched Config Bin Inp32</b>	[Device Para / Modbus / Configb Registers / States]	
inactive	inactive, active ↳ Mode.	S.3
 <i>Latched Configurable Binary Input</i>		

Modbus . <b>Mapped Meas 1</b> ... Modbus . <b>Mapped Meas 16</b>	[Device Para / Modbus / Configb Registers / Measured Values]	
"-"	"-" ... RTD . Hottest Aux Temp ↳ 1..n, TrendReclList.	S.3
 <i>Mapped Measured Values. They can be used to provide measured values to the Modbus Master.</i>		

Modbus . <b>Type of SCADA mapping</b>	[Device Para / Modbus / Config. Data Obj.]	
Standard	Standard, User-defined ↳ Type of SCADA mapping.	S.3
 <i>This setting decides whether the communication protocol shall use the default mapping of data objects, or some user-defined mapping that has been loaded from a *.HptSMap file.</i>		

### 8.5.2 Modbus: Direct Controls

Modbus . <b>Res Diagn Cr</b>	[Operation / Reset/Acknowledge / Reset]	
inactive	inactive, active  Mode.	P.1
<p>☉ All Modbus Diagnosis Counters will be reset.</p>		

Modbus . <b>Unit ID</b>	[Device Para / Modbus / Communication / TCP]	
255	1 ... 255	P.1
<p>☉ The Unit Identifier is used for routing. This parameter is to be set, if a Modbus RTU and a Modbus TCP network should be coupled.</p>		

Modbus . <b>Slave ID</b>	[Device Para / Modbus / Communication / RTU]	
1	1 ... 247	P.1
<p>☉ Device address (Slave ID) within the bus system. Each device address has to be unique within a bus system.</p>		

### 8.5.3 Modbus: Input States

Modbus . <b>Config Bin Inp1-I</b>	[Operation / Status Display / Modbus / Config Registers]	
...		
Modbus . <b>Config Bin Inp32-I</b>		
<p>↓ State of the module input: Config Bin Inp</p>		

### 8.5.4 Modbus: Signals (Output States)

Modbus . <b>Transmission RTU</b>	[Operation / Status Display / Modbus / State]	
<p>↑ Signal: SCADA active</p>		
Modbus . <b>Transmission TCP</b>	[Operation / Status Display / Modbus / State]	
<p>↑ Signal: SCADA active</p>		

Modbus . <b>Device Type</b>		[Operation / Status Display / Modbus / State]
↑	<i>Device Type: Device type code for relationship between device name and its Modbus code.</i>	
	<i>Woodward:</i>	
	<i>MRI4 - 1000</i>	
	<i>MRU4 - 1001</i>	
	<i>MRA4 - 1002</i>	
	<i>MCA4 - 1003</i>	
	<i>MRDT4 - 1005</i>	
	<i>MCDTV4 - 1006</i>	
	<i>MCDGV4 - 1007</i>	
	<i>MRM4 - 1009</i>	
	<i>MRMV4 - 1010</i>	
	<i>MCDLV4 - 1011</i>	


Modbus . <b>Comm Version</b>		[Operation / Status Display / Modbus / State]
↑	<i>Modbus Communication version. This version number changes if something becomes incompatible between different Modbus releases.</i>	



Modbus . <b>Scada Cmd 1</b>		[Operation / Status Display / Modbus / Commands]
	...	
Modbus . <b>Scada Cmd 16</b>		
↑	<i>Scada Command</i>	

### 8.5.5 Modbus: Values


Modbus . <b>Mapped Meas 1</b>		[Operation / Count and RevData / Modbus / Measured Values]
	...	
Modbus . <b>Mapped Meas 16</b>		
✎	<i>Mapped Measured Values. They can be used to provide measured values to the Modbus Master.</i>	


Modbus . <b>Config info</b>		[Device Para / Modbus / Config. Data Obj.]
✎	<i>Configuration comment (entered by the user during SCADA configuration)</i>	


Modbus . <b>Config version</b>	[Device Para / Modbus / Config. Data Obj.]
 <i>Version of the user-defined SCADA configuration</i>	


Modbus . <b>Config status</b>	[Device Para / Modbus / Config. Data Obj.]
Changing	Changing, OK, Config. not avail., Error  <b>Config status.</b>
 <i>Status of the user-defined SCADA configuration.</i>	
<i>Possible values:</i>	
- New SCADA configuration is being loaded, but not active yet.	
- The SCADA configuration is active.	
- The user-defined SCADA configuration is not available (e.g. has not been loaded into the device).	
- Unexpected error. Please contact our service-team.	


### 8.5.6 Modbus: Counters

Modbus . <b>NoOfRequestsTotal</b>	[Operation / Count and RevData / Modbus / TCP] [Operation / Count and RevData / Modbus / RTU]
 <i>Total number of requests. Includes requests for other slaves.</i>	

Modbus . <b>NoOfRequestsForMe</b>	[Operation / Count and RevData / Modbus / TCP] [Operation / Count and RevData / Modbus / RTU]
 <i>Total Number of requests for this slave.</i>	

Modbus . <b>NoOfResponse</b>	[Operation / Count and RevData / Modbus / TCP] [Operation / Count and RevData / Modbus / RTU]
 <i>Total number of requests having been responded.</i>	

Modbus . <b>NoOfQueryInvalid</b>	[Operation / Count and RevData / Modbus / TCP]
 <i>Total number of Request errors. Request could not be interpreted</i>	

Modbus . <b>NoOfInternalError</b>	[Operation / Count and RevData / Modbus / TCP]
 <i>Total Number of Internal errors while interpreting the request.</i>	



Modbus . <b>NoOfFrameErrors</b>	[Operation / Count and RevData / Modbus / RTU]
#	<i>Total Number of Frame Errors. Physically corrupted Frame.</i>
Modbus . <b>NoOfParityErrors</b>	[Operation / Count and RevData / Modbus / RTU]
#	<i>Total number of parity errors. Physically corrupted Frame.</i>
Modbus . <b>NoOfResponseTimeOverruns</b>	[Operation / Count and RevData / Modbus / RTU]
#	<i>Total number of requests with exceeded response time. Physically corrupted Frame.</i>
Modbus . <b>NoOfOverrunErrors</b>	[Operation / Count and RevData / Modbus / RTU]
#	<i>Total Number of Overrun Failures. Physically corrupted Frame.</i>
Modbus . <b>NoOfBreaks</b>	[Operation / Count and RevData / Modbus / RTU]
#	<i>Number of detected communication aborts</i>




## 8.6 IEC 61850



IEC 61850 communication

### 8.6.1 IEC 61850: Global Parameters


IEC 61850 . <b>Function</b>	[Device Para / IEC 61850 / Communication]	
inactive	inactive, active  1..n, OnOffList.	S.3
	<i>Permanent activation or deactivation of module/stage.</i>	


IEC 61850 . <b>Deadb integr time</b>	[Device Para / IEC 61850 / Communication]	
0	0 ... 300	S.3
	<i>Deadband integration time.</i>	


### 8.6.2 IEC 61850: Direct Controls


IEC 61850 . <b>ResetStatistic</b>	[Operation / Reset/Acknowledge / Reset]	
inactive	inactive, active  Mode.	P.1
	<i>Reset of all IEC61850 diagnostic counters</i>	


### 8.6.3 IEC 61850: Signals (Output States)

IEC 61850 . <b>MMS Client connected</b>	[Operation / Status Display / IEC 61850 / State]	
	<i>At least one MMS client is connected to the device</i>	



IEC 61850 . <b>All Goose Subscriber active</b>	[Operation / Status Display / IEC 61850 / State]	
	<i>All Goose subscriber in the device are working</i>	



IEC 61850 . <b>SPCSO1</b> ... IEC 61850 . <b>SPCSO32</b>	[Operation / Status Display / IEC 61850 / ControllInputs]	
	<i>Status bit that can be set by clients like e.g. SCADA (Single Point Controllable Status Output).</i>	



IEC 61850 . <b>GOSINGGIO1.Ind1.stVal</b>	[Operation / Status Display / IEC 61850 / Virtual Inputs 1]
...	[Operation / Status Display / IEC 61850 / Virtual Inputs 2]
IEC 61850 . <b>GOSINGGIO2.Ind32.stVal</b>	
 <i>Signal: Virtual Input (IEC61850 GGIO Ind): State</i>	

IEC 61850 . <b>GOSINGGIO1.Ind1.q</b>	[Operation / Status Display / IEC 61850 / Virtual Inputs 1]
...	[Operation / Status Display / IEC 61850 / Virtual Inputs 2]
IEC 61850 . <b>GOSINGGIO2.Ind32.q</b>	
 <i>Signal: Virtual Input (IEC61850 GGIO Ind): Self-Supervision of the GGIO Input</i>	

### 8.6.4 IEC 61850: Values

IEC 61850 . <b>GoosePublisherState</b>	[Operation / Status Display / IEC 61850 / State]
Off	Off, On, Error  State.
 <i>State of the GOOSE Publisher (on or off)</i>	

IEC 61850 . <b>GooseSubscriberState</b>	[Operation / Status Display / IEC 61850 / State]
Off	Off, On, Error  State.
 <i>State of the GOOSE Subscriber (on or off)</i>	

IEC 61850 . <b>MmsServerState</b>	[Operation / Status Display / IEC 61850 / State]
Off	Off, On, Error  State.
 <i>State of MMS Server (on or off)</i>	

## 8.6.5 IEC 61850: Counters

IEC 61850 . <b>NoOfGooseRxAll</b>	[Operation / Count and RevData / IEC 61850]
#	<i>Total number of received GOOSE messages including messages for other devices (subscribed and not subscribed messages).</i>
IEC 61850 . <b>NoOfGooseRxSubscribed</b>	[Operation / Count and RevData / IEC 61850]
#	<i>Total Number of subscribed GOOSE messages including messages with incorrect content.</i>
IEC 61850 . <b>NoOfGooseRxCorrect</b>	[Operation / Count and RevData / IEC 61850]
#	<i>Total Number of subscribed and correctly received GOOSE messages.</i>
IEC 61850 . <b>NoOfGooseRxNew</b>	[Operation / Count and RevData / IEC 61850]
#	<i>Number of subscribed and correctly received GOOSE messages with new content.</i>
IEC 61850 . <b>NoOfGooseTxAll</b>	[Operation / Count and RevData / IEC 61850]
#	<i>Total Number of GOOSE messages that have been published by this device.</i>
IEC 61850 . <b>NoOfGooseTxNew</b>	[Operation / Count and RevData / IEC 61850]
#	<i>Total Number of new GOOSE messages (modified content) that have been published by this device.</i>
IEC 61850 . <b>NoOfServerRequestsAll</b>	[Operation / Count and RevData / IEC 61850]
#	<i>Total number of MMS Server requests including incorrect requests.</i>
IEC 61850 . <b>NoOfDataReadAll</b>	[Operation / Count and RevData / IEC 61850]
#	<i>Total Number of values read from this device including incorrect requests.</i>
IEC 61850 . <b>NoOfDataReadCorrect</b>	[Operation / Count and RevData / IEC 61850]
#	<i>Total Number of correctly read values from this device.</i>
IEC 61850 . <b>NoOfDataWrittenAll</b>	[Operation / Count and RevData / IEC 61850]
#	<i>Total Number of values written by this device including incorrect ones.</i>

IEC 61850 . <b>NoOfDataWrittenCorrect</b>	[Operation / Count and RevData / IEC 61850]
--	---

#	<i>Total Number of correctly written values by this device.</i>
---	---

IEC 61850 . <b>NoOfDataChangeNotification</b>	[Operation / Count and RevData / IEC 61850]
--	---

#	<i>Number of detected changes within the datasets that are published with GOOSE messages.</i>
---	---



IEC 61850 . <b>No of Client Connections</b>	[Operation / Count and RevData / IEC 61850]
---	---

#	<i>Number of active MMS client connections</i>
---	--


## 8.6.6 IEC 61850 - Virt.Outp.

IEC 61850 communication

### 8.6.6.1 IEC 61850: Global Parameters

IEC 61850 . <b>COU<sub>T</sub>GGIO1.Ind1.stVal</b> ... IEC 61850 . <b>COU<sub>T</sub>GGIO1.Ind32.stVal</b>	[Device Para / IEC 61850 / Virtual Outputs 1]	
“-”	“-” ... Sys . Internal test state  1..n, Assignment List.	S.3
 <i>Virtual Output. This signal can be assigned or visualized via the SCD file to other devices within the IEC61850 substation.</i>		



### 8.6.6.2 IEC 61850: Input States


IEC 61850 . <b>COU<sub>T</sub>GGIO1.Ind1.stVal-I</b> ... IEC 61850 . <b>COU<sub>T</sub>GGIO1.Ind32.stVal-I</b>	[Operation / Status Display / IEC 61850 / Virtual Outputs 1]	
 <i>Module input state: Binary state of the Virtual Output (GGIO)</i>		



## 8.7 IEC103



IEC 60870-5-103 communication


### 8.7.1 IEC103: Global Parameters


IEC103 . <b>Function</b>	[Device Para / IEC103]	
inactive	inactive, active  Mode.	S.3
 <i>Activation or deactivation of the IEC103 communication.</i>		


IEC103 . <b>Slave ID</b>	[Device Para / IEC103]	
1	1 ... 247	S.3
 <i>Device address (Slave ID) within the bus system. Each device address has to be unique within a bus system.</i>		


IEC103 . <b>Baud rate</b>	[Device Para / IEC103]	
19200	1200, 2400, 4800, 9600, 19200, 38400, 57600  Baud rate.	S.3
 <i>Baud rate</i>		


IEC103 . <b>Physical Settings</b>	[Device Para / IEC103]	
8E1	8E1, 8O1, 8N1, 8N2  Byte Frame.	S.3
 <i>Digit 1: Number of bits. Digit 2: E=even parity, O=odd parity, N=no parity. Digit 3: Number of stop bits. More information on the parity: It is possible that the last data bit is followed by a parity bit which is used for recognition of communication errors. The parity bit ensures that with even parity ("EVEN") always an even number of bits with valence "1" or with odd parity ("ODD") an odd number of "1" valence bits are transmitted. But it is also possible to transmit no parity bits (here the setting is "Parity = None"). More information on the stop-bits: The end of a data byte is terminated by the stop-bits.</i>		


IEC103 . <b>t-call</b>	[Device Para / IEC103]	
60s	1s ... 3600s	S.3
 <i>If there is no request telegram sent from Scada to the device after expiry of this time - the device concludes a communication failure within the Scada system.</i>		


<b>IEC103 . Transm priv meas val</b>		[Device Para / IEC103]
inactive	inactive, active	S.3
	↳ Mode.	
 <i>Transmit additional (private) measuring values</i>		


<b>IEC103 . Transfer Disturb Rec</b>		[Device Para / IEC103]
inactive	inactive, active	S.3
	↳ Mode.	
 <i>Activates the transmission of disturbance records</i>		


<b>IEC103 . Timezone</b>		[Device Para / IEC103]
UTC	UTC, Local Time	S.3
	↳ Timezone.	
 <i>Selection whether the timestamps in IEC103 messages shall be given as UTC or local time. ("Local time" always includes the actual daylight saving settings.)</i>		

<b>IEC103 . Energy Pulse Rate</b>		[Device Para / IEC103]
0	0 ... 100	S.3
 <i>The energy values are always transmitted as counter values (i.e. as integer numbers). This setting defines the unit: If "1" is set then each counter increment is 1 kWh, if "2" is set then each counter increment is 2 kWh, etc. The setting "0" has the effect that no energy values are transmitted.</i>		


<b>IEC103 . DFC-Compat.</b>		[Device Para / IEC103]
inactive	inactive, active	S.3
	↳ Mode.	
 <i>This setting is only required for certain substation implementations. If there should be communication problems related to the Command Response Queue this setting switches the device over to a different behavior.</i>		


<b>IEC103 . Optical rest position</b>		[Device Para / IEC103]
Light on	Light off, Light on	S.3
Avail. depends on HW	↳ Optical rest position.	
 <i>Optical rest position</i>		


<b>IEC103 . Ex activate test mode</b>		[Service / Test (Prot inhibit) / Scada / IEC103]
Sgen . Running	"-" ... Sys . Internal test state  ↳ 1..n, Assignment List.	S.3
 <i>The signal assigned to this parameter switches the IEC103 communication into Test Mode.</i>		

<b>IEC103 . Ex activate Block MD</b>		[Service / Test (Prot inhibit) / Scada / IEC103]
"_"	"_" ... Sys . Internal test state  ↳ 1..n, Assignment List.	S.3
 <i>The signal assigned to this parameter activates the blocking of IEC103 transmission in monitor direction.</i>		

### 8.7.2 IEC103: Direct Controls

<b>IEC103 . Res all Diag Cr</b>		[Operation / Reset/Acknowledge / Reset]
inactive	inactive, active  ↳ Mode.	S.3
 <i>Reset all diagnosis counters</i>		

<b>IEC103 . Activate test mode</b>		[Service / Test (Prot inhibit) / Scada / IEC103]
inactive	inactive, active  ↳ Mode.	S.3
 <i>This Direct Control parameter switches the IEC103 communication into Test Mode (or back to normal mode).</i>		

<b>IEC103 . Activate Block MD</b>		[Service / Test (Prot inhibit) / Scada / IEC103]
inactive	inactive, active  ↳ Mode.	S.3
 <i>This Direct Control parameter activates (or deactivates) the blocking of IEC103 transmission in monitor direction.</i>		



### 8.7.3 IEC103: Signals (Output States)

IEC103 . <b>Scada Cmd 1</b>	[Operation / Status Display / IEC103]
...	
IEC103 . <b>Scada Cmd 10</b>	
⬆	<i>Scada Command</i>

IEC103 . <b>Transmission</b>	[Operation / Status Display / IEC103]
⬆	<i>Signal: SCADA active</i>

IEC103 . <b>Failure Event lost</b>	[Operation / Status Display / IEC103]
⬆	<i>Failure event lost</i>

IEC103 . <b>Test mode active</b>	[Operation / Status Display / IEC103]
⬆	<i>Signal: IEC103 communication has been switched over into Test Mode.</i>

IEC103 . <b>Block MD active</b>	[Operation / Status Display / IEC103]
⬆	<i>Signal: The blocking of IEC103 transmission in monitor direction has been activated.</i>

### 8.7.4 IEC103: Counters

IEC103 . <b>NReceived</b>	[Operation / Count and RevData / IEC103]
#	<i>Total Number of received Messages</i>

IEC103 . <b>NSent</b>	[Operation / Count and RevData / IEC103]
#	<i>Total Number of sent Messages</i>

IEC103 . <b>NBadFramings</b>	[Operation / Count and RevData / IEC103]
#	<i>Number of bad Messages</i>

IEC103 . <b>NBadParities</b>	[Operation / Count and RevData / IEC103]
#	<i>Number of Parity Errors</i>

IEC103 . <b>NBreakSignals</b>	[Operation / Count and RevData / IEC103]
#	<i>Number of Communication Interrupts</i>

<b>IEC103 . NInternalError</b>	[Operation / Count and RevData / IEC103]
--------------------------------	--

#	<i>Number of Internal Errors</i>
---	----------------------------------



<b>IEC103 . NBadCharChecksum</b>	[Operation / Count and RevData / IEC103]
----------------------------------	--



#	<i>Number of Checksum Errors</i>
---	----------------------------------


## 8.8 IEC104



IEC 60870-5-104 communication


### 8.8.1 IEC104: Global Parameters









IEC104 . <b>Function</b>	[Device Para / IEC104 / General Settings]	
inactive	inactive, active  Mode.	S.3
	<i>Activation or deactivation of the IEC104 communication.</i>	


IEC104 . <b>TCP Port Config</b>	[Device Para / IEC104 / General Settings]	
Default	Default, Private  Port selection.	S.3
	<i>TCP Port Configuration. This parameter needs to be set to "Private" only if another TCP Port than the default one shall be used.</i>	


IEC104 . <b>Port</b>	[Device Para / IEC104 / General Settings]	
2404	If: IEC104 . TCP Port Config = Default <ul style="list-style-type: none"> <li>• 2404 ... 2404</li> </ul> If: IEC104 . TCP Port Config = Private <ul style="list-style-type: none"> <li>• 49152 ... 65535</li> </ul>	S.3
	<i>IP Port Number.</i>  <i>In general it is recommended to keep the default value. if this is not possible then select a number out of the private range 49152-52151 or 52164-65535 that is not yet in use within your network.</i>	


IEC104 . <b>Timezone</b>	[Device Para / IEC104 / General Settings]	
UTC	UTC, Local Time  Timezone.	S.3
	<i>Selection whether the timestamps in the transmitted communication telegrams shall be given as UTC or local time. ("Local time" always includes the actual daylight saving settings.)</i>	



IEC104 . <b>Deadb integr time</b>	[Device Para / IEC104 / General Settings]	
1s	0s ... 1000s	S.3
	<i>Deadband integration time.</i>	



<b>IEC104 . Timeout SBE</b>		[Device Para / IEC104 / General Settings]	
30s	1s ... 60s		S.3
	<i>The communication outputs can be controlled in a two-stage procedure (SBE: Select Before Execute). These outputs have to be selected first by a Select command. After this the bit is reserved for this Execute request. This setting defines the timer for this reservation: After the timer has elapsed the bit is released.</i>		
<b>IEC104 . Timeout t0</b>		[Device Para / IEC104 / Advanced]	
30s	30s ... 30s		S.3
	<i>Timeout of connection establishment</i>		
<b>IEC104 . Timeout t1</b>		[Device Para / IEC104 / Advanced]	
15s	15s ... 15s		S.3
	<i>Timeout of send or test APDUs</i>		
<b>IEC104 . Timeout t2</b>		[Device Para / IEC104 / Advanced]	
10s	10s ... 10s		S.3
	<i>Timeout for acknowledges in case of no data messages</i>		
<b>IEC104 . Timeout t3</b>		[Device Para / IEC104 / Advanced]	
20s	20s ... 20s		S.3
	<i>Timeout for sending test frames in case of a long idle state</i>		
<b>IEC104 . Param k</b>		[Device Para / IEC104 / Advanced]	
12	12 ... 12		S.3
	<i>Protocol parameter k</i>		
<b>IEC104 . Param w</b>		[Device Para / IEC104 / Advanced]	
8	8 ... 8		S.3
	<i>Protocol parameter w</i>		
<b>IEC104 . Length of address</b>		[Device Para / IEC104 / Advanced]	
2	2 ... 2		S.3
	<i>Number of bytes of the Common Address of the ASDU</i>		



<b>IEC104 . Length of CoT</b>	[Device Para / IEC104 / Advanced]	
2	2 ... 2	S.3
	<i>Number of bytes of the Cause of Transmission</i>	

<b>IEC104 . Length of Inf Obj addr</b>	[Device Para / IEC104 / Advanced]	
3	3 ... 3	S.3
	<i>Number of bytes of the address of the Information Object</i>	

<b>IEC104 . Update time</b>	[Device Para / IEC104 / Advanced]	
1s	1s ... 60s	S.3
	<i>This setting specifies the time after which measurement values are refreshed. If cyclic transmission is selected new values are reported after this time has elapsed.</i>	

<b>IEC104 . Transmit Int. State</b>	[Device Para / IEC104 / Advanced]	
active	inactive, active  Mode.	S.3
	<i>If this parameter is set to "active" (default) then the intermediate position of a switchgear, too, is transmitted. This needs to be changed to "inactive" only in the rare case that the substation communication does not support the reporting of intermediate positions.</i>	

<b>IEC104 . Trans. Cmd. State</b>	[Device Para / IEC104 / Advanced]	
active	inactive, active  Mode.	S.3
	<i>_ If false it suppress change events for command states (Same address as cmd)</i>	

<b>IEC104 . Type of SCADA mapping</b>	[Device Para / IEC104 / Config. Data Obj.]	
Standard	Standard, User-defined  Type of SCADA mapping.	S.3
	<i>This setting decides whether the communication protocol shall use the default mapping of data objects, or some user-defined mapping that has been loaded from a *.HptSMap file.</i>	

### 8.8.2 IEC104: Direct Controls

IEC104 . <b>Res all Diag Cr</b>	[Operation / Reset/Acknowledge / Reset]	
inactive	inactive, active	S.3
	↳ Mode.	
☉	<i>Reset all diagnosis counters</i>	

IEC104 . <b>Common address</b>	[Device Para / IEC104 / General Settings]	
1	1 ... 65535	S.3
☉	<i>Common Address of the ASDU</i>	

### 8.8.3 IEC104: Signals (Output States)

IEC104 . <b>Scada Cmd 1</b>	[Operation / Status Display / IEC104]	
...		
IEC104 . <b>Scada Cmd 16</b>		
↕	<i>Scada Command</i>	

IEC104 . <b>busy</b>	[Operation / Status Display / IEC104]	
↕	<i>This message is set if the protocol is started. It will be reset if the protocol is shut down.</i>	




IEC104 . <b>ready</b>	[Operation / Status Display / IEC104]	
↕	<i>The message will be set if the protocol is successfully started and ready for data exchange.</i>	

IEC104 . <b>Transmission</b>	[Operation / Status Display / IEC104]	
↕	<i>Signal: SCADA active</i>	





IEC104 . <b>Failure Event lost</b>	[Operation / Status Display / IEC104]	
↕	<i>Failure event lost</i>	

### 8.8.4 IEC104: Values

IEC104 . <b>Config info</b>	[Device Para / IEC104 / Config. Data Obj.]	
🔗	<i>Configuration comment (entered by the user during SCADA configuration)</i>	

IEC104 . <b>Config version</b>	[Device Para / IEC104 / Config. Data Obj.]
 <i>Version of the user-defined SCADA configuration</i>	
IEC104 . <b>Config status</b>	[Device Para / IEC104 / Config. Data Obj.]
Changing	Changing, OK, Config. not avail., Error  <a href="#">Config status.</a>
 <i>Status of the user-defined SCADA configuration.</i>	
<i>Possible values:</i>	
- <i>Changing: New SCADA configuration is being loaded, but not active yet.</i>	
- <i>OK: The SCADA configuration is active.</i>	
- <i>Config. not avail.: The user-defined SCADA configuration is not available (e.g. has not been loaded into the device).</i>	
- <i>Error: Unexpected error. Please contact our service-team.</i>	


### 8.8.5 IEC104: Counters


IEC104 . <b>NReceived</b>	[Operation / Count and RevData / IEC104]
 <i>Diagnostic counter: Number of received characters</i>	
IEC104 . <b>NSent</b>	[Operation / Count and RevData / IEC104]
 <i>Diagnostic counter: Number of sent characters</i>	
IEC104 . <b>Num. of lost conn.</b>	[Operation / Count and RevData / IEC104]
 <i>Diagnostic counter: Number of lost connections</i>	
IEC104 . <b>NBadChecksum</b>	[Operation / Count and RevData / IEC104]
 <i>Diagnostic counter: Number of frames received with bad checksum.</i>	


## 8.9 Profibus

Profibus Module


### 8.9.1 Profibus: Global Parameters

Profibus . <b>Config Bin Inp 1</b>	[Device Para / Profibus / Config Bin Inp 1-16]	
...	[Device Para / Profibus / Config Bin Inp 17-32]	
Profibus . <b>Config Bin Inp 32</b>		
"_"	"_" ... Sys . Internal test state  ↳ 1..n, Assignment List.	S.3
 <i>Virtual Digital Input. This corresponds to a virtual binary output of the protective device.</i>		



Profibus . <b>Latched 1</b>	[Device Para / Profibus / Config Bin Inp 1-16]	
...	[Device Para / Profibus / Config Bin Inp 17-32]	
Profibus . <b>Latched 32</b>		
inactive	inactive, active  ↳ Mode.	S.3
 <i>Defines whether the Input is latched.</i>		

Profibus . <b>Type of SCADA mapping</b>	[Device Para / Profibus / Config. Data Obj.]	
Standard	Standard, User-defined  ↳ Type of SCADA mapping.	S.3
 <i>This setting decides whether the communication protocol shall use the default mapping of data objects, or some user-defined mapping that has been loaded from a *.HptSMap file.</i>		


### 8.9.2 Profibus: Direct Controls

Profibus . <b>Slave ID</b>	[Operation / Status Display / Profibus / State]  [Device Para / Profibus / Bus parameters]	
2	2 ... 125	P.1
 <i>Device address (Slave ID) within the bus system. Each device address has to be unique within a bus system.</i>		





Profibus . <b>Reset Comds</b>	[Operation / Reset/Acknowledge / Reset]	
inactive	inactive, active  Mode.	P.1
 <i>All Profibus Commands will be reset.</i>		


### 8.9.3 Profibus: Input States


Profibus . <b>Assignment 1-I</b>	[Operation / Status Display / Profibus / Config Bin Inp 1-16]
...	[Operation / Status Display / Profibus / Config Bin Inp 17-32]
Profibus . <b>Assignment 32-I</b>	
 <i>Module input state: Scada Assignment</i>	

### 8.9.4 Profibus: Signals (Output States)


Profibus . <b>Data OK</b>	[Operation / Status Display / Profibus / State]
 <i>Data within the Input field are OK (Yes=1)</i>	



Profibus . <b>SubModul Err</b>	[Operation / Status Display / Profibus / State]
 <i>Assignable Signal, Failure in Sub-Module, Communication Failure.</i>	



Profibus . <b>Connection active</b>	[Operation / Status Display / Profibus / State]
 <i>Connection active</i>	


Profibus . <b>Scada Cmd 1</b>	[Operation / Status Display / Profibus / Commands]
...	
Profibus . <b>Scada Cmd 16</b>	
 <i>Scada Command</i>	


### 8.9.5 Profibus: Values

Profibus . <b>Slave State</b>	[Operation / Status Display / Profibus / State]
Baud Search	Baud Search ... Data exchange  State.
	<i>Communication State between Slave and Master.</i>

Profibus . <b>Baud rate</b>	[Operation / Status Display / Profibus / State]
--	12 Mb/s ... --  Baud rate.
	<i>The baud rate that has been detected lastly, will still be shown after a connection issue.</i>

Profibus . <b>PNO Id</b>	[Operation / Status Display / Profibus / State]
0C50h	0C50h  PNO Id.
	<i>PNO Identification Number. GSD Identification Number.</i>

Profibus . <b>Config info</b>	[Operation / Status Display / Profibus / State] [Device Para / Profibus / Config. Data Obj.]
	<i>Configuration comment (entered by the user during SCADA configuration)</i>

Profibus . <b>Config version</b>	[Operation / Status Display / Profibus / State] [Device Para / Profibus / Config. Data Obj.]
	<i>Version of the user-defined SCADA configuration</i>

Profibus . <b>Config status</b>	[Operation / Status Display / Profibus / State] [Device Para / Profibus / Config. Data Obj.]
Changing	Changing, OK, Config. not avail., Error  Config status.
	<i>Status of the user-defined SCADA configuration.        Possible values:</i>



## 8.9.6 Profibus: Counters

Profibus . <b>Master ID</b>	[Operation / Status Display / Profibus / State]
#	<i>Device address (Master ID) within the bus system. Each device address has to be unique within a bus system.</i>
Profibus . <b>HO Id PSub</b>	[Operation / Status Display / Profibus / State]
#	<i>Handoff Id of PbSub</i>
Profibus . <b>t-WatchDog</b>	[Operation / Status Display / Profibus / State]
#	<i>The Profibus Chip detects a communication issue if this timer is expired without any communication (Parameterising telegram).</i>
Profibus . <b>Fr Sync Err</b>	[Operation / Count and RevData / Profibus]
#	<i>Frames, that were sent from the Master to the Slave are faulty.</i>
Profibus . <b>Num. CRC err.</b>	[Operation / Count and RevData / Profibus]
#	<i>Number of CRC errors that the subsystem manager has recognized in the received response frames from the subsystem. (Each error caused a subsystem reset.)</i>
Profibus . <b>Num. frame loss err.</b>	[Operation / Count and RevData / Profibus]
#	<i>Number of frame loss errors that the subsystem manager has recognized in the received response frames from the subsystem. (Each error caused a subsystem reset.)</i>
Profibus . <b>Num. trig. CRC err.</b>	[Operation / Count and RevData / Profibus]
#	<i>Number of CRC errors that the subsystem has recognized in the received trigger frames from the host.</i>
Profibus . <b>Num. subsys. res.</b>	[Operation / Count and RevData / Profibus]
#	<i>Number of subsystem restarts or resets that the subsystem manager has caused.</i>



## 8.10 IRIG-B



IRIG-B-Module

### 8.10.1 IRIG-B: Device Planning Parameters



IRIG-B . <b>Mode</b>	[Device planning]	
"_"	"_", use  Mode.	S.3
 <i>IRIG-B-Module, general operation mode</i>		

### 8.10.2 IRIG-B: Global Parameters

IRIG-B . <b>Function</b>	[Device Para / Time / TimeSync / IRIG-B]	
inactive	inactive, active  Mode.	S.3
 <i>Permanent activation or deactivation of module/stage.</i>		

IRIG-B . <b>IRIG-B00X</b>	[Device Para / Time / TimeSync / IRIG-B]	
IRIGB-000	IRIGB-000 ... IRIGB-007  IRIG-B00X.	S.3
 <i>Determination of the Type: IRIG-B00X. IRIG-B types differ in types of included "Coded Expressions" (year, control-functions, straight-binary-seconds).</i>		

### 8.10.3 IRIG-B: Direct Controls

IRIG-B . <b>Res IRIG-B Cr</b>	[Operation / Reset/Acknowledge / Reset]	
inactive	inactive, active  Mode.	P.1
 <i>Resetting of the Diagnosis Counters: IRIG-B</i>		

### 8.10.4 IRIG-B: Signals (Output States)

IRIG-B . <b>IRIG-B active</b>	[Operation / Status Display / TimeSync / IRIG-B]
⬇	<i>Signal: If there is no valid IRIG-B signal for 60 sec, IRIG-B is regarded as inactive.</i>
IRIG-B . <b>High-Low Invert</b>	[Operation / Status Display / TimeSync / IRIG-B]
⬇	<i>Signal: The High and Low signals of the IRIG-B are inverted. This does NOT mean that the wiring is faulty. If the wiring is faulty no IRIG-B signal will be detected.</i>
IRIG-B . <b>Control Signal1</b> ... IRIG-B . <b>Control Signal18</b>	[Operation / Status Display / TimeSync / IRIG-B]
⬇	<i>Signal: IRIG-B Control Signal. The external IRIG-B generator can set these signals. They can be used for further control procedures inside the device (e.g. logic funtions).</i>



### 8.10.5 IRIG-B: Counters

IRIG-B . <b>NoOfFramesOK</b>	[Operation / Count and RevData / TimeSync / IRIG-B]
#	<i>Total Number valid Frames.</i>
IRIG-B . <b>NoOfFrameErrors</b>	[Operation / Count and RevData / TimeSync / IRIG-B]
#	<i>Total Number of Frame Errors. Physically corrupted Frame.</i>
IRIG-B . <b>Edges</b>	[Operation / Count and RevData / TimeSync / IRIG-B]
#	<i>Edges: Total number of rising and falling edges. This signal indicates if a signal is available at the IRIG-B input.</i>



## 8.11 SNTP


SNTP-Module



### 8.11.1 SNTP: Device Planning Parameters

<b>SNTP . Mode</b>	[Device planning]	
"_"	"_", use  Mode.	S.3
 <i>SNTP-Module, general operation mode</i>		



### 8.11.2 SNTP: Global Parameters

<b>SNTP . Server1</b>	[Device Para / Time / TimeSync / SNTP]	
inactive	inactive, active  Mode.	S.3
 <i>Server 1</i>		


<b>SNTP . IP Byte1</b>	[Device Para / Time / TimeSync / SNTP]	
...		
<b>SNTP . IP Byte4</b>		
0	0 ... 255	S.3
 <i>IP1.IP2.IP3.IP4</i>		

<b>SNTP . Server2</b>	[Device Para / Time / TimeSync / SNTP]	
inactive	inactive, active  Mode.	S.3
 <i>Server 2</i>		



### 8.11.3 SNTP: Direct Controls


<b>SNTP . Res Counter</b>	[Operation / Reset/Acknowledge / Reset]	
inactive	inactive, active  Mode.	P.1
 <i>Reset all Counters.</i>		


### 8.11.4 SNTP: Signals (Output States)



<b>SNTP . SNTP active</b>	[Operation / Status Display / TimeSync / SNTP]	
 <i>Signal: If there is no valid SNTP signal for 120 sec, SNTP is regarded as inactive.</i>		



### 8.11.5 SNTP: Values

<b>SNTP . Used Server</b>	[Operation / Status Display / TimeSync / SNTP]	
None	Server1, Server2, None  Server State.	
 <i>Which Server is used for SNTP synchronization.</i>		

<b>SNTP . PrecServer1</b>	[Operation / Status Display / TimeSync / SNTP]	
 <i>Precision of Server 1</i>		

<b>SNTP . PrecServer2</b>	[Operation / Status Display / TimeSync / SNTP]	
 <i>Precision of Server 2</i>		

<b>SNTP . ServerQlty</b>	[Operation / Status Display / TimeSync / SNTP]	
"_"	GOOD, SUFFICIENT, BAD, "-"  State.	
 <i>Quality of Server used for Synchronization (GOOD, SUFFICIENT, BAD)</i>		

<b>SNTP . NetConn</b>	[Operation / Status Display / TimeSync / SNTP]
"_"	GOOD, SUFFICIENT, BAD, "-"  State.
	<i>Quality of Network Connection (GOOD, SUFFICIENT, BAD).</i>

### 8.11.6 SNTP: Counters

<b>SNTP . StratumServer1</b>	[Operation / Status Display / TimeSync / SNTP]
#	<i>Stratum of Server 1</i>

<b>SNTP . StratumServer2</b>	[Operation / Status Display / TimeSync / SNTP]
#	<i>Stratum of Server 2</i>

<b>SNTP . NoOfSyncs</b>	[Operation / Count and RevData / TimeSync / SNTP]
#	<i>Total Number of Synchronizations.</i>

<b>SNTP . NoOfConnectLost</b>	[Operation / Count and RevData / TimeSync / SNTP]
#	<i>Total Number of lost SNTP Connections (no sync for 120 sec).</i>

<b>SNTP . NoOfSmallSyncs</b>	[Operation / Count and RevData / TimeSync / SNTP]
#	<i>Service counter: Total Number of very small Time Corrections.</i>

<b>SNTP . NoOfNormSyncs</b>	[Operation / Count and RevData / TimeSync / SNTP]
#	<i>Service counter: Total Number of normal Time Corrections</i>

<b>SNTP . NoOfBigSyncs</b>	[Operation / Count and RevData / TimeSync / SNTP]
#	<i>Service counter: Total Number of big Time Corrections</i>

<b>SNTP . NoOfFiltSyncs</b>	[Operation / Count and RevData / TimeSync / SNTP]
#	<i>Service counter: Total Number of filtered Time Corrections</i>

<b>SNTP . NoOfSlowTrans</b>	[Operation / Count and RevData / TimeSync / SNTP]
#	<i>Service counter: Total Number of slow Transfers.</i>



<b>SNTP . NoOfHighOffs</b>	[Operation / Count and RevData / TimeSync / SNTP]
----------------------------	---


#	<i>Service counter: Total Number of high Offsets.</i>
---	---

<b>SNTP . NoOfIntTimeouts</b>	[Operation / Count and RevData / TimeSync / SNTP]
-------------------------------	---



#	<i>Service counter: Total Number of internal timeouts.</i>
---	--

## 8.12 TimeSync



Time synchronisation



Date and Time		[Device Para / Time / Date and Time]
	This item represents a special dialog. (See the Technical Manual for details.) <i>(Re-)setting Date and Time</i>	

### 8.12.1 TimeSync: Global Parameters


TimeSync . Time Zones		[Device Para / Time / Timezone]
UTC+0 London	UTC+14 Kiritimati ... UTC-11 Midway Islands	S.3
	 Time Zones.	
	<i>Time Zones</i>	


TimeSync . DST offset		[Device Para / Time / Timezone]
60min	-180min ... 180min	S.3
	<i>Difference to wintertime</i>	

TimeSync . DST manual		[Device Para / Time / Timezone]
active	inactive, active	S.3
	 Mode.	
	<i>Manual setting of the Daylight Saving Time</i>	


TimeSync . Summertime		[Device Para / Time / Timezone]
inactive	inactive, active	S.3
	 Mode.	
	<i>Daylight Saving Time</i>	


TimeSync . Summertime m		[Device Para / Time / Timezone]
March	January ... December	S.3
	 Month of clock change.	
	<i>Month of clock change summertime</i>	


TimeSync . <b>Summertime d</b>		[Device Para / Time / Timezone]
Sunday	Sunday ... General day	S.3
	↳ Date.	
	<i>Day of clock change summertime</i>	


TimeSync . <b>Summertime w</b>		[Device Para / Time / Timezone]
Last	First, Second, Third, Fourth, Last	S.3
	↳ Day of clock change.	
	<i>Place of selected day in month (for clock change summertime)</i>	

TimeSync . <b>Summertime h</b>		[Device Para / Time / Timezone]
2h	0h ... 23h	S.3
	<i>Hour of clock change summertime</i>	

TimeSync . <b>Summertime min</b>		[Device Para / Time / Timezone]
0min	0min ... 59min	S.3
	<i>Minute of clock change summertime</i>	



TimeSync . <b>Wintertime m</b>		[Device Para / Time / Timezone]
October	January ... December	S.3
	↳ Month of clock change.	
	<i>Month of clock change wintertime</i>	

TimeSync . <b>Wintertime d</b>		[Device Para / Time / Timezone]
Sunday	Sunday ... General day	S.3
	↳ Date.	
	<i>Day of clock change wintertime</i>	


TimeSync . <b>Wintertime w</b>		[Device Para / Time / Timezone]
Last	First, Second, Third, Fourth, Last	S.3
	↳ Day of clock change.	
	<i>Place of selected day in month (for clock change wintertime)</i>	

TimeSync . <b>Wintertime h</b>	[Device Para / Time / Timezone]	
3h	0h ... 23h	S.3
	<i>Hour of clock change wintertime</i>	

TimeSync . <b>Wintertime min</b>	[Device Para / Time / Timezone]	
0min	0min ... 59min	S.3
	<i>Minute of clock change wintertime</i>	

TimeSync . <b>TimeSync</b>	[Device Para / Time / TimeSync / TimeSync]	
"_"	"_", IRIG-B . IRIG-B, SNTP . SNTP, Modbus . Modbus, IEC103 . IEC 60870-5-103, IEC104 . IEC104, DNP3 . DNP3   Used Protocol.	S.3
	<i>Time synchronisation</i>	



### 8.12.2 TimeSync: Signals (Output States)

TimeSync . <b>synchronized</b>	[Operation / Status Display / TimeSync / TimeSync]	
	<i>Clock is synchronized.</i>	



## 9 Protection Parameter



Module General Protection



### 9.1 Prot: Global Parameters


Prot . <b>Function</b>	[Protection Para / Global Prot Para / Prot]	
active	inactive, active  Mode.	P.2
 Permanent activation or deactivation of module/stage.		

Prot . <b>ExBlo Fc</b>	[Protection Para / Global Prot Para / Prot]	
inactive	inactive, active  active/inactive.	P.2
 Activate (allow) the external blocking of the global protection functionality of the device.		


Prot . <b>ExBlo1</b> Prot . <b>ExBlo2</b>	[Protection Para / Global Prot Para / Prot]	
"_"	"_" ... Sys . Internal test state  1..n, Assignment List.	P.2
 If external blocking of this module is activated (allowed), the global protection functionality of the device will be blocked if the state of the assigned signal becomes true.		

Prot . <b>Blo TripCmd</b>	[Protection Para / Global Prot Para / Prot]	
inactive	inactive, active  Mode.	P.2
 Permanent blocking of the Trip Command of the entire Protection.		




Prot . <b>ExBlo TripCmd Fc</b>	[Protection Para / Global Prot Para / Prot]	
inactive	inactive, active  active/inactive.	P.2
 Activate (allow) the external blocking of the trip command of the entire device.		

Prot . <b>ExBlo TripCmd</b>	[Protection Para / Global Prot Para / Prot]	
"_"	"_" ... Sys . Internal test state  ↳ 1..n, Assignment List.	P.2
	<i>If external blocking of the tripping command is activated (allowed), the tripping command of the entire device will be blocked if the state of the assigned signal becomes true.</i>	



## 9.2 Prot: Direct Controls

Prot . <b>Res FaultNo a GridFaultNo</b>	[Operation / Reset/Acknowledge / Reset]	
inactive	inactive, active  ↳ Mode.	P.1
	<i>Resetting of fault number and grid fault number.</i>	

## 9.3 Prot: Input States

Prot . <b>ExBlo1-I</b>	[Operation / Status Display / Prot]	
	<i>Module input state: External blocking1</i>	
Prot . <b>ExBlo2-I</b>	[Operation / Status Display / Prot]	
	<i>Module input state: External blocking2</i>	
Prot . <b>ExBlo TripCmd-I</b>	[Operation / Status Display / Prot]	
	<i>Module input state: External Blocking of the Trip Command</i>	

## 9.4 Prot: Signals (Output States)

Prot . <b>active</b>	[Operation / Status Display / All Actives] [Operation / Status Display / Prot]	
	<i>Signal: active</i>	
Prot . <b>Alarm</b>	[Operation / Status Display / Alarms] [Operation / Status Display / Prot]	
	<i>Signal: General Alarm</i>	

Prot . <b>Trip</b>	[Operation / Status Display / Trips] [Operation / Status Display / Prot]
⬆️	<i>Signal: General Trip</i>
Prot . <b>available</b>	[Operation / Status Display / Prot]
⬆️	<i>Signal: Protection is available</i>
Prot . <b>ExBlo</b>	[Operation / Status Display / Prot]
⬆️	<i>Signal: External Blocking</i>
Prot . <b>Blo TripCmd</b>	[Operation / Status Display / Prot]
⬆️	<i>Signal: Trip Command blocked</i>
Prot . <b>ExBlo TripCmd</b>	[Operation / Status Display / Prot]
⬆️	<i>Signal: External Blocking of the Trip Command</i>
Prot . <b>Alarm L1</b>	[Operation / Status Display / Prot]
⬆️	<i>Signal: General-Alarm L1</i>
Prot . <b>Alarm L2</b>	[Operation / Status Display / Prot]
⬆️	<i>Signal: General-Alarm L2</i>
Prot . <b>Alarm L3</b>	[Operation / Status Display / Prot]
⬆️	<i>Signal: General-Alarm L3</i>
Prot . <b>Alarm G</b>	[Operation / Status Display / Prot]
⬆️	<i>Signal: General-Alarm - Earth fault</i>
Prot . <b>Trip L1</b>	[Operation / Status Display / Prot]
⬆️	<i>Signal: General Trip L1</i>
Prot . <b>Trip L2</b>	[Operation / Status Display / Prot]
⬆️	<i>Signal: General Trip L2</i>



<b>Prot . Trip L3</b>	[Operation / Status Display / Prot]
⬆	<i>Signal: General Trip L3</i>
<b>Prot . Trip G</b>	[Operation / Status Display / Prot]
⬆	<i>Signal: General Trip Ground fault</i>
<b>Prot . Res FaultNo a GridFaultNo</b>	[Operation / Status Display / Prot]
⬆	<i>Signal: Resetting of fault number and grid fault number.</i>
<b>Prot . FaultNo</b>	[Operation / Count and RevData / Prot]
⬆	<i>Fault number</i>
<b>Prot . No. of Grid Fault</b>	[Operation / Count and RevData / Prot]
⬆	<i>Number of grid fault: A grid fault, e.g. a short circuit, might cause several faults with trip and autoreclosing; in this case, the fault number counts each fault, but the grid fault number remains the same.</i>





## 9.5 MStart


Motor Start


### 9.5.1 MStart: Global Parameters











MStart . <b>Reversing</b>	[Field Para / Motor Nominal Values]	
inactive	inactive, active  active/inactive.	P.2
	<p><i>This setting specifies whether or not the starter for this motor is designed to reverse the phase sequence and to make the motor run in either direction.</i></p> <p><i>If set to “active”, either phase sequence is accepted during a motor start.</i></p> <p><i>If set to “inactive”, the reversed phase sequence leads to a trip.</i></p>	


MStart . <b>Ib</b>	[Field Para / Motor Nominal Values]	
10A	10A ... 6000A	P.2
	<p><i>Full load current (amperes). Set to maximum stator continuous RMS current primary (actual motor winding) amperes in each phase. Use motor nameplate or manufacturers data. Note that the ratio Ib/CT prim must lie between 0.25 and 1.5 in order to have reliable motor protection.</i></p>	



MStart . <b>LRC</b>	[Field Para / Motor Nominal Values]	
3.00Ib	3.00Ib ... 12.00Ib	P.2
	<p><i>Set to the locked-rotor current (the current the motor draws when stalled), in times of Ib. Use motor nameplate or manufacturers data.</i></p>	


MStart . <b>LRTC</b>	[Field Para / Motor Nominal Values]	
1s	1s ... 120s	P.2
	<p><i>Specifies how long a locked-rotor or stall condition can be maintained before the motor is damaged, in seconds, for a cold start. Use motor nameplate or manufacturers data.</i></p>	



MStart . <b>STPC</b>	[Field Para / Motor Nominal Values]	
0.02Ib	0.02Ib ... 0.20Ib	P.2
	<p><i>Stop current threshold, in percent of Ib, if the actual current is below the threshold for at least 300 milliseconds. If a stop state occurs, the jogging functions Starts per Hour Allowed (SPH), Time Between Starts (TBS) and Anti-Backspin (ABS) are enforced. All phases of the current must be below this level before a stop will be declared.</i></p>	


<b>MStart . k-Factor</b>	[Field Para / Motor Nominal Values]	
0.85	0.25 ... 1.50	P.2
	<i>The k-Factor is to be calculated by the maximum allowed continuous current over the rated current transformer current (e.g. 1.2 times rated motor current over rated transformer current).</i>	
<b>MStart . ExBlo TripCmd</b>	[Protection Para / Global Prot Para / MStart / Start Control]	
"_"	"_" ... Sys . Internal test state  1..n, Assignment List.	P.2
	<i>External blocking of the Trip Command of the module/the stage, if blocking is activated (allowed) within a parameter set and if the state of the assigned signal is true.</i>	
<b>MStart . TRN Criteria</b>	[Protection Para / Global Prot Para / MStart / Start Control]	
TRN T and I	TRN I, TRN TIME, TRN T and I, TRN T or I  1..n, TRN List.	P.2
	<i>Start transition criterion</i>	
<b>MStart . TRNT</b>	[Protection Para / Global Prot Para / MStart / Start Control]	
10s	0s ... 1200s	P.2
	<i>Motor start transition time limit</i>	
<b>MStart . TRNC</b>	[Protection Para / Global Prot Para / MStart / Start Control]	
1.30Ib	0.10Ib ... 3.00Ib	P.2
	<i>Motor start transitions current level in Ib%</i>	
<b>MStart . NOCS</b>	[Protection Para / Global Prot Para / MStart / Start Control]	
1	1 ... 5	P.2
	<i>Number of cold starts limit</i>	
<b>MStart . TBS Fc</b>	[Protection Para / Global Prot Para / MStart / Start Control]	
inactive	inactive, active  Mode.	P.2
	<i>Time Between Starts on/off</i>	



<b>MStart . TBS Timer</b>	[Protection Para / Global Prot Para / MStart / Start Control]	
60min	1min ... 240min	P.2
 <i>Time Between Starts Limit</i>		


<b>MStart . SPH Fc</b>	[Protection Para / Global Prot Para / MStart / Start Control]	
inactive	inactive, active  Mode.	P.2
 <i>Starts Per Hour</i>		







<b>MStart . SPH</b>	[Protection Para / Global Prot Para / MStart / Start Control]	
1	1 ... 10	P.2
 <i>SPH</i>		



<b>MStart . INSQReportFrom</b>	[Protection Para / Global Prot Para / MStart / Start Control]	
inactive	inactive, InSq Start2Run, InSq Stop2Start  1..n, InSq.	P.2
 <i>INcomplete SeQuence report time starting point</i>		



<b>MStart . INSQReportTime</b>	[Protection Para / Global Prot Para / MStart / Start Control]	
1s	1s ... 240s	P.2
 <i>INSQ Report back time</i>		



<b>MStart . LAT Fc</b>	[Protection Para / Global Prot Para / MStart / Start Control]	
inactive	inactive, active  Mode.	P.2
 <i>Long Time Acceleration Timer</i>		



<b>MStart . LAT Timer</b>	[Protection Para / Global Prot Para / MStart / Start Control]	
1200s	1s ... 1200s	P.2
 <i>Large motors with a high inertia may experience starting currents that exceed the locked rotor current and time. The protective relay has logic and provisions for a zero speed switch input to differentiate between a stall and start condition. If the motor is spinning then the relay will not trip on the normal locked rotor time allowing the motor to start.</i>		



<b>MStart . ABS Fc</b>		[Protection Para / Global Prot Para / MStart / Start Control]	
inactive	inactive, active		P.2
	↳ Mode.		
	<i>For certain applications, such as pumping a fluid up a pipe, the motor may be driven backward for a period of time after it stops. The protective relay provides an anti-backspin timer to prevent starting the motor while it is spinning in the reverse direction. The timer begins counting from the moment a stop is declared by the relay.</i>		
<b>MStart . ABS Timer</b>		[Protection Para / Global Prot Para / MStart / Start Control]	
3600s	1s ... 3600s		P.2
	<i>For certain applications, such as pumping a fluid up a pipe, the motor may be driven backward for a period of time after it stops. The protective relay provides an anti-backspin timer to prevent starting the motor while it is spinning in the reverse direction. The timer begins counting from the moment a stop is declared by the relay.</i>		
<b>MStart . ZSS</b>		[Protection Para / Global Prot Para / MStart / Start Control]	
inactive	inactive, active		P.2
	↳ 1..n, Zero speed.		
	Zero Speed Switch		
<b>MStart . EmgOvr</b>		[Protection Para / Global Prot Para / MStart / Start Control]	
inactive	inactive, DI, HMI, DI or HMI		P.2
	↳ EmgOvr.		
	<i>Emergency override options. Signal has to be active in order to release the thermal capacity of the motor. Please notice that by doing this you run the risk of damaging the motor. "EMGOVR" has to be set to "DI" or "DI or UI" for this input to take effect.</i>		
<b>MStart . RemStartBlo Fc</b>		[Protection Para / Global Prot Para / MStart / Start Control]	
inactive	inactive, active		P.2
	↳ Mode.		
	RemStartBlo Fc		
<b>MStart . ThermBlo Fc</b>		[Protection Para / Global Prot Para / MStart / Start Control]	
inactive	inactive, active		P.2
	↳ Mode.		
	ThermBlo Fc		


<b>MStart . RemStartBlock</b>	[Protection Para / Global Prot Para / MStart / Motor Inputs]
"_"	"_" ... DI Slot X1 . DI 4  1..n, Dig Inputs.
 Remote Motor Start Blocking	


<b>MStart . EmgOvr</b>	[Protection Para / Global Prot Para / MStart / Motor Inputs]
"_"	"_" ... DI Slot X1 . DI 4  1..n, Dig Inputs.
 Emergency Override. Signal has to be active in order to release the thermal capacity of the motor. Please notice that by doing this you run the risk of damaging the motor. "EMGOVR" has to be set to "DI" or "DI or UI" for this input to take effect	

<b>MStart . INSQ</b>	[Protection Para / Global Prot Para / MStart / Motor Inputs]
"_"	"_" ... DI Slot X1 . DI 4  1..n, Dig Inputs.
 INcomplete Sequence	


<b>MStart . ZSS</b>	[Protection Para / Global Prot Para / MStart / Motor Inputs]
"_"	"_" ... DI Slot X1 . DI 4  1..n, Dig Inputs.
 Zero Speed Switch	


<b>MStart . STPC Blo</b>	[Protection Para / Global Prot Para / MStart / Motor Inputs]
"_"	"_" ... DI Slot X1 . DI 4  1..n, Dig Inputs.
 With this setting a Digital Input keeps the Motor in the RUN mode, even when the motor current drops below STPC (motor stop current).	


<b>MStart . t-Blo-IOC</b>	[Protection Para / Global Prot Para / MStart / Start Delay Timer]
0.05s	0.03s ... 1.00s
 Phase Overcurrent Start Delay. Phase Overcurrent elements are blocked for the time programmed under this parameter, while the motor is starting.	

MStart . <b>t-Blo-GOC</b>	[Protection Para / Global Prot Para / MStart / Start Delay Timer]	
0.08s	0.03s ... 1.00s	P.2
	<i>Ground Overcurrent Start Delay. Ground Overcurrent elements are blocked for the time programmed under this parameter, while the motor is starting</i>	



MStart . <b>t-Blo-I&lt;</b>	[Protection Para / Global Prot Para / MStart / Start Delay Timer]	
60s	0s ... 1200s	P.2
	<i>Underload Start Delay. 37[x] elements are blocked for the time programmed under this parameter, while the motor is starting</i>	


MStart . <b>t-Blo-I2&gt;</b>	[Protection Para / Global Prot Para / MStart / Start Delay Timer]	
10.00s	0.03s ... 1200.00s	P.2
	<i>Current Unbalance Start Delay. 46[x] elements are blocked for the time programmed under this parameter, while the motor is starting</i>	

MStart . <b>t-Blo-JAM</b>	[Protection Para / Global Prot Para / MStart / Start Delay Timer]	
60.00s	0.03s ... 1200.00s	P.2
	<i>Jam Start Delay. 50J[x] elements are blocked for the time programmed under this parameter, while the motor is starting</i>	


MStart . <b>t-Blo-Generic1</b>	[Protection Para / Global Prot Para / MStart / Start Delay Timer]	
...		
MStart . <b>t-Blo-Generic5</b>		
0s	0s ... 1200s	P.2
	<i>Generic Start Delay. This value can be used to block any protective element.</i>	


## 9.5.2 MStart: Setting Group Parameters

MStart . <b>Blo TripCmd</b>	[Protection Para / Set 1...4 / MStart / Start Control]	
inactive	inactive, active  Mode.	P.2
	<i>Permanent blocking of the Trip Command of the module/stage.</i>	


MStart . <b>ExBlo TripCmd Fc</b>	[Protection Para / Set 1...4 / MStart / Start Control]
inactive	inactive, active ↳ active/inactive.
	<i>Activate (allow) or inactivate (disallow) blocking of the module/stage. This parameter is only effective if a signal is assigned to the corresponding global protection parameter. If the signal becomes true, those modules/stages are blocked that are parameterized "ExBlo TripCmd Fc=active".</i>


### 9.5.3 MStart: Direct Controls


MStart . <b>RstForcedStart</b>	[Operation / Reset/Acknowledge / Reset]
inactive	inactive, active ↳ Mode.
	<i>Reset Forced Start flag</i>


MStart . <b>EmergOverHMI</b>	[Operation / Reset/Acknowledge / EmgOvr]
inactive	inactive, active ↳ Mode.
	<i>Emergency override through front display</i>

### 9.5.4 MStart: Input States

MStart . <b>ExBlo TripCmd-I</b>	[Operation / Status Display / MStart / Start Control]
	<i>Module input state: External Blocking of the Trip Command</i>

MStart . <b>RemStartBlock-I</b>	[Operation / Status Display / MStart / Motor Inputs]
	<i>State of the module input: Remote Motor Start Blocking</i>

MStart . <b>EmgOvr-I</b>	[Operation / Status Display / MStart / Motor Inputs]
	<i>State of the module input: Emergency Override. Signal has to be active in order to release the thermal capacity of the motor. Please notice that by doing this you run the risk of damaging the motor. "EMGOVR" has to be set to "DI" or "DI or UI" for this input to take effect</i>

MStart . <b>INSQ-I</b>	[Operation / Status Display / MStart / Motor Inputs]
	<i>State of the module input: INcomplete SeQuence</i>

MStart . <b>ZSS-I</b>	[Operation / Status Display / MStart / Motor Inputs]
↓	<i>State of the module input: Zero Speed Switch</i>

MStart . <b>STPC Blo-I</b>	[Operation / Status Display / MStart / Motor Inputs]
↓	<i>State of the module input: With this setting a Digital Input keeps the Motor in the RUN mode, even when the motor current drops below STPC (motor stop current).</i>

### 9.5.5 MStart: Signals (Output States)

MStart . <b>active</b>	[Operation / Status Display / All Actives]
	[Operation / Status Display / MStart / Start Control]
↓	<i>Signal: active</i>

MStart . <b>Trip</b>	[Operation / Status Display / Trips]
	[Operation / Status Display / MStart / Start Control]
↓	<i>Signal: Trip</i>

MStart . <b>TripCmd</b>	[Operation / Status Display / TripCmds]
	[Operation / Status Display / MStart / Start Control]
↓	<i>Signal: Trip Command</i>













MStart . <b>Start</b>	[Operation / Status Display / MStart / Start Control]
↓	<i>Signal: Motor is in start mode</i>












MStart . <b>Run</b>	[Operation / Status Display / MStart / Start Control]
↓	<i>Signal: Motor is in run mode</i>










MStart . <b>Stop</b>	[Operation / Status Display / MStart / Start Control]
↓	<i>Signal: Motor is in stop mode</i>

MStart . <b>Blo</b>	[Operation / Status Display / MStart / Start Control]
↓	<i>Signal: Motor is blocked for starting or transition to Run mode</i>







<b>MStart . SPHBlocked</b>	[Operation / Status Display / MStart / Start Control]
 <i>Signal: Motor is prohibited to start due to starts per hour limits</i>	
<b>MStart . SPHBlockAlarm</b>	[Operation / Status Display / MStart / Start Control]
 <i>Signal: Motor is prohibited to start due to starts per hour limits, would come active in the next stop</i>	
<b>MStart . TBSBlocked</b>	[Operation / Status Display / MStart / Start Control]
 <i>Signal: Motor is prohibited to start due to time between starts limits</i>	
<b>MStart . ThermalBlo</b>	[Operation / Status Display / MStart / Start Control]
 <i>Signal: Thermal block</i>	
<b>MStart . RemBlockStart</b>	[Operation / Status Display / MStart / Start Control]
 <i>Signal: Motor is prohibited to start due to external blocking through digital input DI</i>	
<b>MStart . TransitionTrip</b>	[Operation / Status Display / MStart / Start Control]
 <i>Signal: Start transition fail trip</i>	
<b>MStart . ZSSTrip</b>	[Operation / Status Display / MStart / Start Control]
 <i>Signal: Zero speed trip (possible locked rotor)</i>	
<b>MStart . INSQSP2STFail</b>	[Operation / Status Display / MStart / Start Control]
 <i>Signal: Fail to transit from stop to start based on reported back time</i>	
<b>MStart . INSQSt2RunFail</b>	[Operation / Status Display / MStart / Start Control]
 <i>Signal: Fail to transit from start to run based on reported back time</i>	
<b>MStart . LATBlock</b>	[Operation / Status Display / MStart / Start Control]
 <i>Signal: Long acceleration timer enforced</i>	
<b>MStart . Blo TripCmd</b>	[Operation / Status Display / MStart / Start Control]
 <i>Signal: Trip Command blocked</i>	
<b>MStart . ColdStartSeq</b>	[Operation / Status Display / MStart / Start Control]
 <i>Signal: Motor cold start sequence flag</i>	

<b>MStart . ForcedStart</b>	[Operation / Status Display / MStart / Start Control]
 <i>Signal: Motor being forced to start</i>	
<b>MStart . TripPhaseReverse</b>	[Operation / Status Display / MStart / Start Control]
 <i>Signal: Relay tripped because of phase reverse detection</i>	
<b>MStart . EmergOverrideDI</b>	[Operation / Status Display / MStart / Start Control]
 <i>Signal: Emergency override start blocking through digital input DI</i>	
<b>MStart . EmergOverrideUI</b>	[Operation / Status Display / MStart / Start Control]
 <i>Signal: Emergency override start blocking through front panel</i>	
<b>MStart . ABSActive</b>	[Operation / Status Display / MStart / Start Control]
 <i>Signal: Anti-backspin is active. For certain applications, such as pumping a fluid up a pipe, the motor may be driven backward for a period of time after it stops. The anti-backspin timer prevents starting the motor while it is spinning in the reverse direction.</i>	
<b>MStart . I_Transit</b>	[Operation / Status Display / MStart / Start Control]
 <i>Signal: Current transition signal</i>	
<b>MStart . T_Transit</b>	[Operation / Status Display / MStart / Start Control]
 <i>Signal: Time transition signal</i>	
<b>MStart . MotorStopBlo</b>	[Operation / Status Display / MStart / Start Control]
 <i>Signal: Motor stop block other protection functions</i>	
<b>MStart . Rotating forward</b>	[Operation / Status Display / MStart / Start Control]
 <i>Signal: Rotation Direction forward</i>	
<b>MStart . Rotating backward</b>	[Operation / Status Display / MStart / Start Control]
 <i>Signal: Rotation Direction reverse</i>	
<b>MStart . NOCSBlocked</b>	[Operation / Status Display / MStart / Start Control]
 <i>Signal: Motor is prohibited to start due to number of cold start limits</i>	

<b>MStart . Blo-GOCStart</b>	[Operation / Status Display / MStart / Start Delay Timer]
 <i>Signal: Ground Instantaneous Overcurrent Start Delay. GOC (Instantaneous Overcurrent) elements are blocked for the time programmed under this parameter</i>	
<b>MStart . Blo-IOCStart</b>	[Operation / Status Display / MStart / Start Delay Timer]
 <i>Signal: Phase Instantaneous Overcurrent Start Delay. IOC (Instantaneous Overcurrent) elements are blocked for the time programmed under this parameter</i>	
<b>MStart . Blo-I&lt;Start</b>	[Operation / Status Display / MStart / Start Delay Timer]
 <i>Signal: Underload Start Delay. Underload(Instantaneous Overcurrent) elements are blocked for the time programmed under this parameter</i>	
<b>MStart . Blo-JamStart</b>	[Operation / Status Display / MStart / Start Delay Timer]
 <i>Signal: JAM Start Delay. JAM(Instantaneous Overcurrent) elements are blocked for the time programmed under this parameter</i>	
<b>MStart . Blo-I2&gt;Start</b>	[Operation / Status Display / MStart / Start Delay Timer]
 <i>Signal: Motor start block current unbalance signal</i>	
<b>MStart . Blo-Generic1</b>	[Operation / Status Display / MStart / Start Delay Timer]
 <i>Generic Start Delay. This value can be used to block any protective element.1</i>	
<b>MStart . Blo-Generic2</b>	[Operation / Status Display / MStart / Start Delay Timer]
 <i>Generic Start Delay. This value can be used to block any protective element.2</i>	
<b>MStart . Blo-Generic3</b>	[Operation / Status Display / MStart / Start Delay Timer]
 <i>Generic Start Delay. This value can be used to block any protective element.3</i>	
<b>MStart . Blo-Generic4</b>	[Operation / Status Display / MStart / Start Delay Timer]
 <i>Generic Start Delay. This value can be used to block any protective element.4</i>	
<b>MStart . Blo-Generic5</b>	[Operation / Status Display / MStart / Start Delay Timer]
 <i>Generic Start Delay. This value can be used to block any protective element.5</i>	

### 9.5.6 MStart: Values

MStart . <b>I3 PRMS avg</b>	[Operation / Measured Values / Current RMS]
 Average RMS current of all 3 phases	
MStart . <b>RunTime</b>	[Operation / History / OperationsCr]
 Motor Operation time since last reset.	
MStart . <b>Highest%I2/I1</b>	[Operation / History / OperationsCr]
 Highest %I2/I1 value since last reset. The time stamp indicates the point in time when the maximum unbalanced load has occurred.	
MStart . <b>TRunTime</b>	[Operation / History / TotalCr]
 Motor Operation (Motor run time) time since last reset.	

### 9.5.7 MStart: Statistical Values

MStart . <b>IL1 avg Ib</b>	[Operation / Statistics / Demand / Current Demand]
<input checked="" type="checkbox"/> IL1 average value as multiple of Ib	
MStart . <b>IL2 avg Ib</b>	[Operation / Statistics / Demand / Current Demand]
<input checked="" type="checkbox"/> IL2 average value as multiple of Ib	
MStart . <b>IL3 avg Ib</b>	[Operation / Statistics / Demand / Current Demand]
<input checked="" type="checkbox"/> IL3 average value as multiple of Ib	
MStart . <b>I3P Fla Demand</b>	[Operation / Statistics / Demand / Current Demand]
<input checked="" type="checkbox"/> RMS current of all 3 phases calculated in a fixed demand window as percentages of Ib	
MStart . <b>IL1 max Ib</b>	[Operation / Statistics / Max / Current]
<input checked="" type="checkbox"/> IL1 maximum value as multiple of Ib	
MStart . <b>IL2 max Ib</b>	[Operation / Statistics / Max / Current]
<input checked="" type="checkbox"/> IL2 maximum value as multiple of Ib	

MStart . <b>IL3 max Ib</b>	[Operation / Statistics / Max / Current]
<input checked="" type="checkbox"/> <i>IL3 maximum value as multiple of Ib</i>	

MStart . <b>IL1 min Ib</b>	[Operation / Statistics / Min / Current]
<input checked="" type="checkbox"/> <i>IL1 minimum value as multiple of Ib</i>	

MStart . <b>IL2 min Ib</b>	[Operation / Statistics / Min / Current]
<input checked="" type="checkbox"/> <i>IL2 minimum value as multiple of Ib</i>	

MStart . <b>IL3 min Ib</b>	[Operation / Statistics / Min / Current]
<input checked="" type="checkbox"/> <i>IL3 minimum value as multiple of Ib</i>	

### 9.5.8 MStart: Counters

MStart . <b>IL1 Ib</b>	[Operation / Measured Values / Current RMS]
<input type="checkbox"/> <i>Measured value: Phase current as multiple of Ib</i>	

MStart . <b>IL2 Ib</b>	[Operation / Measured Values / Current RMS]
<input type="checkbox"/> <i>Measured value: Phase current as multiple of Ib</i>	

MStart . <b>IL3 Ib</b>	[Operation / Measured Values / Current RMS]
<input type="checkbox"/> <i>Measured value: Phase current as multiple of Ib</i>	

MStart . <b>I3 P (%Ib) avg</b>	[Operation / Measured Values / Current RMS]
<input type="checkbox"/> <i>Average RMS current of all 3 phases as percentages of Ib</i>	

MStart . <b>StartPerHour</b>	[Operation / Measured Values / Motor]
<input type="checkbox"/> <i>StartPerHour</i>	

MStart . <b>SPH Release</b>	[Operation / Measured Values / Motor]
<input type="checkbox"/> <i>In case that the Motor is blocked by a SPH blocking, this timer needs to be expired before the blocking is released and the next motor start is permitted. The next Motor Start will increment the SPH counter again.</i>	

MStart . <b>WaitTimeStarts</b>	[Operation / Measured Values / Motor]
<input type="checkbox"/> <i>Wait time between starts remained</i>	

<b>MStart . ColdStartPermit</b>	[Operation / Measured Values / Motor]
#	<i>Number of cold starts remaining</i>
<b>MStart . AntiBackSpin</b>	[Operation / Measured Values / Motor]
#	<i>Anti-BackspinTimer</i>
<b>MStart . OCNT</b>	[Operation / History / OperationsCr]
#	<i>Motor Operation count since last reset.</i>
<b>MStart . HighestStartI</b>	[Operation / History / OperationsCr]
#	<i>Highest starting phase current. The time stamp indicates the point in time when the maximum current has occurred.</i>
<b>MStart . HighestRunI</b>	[Operation / History / OperationsCr]
#	<i>Highest running phase current. The time stamp indicates the point in time when the maximum current has occurred.</i>
<b>MStart . nEmrgOvr</b>	[Operation / History / OperationsCr]
#	<i>Number of emergency overrides since last reset.</i>
<b>MStart . nTRNTrips</b>	[Operation / History / TripCmdCr]
#	<i>Number of transition trips since last reset.</i>
<b>MStart . nRevTrips</b>	[Operation / History / TripCmdCr]
#	<i>Number of reverse spinning trips since last reset.</i>
<b>MStart . nZSWTrips</b>	[Operation / History / TripCmdCr]
#	<i>Number of zero speed switch trips since last reset.</i>
<b>MStart . nISQT</b>	[Operation / History / TripCmdCr]
#	<i>Number of incomplete sequence trips since last reset.</i>
<b>MStart . nSPHBlocks</b>	[Operation / History / TripCmdCr]
#	<i>Number of start per hour blocks since last reset.</i>
<b>MStart . nTBSBlocks</b>	[Operation / History / TripCmdCr]
#	<i>Number of time between start blocks since last reset.</i>

MStart . **TOCS**



[Operation / History / TotalCr]

# *Total Motor Operation count since last reset.*



## 9.6 I[1] ... I[6]



### Phase Overcurrent Stage



#### 9.6.1 I[1]: Device Planning Parameters

I[1] . <b>Mode</b>	[Device planning]	
non directional	"-", non directional  I>.	S.3
	Phase Overcurrent Stage, general operation mode	



#### 9.6.2 I[1]: Global Parameters



I[1] . <b>ExBlo1</b>	[Protection Para / Global Prot Para / I-Prot / I[1]]	
I[1] . <b>ExBlo2</b>		
"_"	"-" ... Sys . Internal test state  1..n, Assignment List.	P.2
	External blocking of the module, if blocking is activated (allowed) within a parameter set and if the state of the assigned signal is true.	



I[1] . <b>ExBlo dur. Mot.Strt</b>	[Protection Para / Global Prot Para / I-Prot / I[1]]	
MStart . Blo-IOCStart	"-" ... MStart . Blo-FrqStart  1..n, Trip Cmds.	P.2
	External blocking of the module, if the state of the assigned signal is true. This way it is possible to block the module during the motor start phase.	



I[1] . <b>ExBlo TripCmd</b>	[Protection Para / Global Prot Para / I-Prot / I[1]]	
"_"	"-" ... Sys . Internal test state  1..n, Assignment List.	P.2
	External blocking of the Trip Command of the module/the stage, if blocking is activated (allowed) within a parameter set and if the state of the assigned signal is true.	





I[1] . <b>Ex rev Interl</b>	[Protection Para / Global Prot Para / I-Prot / I[1]]	
"_"	"_" ... Sys . Internal test state  1..n, Assignment List.	P.2
	<i>External blocking of the module by external reverse interlocking, if blocking is activated (allowed) within a parameter set and if the state of the assigned signal is true.</i>	



I[1] . <b>AdaptSet 1</b>	[Protection Para / Global Prot Para / I-Prot / I[1]]	
"_"	"_" ... Logics . LE80.Out inverted  AdaptSet.	P.2
	<i>Assignment Adaptive Parameter 1</i>	

I[1] . <b>AdaptSet 2</b>	[Protection Para / Global Prot Para / I-Prot / I[1]]	
"_"	"_" ... Logics . LE80.Out inverted  AdaptSet.	P.2
	<i>Assignment Adaptive Parameter 2</i>	

I[1] . <b>AdaptSet 3</b>	[Protection Para / Global Prot Para / I-Prot / I[1]]	
"_"	"_" ... Logics . LE80.Out inverted  AdaptSet.	P.2
	<i>Assignment Adaptive Parameter 3</i>	

I[1] . <b>AdaptSet 4</b>	[Protection Para / Global Prot Para / I-Prot / I[1]]	
"_"	"_" ... Logics . LE80.Out inverted  AdaptSet.	P.2
	<i>Assignment Adaptive Parameter 4</i>	

### 9.6.3 I[1]: Setting Group Parameters

I[1] . <b>Function</b>	[Protection Para / Set 1...4 / I-Prot / I[1]]	
active	inactive, active  Mode.	P.2
	<i>Permanent activation or deactivation of module/stage.</i>	


I[1] . <b>ExBlo Fc</b>	[Protection Para / Set 1...4 / I-Prot / I[1]]	
inactive	inactive, active ↳ active/inactive.	P.2
🔗	<i>Activate (allow) or inactivate (disallow) blocking of the module/stage. This parameter is only effective if a signal is assigned to the corresponding global protection parameter. If the signal becomes true, those modules/stages are blocked that are parameterized "ExBlo Fc=active".</i>	



I[1] . <b>Ex rev Interl Fc</b>	[Protection Para / Set 1...4 / I-Prot / I[1]]	
inactive	inactive, active ↳ active/inactive.	P.2
🔗	<i>Activate (allow) or inactivate (disallow) blocking of the module/stage. This parameter is only effective if a signal is assigned to the corresponding global protection parameter. If the signal becomes true, those modules/stages are blocked that are parameterized "Ex rev Interl Fc = active".</i>	


I[1] . <b>Blo TripCmd</b>	[Protection Para / Set 1...4 / I-Prot / I[1]]	
inactive	inactive, active ↳ Mode.	P.2
🔗	<i>Permanent blocking of the Trip Command of the module/stage.</i>	


I[1] . <b>ExBlo TripCmd Fc</b>	[Protection Para / Set 1...4 / I-Prot / I[1]]	
inactive	inactive, active ↳ active/inactive.	P.2
🔗	<i>Activate (allow) or inactivate (disallow) blocking of the module/stage. This parameter is only effective if a signal is assigned to the corresponding global protection parameter. If the signal becomes true, those modules/stages are blocked that are parameterized "ExBlo TripCmd Fc=active".</i>	



I[1] . <b>Measuring method</b>	[Protection Para / Set 1...4 / I-Prot / I[1]]	
Fundamental	Fundamental, True RMS, I2 ↳ Measuring method.	P.2
🔗	<i>Measuring method: fundamental or rms or 3rd harmonic (only generator protection relays)</i>	



I[1] . <b>I&gt;</b>	[Protection Para / Set 1...4 / I-Prot / I[1]]	
2.0In ⊕ Adapt. Param.	0.02In ... 40.00In	P.2
 <i>If the pickup value is exceeded, the module/element starts to time out to trip.</i>		

I[1] . <b>Char</b>	[Protection Para / Set 1...4 / I-Prot / I[1]]	
DEFT ⊕ Adapt. Param.	DEFT ... I4T  Char.	P.2
 <i>Characteristic</i>		


I[1] . <b>t</b>	[Protection Para / Set 1...4 / I-Prot / I[1]]	
0.5s ⊕ Adapt. Param.	0.00s ... 300.00s	P.2
 <i>Tripping delay</i>		


I[1] . <b>tchar</b>	[Protection Para / Set 1...4 / I-Prot / I[1]]	
1 ⊕ Adapt. Param.	0.02 ... 20.00	P.2
 <i>Time multiplier/tripping characteristic factor. The setting range depends on the selected tripping curve.</i>		


I[1] . <b>Reset Mode</b>	[Protection Para / Set 1...4 / I-Prot / I[1]]	
instantaneous ⊕ Adapt. Param.	instantaneous, delayed, calculated  Reset Mode.	P.2
 <i>Reset Mode</i>		


I[1] . <b>t-reset delay</b>	[Protection Para / Set 1...4 / I-Prot / I[1]]	
0s	0.00s ... 60.00s	P.2
<i>Only available if:</i> <ul style="list-style-type: none"> <li>I[1] . Reset Mode = delayed</li> </ul>		
 Adapt. Param.		
 <i>Reset delay for intermittent phase failures (INV characteristics only)</i>		


### 9.6.4 I[1]: Input States


I[1] . <b>ExBlo1-I</b>	[Operation / Status Display / I-Prot / I[1]]
 <i>Module input state: External blocking1</i>	


I[1] . <b>ExBlo2-I</b>	[Operation / Status Display / I-Prot / I[1]]
 <i>Module input state: External blocking2</i>	


I[1] . <b>ExBlo TripCmd-I</b>	[Operation / Status Display / I-Prot / I[1]]
 <i>Module input state: External Blocking of the Trip Command</i>	

I[1] . <b>Ex rev Interl-I</b>	[Operation / Status Display / I-Prot / I[1]]
 <i>Module input state: External reverse interlocking</i>	

I[1] . <b>AdaptSet1-I</b>	[Operation / Status Display / I-Prot / I[1]]
 <i>Module input state: Adaptive Parameter1</i>	

I[1] . <b>AdaptSet2-I</b>	[Operation / Status Display / I-Prot / I[1]]
 <i>Module input state: Adaptive Parameter2</i>	

I[1] . <b>AdaptSet3-I</b>	[Operation / Status Display / I-Prot / I[1]]
 <i>Module input state: Adaptive Parameter3</i>	

I[1] . <b>AdaptSet4-I</b>	[Operation / Status Display / I-Prot / I[1]]
 <i>Module input state: Adaptive Parameter4</i>	

### 9.6.5 I[1]: Signals (Output States)

I[1] . <b>active</b>	[Operation / Status Display / All Actives] [Operation / Status Display / I-Prot / I[1]]
⬇ Signal: active	
I[1] . <b>Alarm</b>	[Operation / Status Display / Alarms] [Operation / Status Display / I-Prot / I[1]]
⬇ Signal: Alarm	
I[1] . <b>Trip</b>	[Operation / Status Display / Trips] [Operation / Status Display / I-Prot / I[1]]
⬇ Signal: Trip	
I[1] . <b>TripCmd</b>	[Operation / Status Display / TripCmds] [Operation / Status Display / I-Prot / I[1]]
⬇ Signal: Trip Command	
I[1] . <b>ExBlo</b>	[Operation / Status Display / I-Prot / I[1]]
⬇ Signal: External Blocking	
I[1] . <b>Ex rev Interl</b>	[Operation / Status Display / I-Prot / I[1]]
⬇ Signal: External reverse Interlocking	
I[1] . <b>Blo TripCmd</b>	[Operation / Status Display / I-Prot / I[1]]
⬇ Signal: Trip Command blocked	
I[1] . <b>ExBlo TripCmd</b>	[Operation / Status Display / I-Prot / I[1]]
⬇ Signal: External Blocking of the Trip Command	
I[1] . <b>Alarm L1</b>	[Operation / Status Display / I-Prot / I[1]]
⬇ Signal: Alarm L1	

I[1] . <b>Alarm L2</b>	[Operation / Status Display / I-Prot / I[1]]
↕	<i>Signal: Alarm L2</i>
I[1] . <b>Alarm L3</b>	[Operation / Status Display / I-Prot / I[1]]
↕	<i>Signal: Alarm L3</i>
I[1] . <b>Trip L1</b>	[Operation / Status Display / I-Prot / I[1]]
↕	<i>Signal: General Trip Phase L1</i>
I[1] . <b>Trip L2</b>	[Operation / Status Display / I-Prot / I[1]]
↕	<i>Signal: General Trip Phase L2</i>
I[1] . <b>Trip L3</b>	[Operation / Status Display / I-Prot / I[1]]
↕	<i>Signal: General Trip Phase L3</i>
I[1] . <b>DefaultSet</b>	[Operation / Status Display / I-Prot / I[1]]
↕	<i>Signal: Default Parameter Set</i>
I[1] . <b>AdaptSet 1</b>	[Operation / Status Display / I-Prot / I[1]]
↕	<i>Signal: Adaptive Parameter 1</i>
I[1] . <b>AdaptSet 2</b>	[Operation / Status Display / I-Prot / I[1]]
↕	<i>Signal: Adaptive Parameter 2</i>
I[1] . <b>AdaptSet 3</b>	[Operation / Status Display / I-Prot / I[1]]
↕	<i>Signal: Adaptive Parameter 3</i>
I[1] . <b>AdaptSet 4</b>	[Operation / Status Display / I-Prot / I[1]]
↕	<i>Signal: Adaptive Parameter 4</i>

### 9.6.6 I[1]: Counters

I[1] . <b>NumberOfAlarms</b>	[Operation / History / AlarmCr]
#	<i>Number of alarms since last reset.</i>

I[1] . **NumberOfTripCmds**


[Operation / History / TripCmdCr]


# *Number of trip commands since last reset*

## 9.7 IG[1] ... IG[4]


Earth current protection - Stage


### 9.7.1 IG[1]: Device Planning Parameters

IG[1] . <b>Mode</b>	[Device planning]	
"_"	"_", non directional ↳ Earth overcurrent.	S.3
 <i>Earth current protection - Stage, general operation mode</i>		


IG[1] . <b>Superv. only</b>	[Device planning]	
no	no, yes ↳ yes/no.	S.3
 <i>Earth current protection - Stage, if set to "Yes": Restriction of the function to a supervision functionality, i.e. there is no general alarm, no general trip and no trip command.</i>		


### 9.7.2 IG[1]: Global Parameters

IG[1] . <b>ExBlo1</b>	[Protection Para / Global Prot Para / I-Prot / IG[1]]	
IG[1] . <b>ExBlo2</b>		
"_"	"_" ... Sys . Internal test state ↳ 1..n, Assignment List.	P.2
 <i>External blocking of the module, if blocking is activated (allowed) within a parameter set and if the state of the assigned signal is true.</i>		


IG[1] . <b>ExBlo dur. Mot.Strt</b>	[Protection Para / Global Prot Para / I-Prot / IG[1]]	
"_"	"_" ... MStart . Blo-FrqStart ↳ 1..n, Trip Cmds.	P.2
 <i>External blocking of the module, if the state of the assigned signal is true. This way it is possible to block the module during the motor start phase.</i>		




<b>IG[1] . ExBlo TripCmd</b>	[Protection Para / Global Prot Para / I-Prot / IG[1]]	
"_"	"_" ... Sys . Internal test state	P.2
Only available if:	↳ 1..n, Assignment List.	
• IG[1] . Superv. only = no		
	<i>External blocking of the Trip Command of the module/the stage, if blocking is activated (allowed) within a parameter set and if the state of the assigned signal is true.</i>	

<b>IG[1] . Ex rev Interl</b>	[Protection Para / Global Prot Para / I-Prot / IG[1]]	
"_"	"_" ... Sys . Internal test state	P.2
	↳ 1..n, Assignment List.	
	<i>External blocking of the module by external reverse interlocking, if blocking is activated (allowed) within a parameter set and if the state of the assigned signal is true.</i>	



<b>IG[1] . AdaptSet 1</b>	[Protection Para / Global Prot Para / I-Prot / IG[1]]	
"_"	"_" ... Logics . LE80.Out inverted	P.2
	↳ AdaptSet.	
	<i>Assignment Adaptive Parameter 1</i>	



<b>IG[1] . AdaptSet 2</b>	[Protection Para / Global Prot Para / I-Prot / IG[1]]	
"_"	"_" ... Logics . LE80.Out inverted	P.2
	↳ AdaptSet.	
	<i>Assignment Adaptive Parameter 2</i>	



<b>IG[1] . AdaptSet 3</b>	[Protection Para / Global Prot Para / I-Prot / IG[1]]	
"_"	"_" ... Logics . LE80.Out inverted	P.2
	↳ AdaptSet.	
	<i>Assignment Adaptive Parameter 3</i>	



<b>IG[1] . AdaptSet 4</b>	[Protection Para / Global Prot Para / I-Prot / IG[1]]	
"_"	"_" ... Logics . LE80.Out inverted	P.2
	↳ AdaptSet.	
	<i>Assignment Adaptive Parameter 4</i>	



### 9.7.3 IG[1]: Setting Group Parameters


IG[1] . <b>Function</b>	[Protection Para / Set 1...4 / I-Prot / IG[1]]
inactive	inactive, active  Mode.
 Permanent activation or deactivation of module/stage.	


IG[1] . <b>ExBlo Fc</b>	[Protection Para / Set 1...4 / I-Prot / IG[1]]
inactive	inactive, active  active/inactive.
 Activate (allow) or inactivate (disallow) blocking of the module/stage. This parameter is only effective if a signal is assigned to the corresponding global protection parameter. If the signal becomes true, those modules/stages are blocked that are parameterized "ExBlo Fc=active".	


IG[1] . <b>Ex rev Interl Fc</b>	[Protection Para / Set 1...4 / I-Prot / IG[1]]
inactive	inactive, active  active/inactive.
 Activate (allow) or inactivate (disallow) blocking of the module/stage. This parameter is only effective if a signal is assigned to the corresponding global protection parameter. If the signal becomes true, those modules/stages are blocked that are parameterized "Ex rev Interl Fc = active".	



IG[1] . <b>Blo TripCmd</b>	[Protection Para / Set 1...4 / I-Prot / IG[1]]
inactive	inactive, active  Mode.
Only available if: <ul style="list-style-type: none"> <li>• IG[1] . Superv. only = no</li> </ul>	
 Permanent blocking of the Trip Command of the module/stage.	



IG[1] . <b>ExBlo TripCmd Fc</b>	[Protection Para / Set 1...4 / I-Prot / IG[1]]
inactive	inactive, active  active/inactive.
Only available if: <ul style="list-style-type: none"> <li>• IG[1] . Superv. only = no</li> </ul>	
 Activate (allow) or inactivate (disallow) blocking of the module/stage. This parameter is only effective if a signal is assigned to the corresponding global protection parameter. If the signal becomes true, those modules/stages are blocked that are parameterized "ExBlo TripCmd Fc=active".	



IG[1] . <b>IG Source</b>		[Protection Para / Set 1...4 / I-Prot / IG[1]]
CT . calculated	CT . sensitive measurement, CT . measured, CT . calculated	P.2
		↳ Measuring Channel.
 Selection if measured or calculated ground current should be used.		


IG[1] . <b>Measuring method</b>		[Protection Para / Set 1...4 / I-Prot / IG[1]]
Fundamental	Fundamental, True RMS	P.2
		↳ Measuring method.
 Measuring method: fundamental or rms or 3rd harmonic (only generator protection relays)		


IG[1] . <b>Meas Circuit Superv</b>		[Protection Para / Set 1...4 / I-Prot / IG[1]]
Sys . inactive	Sys . inactive	P.2
		↳ VTS Block.
 Activates the use of the measuring circuit supervision. In this case the module will be blocked if a measuring circuit supervision module (e.g. LOP, VTS) signals a disturbed measuring circuit (e.g. caused by a fuse failure).		



IG[1] . <b>IG&gt;</b>		[Protection Para / Set 1...4 / I-Prot / IG[1]]
0.02In	0.02In ... 20.00In	P.2
 Adapt. Param.		
 If the pickup value is exceeded, the module/stage will be started.		


IG[1] . <b>IGs&gt;</b>		[Protection Para / Set 1...4 / I-Prot / IG[1]]
0.02In	0.002In ... 2.000In	P.2
 Adapt. Param.		
 If the pickup value is exceeded, the module/stage will be started.		

IG[1] . <b>Char</b>		[Protection Para / Set 1...4 / I-Prot / IG[1]]
DEFT	DEFT ... RXIDG	P.2
 Adapt. Param.		↳ Char.
 Characteristic		


<b>IG[1] . t</b>	[Protection Para / Set 1...4 / I-Prot / IG[1]]	
0.00s	0.00s ... 300.00s	P.2
⊕ Adapt. Param.		
 <i>Tripping delay</i>		


<b>IG[1] . tchar</b>	[Protection Para / Set 1...4 / I-Prot / IG[1]]	
1	0.02 ... 20.00	P.2
⊕ Adapt. Param.		
 <i>Time multiplier/tripping characteristic factor. The setting range depends on the selected tripping curve.</i>		

<b>IG[1] . Reset Mode</b>	[Protection Para / Set 1...4 / I-Prot / IG[1]]	
instantaneous	instantaneous, delayed, calculated	P.2
⊕ Adapt. Param.	 <b>Reset Mode.</b>	
 <i>Reset Mode</i>		

<b>IG[1] . t-reset delay</b>	[Protection Para / Set 1...4 / I-Prot / IG[1]]	
0.00s	0.00s ... 60.00s	P.2
<i>Only available if:</i>		
• IG[1] . Reset Mode = delayed		
⊕ Adapt. Param.		
 <i>Reset delay for intermittent phase failures (INV characteristics only)</i>		

### 9.7.4 IG[1]: Input States

<b>IG[1] . ExBlo1-I</b>	[Operation / Status Display / I-Prot / IG[1]]	
 <i>Module input state: External blocking1</i>		

<b>IG[1] . ExBlo2-I</b>	[Operation / Status Display / I-Prot / IG[1]]	
 <i>Module input state: External blocking2</i>		

IG[1] . <b>ExBlo TripCmd-I</b>	[Operation / Status Display / I-Prot / IG[1]]
↓	<p><i>Only available if:</i></p> <ul style="list-style-type: none"> <li>• IG[1] . Superv. only = no</li> </ul> <p><i>Module input state: External Blocking of the Trip Command</i></p>

IG[1] . <b>Ex rev Interl-I</b>	[Operation / Status Display / I-Prot / IG[1]]
↓	<i>Module input state: External reverse interlocking</i>

IG[1] . <b>AdaptSet1-I</b>	[Operation / Status Display / I-Prot / IG[1]]
↓	<i>Module input state: Adaptive Parameter1</i>

IG[1] . <b>AdaptSet2-I</b>	[Operation / Status Display / I-Prot / IG[1]]
↓	<i>Module input state: Adaptive Parameter2</i>

IG[1] . <b>AdaptSet3-I</b>	[Operation / Status Display / I-Prot / IG[1]]
↓	<i>Module input state: Adaptive Parameter3</i>

IG[1] . <b>AdaptSet4-I</b>	[Operation / Status Display / I-Prot / IG[1]]
↓	<i>Module input state: Adaptive Parameter4</i>

### 9.7.5 IG[1]: Signals (Output States)

IG[1] . <b>active</b>	[Operation / Status Display / All Actives] [Operation / Status Display / I-Prot / IG[1]]
↑	<i>Signal: active</i>

IG[1] . <b>Alarm</b>	[Operation / Status Display / Alarms] [Operation / Status Display / I-Prot / IG[1]]
↑	<i>Signal: Alarm IG</i>

IG[1] . <b>Trip</b>	[Operation / Status Display / Trips] [Operation / Status Display / I-Prot / IG[1]]
↑	<i>Signal: Trip</i>

<b>IG[1] . TripCmd</b>	[Operation / Status Display / TripCmds] [Operation / Status Display / I-Prot / IG[1]]
<p>⤴ <i>Only available if:</i></p> <ul style="list-style-type: none"> <li>• IG[1] . Superv. only = no</li> </ul> <p><i>Signal: Trip Command</i></p>	
<b>IG[1] . ExBlo</b>	[Operation / Status Display / I-Prot / IG[1]]
<p>⤴ <i>Signal: External Blocking</i></p>	
<b>IG[1] . Ex rev Interl</b>	[Operation / Status Display / I-Prot / IG[1]]
<p>⤴ <i>Signal: External reverse Interlocking</i></p>	
<b>IG[1] . Blo TripCmd</b>	[Operation / Status Display / I-Prot / IG[1]]
<p>⤴ <i>Only available if:</i></p> <ul style="list-style-type: none"> <li>• IG[1] . Superv. only = no</li> </ul> <p><i>Signal: Trip Command blocked</i></p>	
<b>IG[1] . ExBlo TripCmd</b>	[Operation / Status Display / I-Prot / IG[1]]
<p>⤴ <i>Only available if:</i></p> <ul style="list-style-type: none"> <li>• IG[1] . Superv. only = no</li> </ul> <p><i>Signal: External Blocking of the Trip Command</i></p>	
<b>IG[1] . DefaultSet</b>	[Operation / Status Display / I-Prot / IG[1]]
<p>⤴ <i>Signal: Default Parameter Set</i></p>	
<b>IG[1] . AdaptSet 1</b>	[Operation / Status Display / I-Prot / IG[1]]
<p>⤴ <i>Signal: Adaptive Parameter 1</i></p>	
<b>IG[1] . AdaptSet 2</b>	[Operation / Status Display / I-Prot / IG[1]]
<p>⤴ <i>Signal: Adaptive Parameter 2</i></p>	
<b>IG[1] . AdaptSet 3</b>	[Operation / Status Display / I-Prot / IG[1]]
<p>⤴ <i>Signal: Adaptive Parameter 3</i></p>	

IG[1] . <b>AdaptSet 4</b>	[Operation / Status Display / I-Prot / IG[1]]
↕	<i>Signal: Adaptive Parameter 4</i>

### 9.7.6 IG[1]: Counters


IG[1] . <b>NumberOfAlarms</b>	[Operation / History / AlarmCr]
#	<i>Number of alarms since last reset.</i>


IG[1] . <b>NumberOfTripCmds</b>	[Operation / History / TripCmdCr]
#	<p><i>Only available if:</i></p> <ul style="list-style-type: none"> <li>• IG[1] . Superv. only = no</li> </ul> <p><i>Number of trip commands since last reset</i></p>


## 9.8 ThR


Thermal replica module

### 9.8.1 ThR: Global Parameters

ThR . <b>ExBlo1</b>	[Protection Para / Global Prot Para / I-Prot / ThR]	
ThR . <b>ExBlo2</b>		
"_"	"_" ... Sys . Internal test state  ↳ 1..n, Assignment List.	P.2
	<i>External blocking of the module, if blocking is activated (allowed) within a parameter set and if the state of the assigned signal is true.</i>	

ThR . <b>ExBlo TripCmd</b>	[Protection Para / Global Prot Para / I-Prot / ThR]	
"_"	"_" ... Sys . Internal test state  ↳ 1..n, Assignment List.	P.2
	<i>External blocking of the Trip Command of the module/the stage, if blocking is activated (allowed) within a parameter set and if the state of the assigned signal is true.</i>	



ThR . <b>Use RTD values</b>	[Protection Para / Global Prot Para / I-Prot / ThR]	
inactive <i>Avail. depends on HW</i>	If: slot 2 = 4 Digital Inputs   4 Output Relays , Analog Output  IRIG-B  • inactive, active  If: slot 2 ≠ 4 Digital Inputs   4 Output Relays , Analog Output  IRIG-B  • inactive  ↳ Mode.	P.2
	<i>Take RTD values into account for the calculation of the Thermal Model.</i>	



ThR . <b>K2</b>	[Protection Para / Global Prot Para / I-Prot / ThR]	
6.01	0.10 ... 10.00	P.2
	<i>This value represents the negative sequence current weighting factor of the motor.</i>	







ThR . <b><math>\tau</math>-cool</b>	[Protection Para / Global Prot Para / I-Prot / ThR]	
60s	5s ... 240s	P.2
 <i>Cooling time constant</i>		



## 9.8.2 ThR: Setting Group Parameters


ThR . <b>Function</b>	[Protection Para / Set 1...4 / I-Prot / ThR]	
active	inactive, active  Mode.	P.2
 <i>Permanent activation or deactivation of module/stage.</i>		


ThR . <b>ExBlo Fc</b>	[Protection Para / Set 1...4 / I-Prot / ThR]	
inactive	inactive, active  active/inactive.	P.2
 <i>Activate (allow) or inactivate (disallow) blocking of the module/stage. This parameter is only effective if a signal is assigned to the corresponding global protection parameter. If the signal becomes true, those modules/stages are blocked that are parameterized "ExBlo Fc=active".</i>		



ThR . <b>Blo TripCmd</b>	[Protection Para / Set 1...4 / I-Prot / ThR]	
inactive	inactive, active  Mode.	P.2
 <i>Permanent blocking of the Trip Command of the module/stage.</i>		


ThR . <b>ExBlo TripCmd Fc</b>	[Protection Para / Set 1...4 / I-Prot / ThR]	
inactive	inactive, active  active/inactive.	P.2
 <i>Activate (allow) or inactivate (disallow) blocking of the module/stage. This parameter is only effective if a signal is assigned to the corresponding global protection parameter. If the signal becomes true, those modules/stages are blocked that are parameterized "ExBlo TripCmd Fc=active".</i>		


ThR . <b>Trip Function</b>	[Protection Para / Set 1...4 / I-Prot / ThR]	
active	inactive, active  Mode.	P.2
	<i>Turn on or off the trip function</i>	

ThR . <b>Trip Threshold</b>	[Protection Para / Set 1...4 / I-Prot / ThR]	
0.99	0.60 ... 0.99	P.2
	<i>Trip threshold at which the thermal model will trip, based on percentage of thermal capacity used. This value should typically always be set at 0.99</i>	


ThR . <b>t-Trip Delay</b>	[Protection Para / Set 1...4 / I-Prot / ThR]	
0.0s	0.0s ... 3600.0s	P.2
	<i>Thermal capacity used trip delay</i>	

ThR . <b>Alarm Function</b>	[Protection Para / Set 1...4 / I-Prot / ThR]	
active	inactive, active  Mode.	P.2
	<i>Turn on or off the alarm function</i>	


ThR . <b>Alarm Threshold</b>	[Protection Para / Set 1...4 / I-Prot / ThR]	
0.70	0.60 ... 0.99	P.2
	<i>Alarm threshold at which the thermal model will trip, based on percentage of thermal capacity used</i>	


ThR . <b>t-Alarm Delay</b>	[Protection Para / Set 1...4 / I-Prot / ThR]	
1min	1min ... 360min	P.2
	<i>Thermal capacity used alarm delay</i>	

### 9.8.3 ThR: Direct Controls


ThR . <b>Res I2T Used</b>	[Operation / Reset/Acknowledge / Reset]	
inactive	inactive, active  Mode.	S.3
<input checked="" type="radio"/> <i>Reset thermal capacity used.</i>		


### 9.8.4 ThR: Input States


ThR . <b>ExBlo1-I</b>	[Operation / Status Display / I-Prot / ThR]
ThR . <b>ExBlo2-I</b>	
	<i>Module input state: External blocking</i>

ThR . <b>ExBlo TripCmd-I</b>	[Operation / Status Display / I-Prot / ThR]
	<i>Module input state: External Blocking of the Trip Command</i>

### 9.8.5 ThR: Signals (Output States)

ThR . <b>active</b>	[Operation / Status Display / All Actives] [Operation / Status Display / I-Prot / ThR]
	<i>Signal: active</i>

ThR . <b>Alarm</b>	[Operation / Status Display / Alarms] [Operation / Status Display / I-Prot / ThR]
	<i>Signal: Alarm</i>

ThR . <b>Alarm Pickup</b>	[Operation / Status Display / Alarms] [Operation / Status Display / I-Prot / ThR]
	<i>Signal: Alarm Pickup</i>

ThR . <b>Alarm Timeout</b>	[Operation / Status Display / Alarms] [Operation / Status Display / I-Prot / ThR]
⬇	<i>Signal: Alarm Timeout</i>
ThR . <b>Trip</b>	[Operation / Status Display / Trips] [Operation / Status Display / I-Prot / ThR]
⬇	<i>Signal: Trip</i>
ThR . <b>TripCmd</b>	[Operation / Status Display / TripCmds] [Operation / Status Display / I-Prot / ThR]
⬇	<i>Signal: Trip Command</i>
ThR . <b>ExBlo</b>	[Operation / Status Display / I-Prot / ThR]
⬇	<i>Signal: External Blocking</i>
ThR . <b>Blo TripCmd</b>	[Operation / Status Display / I-Prot / ThR]
⬇	<i>Signal: Trip Command blocked</i>
ThR . <b>ExBlo TripCmd</b>	[Operation / Status Display / I-Prot / ThR]
⬇	<i>Signal: External Blocking of the Trip Command</i>
ThR . <b>RTD effective</b>	[Operation / Status Display / I-Prot / ThR]
⬇	<p><i>This state becomes true if the following conditions are all fulfilled:</i></p> <ul style="list-style-type: none"> <li>- <i>the state "Load above SF" is true,</i></li> <li>- <i>RTD functionality is active,</i></li> <li>- <i>for at least one temperature a valid value above 0°C is being displayed.</i></li> </ul>
ThR . <b>Load above SF</b>	[Operation / Status Display / I-Prot / ThR]
⬇	<i>"Load above Service Factor": If the current exceeds the set value of "UTC" ("Ultimate trip threshold") then the used thermal capacity counts up and the state "Load above SF" is becoming true. If the current is below the "UTC" value this state is false.</i>



### 9.8.6 ThR: Counters

ThR . <b>I2T Used</b>	[Operation / Measured Values / ThR]
#	<i>Thermal capacity used.</i>
ThR . <b>I2T Remained</b>	[Operation / Measured Values / ThR]
#	<i>Thermal capacity remained.</i>
ThR . <b>nAlarms</b>	[Operation / History / AlarmCr]
#	<i>nAlarms</i>
ThR . <b>NumberOfTripCmds</b>	[Operation / History / TripCmdCr]
#	<i>Number of trip commands since last reset</i>



## 9.9 Jam[1] ... Jam[2]



Locked Rotor (JAM)



### 9.9.1 Jam[1]: Device Planning Parameters

Jam[1] . <b>Mode</b>	[Device planning]	
use	"-", use  Mode.	S.3
	<i>Locked Rotor (JAM), general operation mode</i>	


### 9.9.2 Jam[1]: Global Parameters


Jam[1] . <b>ExBlo1</b>	[Protection Para / Global Prot Para / JAM-Prot / Jam[1]]	
Jam[1] . <b>ExBlo2</b>		
"_"	"-" ... Sys . Internal test state  1..n, Assignment List.	P.2
	<i>External blocking of the module, if blocking is activated (allowed) within a parameter set and if the state of the assigned signal is true.</i>	


Jam[1] . <b>ExBlo dur. Mot.Strt</b>	[Protection Para / Global Prot Para / JAM-Prot / Jam[1]]	
MStart . Blo-JamStart	"-" ... MStart . Blo-FrqStart  1..n, Trip Cmds.	P.2
	<i>External blocking of the module, if the state of the assigned signal is true. This way it is possible to block the module during the motor start phase.</i>	


Jam[1] . <b>ExBlo TripCmd</b>	[Protection Para / Global Prot Para / JAM-Prot / Jam[1]]	
"_"	"-" ... Sys . Internal test state  1..n, Assignment List.	P.2
	<i>External blocking of the Trip Command of the module/the stage, if blocking is activated (allowed) within a parameter set and if the state of the assigned signal is true.</i>	


### 9.9.3 Jam[1]: Setting Group Parameters


<b>Jam[1] . Function</b>		[Protection Para / Set 1...4 / JAM-Prot / Jam[1]]
inactive	inactive, active	P.2
	↳ Mode.	
 Permanent activation or deactivation of module/stage.		

<b>Jam[1] . ExBlo Fc</b>		[Protection Para / Set 1...4 / JAM-Prot / Jam[1]]
inactive	inactive, active	P.2
	↳ active/inactive.	
 Activate (allow) or inactivate (disallow) blocking of the module/stage. This parameter is only effective if a signal is assigned to the corresponding global protection parameter. If the signal becomes true, those modules/stages are blocked that are parameterized "ExBlo Fc=active".		

<b>Jam[1] . Blo TripCmd</b>		[Protection Para / Set 1...4 / JAM-Prot / Jam[1]]
inactive	inactive, active	P.2
	↳ Mode.	
 Permanent blocking of the Trip Command of the module/stage.		

<b>Jam[1] . ExBlo TripCmd Fc</b>		[Protection Para / Set 1...4 / JAM-Prot / Jam[1]]
inactive	inactive, active	P.2
	↳ active/inactive.	
 Activate (allow) or inactivate (disallow) blocking of the module/stage. This parameter is only effective if a signal is assigned to the corresponding global protection parameter. If the signal becomes true, those modules/stages are blocked that are parameterized "ExBlo TripCmd Fc=active".		

<b>Jam[1] . Pickup</b>		[Protection Para / Set 1...4 / JAM-Prot / Jam[1]]
10lb	1.00lb ... 12.00lb	P.2
 JAM based on a multiplier of lb		

<b>Jam[1] . t</b>		[Protection Para / Set 1...4 / JAM-Prot / Jam[1]]
2.0s	0.0s ... 1200.0s	P.2
 Tripping delay		

### 9.9.4 Jam[1]: Input States

Jam[1] . <b>ExBlo1-I</b>	[Operation / Status Display / JAM-Prot / Jam[1]]
↓	<i>Module input state: External blocking1</i>
Jam[1] . <b>ExBlo2-I</b>	[Operation / Status Display / JAM-Prot / Jam[1]]
↓	<i>Module input state: External blocking2</i>
Jam[1] . <b>ExBlo TripCmd-I</b>	[Operation / Status Display / JAM-Prot / Jam[1]]
↓	<i>Module input state: External Blocking of the Trip Command</i>

### 9.9.5 Jam[1]: Signals (Output States)

Jam[1] . <b>active</b>	[Operation / Status Display / All Actives] [Operation / Status Display / JAM-Prot / Jam[1]]
↑	<i>Signal: active</i>
Jam[1] . <b>Alarm</b>	[Operation / Status Display / Alarms] [Operation / Status Display / JAM-Prot / Jam[1]]
↑	<i>Signal: Alarm</i>
Jam[1] . <b>Trip</b>	[Operation / Status Display / Trips] [Operation / Status Display / JAM-Prot / Jam[1]]
↑	<i>Signal: Trip</i>
Jam[1] . <b>TripCmd</b>	[Operation / Status Display / TripCmds] [Operation / Status Display / JAM-Prot / Jam[1]]
↑	<i>Signal: Trip Command</i>
Jam[1] . <b>ExBlo</b>	[Operation / Status Display / JAM-Prot / Jam[1]]
↑	<i>Signal: External Blocking</i>
Jam[1] . <b>Blo TripCmd</b>	[Operation / Status Display / JAM-Prot / Jam[1]]
↑	<i>Signal: Trip Command blocked</i>



Jam[1] . <b>ExBlo TripCmd</b>	[Operation / Status Display / JAM-Prot / Jam[1]]
↕	<i>Signal: External Blocking of the Trip Command</i>

### 9.9.6 Jam[1]: Counters


Jam[1] . <b>NumberOfAlarms</b>	[Operation / History / AlarmCr]
#	<i>Number of alarms since last reset.</i>

Jam[1] . <b>NumberOfTripCmds</b>	[Operation / History / TripCmdCr]
#	<i>Number of trip commands since last reset</i>


## 9.10 I<[1] ... I<[3]


Underload / Undercurrent


### 9.10.1 I<[1]: Device Planning Parameters

I<[1] . <b>Mode</b>	[Device planning]	
use	“-”, use  ↳ Mode.	S.3
 Underload / Undercurrent, general operation mode		


### 9.10.2 I<[1]: Global Parameters


I<[1] . <b>ExBlo1</b> I<[1] . <b>ExBlo2</b>	[Protection Para / Global Prot Para / Underload-Prot / I<[1]]	
“-”	“-” ... Sys . Internal test state  ↳ 1..n, Assignment List.	P.2
 External blocking of the module, if blocking is activated (allowed) within a parameter set and if the state of the assigned signal is true.		


I<[1] . <b>ExBlo dur. Mot.Strt</b>	[Protection Para / Global Prot Para / Underload-Prot / I<[1]]	
MStart . Blo-I<Start	“-” ... MStart . Blo-FrqStart  ↳ 1..n, Trip Cmds.	P.2
 External blocking of the module, if the state of the assigned signal is true. This way it is possible to block the module during the motor start phase.		


I<[1] . <b>ExBlo TripCmd</b>	[Protection Para / Global Prot Para / Underload-Prot / I<[1]]	
“-”	“-” ... Sys . Internal test state  ↳ 1..n, Assignment List.	P.2
 External blocking of the Trip Command of the module/the stage, if blocking is activated (allowed) within a parameter set and if the state of the assigned signal is true.		


### 9.10.3 I<[1]: Setting Group Parameters


I<[1] . <b>Function</b>	[Protection Para / Set 1...4 / Underload-Prot / I<[1]]	
inactive	inactive, active ↳ Mode.	P.2
 Permanent activation or deactivation of module/stage.		


I<[1] . <b>ExBlo Fc</b>	[Protection Para / Set 1...4 / Underload-Prot / I<[1]]	
inactive	inactive, active ↳ active/inactive.	P.2
 Activate (allow) or inactivate (disallow) blocking of the module/stage. This parameter is only effective if a signal is assigned to the corresponding global protection parameter. If the signal becomes true, those modules/stages are blocked that are parameterized "ExBlo Fc=active".		



I<[1] . <b>Blo TripCmd</b>	[Protection Para / Set 1...4 / Underload-Prot / I<[1]]	
inactive	inactive, active ↳ Mode.	P.2
 Permanent blocking of the Trip Command of the module/stage.		

I<[1] . <b>ExBlo TripCmd Fc</b>	[Protection Para / Set 1...4 / Underload-Prot / I<[1]]	
inactive	inactive, active ↳ active/inactive.	P.2
 Activate (allow) or inactivate (disallow) blocking of the module/stage. This parameter is only effective if a signal is assigned to the corresponding global protection parameter. If the signal becomes true, those modules/stages are blocked that are parameterized "ExBlo TripCmd Fc=active".		


I<[1] . <b>Undercurrent</b>	[Protection Para / Set 1...4 / Underload-Prot / I<[1]]	
0.50I <sub>b</sub>	0.05I <sub>b</sub> ... 0.90I <sub>b</sub>	P.2
 Underload Pickup based on a multiplier of I <sub>b</sub>		


I<[1] . <b>Alarm Mode</b>	[Protection Para / Set 1...4 / Underload-Prot / I<[1]]	
any one	any one, all ↳ Alarm Mode.	P.2
 Indicates if one, two of three or all phases are required for operation		


I<[1] . <b>t</b>	[Protection Para / Set 1...4 / Underload-Prot / I<[1]]	
10.0s	0.4s ... 1200.0s	P.2
 <i>Tripping delay</i>		

I<[1] . <b>MeasCircSv Curr</b>	[Protection Para / Set 1...4 / Underload-Prot / I<[1]]	
Sys . inactive	Sys . inactive, CTS . active  VTS Block.	P.2
 <i>Measuring Circuit Supervision Current</i>		


### 9.10.4 I<[1]: Input States


I<[1] . <b>ExBlo1-I</b>	[Operation / Status Display / Underload-Prot / I<[1]]	
 <i>Module input state: External blocking1</i>		


I<[1] . <b>ExBlo2-I</b>	[Operation / Status Display / Underload-Prot / I<[1]]	
 <i>Module input state: External blocking2</i>		

I<[1] . <b>ExBlo TripCmd-I</b>	[Operation / Status Display / Underload-Prot / I<[1]]	
 <i>Module input state: External Blocking of the Trip Command</i>		

### 9.10.5 I<[1]: Signals (Output States)

I<[1] . <b>active</b>	[Operation / Status Display / All Actives] [Operation / Status Display / Underload-Prot / I<[1]]	
 <i>Signal: active</i>		

I<[1] . <b>Alarm</b>	[Operation / Status Display / Alarms] [Operation / Status Display / Underload-Prot / I<[1]]	
 <i>Signal: Alarm</i>		

I<[1] . <b>Trip</b>	[Operation / Status Display / Trips] [Operation / Status Display / Underload-Prot / I<[1]]	
 <i>Signal: Trip</i>		

I<[1] . <b>TripCmd</b>	[Operation / Status Display / TripCmds] [Operation / Status Display / Underload-Prot / I<[1]]
⤴	<i>Signal: Trip Command</i>

I<[1] . <b>ExBlo</b>	[Operation / Status Display / Underload-Prot / I<[1]]
⤴	<i>Signal: External Blocking</i>

I<[1] . <b>Blo TripCmd</b>	[Operation / Status Display / Underload-Prot / I<[1]]
⤴	<i>Signal: Trip Command blocked</i>

I<[1] . <b>ExBlo TripCmd</b>	[Operation / Status Display / Underload-Prot / I<[1]]
⤴	<i>Signal: External Blocking of the Trip Command</i>

### 9.10.6 I<[1]: Counters


I<[1] . <b>NumberOfAlarms</b>	[Operation / History / AlarmCr]
#	<i>Number of alarms since last reset.</i>

I<[1] . <b>NumberOfTripCmds</b>	[Operation / History / TripCmdCr]
#	<i>Number of trip commands since last reset</i>


## 9.11 MLS

Mechanical Load Shedding


### 9.11.1 MLS: Device Planning Parameters


<b>MLS . Mode</b>	[Device planning]	
use	“-”, use  ↳ Mode.	S.3
	<i>Mechanical Load Shedding, general operation mode</i>	


### 9.11.2 MLS: Global Parameters


<b>MLS . ExBlo1</b>	[Protection Para / Global Prot Para / MLS]	
<b>MLS . ExBlo2</b>		
“-”	“-” ... Sys . Internal test state  ↳ 1..n, Assignment List.	P.2
	<i>External blocking of the module, if blocking is activated (allowed) within a parameter set and if the state of the assigned signal is true.</i>	


### 9.11.3 MLS: Setting Group Parameters


<b>MLS . Function</b>	[Protection Para / Set 1...4 / MLS]	
inactive	inactive, active  ↳ Mode.	P.2
	<i>Permanent activation or deactivation of module/stage.</i>	

<b>MLS . ExBlo Fc</b>	[Protection Para / Set 1...4 / MLS]	
inactive	inactive, active  ↳ active/inactive.	P.2
	<i>Activate (allow) or inactivate (disallow) blocking of the module/stage. This parameter is only effective if a signal is assigned to the corresponding global protection parameter. If the signal becomes true, those modules/stages are blocked that are parameterized "ExBlo Fc=active".</i>	


<b>MLS . Pickup Threshold</b>	[Protection Para / Set 1...4 / MLS]	
0.90Ib	0.50Ib ... 1.50Ib	P.2
	<i>Mechanical load shedding pickup current as multiplier of Ib</i>	


<b>MLS . t-Pickup Delay</b>	[Protection Para / Set 1...4 / MLS]	
1.0s	0.0s ... 5.0s	P.2
	<i>Trip delay time</i>	

<b>MLS . Dropout Threshold</b>	[Protection Para / Set 1...4 / MLS]	
0.50Ib	0.50Ib ... 1.50Ib	P.2
	<i>Mechanical load reclosure current (Dropout of Load shedding) as multiplier of Ib</i>	


<b>MLS . t-Drop Delay</b>	[Protection Para / Set 1...4 / MLS]	
1.0s	0.0s ... 5.0s	P.2
	<i>Dropout delay time</i>	


#### 9.11.4 MLS: Input States

<b>MLS . ExBlo1-I</b>	[Operation / Status Display / MLS]	
	<i>Module input state: External blocking1</i>	

<b>MLS . ExBlo2-I</b>	[Operation / Status Display / MLS]	
	<i>Module input state: External blocking2</i>	

#### 9.11.5 MLS: Signals (Output States)

<b>MLS . active</b>	[Operation / Status Display / All Actives]	
	[Operation / Status Display / MLS]	
	<i>Signal: active</i>	

<b>MLS . Alarm</b>	[Operation / Status Display / Alarms]	
	[Operation / Status Display / MLS]	
	<i>Signal: Alarm</i>	

<b>MLS . Trip</b>	[Operation / Status Display / Trips] [Operation / Status Display / MLS]
↕	<i>Signal: Trip</i>



<b>MLS . ExBlo</b>	[Operation / Status Display / MLS]
↕	<i>Signal: External Blocking</i>





## 9.12 I2>[1] ... I2>[2]



Unbalanced Load-Stage



### 9.12.1 I2>[1]: Device Planning Parameters

I2>[1] . <b>Mode</b>	[Device planning]	
use	“-”, use  Device planning.	S.3
	<i>Unbalanced Load-Stage, general operation mode</i>	



### 9.12.2 I2>[1]: Global Parameters



I2>[1] . <b>ExBlo1</b>	[Protection Para / Global Prot Para / I-Prot / I2>[1]]	
I2>[1] . <b>ExBlo2</b>		
“-”	“-” ... Sys . Internal test state  1..n, Assignment List.	P.2
	<i>External blocking of the module, if blocking is activated (allowed) within a parameter set and if the state of the assigned signal is true.</i>	



I2>[1] . <b>ExBlo dur. Mot.Strt</b>	[Protection Para / Global Prot Para / I-Prot / I2>[1]]	
MStart . Blo-I2>Start	“-” ... MStart . Blo-FrqStart  1..n, Trip Cmds.	P.2
	<i>External blocking of the module, if the state of the assigned signal is true. This way it is possible to block the module during the motor start phase.</i>	



I2>[1] . <b>ExBlo TripCmd</b>	[Protection Para / Global Prot Para / I-Prot / I2>[1]]	
“-”	“-” ... Sys . Internal test state  1..n, Assignment List.	P.2
	<i>External blocking of the Trip Command of the module/the stage, if blocking is activated (allowed) within a parameter set and if the state of the assigned signal is true.</i>	


### 9.12.3 I2>[1]: Setting Group Parameters



I2>[1] . <b>Function</b>	[Protection Para / Set 1...4 / I-Prot / I2>[1]]
inactive	inactive, active  Mode.
 Permanent activation or deactivation of module/stage.	


I2>[1] . <b>ExBlo Fc</b>	[Protection Para / Set 1...4 / I-Prot / I2>[1]]
inactive	inactive, active  active/inactive.
 Activate (allow) or inactivate (disallow) blocking of the module/stage. This parameter is only effective if a signal is assigned to the corresponding global protection parameter. If the signal becomes true, those modules/stages are blocked that are parameterized "ExBlo Fc=active".	


I2>[1] . <b>Blo TripCmd</b>	[Protection Para / Set 1...4 / I-Prot / I2>[1]]
inactive	inactive, active  Mode.
 Permanent blocking of the Trip Command of the module/stage.	


I2>[1] . <b>ExBlo TripCmd Fc</b>	[Protection Para / Set 1...4 / I-Prot / I2>[1]]
inactive	inactive, active  active/inactive.
 Activate (allow) or inactivate (disallow) blocking of the module/stage. This parameter is only effective if a signal is assigned to the corresponding global protection parameter. If the signal becomes true, those modules/stages are blocked that are parameterized "ExBlo TripCmd Fc=active".	


I2>[1] . <b>I2&gt;</b>	[Protection Para / Set 1...4 / I-Prot / I2>[1]]
0.08In	0.01In ... 4.00In
 The Threshold setting defines a minimum operating current magnitude of I2 for the 46 function to operate, which ensures that the relay has a solid basis for initiating a current unbalance trip. This is a supervisory function and not a trip level.	


I2>[1] . <b>%(I2/I1)</b>	[Protection Para / Set 1...4 / I-Prot / I2>[1]]	
inactive	inactive, active  Mode.	P.2
	<i>The %(I2/I1) setting is the unbalance trip pickup setting. It is defined by the ratio of negative sequence current to positive sequence current (% Unbalance=I2/I1). Phase sequence will be taken into account automatically.</i>	

I2>[1] . <b>%(I2/I1)</b>	[Protection Para / Set 1...4 / I-Prot / I2>[1]]	
20%	2% ... 40%	P.2
	<i>The %(I2/I1) setting is the unbalance trip pickup setting. It is defined by the ratio of negative sequence current to positive sequence current (% Unbalance=I2/I1). Phase sequence will be taken into account automatically.</i>	


I2>[1] . <b>Char</b>	[Protection Para / Set 1...4 / I-Prot / I2>[1]]	
DEFT	DEFT, INV  Char.	P.2
	Characteristic	


I2>[1] . <b>t</b>	[Protection Para / Set 1...4 / I-Prot / I2>[1]]	
0.00s	0.00s ... 300.00s	P.2
	Tripping delay	


I2>[1] . <b>K</b>	[Protection Para / Set 1...4 / I-Prot / I2>[1]]	
10.0s	1.00s ... 200.00s	P.2
	<i>This setting is the negative sequence capability constant. This value is normally provided by the generator manufacturer.</i>	

I2>[1] . <b><math>\tau</math>-cool</b>	[Protection Para / Set 1...4 / I-Prot / I2>[1]]	
0.0s	0.0s ... 60000.0s	P.2
	<i>If the unbalanced load current falls below the pickup value, the cooling-off time is taken into account. If the unbalanced load exceeds the pickup value again, than the saved heat within the electrical equipment will lead to an accelerated trip.</i>	


## 9.12.4 I2>[1]: Input States


I2>[1] . <b>ExBlo1-I</b>	[Operation / Status Display / I-Prot / I2>[1]]	
	Module input state: External blocking1	


I2>[1] . <b>ExBlo2-I</b>	[Operation / Status Display / I-Prot / I2>[1]]
 <i>Module input state: External blocking2</i>	


I2>[1] . <b>ExBlo TripCmd-I</b>	[Operation / Status Display / I-Prot / I2>[1]]
 <i>Module input state: External Blocking of the Trip Command</i>	


### 9.12.5 I2>[1]: Signals (Output States)


I2>[1] . <b>active</b>	[Operation / Status Display / All Actives] [Operation / Status Display / I-Prot / I2>[1]]
 <i>Signal: active</i>	


I2>[1] . <b>Alarm</b>	[Operation / Status Display / Alarms] [Operation / Status Display / I-Prot / I2>[1]]
 <i>Signal: Alarm Negative Sequence</i>	

I2>[1] . <b>Trip</b>	[Operation / Status Display / Trips] [Operation / Status Display / I-Prot / I2>[1]]
 <i>Signal: Trip</i>	

I2>[1] . <b>TripCmd</b>	[Operation / Status Display / TripCmds] [Operation / Status Display / I-Prot / I2>[1]]
 <i>Signal: Trip Command</i>	

I2>[1] . <b>ExBlo</b>	[Operation / Status Display / I-Prot / I2>[1]]
 <i>Signal: External Blocking</i>	

I2>[1] . <b>Blo TripCmd</b>	[Operation / Status Display / I-Prot / I2>[1]]
 <i>Signal: Trip Command blocked</i>	

I2>[1] . <b>ExBlo TripCmd</b>	[Operation / Status Display / I-Prot / I2>[1]]
 <i>Signal: External Blocking of the Trip Command</i>	

### 9.12.6 I2>[1]: Counters

I2>[1] . <b>NumberOfAlarms</b>	[Operation / History / AlarmCr]
--------------------------------	---------------------------------

#	<i>Number of alarms since last reset.</i>
---	---


I2>[1] . <b>NumberOfTripCmds</b>	[Operation / History / TripCmdCr]
----------------------------------	-----------------------------------

#	<i>Number of trip commands since last reset</i>
---	---


## 9.13 ExP[1] ... ExP[4]


External Protection - Module


### 9.13.1 ExP[1]: Device Planning Parameters


ExP[1] . <b>Mode</b>	[Device planning]	
"_"	"_", use ↳ Device planning.	S.3
	External Protection - Module, general operation mode	

### 9.13.2 ExP[1]: Global Parameters


ExP[1] . <b>ExBlo1</b>	[Protection Para / Global Prot Para / ExP / ExP[1]]	
ExP[1] . <b>ExBlo2</b>		
"_"	"_" ... Sys . Internal test state ↳ 1..n, Assignment List.	P.2
	External blocking of the module, if blocking is activated (allowed) within a parameter set and if the state of the assigned signal is true.	


ExP[1] . <b>ExBlo TripCmd</b>	[Protection Para / Global Prot Para / ExP / ExP[1]]	
"_"	"_" ... Sys . Internal test state ↳ 1..n, Assignment List.	P.2
	External blocking of the Trip Command of the module/the stage, if blocking is activated (allowed) within a parameter set and if the state of the assigned signal is true.	


ExP[1] . <b>Alarm</b>	[Protection Para / Global Prot Para / ExP / ExP[1]]	
"_"	"_" ... Sys . Internal test state ↳ 1..n, Assignment List.	P.2
	Assignment for External Alarm	


<b>ExP[1] . Trip</b>	[Protection Para / Global Prot Para / ExP / ExP[1]]	
"_"	"_" ... Sys . Internal test state ↳ 1..n, Assignment List.	P.2
 External trip of the CB if the state of the assigned signal is true.		

### 9.13.3 ExP[1]: Setting Group Parameters

<b>ExP[1] . Function</b>	[Protection Para / Set 1...4 / ExP / ExP[1]]	
inactive	inactive, active ↳ Mode.	P.2
 Permanent activation or deactivation of module/stage.		

<b>ExP[1] . ExBlo Fc</b>	[Protection Para / Set 1...4 / ExP / ExP[1]]	
inactive	inactive, active ↳ active/inactive.	P.2
 Activate (allow) or inactivate (disallow) blocking of the module/stage. This parameter is only effective if a signal is assigned to the corresponding global protection parameter. If the signal becomes true, those modules/stages are blocked that are parameterized "ExBlo Fc=active".		

<b>ExP[1] . Blo TripCmd</b>	[Protection Para / Set 1...4 / ExP / ExP[1]]	
inactive	inactive, active ↳ Mode.	P.2
 Permanent blocking of the Trip Command of the module/stage.		

<b>ExP[1] . ExBlo TripCmd Fc</b>	[Protection Para / Set 1...4 / ExP / ExP[1]]	
inactive	inactive, active ↳ active/inactive.	P.2
 Activate (allow) or inactivate (disallow) blocking of the module/stage. This parameter is only effective if a signal is assigned to the corresponding global protection parameter. If the signal becomes true, those modules/stages are blocked that are parameterized "ExBlo TripCmd Fc=active".		

### 9.13.4 ExP[1]: Input States

ExP[1] . <b>ExBlo1-I</b>	[Operation / Status Display / ExP / ExP[1]]
↓	<i>Module input state: External blocking1</i>
ExP[1] . <b>ExBlo2-I</b>	[Operation / Status Display / ExP / ExP[1]]
↓	<i>Module input state: External blocking2</i>
ExP[1] . <b>ExBlo TripCmd-I</b>	[Operation / Status Display / ExP / ExP[1]]
↓	<i>Module input state: External Blocking of the Trip Command</i>
ExP[1] . <b>Alarm-I</b>	[Operation / Status Display / ExP / ExP[1]]
↓	<i>Module input state: Alarm</i>
ExP[1] . <b>Trip-I</b>	[Operation / Status Display / ExP / ExP[1]]
↓	<i>Module input state: Trip</i>

### 9.13.5 ExP[1]: Signals (Output States)

ExP[1] . <b>active</b>	[Operation / Status Display / All Actives] [Operation / Status Display / ExP / ExP[1]]
↑	<i>Signal: active</i>
ExP[1] . <b>Alarm</b>	[Operation / Status Display / Alarms] [Operation / Status Display / ExP / ExP[1]]
↑	<i>Signal: Alarm</i>
ExP[1] . <b>Trip</b>	[Operation / Status Display / Trips] [Operation / Status Display / ExP / ExP[1]]
↑	<i>Signal: Trip</i>
ExP[1] . <b>TripCmd</b>	[Operation / Status Display / TripCmds] [Operation / Status Display / ExP / ExP[1]]
↑	<i>Signal: Trip Command</i>



ExP[1] . <b>ExBlo</b>	[Operation / Status Display / ExP / ExP[1]]
⬆	<i>Signal: External Blocking</i>
ExP[1] . <b>Blo TripCmd</b>	[Operation / Status Display / ExP / ExP[1]]
⬆	<i>Signal: Trip Command blocked</i>
ExP[1] . <b>ExBlo TripCmd</b>	[Operation / Status Display / ExP / ExP[1]]
⬆	<i>Signal: External Blocking of the Trip Command</i>

### 9.13.6 ExP[1]: Counters



ExP[1] . <b>NumberOfAlarms</b>	[Operation / History / AlarmCr]
#	<i>Number of alarms since last reset.</i>
ExP[1] . <b>NumberOfTripCmds</b>	[Operation / History / TripCmdCr]
#	<i>Number of trip commands since last reset</i>


## 9.14 URTD

Universal Resistance Temperature Detector



### 9.14.1 URTD: Global Parameters

URTD . <b>Temperature Unit</b>	[Device Para / Measurment Display / General Settings]
Celsius	Celsius, Fahrenheit  Units.
 <i>Temperature Unit</i>	

URTD . <b>Force Mode</b>	[Service / Test (Prot inhibit) / URTD]
permanent	permanent, timeout  Mode.
 <i>By means of this function the normal Output Relay States can be overwritten (forced) in case that the Relay is not in a disarmed state. The relays can be set from normal operation (relay works according to the assigned signals) to "force energized" or "force de-energized" state.</i>	

URTD . <b>t-Timeout Force</b>	[Service / Test (Prot inhibit) / URTD]
0.03s  <i>Only available if:</i> <ul style="list-style-type: none"> <li>• URTD . Force Mode = timeout</li> </ul>	0.00s ... 300.00s
 <i>The Output State will be set by force for the duration of this time. That means for the duration of this time the Output Relay does not show the state of the signals that are assigned on it.</i>	

### 9.14.2 URTD: Direct Controls

URTD . <b>Function</b>	[Service / Test (Prot inhibit) / URTD]
inactive	inactive, active  active/inactive.
 <i>Permanent activation or deactivation of module/stage.</i>	

URTD . <b>Force Windg1</b>	[Service / Test (Prot inhibit) / URTD]
0	If: URTD . Temperature Unit = Fahrenheit • 32 ... 392  If: URTD . Temperature Unit = Celsius • 0 ... 200
<input checked="" type="radio"/> <i>Force Winding 1</i>	

URTD . <b>Force Windg2</b>	[Service / Test (Prot inhibit) / URTD]
0	If: URTD . Temperature Unit = Fahrenheit • 32 ... 392  If: URTD . Temperature Unit = Celsius • 0 ... 200
<input checked="" type="radio"/> <i>Force Winding 2</i>	

URTD . <b>Force Windg3</b>	[Service / Test (Prot inhibit) / URTD]
0	If: URTD . Temperature Unit = Fahrenheit • 32 ... 392  If: URTD . Temperature Unit = Celsius • 0 ... 200
<input checked="" type="radio"/> <i>Force Winding 3</i>	

URTD . <b>Force Windg4</b>	[Service / Test (Prot inhibit) / URTD]
0	If: URTD . Temperature Unit = Fahrenheit • 32 ... 392  If: URTD . Temperature Unit = Celsius • 0 ... 200
<input checked="" type="radio"/> <i>Force Winding 4</i>	

URTD . <b>Force Windg5</b>	[Service / Test (Prot inhibit) / URTD]
0	If: URTD . Temperature Unit = Fahrenheit • 32 ... 392  If: URTD . Temperature Unit = Celsius • 0 ... 200
<input checked="" type="radio"/> <i>Force Winding 5</i>	

URTD . <b>Force Windg6</b>	[Service / Test (Prot inhibit) / URTD]
0	If: URTD . Temperature Unit = Fahrenheit • 32 ... 392  If: URTD . Temperature Unit = Celsius • 0 ... 200
<input checked="" type="radio"/> <i>Force Winding 6</i>	

URTD . <b>Force MotBear1</b>	[Service / Test (Prot inhibit) / URTD]
0	If: URTD . Temperature Unit = Fahrenheit • 32 ... 392  If: URTD . Temperature Unit = Celsius • 0 ... 200
<input checked="" type="radio"/> <i>Force Motor Bearing 1</i>	

URTD . <b>Force MotBear2</b>	[Service / Test (Prot inhibit) / URTD]
0	If: URTD . Temperature Unit = Fahrenheit • 32 ... 392  If: URTD . Temperature Unit = Celsius • 0 ... 200
<input checked="" type="radio"/> <i>Force Motor Bearing 2</i>	

URTD . <b>Force LoadBear1</b>	[Service / Test (Prot inhibit) / URTD]
0	If: URTD . Temperature Unit = Fahrenheit • 32 ... 392  If: URTD . Temperature Unit = Celsius • 0 ... 200
<input checked="" type="radio"/> <i>Force Load Bearing 1</i>	


URTD . <b>Force LoadBear2</b>	[Service / Test (Prot inhibit) / URTD]
0	If: URTD . Temperature Unit = Fahrenheit • 32 ... 392  If: URTD . Temperature Unit = Celsius • 0 ... 200
<input checked="" type="radio"/> <i>Force Load Bearing 2</i>	


URTD . <b>Force Aux1</b>	[Service / Test (Prot inhibit) / URTD]
0	If: URTD . Temperature Unit = Fahrenheit • 32 ... 392  If: URTD . Temperature Unit = Celsius • 0 ... 200
<input checked="" type="radio"/> <i>Force Auxiliary1</i>	


URTD . <b>Force Aux2</b>	[Service / Test (Prot inhibit) / URTD]
0	If: URTD . Temperature Unit = Fahrenheit • 32 ... 392  If: URTD . Temperature Unit = Celsius • 0 ... 200
<input checked="" type="radio"/> <i>Force Auxiliary2</i>	


### 9.14.3 URTD: Signals (Output States)


<b>URTD . Windg1 Superv</b>	[Operation / Status Display / Temp-Prot / URTD]
⬇	<i>Signal: Windg1, Channel Supervision. The value "1" reports a detected channel failure. (The value "0" means that this RTD channel is healthy.)</i>
<b>URTD . Windg2 Superv</b>	[Operation / Status Display / Temp-Prot / URTD]
⬇	<i>Signal: Windg2, Channel Supervision. The value "1" reports a detected channel failure. (The value "0" means that this RTD channel is healthy.)</i>
<b>URTD . Windg3 Superv</b>	[Operation / Status Display / Temp-Prot / URTD]
⬇	<i>Signal: Windg3, Channel Supervision. The value "1" reports a detected channel failure. (The value "0" means that this RTD channel is healthy.)</i>
<b>URTD . Windg4 Superv</b>	[Operation / Status Display / Temp-Prot / URTD]
⬇	<i>Signal: Windg4, Channel Supervision. The value "1" reports a detected channel failure. (The value "0" means that this RTD channel is healthy.)</i>
<b>URTD . Windg5 Superv</b>	[Operation / Status Display / Temp-Prot / URTD]
⬇	<i>Signal: Windg5, Channel Supervision. The value "1" reports a detected channel failure. (The value "0" means that this RTD channel is healthy.)</i>
<b>URTD . Windg6 Superv</b>	[Operation / Status Display / Temp-Prot / URTD]
⬇	<i>Signal: Windg6, Channel Supervision. The value "1" reports a detected channel failure. (The value "0" means that this RTD channel is healthy.)</i>
<b>URTD . MotBear1 Superv</b>	[Operation / Status Display / Temp-Prot / URTD]
⬇	<i>Signal: MotBear1, Channel Supervision. The value "1" reports a detected channel failure. (The value "0" means that this RTD channel is healthy.)</i>
<b>URTD . MotBear2 Superv</b>	[Operation / Status Display / Temp-Prot / URTD]
⬇	<i>Signal: MotBear2, Channel Supervision. The value "1" reports a detected channel failure. (The value "0" means that this RTD channel is healthy.)</i>
<b>URTD . LoadBear1 Superv</b>	[Operation / Status Display / Temp-Prot / URTD]
⬇	<i>Signal: LoadBear1, Channel Supervision. The value "1" reports a detected channel failure. (The value "0" means that this RTD channel is healthy.)</i>


<b>URTD . LoadBear2 Superv</b>	[Operation / Status Display / Temp-Prot / URTD]
 <i>Signal: LoadBear2, Channel Supervision. The value "1" reports a detected channel failure. (The value "0" means that this RTD channel is healthy.)</i>	

<b>URTD . Aux1 Superv</b>	[Operation / Status Display / Temp-Prot / URTD]
 <i>Signal: Aux1, Channel Supervision. The value "1" reports a detected channel failure. (The value "0" means that this RTD channel is healthy.)</i>	


<b>URTD . Aux2 Superv</b>	[Operation / Status Display / Temp-Prot / URTD]
 <i>Signal: Aux2, Channel Supervision. The value "1" reports a detected channel failure. (The value "0" means that this RTD channel is healthy.)</i>	


<b>URTD . Superv</b>	[Operation / Status Display / Temp-Prot / URTD]
 <i>Signal: URTD Channel Supervision. The value "1" reports a detected channel failure. (The value "0" means that all RTD channels are healthy.)</i>	


<b>URTD . Connection active</b>	[Operation / Status Display / Temp-Prot / URTD]
 <i>Signal: There is an active connection between the Temperature Detector (URTD) and the protective relay.</i>	


<b>URTD . Outs forced</b>	[Operation / Status Display / Temp-Prot / URTD]
 <i>Signal: The State of at least one Relay Output has been set by force. That means that the state of at least one Relay is forced and hence does not show the state of the assigned signals.</i>	

#### 9.14.4 URTD: Values

<b>URTD . Windg1</b>	[Operation / Measured Values / URTD]
 <i>Winding 1</i>	

<b>URTD . Windg2</b>	[Operation / Measured Values / URTD]
 <i>Winding 2</i>	

<b>URTD . Windg3</b>	[Operation / Measured Values / URTD]
 <i>Winding 3</i>	

<b>URTD . Windg4</b>	[Operation / Measured Values / URTD]
 <i>Winding 4</i>	

<b>URTD . Windg5</b>	[Operation / Measured Values / URTD]
 <i>Winding 5</i>	
<b>URTD . Windg6</b>	[Operation / Measured Values / URTD]
 <i>Winding 6</i>	
<b>URTD . MotBear1</b>	[Operation / Measured Values / URTD]
 <i>Motor Bearing 1</i>	
<b>URTD . MotBear2</b>	[Operation / Measured Values / URTD]
 <i>Motor Bearing 2</i>	
<b>URTD . LoadBear1</b>	[Operation / Measured Values / URTD]
 <i>Load Bearing 1</i>	
<b>URTD . LoadBear2</b>	[Operation / Measured Values / URTD]
 <i>Load Bearing 2</i>	
<b>URTD . Aux1</b>	[Operation / Measured Values / URTD]
 <i>Auxiliary1</i>	
<b>URTD . Aux2</b>	[Operation / Measured Values / URTD]
 <i>Auxiliary2</i>	
<b>URTD . RTD Max</b>	[Operation / Measured Values / URTD]
 <i>Maximum temperature of all channels.</i>	

### 9.14.5 URTD: Statistical Values

<b>URTD . Windg1 max</b>	[Operation / Statistics / Max / URTD]
<input checked="" type="checkbox"/> <i>Winding1 Maximum Value</i>	
<b>URTD . Windg2 max</b>	[Operation / Statistics / Max / URTD]
<input checked="" type="checkbox"/> <i>Winding2 Maximum Value</i>	





URTD . <b>Windg3 max</b>	[Operation / Statistics / Max / URTD]
<input checked="" type="checkbox"/> <i>Winding3 Maximum Value</i>	
URTD . <b>Windg4 max</b>	[Operation / Statistics / Max / URTD]
<input checked="" type="checkbox"/> <i>Winding4 Maximum Value</i>	
URTD . <b>Windg5 max</b>	[Operation / Statistics / Max / URTD]
<input checked="" type="checkbox"/> <i>Winding5 Maximum Value</i>	
URTD . <b>Windg6 max</b>	[Operation / Statistics / Max / URTD]
<input checked="" type="checkbox"/> <i>Winding6 Maximum Value</i>	
URTD . <b>MotBear1 max</b>	[Operation / Statistics / Max / URTD]
<input checked="" type="checkbox"/> <i>Motor Bearing1 Maximum Value</i>	
URTD . <b>MotBear2 max</b>	[Operation / Statistics / Max / URTD]
<input checked="" type="checkbox"/> <i>Motor Bearing2 Maximum Value</i>	
URTD . <b>LoadBear1 max</b>	[Operation / Statistics / Max / URTD]
<input checked="" type="checkbox"/> <i>Load Bearing1 Maximum Value</i>	
URTD . <b>LoadBear2 max</b>	[Operation / Statistics / Max / URTD]
<input checked="" type="checkbox"/> <i>Load Bearing2 Maximum Value</i>	
URTD . <b>Aux1 max</b>	[Operation / Statistics / Max / URTD]
<input checked="" type="checkbox"/> <i>Auxiliary1 Maximum Value</i>	
URTD . <b>Aux2 max</b>	[Operation / Statistics / Max / URTD]
<input checked="" type="checkbox"/> <i>Auxiliary2 Maximum Value</i>	



## 9.15 RTD



Temperature Protection Module



### 9.15.1 RTD: Device Planning Parameters

<b>RTD . Mode</b>	[Device planning]	
"_"	"_" , use  Device planning.	S.3
 <i>general operation mode</i>		


### 9.15.2 RTD: Global Parameters


<b>RTD . ExBlo1</b>	[Protection Para / Global Prot Para / Temp-Prot / RTD]	
<b>RTD . ExBlo2</b>		
"_"	"_" ... Sys . Internal test state  1..n, Assignment List.	P.2
 <i>External blocking of the module, if blocking is activated (allowed) within a parameter set and if the state of the assigned signal is true.</i>		


<b>RTD . ExBlo TripCmd</b>	[Protection Para / Global Prot Para / Temp-Prot / RTD]	
"_"	"_" ... Sys . Internal test state  1..n, Assignment List.	P.2
 <i>External blocking of the Trip Command of the module/the stage, if blocking is activated (allowed) within a parameter set and if the state of the assigned signal is true.</i>		


<b>RTD . TripCmd Selection</b>	[Protection Para / Global Prot Para / Temp-Prot / RTD]	
Trip	Trip, Voting Trip  TripCmd Selection.	P.2
 <i>This parameter determines if the final trip of the RTD module is issued by the default way or by the voting groups.</i>		



### 9.15.3 RTD: Setting Group Parameters



<b>RTD . Function</b>	[Protection Para / Set 1...4 / Temp-Prot / RTD / General Settings]	
	[Protection Para / Set 1...4 / Temp-Prot / RTD / Voting1]	
	[Protection Para / Set 1...4 / Temp-Prot / RTD / Voting2]	
inactive	inactive, active	P.2
	↳ Mode.	
	<i>Permanent activation or deactivation of module/stage.</i>	

<b>RTD . ExBlo Fc</b>	[Protection Para / Set 1...4 / Temp-Prot / RTD / General Settings]	
inactive	inactive, active	P.2
	↳ active/inactive.	
	<i>Activate (allow) or inactivate (disallow) blocking of the module/stage. This parameter is only effective if a signal is assigned to the corresponding global protection parameter. If the signal becomes true, those modules/stages are blocked that are parameterized "ExBlo Fc=active".</i>	


<b>RTD . Blo TripCmd</b>	[Protection Para / Set 1...4 / Temp-Prot / RTD / General Settings]	
inactive	inactive, active	P.2
	↳ Mode.	
	<i>Permanent blocking of the Trip Command of the module/stage.</i>	

<b>RTD . ExBlo TripCmd Fc</b>	[Protection Para / Set 1...4 / Temp-Prot / RTD / General Settings]	
inactive	inactive, active	P.2
	↳ active/inactive.	
	<i>Activate (allow) or inactivate (disallow) blocking of the module/stage. This parameter is only effective if a signal is assigned to the corresponding global protection parameter. If the signal becomes true, those modules/stages are blocked that are parameterized "ExBlo TripCmd Fc=active".</i>	



<b>RTD . Windg 1 Alarm Function</b>	[Protection Para / Set 1...4 / Temp-Prot / RTD / Windg 1]	
active	inactive, active  Mode.	P.2
	<i>Winding 1 Alarm Function</i>	



<b>RTD . Windg 1 Trip Function</b>	[Protection Para / Set 1...4 / Temp-Prot / RTD / Windg 1]	
active	inactive, active  Mode.	P.2
	<i>Winding 1 Trip Function</i>	

<b>RTD . Windg 1 Alarm</b>	[Protection Para / Set 1...4 / Temp-Prot / RTD / Windg 1]	
80°C	0°C ... 200°C	P.2
	<i>Winding 1 Threshold for Temperature Alarm</i>	


<b>RTD . Windg 1 t-Delay</b>	[Protection Para / Set 1...4 / Temp-Prot / RTD / Windg 1]	
1min	0min ... 360min	P.2
	<i>Winding 1 If this time is expired a Temperature Alarm will be generated.</i>	

<b>RTD . Windg 1 Trip</b>	[Protection Para / Set 1...4 / Temp-Prot / RTD / Windg 1]	
100°C	0°C ... 200°C	P.2
	<i>Winding 1 Threshold for Temperature Trip</i>	



<b>RTD . Windg 2 Alarm Function</b>	[Protection Para / Set 1...4 / Temp-Prot / RTD / Windg 2]	
active	inactive, active  Mode.	P.2
	<i>Winding 2 Alarm Function</i>	



<b>RTD . Windg 2 Trip Function</b>	[Protection Para / Set 1...4 / Temp-Prot / RTD / Windg 2]	
active	inactive, active  Mode.	P.2
	<i>Winding 2 Trip Function</i>	

<b>RTD . Windg 2 Alarm</b>	[Protection Para / Set 1...4 / Temp-Prot / RTD / Windg 2]	
80°C	0°C ... 200°C	P.2
	<i>Winding 2 Threshold for Temperature Alarm</i>	


<b>RTD . Windg 2 t-Delay</b>	[Protection Para / Set 1...4 / Temp-Prot / RTD / Windg 2]	
1min	0min ... 360min	P.2
	<i>Winding 2 If this time is expired a Temperature Alarm will be generated.</i>	

<b>RTD . Windg 2 Trip</b>	[Protection Para / Set 1...4 / Temp-Prot / RTD / Windg 2]	
100°C	0°C ... 200°C	P.2
	<i>Winding 2 Threshold for Temperature Trip</i>	



<b>RTD . Windg 3 Alarm Function</b>	[Protection Para / Set 1...4 / Temp-Prot / RTD / Windg 3]	
active	inactive, active  Mode.	P.2
	<i>Winding 3 Alarm Function</i>	



<b>RTD . Windg 3 Trip Function</b>	[Protection Para / Set 1...4 / Temp-Prot / RTD / Windg 3]	
active	inactive, active  Mode.	P.2
	<i>Winding 3 Trip Function</i>	

<b>RTD . Windg 3 Alarm</b>	[Protection Para / Set 1...4 / Temp-Prot / RTD / Windg 3]	
80°C	0°C ... 200°C	P.2
	<i>Winding 3 Threshold for Temperature Alarm</i>	


<b>RTD . Windg 3 t-Delay</b>	[Protection Para / Set 1...4 / Temp-Prot / RTD / Windg 3]	
1min	0min ... 360min	P.2
	<i>Winding 3 If this time is expired a Temperature Alarm will be generated.</i>	

<b>RTD . Windg 3 Trip</b>	[Protection Para / Set 1...4 / Temp-Prot / RTD / Windg 3]	
100°C	0°C ... 200°C	P.2
	<i>Winding 3 Threshold for Temperature Trip</i>	



<b>RTD . Windg 4 Alarm Function</b>		[Protection Para / Set 1...4 / Temp-Prot / RTD / Windg 4]
active	inactive, active	P.2
		 Mode.
 <i>Winding 4 Alarm Function</i>		



<b>RTD . Windg 4 Trip Function</b>		[Protection Para / Set 1...4 / Temp-Prot / RTD / Windg 4]
active	inactive, active	P.2
		 Mode.
 <i>Winding 4 Trip Function</i>		

<b>RTD . Windg 4 Alarm</b>		[Protection Para / Set 1...4 / Temp-Prot / RTD / Windg 4]
80°C	0°C ... 200°C	P.2
 <i>Winding 4 Threshold for Temperature Alarm</i>		


<b>RTD . Windg 4 t-Delay</b>		[Protection Para / Set 1...4 / Temp-Prot / RTD / Windg 4]
1min	0min ... 360min	P.2
 <i>Winding 4 If this time is expired a Temperature Alarm will be generated.</i>		

<b>RTD . Windg 4 Trip</b>		[Protection Para / Set 1...4 / Temp-Prot / RTD / Windg 4]
100°C	0°C ... 200°C	P.2
 <i>Winding 4 Threshold for Temperature Trip</i>		



<b>RTD . Windg 5 Alarm Function</b>		[Protection Para / Set 1...4 / Temp-Prot / RTD / Windg 5]
active	inactive, active	P.2
		 Mode.
 <i>Winding 5 Alarm Function</i>		



<b>RTD . Windg 5 Trip Function</b>		[Protection Para / Set 1...4 / Temp-Prot / RTD / Windg 5]
active	inactive, active	P.2
		 Mode.
 <i>Winding 5 Trip Function</i>		

<b>RTD . Windg 5 Alarm</b>	[Protection Para / Set 1...4 / Temp-Prot / RTD / Windg 5]	
80°C	0°C ... 200°C	P.2
	<i>Winding 5 Threshold for Temperature Alarm</i>	


<b>RTD . Windg 5 t-Delay</b>	[Protection Para / Set 1...4 / Temp-Prot / RTD / Windg 5]	
1min	0min ... 360min	P.2
	<i>Winding 5 If this time is expired a Temperature Alarm will be generated.</i>	

<b>RTD . Windg 5 Trip</b>	[Protection Para / Set 1...4 / Temp-Prot / RTD / Windg 5]	
100°C	0°C ... 200°C	P.2
	<i>Winding 5 Threshold for Temperature Trip</i>	


<b>RTD . Windg 6 Alarm Function</b>	[Protection Para / Set 1...4 / Temp-Prot / RTD / Windg 6]	
active	inactive, active  Mode.	P.2
	<i>Winding 6 Alarm Function</i>	


<b>RTD . Windg 6 Trip Function</b>	[Protection Para / Set 1...4 / Temp-Prot / RTD / Windg 6]	
active	inactive, active  Mode.	P.2
	<i>Winding 6 Trip Function</i>	


<b>RTD . Windg 6 Alarm</b>	[Protection Para / Set 1...4 / Temp-Prot / RTD / Windg 6]	
80°C	0°C ... 200°C	P.2
	<i>Winding 6 Threshold for Temperature Alarm</i>	


<b>RTD . Windg 6 t-Delay</b>	[Protection Para / Set 1...4 / Temp-Prot / RTD / Windg 6]	
1min	0min ... 360min	P.2
	<i>Winding 6 If this time is expired a Temperature Alarm will be generated.</i>	

<b>RTD . Windg 6 Trip</b>	[Protection Para / Set 1...4 / Temp-Prot / RTD / Windg 6]	
100°C	0°C ... 200°C	P.2
	<i>Winding 6 Threshold for Temperature Trip</i>	


<b>RTD . MotBear 1 Alarm Function</b>	[Protection Para / Set 1...4 / Temp-Prot / RTD / MotBear 1]	
active	inactive, active ↳ Mode.	P.2
 <i>Motor Bearing 1 Alarm Function</i>		


<b>RTD . MotBear 1 Trip Function</b>	[Protection Para / Set 1...4 / Temp-Prot / RTD / MotBear 1]	
active	inactive, active ↳ Mode.	P.2
 <i>Motor Bearing 1 Trip Function</i>		

<b>RTD . MotBear 1 Alarm</b>	[Protection Para / Set 1...4 / Temp-Prot / RTD / MotBear 1]	
80°C	0°C ... 200°C	P.2
 <i>Motor Bearing 1 Threshold for Temperature Alarm</i>		


<b>RTD . MotBear 1 t-Delay</b>	[Protection Para / Set 1...4 / Temp-Prot / RTD / MotBear 1]	
1min	0min ... 360min	P.2
 <i>Motor Bearing 1 If this time is expired a Temperature Alarm will be generated.</i>		

<b>RTD . MotBear 1 Trip</b>	[Protection Para / Set 1...4 / Temp-Prot / RTD / MotBear 1]	
100°C	0°C ... 200°C	P.2
 <i>Motor Bearing 1 Threshold for Temperature Trip</i>		

<b>RTD . MotBear 2 Alarm Function</b>	[Protection Para / Set 1...4 / Temp-Prot / RTD / MotBear 2]	
active	inactive, active ↳ Mode.	P.2
 <i>Motor Bearing 2 Alarm Function</i>		



<b>RTD . MotBear 2 Trip Function</b>	[Protection Para / Set 1...4 / Temp-Prot / RTD / MotBear 2]	
active	inactive, active ↳ Mode.	P.2
 <i>Motor Bearing 2 Trip Function</i>		






<b>RTD . MotBear 2 Alarm</b>	[Protection Para / Set 1...4 / Temp-Prot / RTD / MotBear 2]	
80°C	0°C ... 200°C	P.2
	<i>Motor Bearing 2 Threshold for Temperature Alarm</i>	


<b>RTD . MotBear 2 t-Delay</b>	[Protection Para / Set 1...4 / Temp-Prot / RTD / MotBear 2]	
1min	0min ... 360min	P.2
	<i>Motor Bearing 2 If this time is expired a Temperature Alarm will be generated.</i>	


<b>RTD . MotBear 2 Trip</b>	[Protection Para / Set 1...4 / Temp-Prot / RTD / MotBear 2]	
100°C	0°C ... 200°C	P.2
	<i>Motor Bearing 2 Threshold for Temperature Trip</i>	



<b>RTD . LoadBear 1 Alarm Function</b>	[Protection Para / Set 1...4 / Temp-Prot / RTD / LoadBear 1]	
active	inactive, active  Mode.	P.2
	<i>Load Bearing 1 Alarm Function</i>	



<b>RTD . LoadBear 1 Trip Function</b>	[Protection Para / Set 1...4 / Temp-Prot / RTD / LoadBear 1]	
active	inactive, active  Mode.	P.2
	<i>Load Bearing 1 Trip Function</i>	

<b>RTD . LoadBear 1 Alarm</b>	[Protection Para / Set 1...4 / Temp-Prot / RTD / LoadBear 1]	
80°C	0°C ... 200°C	P.2
	<i>Load Bearing 1 Threshold for Temperature Alarm</i>	


<b>RTD . LoadBear 1 t-Delay</b>	[Protection Para / Set 1...4 / Temp-Prot / RTD / LoadBear 1]	
1min	0min ... 360min	P.2
	<i>Load Bearing 1 If this time is expired a Temperature Alarm will be generated.</i>	

<b>RTD . LoadBear 1 Trip</b>	[Protection Para / Set 1...4 / Temp-Prot / RTD / LoadBear 1]	
80°C	0°C ... 200°C	P.2
	<i>Load Bearing 1 Threshold for Temperature Trip</i>	



<b>RTD . LoadBear 2 Alarm Function</b>	[Protection Para / Set 1...4 / Temp-Prot / RTD / LoadBear 2]	
active	inactive, active  Mode.	P.2
 <i>Load Bearing 2 Alarm Function</i>		



<b>RTD . LoadBear 2 Trip Function</b>	[Protection Para / Set 1...4 / Temp-Prot / RTD / LoadBear 2]	
active	inactive, active  Mode.	P.2
 <i>Load Bearing 2 Trip Function</i>		

<b>RTD . LoadBear 2 Alarm</b>	[Protection Para / Set 1...4 / Temp-Prot / RTD / LoadBear 2]	
80°C	0°C ... 200°C	P.2
 <i>Load Bearing 2 Threshold for Temperature Alarm</i>		


<b>RTD . LoadBear 2 t-Delay</b>	[Protection Para / Set 1...4 / Temp-Prot / RTD / LoadBear 2]	
1min	0min ... 360min	P.2
 <i>Load Bearing 2 If this time is expired a Temperature Alarm will be generated.</i>		

<b>RTD . LoadBear 2 Trip</b>	[Protection Para / Set 1...4 / Temp-Prot / RTD / LoadBear 2]	
80°C	0°C ... 200°C	P.2
 <i>Load Bearing 2 Threshold for Temperature Trip</i>		



<b>RTD . Aux1 Alarm Function</b>	[Protection Para / Set 1...4 / Temp-Prot / RTD / Aux 1]	
active	inactive, active  Mode.	P.2
 <i>Auxiliary 1 Alarm Function</i>		



<b>RTD . Aux1 Trip Function</b>	[Protection Para / Set 1...4 / Temp-Prot / RTD / Aux 1]	
active	inactive, active  Mode.	P.2
 <i>Auxiliary 1 Trip Function</i>		


<b>RTD . Aux1 Alarm</b>	[Protection Para / Set 1...4 / Temp-Prot / RTD / Aux 1]	
80°C	0°C ... 200°C	P.2
	<i>Auxiliary 1 Threshold for Temperature Alarm</i>	


<b>RTD . Aux1 t-Delay</b>	[Protection Para / Set 1...4 / Temp-Prot / RTD / Aux 1]	
1min	0min ... 360min	P.2
	<i>Auxiliary 1 If this time is expired a Temperature Alarm will be generated.</i>	


<b>RTD . Aux1 Trip</b>	[Protection Para / Set 1...4 / Temp-Prot / RTD / Aux 1]	
100°C	0°C ... 200°C	P.2
	<i>Auxiliary 1 Threshold for Temperature Trip</i>	



<b>RTD . Aux2 Alarm Function</b>	[Protection Para / Set 1...4 / Temp-Prot / RTD / Aux 2]	
active	inactive, active  Mode.	P.2
	<i>Auxiliary 2 Alarm Function</i>	



<b>RTD . Aux2 Trip Function</b>	[Protection Para / Set 1...4 / Temp-Prot / RTD / Aux 2]	
active	inactive, active  Mode.	P.2
	<i>Auxiliary 2 Trip Function</i>	

<b>RTD . Aux2 Alarm</b>	[Protection Para / Set 1...4 / Temp-Prot / RTD / Aux 2]	
80°C	0°C ... 200°C	P.2
	<i>Auxiliary 2 Threshold for Temperature Alarm</i>	


<b>RTD . Aux2 t-Delay</b>	[Protection Para / Set 1...4 / Temp-Prot / RTD / Aux 2]	
1min	0min ... 360min	P.2
	<i>Auxiliary 2 If this time is expired a Temperature Alarm will be generated.</i>	

<b>RTD . Aux2 Trip</b>	[Protection Para / Set 1...4 / Temp-Prot / RTD / Aux 2]	
100°C	0°C ... 200°C	P.2
	<i>Auxiliary 2 Threshold for Temperature Trip</i>	



<b>RTD . Windg Alarm Function</b>	[Protection Para / Set 1...4 / Temp-Prot / RTD / Windg Group]	
inactive	inactive, active  Mode.	P.2
 <i>Winding Alarm Function</i>		



<b>RTD . Windg Trip Function</b>	[Protection Para / Set 1...4 / Temp-Prot / RTD / Windg Group]	
inactive	inactive, active  Mode.	P.2
 <i>Winding Trip Function</i>		

<b>RTD . Windg Alarm</b>	[Protection Para / Set 1...4 / Temp-Prot / RTD / Windg Group]	
80°C	0°C ... 200°C	P.2
 <i>Winding Threshold for Temperature Alarm</i>		

<b>RTD . Windg t-Delay</b>	[Protection Para / Set 1...4 / Temp-Prot / RTD / Windg Group]	
1min	0min ... 360min	P.2
 <i>Winding If this time is expired a Temperature Alarm will be generated.</i>		

<b>RTD . Windg Trip</b>	[Protection Para / Set 1...4 / Temp-Prot / RTD / Windg Group]	
100°C	0°C ... 200°C	P.2
 <i>Winding Threshold for Temperature Trip</i>		



<b>RTD . MotBear Alarm Function</b>	[Protection Para / Set 1...4 / Temp-Prot / RTD / MotBear Group]	
inactive	inactive, active  Mode.	P.2
 <i>Motor Bearing Alarm Function</i>		



<b>RTD . MotBear Trip Function</b>	[Protection Para / Set 1...4 / Temp-Prot / RTD / MotBear Group]	
inactive	inactive, active  Mode.	P.2
 <i>Motor Bearing Trip Function</i>		

<b>RTD . MotBear Alarm</b>	[Protection Para / Set 1...4 / Temp-Prot / RTD / MotBear Group]	
80°C	0°C ... 200°C	P.2
	<i>Motor Bearing Threshold for Temperature Alarm</i>	


<b>RTD . MotBear t-Delay</b>	[Protection Para / Set 1...4 / Temp-Prot / RTD / MotBear Group]	
1min	0min ... 360min	P.2
	<i>Motor Bearing If this time is expired a Temperature Alarm will be generated.</i>	

<b>RTD . MotBear Trip</b>	[Protection Para / Set 1...4 / Temp-Prot / RTD / MotBear Group]	
100°C	0°C ... 200°C	P.2
	<i>Motor Bearing Threshold for Temperature Trip</i>	



<b>RTD . LoadBear Alarm Function</b>	[Protection Para / Set 1...4 / Temp-Prot / RTD / LoadBear Group]	
inactive	inactive, active  Mode.	P.2
	<i>Load Bearing Alarm Function</i>	



<b>RTD . LoadBear Trip Function</b>	[Protection Para / Set 1...4 / Temp-Prot / RTD / LoadBear Group]	
inactive	inactive, active  Mode.	P.2
	<i>Load Bearing Trip Function</i>	


<b>RTD . LoadBear Alarm</b>	[Protection Para / Set 1...4 / Temp-Prot / RTD / LoadBear Group]	
80°C	0°C ... 200°C	P.2
	<i>Load Bearing Threshold for Temperature Alarm</i>	


<b>RTD . LoadBear t-Delay</b>	[Protection Para / Set 1...4 / Temp-Prot / RTD / LoadBear Group]	
1min	0min ... 360min	P.2
	<i>Load Bearing If this time is expired a Temperature Alarm will be generated.</i>	


<b>RTD . LoadBear Trip</b>	[Protection Para / Set 1...4 / Temp-Prot / RTD / LoadBear Group]	
100°C	0°C ... 200°C	P.2
	<i>Load Bearing Threshold for Temperature Trip</i>	


<b>RTD . Aux Alarm Function</b>	[Protection Para / Set 1...4 / Temp-Prot / RTD / Aux Group]	
inactive	inactive, active  Mode.	P.2
	<i>Auxiliary Alarm Function</i>	



<b>RTD . Aux Trip Function</b>	[Protection Para / Set 1...4 / Temp-Prot / RTD / Aux Group]	
inactive	inactive, active  Mode.	P.2
	<i>Auxiliary Trip Function</i>	



<b>RTD . Aux Alarm</b>	[Protection Para / Set 1...4 / Temp-Prot / RTD / Aux Group]	
80°C	0°C ... 200°C	P.2
	<i>Auxiliary Threshold for Temperature Alarm</i>	



<b>RTD . Aux t-Delay</b>	[Protection Para / Set 1...4 / Temp-Prot / RTD / Aux Group]	
1min	0min ... 360min	P.2
	<i>Auxiliary If this time is expired a Temperature Alarm will be generated.</i>	



<b>RTD . Aux Trip</b>	[Protection Para / Set 1...4 / Temp-Prot / RTD / Aux Group]	
100°C	0°C ... 200°C	P.2
	<i>Auxiliary Threshold for Temperature Trip</i>	



<b>RTD . Voting 1</b>	[Protection Para / Set 1...4 / Temp-Prot / RTD / Voting1]	
<b>RTD . Voting 2</b>	[Protection Para / Set 1...4 / Temp-Prot / RTD / Voting2]	
1	1 ... 12	P.2
	<i>Voting: This parameter defines how many of the selected channels must be over its threshold level for getting a voting trip</i>	



<b>RTD . Windg 1</b>		[Protection Para / Set 1...4 / Temp-Prot / RTD / Voting1] [Protection Para / Set 1...4 / Temp-Prot / RTD / Voting2]
no	no, yes  yes/no.	P.2
	<i>Winding 1</i>	



<b>RTD . Windg 2</b>		[Protection Para / Set 1...4 / Temp-Prot / RTD / Voting1] [Protection Para / Set 1...4 / Temp-Prot / RTD / Voting2]
no	no, yes  yes/no.	P.2
	<i>Winding 2</i>	



<b>RTD . Windg 3</b>		[Protection Para / Set 1...4 / Temp-Prot / RTD / Voting1] [Protection Para / Set 1...4 / Temp-Prot / RTD / Voting2]
no	no, yes  yes/no.	P.2
	<i>Winding 3</i>	



<b>RTD . Windg 4</b>		[Protection Para / Set 1...4 / Temp-Prot / RTD / Voting1] [Protection Para / Set 1...4 / Temp-Prot / RTD / Voting2]
no	no, yes  yes/no.	P.2
	<i>Winding 4</i>	



<b>RTD . Windg 5</b>		[Protection Para / Set 1...4 / Temp-Prot / RTD / Voting1] [Protection Para / Set 1...4 / Temp-Prot / RTD / Voting2]
no	no, yes  yes/no.	P.2
	<i>Winding 5</i>	

<b>RTD . Windg 6</b>		[Protection Para / Set 1...4 / Temp-Prot / RTD / Voting1] [Protection Para / Set 1...4 / Temp-Prot / RTD / Voting2]
no	no, yes  yes/no.	P.2
 <i>Winding 6</i>		



<b>RTD . MotBear 1</b>		[Protection Para / Set 1...4 / Temp-Prot / RTD / Voting1] [Protection Para / Set 1...4 / Temp-Prot / RTD / Voting2]
no	no, yes  yes/no.	P.2
 <i>Motor Bearing 1</i>		



<b>RTD . MotBear 2</b>		[Protection Para / Set 1...4 / Temp-Prot / RTD / Voting1] [Protection Para / Set 1...4 / Temp-Prot / RTD / Voting2]
no	no, yes  yes/no.	P.2
 <i>Motor Bearing 2</i>		

<b>RTD . LoadBear 1</b>		[Protection Para / Set 1...4 / Temp-Prot / RTD / Voting1] [Protection Para / Set 1...4 / Temp-Prot / RTD / Voting2]
no	no, yes  yes/no.	P.2
 <i>Load Bearing 1</i>		


<b>RTD . LoadBear 2</b>		[Protection Para / Set 1...4 / Temp-Prot / RTD / Voting1] [Protection Para / Set 1...4 / Temp-Prot / RTD / Voting2]
no	no, yes  yes/no.	P.2
 <i>Load Bearing 2</i>		





RTD . <b>Aux1</b>	[Protection Para / Set 1...4 / Temp-Prot / RTD / Voting1] [Protection Para / Set 1...4 / Temp-Prot / RTD / Voting2]	
no	no, yes  yes/no.	P.2
 Auxiliary1		

RTD . <b>Aux2</b>	[Protection Para / Set 1...4 / Temp-Prot / RTD / Voting1] [Protection Para / Set 1...4 / Temp-Prot / RTD / Voting2]	
no	no, yes  yes/no.	P.2
 Auxiliary2		


#### 9.15.4 RTD: Input States


RTD . <b>ExBlo1-I</b>	[Operation / Status Display / Temp-Prot / RTD / General]
 Module input state: External blocking1	


RTD . <b>ExBlo2-I</b>	[Operation / Status Display / Temp-Prot / RTD / General]
 Module input state: External blocking2	


RTD . <b>ExBlo TripCmd-I</b>	[Operation / Status Display / Temp-Prot / RTD / General]
 Module input state: External Blocking of the Trip Command	


#### 9.15.5 RTD: Signals (Output States)


RTD . <b>active</b>	[Operation / Status Display / All Actives] [Operation / Status Display / Temp-Prot / RTD / General]
 Signal: active	


RTD . <b>Alarm</b>	[Operation / Status Display / Alarms] [Operation / Status Display / Temp-Prot / RTD / General]
 Alarm RTD Temperature Protection	


<b>RTD . Windg 1 Alarm</b>	[Operation / Status Display / Alarms] [Operation / Status Display / Temp-Prot / RTD / Windg 1]
 <i>Winding 1 Alarm RTD Temperature Protection</i>	


<b>RTD . Windg 1 Timeout Alarm</b>	[Operation / Status Display / Alarms] [Operation / Status Display / Temp-Prot / RTD / Windg 1]
 <i>Winding 1 Timeout Alarm</i>	


<b>RTD . Windg 2 Alarm</b>	[Operation / Status Display / Alarms] [Operation / Status Display / Temp-Prot / RTD / Windg 2]
 <i>Winding 2 Alarm RTD Temperature Protection</i>	









<b>RTD . Windg 2 Timeout Alarm</b>	[Operation / Status Display / Alarms] [Operation / Status Display / Temp-Prot / RTD / Windg 2]
 <i>Winding 2 Timeout Alarm</i>	

<b>RTD . Windg 3 Alarm</b>	[Operation / Status Display / Alarms] [Operation / Status Display / Temp-Prot / RTD / Windg 3]
 <i>Winding 3 Alarm RTD Temperature Protection</i>	

<b>RTD . Windg 3 Timeout Alarm</b>	[Operation / Status Display / Alarms] [Operation / Status Display / Temp-Prot / RTD / Windg 3]
 <i>Winding 3 Timeout Alarm</i>	

<b>RTD . Windg 4 Alarm</b>	[Operation / Status Display / Alarms] [Operation / Status Display / Temp-Prot / RTD / Windg 4]
 <i>Winding 4 Alarm RTD Temperature Protection</i>	

<b>RTD . Windg 4 Timeout Alarm</b>	[Operation / Status Display / Alarms] [Operation / Status Display / Temp-Prot / RTD / Windg 4]
 <i>Winding 4 Timeout Alarm</i>	

<b>RTD . Windg 5 Alarm</b>	[Operation / Status Display / Alarms] [Operation / Status Display / Temp-Prot / RTD / Windg 5]
 <i>Winding 5 Alarm RTD Temperature Protection</i>	
<b>RTD . Windg 5 Timeout Alarm</b>	[Operation / Status Display / Alarms] [Operation / Status Display / Temp-Prot / RTD / Windg 5]
 <i>Winding 5 Timeout Alarm</i>	
<b>RTD . Windg 6 Alarm</b>	[Operation / Status Display / Alarms] [Operation / Status Display / Temp-Prot / RTD / Windg 6]
 <i>Winding 6 Alarm RTD Temperature Protection</i>	
<b>RTD . Windg 6 Timeout Alarm</b>	[Operation / Status Display / Alarms] [Operation / Status Display / Temp-Prot / RTD / Windg 6]
 <i>Winding 6 Timeout Alarm</i>	
<b>RTD . MotBear 1 Alarm</b>	[Operation / Status Display / Alarms] [Operation / Status Display / Temp-Prot / RTD / MotBear 1]
 <i>Motor Bearing 1 Alarm RTD Temperature Protection</i>	
<b>RTD . MotBear 1 Timeout Alarm</b>	[Operation / Status Display / Alarms] [Operation / Status Display / Temp-Prot / RTD / MotBear 1]
 <i>Motor Bearing 1 Timeout Alarm</i>	
<b>RTD . MotBear 2 Alarm</b>	[Operation / Status Display / Alarms] [Operation / Status Display / Temp-Prot / RTD / MotBear 2]
 <i>Motor Bearing 2 Alarm RTD Temperature Protection</i>	
<b>RTD . MotBear 2 Timeout Alarm</b>	[Operation / Status Display / Alarms] [Operation / Status Display / Temp-Prot / RTD / MotBear 2]
 <i>Motor Bearing 2 Timeout Alarm</i>	

<b>RTD . LoadBear 1 Alarm</b>	[Operation / Status Display / Alarms] [Operation / Status Display / Temp-Prot / RTD / LoadBear 1]
 <i>Load Bearing 1 Alarm RTD Temperature Protection</i>	
<b>RTD . LoadBear 1 Timeout Alarm</b>	[Operation / Status Display / Alarms] [Operation / Status Display / Temp-Prot / RTD / LoadBear 1]
 <i>Load Bearing 1 Timeout Alarm</i>	
<b>RTD . LoadBear 2 Alarm</b>	[Operation / Status Display / Alarms] [Operation / Status Display / Temp-Prot / RTD / LoadBear 2]
 <i>Load Bearing 2 Alarm RTD Temperature Protection</i>	
<b>RTD . LoadBear 2 Timeout Alarm</b>	[Operation / Status Display / Alarms] [Operation / Status Display / Temp-Prot / RTD / LoadBear 2]
 <i>Load Bearing 2 Timeout Alarm</i>	
<b>RTD . Aux1 Alarm</b>	[Operation / Status Display / Alarms] [Operation / Status Display / Temp-Prot / RTD / Aux1]
 <i>Auxiliary 1 Alarm RTD Temperature Protection</i>	
<b>RTD . Aux1 Timeout Alarm</b>	[Operation / Status Display / Alarms] [Operation / Status Display / Temp-Prot / RTD / Aux1]
 <i>Auxiliary 1 Timeout Alarm</i>	
<b>RTD . Aux2 Alarm</b>	[Operation / Status Display / Alarms] [Operation / Status Display / Temp-Prot / RTD / Aux2]
 <i>Auxiliary 2 Alarm RTD Temperature Protection</i>	
<b>RTD . Aux2 Timeout Alarm</b>	[Operation / Status Display / Alarms] [Operation / Status Display / Temp-Prot / RTD / Aux2]
 <i>Auxiliary 2 Timeout Alarm</i>	

<b>RTD . Alarm WD Group</b>	[Operation / Status Display / Alarms] [Operation / Status Display / Temp-Prot / RTD / Windg Group]
-----------------------------	---

 *Alarm all Windings*


<b>RTD . TimeoutAlmWDGrp</b>	[Operation / Status Display / Alarms] [Operation / Status Display / Temp-Prot / RTD / Windg Group]
------------------------------	---

 *Timeout Alarm all Windings*

<b>RTD . Alarm MB Group</b>	[Operation / Status Display / Alarms] [Operation / Status Display / Temp-Prot / RTD / MotBear Group]
-----------------------------	---

 *Alarm all Motor Bearings*

<b>RTD . TimeoutAlmMBGrp</b>	[Operation / Status Display / Alarms] [Operation / Status Display / Temp-Prot / RTD / MotBear Group]
------------------------------	---

 *Timeout Alarm all Motor Bearings*

<b>RTD . Alarm LB Group</b>	[Operation / Status Display / Alarms] [Operation / Status Display / Temp-Prot / RTD / LoadBear Group]
-----------------------------	--






 *Alarm all Load Bearings*

<b>RTD . TimeoutAlmLBGrp</b>	[Operation / Status Display / Alarms] [Operation / Status Display / Temp-Prot / RTD / LoadBear Group]
------------------------------	--

 *Timeout Alarm all Load Bearings*

<b>RTD . Alarm Aux Group</b>	[Operation / Status Display / Alarms] [Operation / Status Display / Temp-Prot / RTD / Aux Group]
------------------------------	---

 *Alarm Auxiliary Group*


<b>RTD . TimeoutAlmAuxGrp</b>	[Operation / Status Display / Alarms] [Operation / Status Display / Temp-Prot / RTD / Aux Group]
 <i>Timeout Alarm Auxiliary Group</i>	
<b>RTD . Trip</b>	[Operation / Status Display / Trips] [Operation / Status Display / Temp-Prot / RTD / General]
 <i>Signal: Trip</i>	
<b>RTD . TripCmd</b>	[Operation / Status Display / TripCmds] [Operation / Status Display / Temp-Prot / RTD / General]
 <i>Signal: Trip Command</i>	
<b>RTD . ExBlo</b>	[Operation / Status Display / Temp-Prot / RTD / General]
 <i>Signal: External Blocking</i>	
<b>RTD . Blo TripCmd</b>	[Operation / Status Display / Temp-Prot / RTD / General]
 <i>Signal: Trip Command blocked</i>	
<b>RTD . ExBlo TripCmd</b>	[Operation / Status Display / Temp-Prot / RTD / General]
 <i>Signal: External Blocking of the Trip Command</i>	
<b>RTD . Timeout Alarm</b>	[Operation / Status Display / Temp-Prot / RTD / General]
 <i>Alarm timeout expired</i>	
<b>RTD . Windg 1 Trip</b>	[Operation / Status Display / Temp-Prot / RTD / Windg 1]
 <i>Winding 1 Signal: Trip</i>	
<b>RTD . Windg 1 Invalid</b>	[Operation / Status Display / Temp-Prot / RTD / Windg 1]
 <i>Winding 1 Signal: Invalid Temperature Measurement Value (e.g caused by an defective or interrupted RTD Measurement)</i>	
<b>RTD . Windg 2 Trip</b>	[Operation / Status Display / Temp-Prot / RTD / Windg 2]
 <i>Winding 2 Signal: Trip</i>	

<b>RTD . Windg 2 Invalid</b>	[Operation / Status Display / Temp-Prot / RTD / Windg 2]
 <i>Winding 2 Signal: Invalid Temperature Measurement Value (e.g caused by an defective or interrupted RTD Measurement)</i>	
<b>RTD . Windg 3 Trip</b>	[Operation / Status Display / Temp-Prot / RTD / Windg 3]
 <i>Winding 3 Signal: Trip</i>	
<b>RTD . Windg 3 Invalid</b>	[Operation / Status Display / Temp-Prot / RTD / Windg 3]
 <i>Winding 3 Signal: Invalid Temperature Measurement Value (e.g caused by an defective or interrupted RTD Measurement)</i>	
<b>RTD . Windg 4 Trip</b>	[Operation / Status Display / Temp-Prot / RTD / Windg 4]
 <i>Winding 4 Signal: Trip</i>	
<b>RTD . Windg 4 Invalid</b>	[Operation / Status Display / Temp-Prot / RTD / Windg 4]
 <i>Winding 4 Signal: Invalid Temperature Measurement Value (e.g caused by an defective or interrupted RTD Measurement)</i>	
<b>RTD . Windg 5 Trip</b>	[Operation / Status Display / Temp-Prot / RTD / Windg 5]
 <i>Winding 5 Signal: Trip</i>	
<b>RTD . Windg 5 Invalid</b>	[Operation / Status Display / Temp-Prot / RTD / Windg 5]
 <i>Winding 5 Signal: Invalid Temperature Measurement Value (e.g caused by an defective or interrupted RTD Measurement)</i>	
<b>RTD . Windg 6 Trip</b>	[Operation / Status Display / Temp-Prot / RTD / Windg 6]
 <i>Winding 6 Signal: Trip</i>	
<b>RTD . Windg 6 Invalid</b>	[Operation / Status Display / Temp-Prot / RTD / Windg 6]
 <i>Winding 6 Signal: Invalid Temperature Measurement Value (e.g caused by an defective or interrupted RTD Measurement)</i>	
<b>RTD . MotBear 1 Trip</b>	[Operation / Status Display / Temp-Prot / RTD / MotBear 1]
 <i>Motor Bearing 1 Signal: Trip</i>	
<b>RTD . MotBear 1 Invalid</b>	[Operation / Status Display / Temp-Prot / RTD / MotBear 1]
 <i>Motor Bearing 1 Signal: Invalid Temperature Measurement Value (e.g caused by an defective or interrupted RTD Measurement)</i>	


<b>RTD . MotBear 2 Trip</b>	[Operation / Status Display / Temp-Prot / RTD / MotBear 2]
 <i>Motor Bearing 2 Signal: Trip</i>	
<b>RTD . MotBear 2 Invalid</b>	[Operation / Status Display / Temp-Prot / RTD / MotBear 2]
 <i>Motor Bearing 2 Signal: Invalid Temperature Measurement Value (e.g caused by an defective or interrupted RTD Measurement)</i>	
<b>RTD . LoadBear 1 Trip</b>	[Operation / Status Display / Temp-Prot / RTD / LoadBear 1]
 <i>Load Bearing 1 Signal: Trip</i>	
<b>RTD . LoadBear 1 Invalid</b>	[Operation / Status Display / Temp-Prot / RTD / LoadBear 1]
 <i>Load Bearing 1 Signal: Invalid Temperature Measurement Value (e.g caused by an defective or interrupted RTD Measurement)</i>	
<b>RTD . LoadBear 2 Trip</b>	[Operation / Status Display / Temp-Prot / RTD / LoadBear 2]
 <i>Load Bearing 2 Signal: Trip</i>	
<b>RTD . LoadBear 2 Invalid</b>	[Operation / Status Display / Temp-Prot / RTD / LoadBear 2]
 <i>Load Bearing 2 Signal: Invalid Temperature Measurement Value (e.g caused by an defective or interrupted RTD Measurement)</i>	
<b>RTD . Aux1 Trip</b>	[Operation / Status Display / Temp-Prot / RTD / Aux1]
 <i>Auxiliary 1 Signal: Trip</i>	
<b>RTD . Aux1 Invalid</b>	[Operation / Status Display / Temp-Prot / RTD / Aux1]
 <i>Auxiliary 1 Signal: Invalid Temperature Measurement Value (e.g caused by an defective or interrupted RTD Measurement)</i>	
<b>RTD . Aux2 Trip</b>	[Operation / Status Display / Temp-Prot / RTD / Aux2]
 <i>Auxiliary 2 Signal: Trip</i>	
<b>RTD . Aux2 Invalid</b>	[Operation / Status Display / Temp-Prot / RTD / Aux2]
 <i>Auxiliary 2 Signal: Invalid Temperature Measurement Value (e.g caused by an defective or interrupted RTD Measurement)</i>	
<b>RTD . Trip WD Group</b>	[Operation / Status Display / Temp-Prot / RTD / Windg Group]
 <i>Trip all Windings</i>	





<b>RTD . Windg Group Invalid</b>	[Operation / Status Display / Temp-Prot / RTD / Windg Group]
 <i>Winding Group Signal: Invalid Temperature Measurement Value (e.g caused by an defective or interrupted RTD Measurement)</i>	
<b>RTD . Trip MB Group</b>	[Operation / Status Display / Temp-Prot / RTD / MotBear Group]
 <i>Trip all Motor Bearings</i>	
<b>RTD . MotBear Group Invalid</b>	[Operation / Status Display / Temp-Prot / RTD / MotBear Group]
 <i>Motor Bearing Group Signal: Invalid Temperature Measurement Value (e.g caused by an defective or interrupted RTD Measurement)</i>	
<b>RTD . Trip LB Group</b>	[Operation / Status Display / Temp-Prot / RTD / LoadBear Group]
 <i>Trip all Load Bearings</i>	
<b>RTD . LoadBear Group Invalid</b>	[Operation / Status Display / Temp-Prot / RTD / LoadBear Group]
 <i>Load Bearing Group Signal: Invalid Temperature Measurement Value (e.g caused by an defective or interrupted RTD Measurement)</i>	
<b>RTD . Trip Aux Group</b>	[Operation / Status Display / Temp-Prot / RTD / Aux Group]
 <i>Trip Auxiliary Group</i>	
<b>RTD . AuxGrpInvalid</b>	[Operation / Status Display / Temp-Prot / RTD / Aux Group]
 <i>Invalid Auxiliary Group</i>	
<b>RTD . Trip Any Group</b>	[Operation / Status Display / Temp-Prot / RTD / Any Group]
 <i>Trip Any Group</i>	
<b>RTD . Alarm Any Group</b>	[Operation / Status Display / Temp-Prot / RTD / Any Group]
 <i>Alarm Any Group</i>	
<b>RTD . TimeoutAlmAnyGrp</b>	[Operation / Status Display / Temp-Prot / RTD / Any Group]
 <i>Timeout Alarm Any Group</i>	
<b>RTD . Trip Group 1</b>	[Operation / Status Display / Temp-Prot / RTD / Voting]
 <i>Trip Group 1</i>	


<b>RTD . Trip Group 2</b>	[Operation / Status Display / Temp-Prot / RTD / Voting]
 Trip Group 2	


### 9.15.6 RTD: Counters


<b>RTD . HottestWindingTemp</b>	[Operation / Measured Values / URTD]
 Hottest motor winding temperature in degrees C.	


<b>RTD . Hottest MotBearTemp</b>	[Operation / Measured Values / URTD]
 Hottest motor bearing temperature in degrees C.	


<b>RTD . Hottest LoadBearTemp</b>	[Operation / Measured Values / URTD]
 Hottest load bearing temperature in degrees C.	


<b>RTD . Hottest Aux Temp</b>	[Operation / Measured Values / URTD]
 Hottest Auxiliary temperature in degrees C.	


<b>RTD . HighestWdTemp</b>	[Operation / History / OperationsCr]
 Highest motor winding temperature in degrees.	

<b>RTD . HighestMbTemp</b>	[Operation / History / OperationsCr]
 Highest motor bearing temperature in degrees.	

<b>RTD . HighestLbTemp</b>	[Operation / History / OperationsCr]
 Highest load bearing temperature in degrees.	

<b>RTD . HighestAuxTemp</b>	[Operation / History / OperationsCr]
 Highest Auxiliary temperature in degrees.	

<b>RTD . nWdAlarms</b>	[Operation / History / AlarmCr]
 Number of winding temperature alarms since last reset.	

<b>RTD . nMbAlarms</b>	[Operation / History / AlarmCr]
 Number of motor bearing temperature alarms since last reset.	

<b>RTD . nLbAlarms</b>	[Operation / History / AlarmCr]
------------------------	---------------------------------

#	<i>Number of load bearing temperature alarms since last reset.</i>
---	--

<b>RTD . nAuxAlarms</b>	[Operation / History / AlarmCr]
-------------------------	---------------------------------

#	<i>Number of auxiliary temperature alarms since last reset.</i>
---	---

<b>RTD . nChannelFails</b>	[Operation / History / AlarmCr]
----------------------------	---------------------------------

#	<i>Number of RTD channel failures.</i>
---	--

<b>RTD . nWdTrips</b>	[Operation / History / TripCmdCr]
-----------------------	-----------------------------------

#	<i>Number of winding temperature trips since last reset.</i>
---	--

<b>RTD . nMbTrips</b>	[Operation / History / TripCmdCr]
-----------------------	-----------------------------------

#	<i>Number of motor bearing temperature trips since last reset.</i>
---	--

<b>RTD . nLbTrips</b>	[Operation / History / TripCmdCr]
-----------------------	-----------------------------------

#	<i>Number of load bearing temperature trips since last reset.</i>
---	---

<b>RTD . nAuxTrips</b>	[Operation / History / TripCmdCr]
------------------------	-----------------------------------


#	<i>Number of auxiliary temperature trips since last reset.</i>
---	--

## 9.16 Supervision


### 9.16.1 CBF


Circuit breaker failure protection module

#### 9.16.1.1 CBF: Device Planning Parameters

<b>CBF . Mode</b>	[Device planning]	
"_"	"-", use  ↳ Device planning.	S.3
 <i>Module Circuit Breaker Failure protection, general operation mode</i>		

#### 9.16.1.2 CBF: Global Parameters


<b>CBF . Scheme</b>	[Protection Para / Global Prot Para / Supervision / CBF]	
50BF	50BF, CB Pos, 50BF and CB Pos  ↳ Scheme.	P.2
 <i>Scheme</i>		


<b>CBF . ExBlo1</b>	[Protection Para / Global Prot Para / Supervision / CBF]	
<b>CBF . ExBlo2</b>		
"_"	"-" ... Sys . Internal test state  ↳ 1..n, Assignment List.	P.2
 <i>External blocking of the module, if blocking is activated (allowed) within a parameter set and if the state of the assigned signal is true.</i>		


<b>CBF . Trigger</b>	[Protection Para / Global Prot Para / Supervision / CBF]	
All Trips	- . -, All Trips, External Trips, Current Trips  ↳ Trigger.	P.2
 <i>Determining the trigger mode for the Breaker Failure.</i>		


CBF . <b>Trigger1</b>	[Protection Para / Global Prot Para / Supervision / CBF]	
CBF . <b>Trigger2</b>		
CBF . <b>Trigger3</b>		
"-"	"-" ... Logics . LE80.Out inverted ↳ Trigger.	P.2
 Trigger that will start the CBF		

### 9.16.1.3 CBF: Setting Group Parameters


CBF . <b>Function</b>	[Protection Para / Set 1...4 / Supervision / CBF]	
inactive	inactive, active ↳ Mode.	P.2
 Permanent activation or deactivation of module/stage.		

CBF . <b>ExBlo Fc</b>	[Protection Para / Set 1...4 / Supervision / CBF]	
inactive	inactive, active ↳ active/inactive.	P.2
 Activate (allow) or inactivate (disallow) blocking of the module/stage. This parameter is only effective if a signal is assigned to the corresponding global protection parameter. If the signal becomes true, those modules/stages are blocked that are parameterized "ExBlo Fc=active".		


CBF . <b>I-CBF &gt;</b>	[Protection Para / Set 1...4 / Supervision / CBF]	
0.02In	0.02In ... 4.00In	P.2
 Breaker Failure Alarm will be initiated if this threshold is still exceeded after the timer has expired (50 BF).		


CBF . <b>t-CBF</b>	[Protection Para / Set 1...4 / Supervision / CBF]	
0.20s	0.00s ... 10.00s	P.2
 If the delay time is expired, an CBF alarm is given out.		


**9.16.1.4 CBF: Direct Controls**

<b>CBF . Res Lockout</b>	[Operation / Reset/Acknowledge / Reset]	
inactive	inactive, active  Mode.	P.1
<input checked="" type="radio"/> <i>Reset Lockout</i>		


**9.16.1.5 CBF: Input States**


<b>CBF . ExBlo1-I</b>	[Operation / Status Display / Supervision / CBF]	
 <i>Module input state: External blocking1</i>		


<b>CBF . ExBlo2-I</b>	[Operation / Status Display / Supervision / CBF]	
 <i>Module input state: External blocking2</i>		

<b>CBF . Trigger1-I</b>	[Operation / Status Display / Supervision / CBF]	
<b>CBF . Trigger2-I</b>		
<b>CBF . Trigger3-I</b>		
 <i>Module Input: Trigger that will start the CBF</i>		

**9.16.1.6 CBF: Signals (Output States)**

<b>CBF . active</b>	[Operation / Status Display / All Actives]
	[Operation / Status Display / Supervision / CBF]
 <i>Signal: active</i>	

<b>CBF . Alarm</b>	[Operation / Status Display / Alarms]
	[Operation / Status Display / Supervision / CBF]
 <i>Signal: Circuit Breaker Failure</i>	


<b>CBF . ExBlo</b>	[Operation / Status Display / Supervision / CBF]
 <i>Signal: External Blocking</i>	

<b>CBF . Waiting for Trigger</b>	[Operation / Status Display / Supervision / CBF]
⬆	<i>Waiting for Trigger</i>
<b>CBF . running</b>	[Operation / Status Display / Supervision / CBF]
⬆	<i>Signal: CBF-Module started</i>
<b>CBF . Lockout</b>	[Operation / Status Display / Supervision / CBF]
⬆	<i>Signal: Lockout</i>
<b>CBF . Res Lockout</b>	[Operation / Status Display / Supervision / CBF]
⬆	<i>Signal: Reset Lockout</i>


## 9.16.2 TCS


Trip circuit supervision


### 9.16.2.1 TCS: Device Planning Parameters

<b>TCS . Mode</b>	[Device planning]	
"_"	"_", use ↳ Device planning.	S.3
 Trip circuit supervision, general operation mode		


### 9.16.2.2 TCS: Global Parameters

<b>TCS . Mode</b>	[Protection Para / Global Prot Para / Supervision / TCS]	
Closed	Closed, Either ↳ Mode.	P.2
 Select if trip circuit is going to be monitored when the breaker is closed or when the breaker is either open or close.		


<b>TCS . Input 1</b>	[Protection Para / Global Prot Para / Supervision / TCS]	
"_"	"_" ... DI Slot X1 . DI 4 ↳ 1..n, Dig Inputs.	P.2
 Select the input configured to monitor the trip coil when the breaker is closed.		


<b>TCS . Input 2</b>	[Protection Para / Global Prot Para / Supervision / TCS]	
"_"	"_" ... DI Slot X1 . DI 4 ↳ 1..n, Dig Inputs.	P.2
Only available if: <ul style="list-style-type: none"> <li>TCS . Mode = Either</li> </ul>		
 Select the input configured to monitor the trip coil when the breaker is open. Only available if Mode set to "Either".		




TCS . <b>ExBlo1</b>	[Protection Para / Global Prot Para / Supervision / TCS]	
TCS . <b>ExBlo2</b>		
"_"	"_" ... Sys . Internal test state  ↳ 1..n, Assignment List.	P.2
	<i>External blocking of the module, if blocking is activated (allowed) within a parameter set and if the state of the assigned signal is true.</i>	



### 9.16.2.3 TCS: Setting Group Parameters

TCS . <b>Function</b>	[Protection Para / Set 1...4 / Supervision / TCS]	
inactive	inactive, active  ↳ Mode.	P.2
	<i>Permanent activation or deactivation of module/stage.</i>	

TCS . <b>ExBlo Fc</b>	[Protection Para / Set 1...4 / Supervision / TCS]	
inactive	inactive, active  ↳ active/inactive.	P.2
	<i>Activate (allow) or inactivate (disallow) blocking of the module/stage. This parameter is only effective if a signal is assigned to the corresponding global protection parameter. If the signal becomes true, those modules/stages are blocked that are parameterized "ExBlo Fc=active".</i>	

TCS . <b>t-TCS</b>	[Protection Para / Set 1...4 / Supervision / TCS]	
0.2s	0.10s ... 10.00s	P.2
	<i>Delay time of the Trip Circuit Supervision</i>	

### 9.16.2.4 TCS: Input States

TCS . <b>Aux ON-I</b>	[Operation / Status Display / Supervision / TCS]	
	<i>Module Input State: Position indicator/check-back signal of the CB (52a)</i>	
TCS . <b>Aux OFF-I</b>	[Operation / Status Display / Supervision / TCS]	
	<i>Module input state: Position indicator/check-back signal of the CB (52b)</i>	

<b>TCS . ExBlo1-I</b>	[Operation / Status Display / Supervision / TCS]
⬇	<i>Module input state: External blocking1</i>

<b>TCS . ExBlo2-I</b>	[Operation / Status Display / Supervision / TCS]
⬇	<i>Module input state: External blocking2</i>

### 9.16.2.5 TCS: Signals (Output States)

<b>TCS . active</b>	[Operation / Status Display / All Actives] [Operation / Status Display / Supervision / TCS]
⬆	<i>Signal: active</i>

<b>TCS . Alarm</b>	[Operation / Status Display / Alarms] [Operation / Status Display / Supervision / TCS]
⬆	<i>Signal: Alarm Trip Circuit Supervision</i>



<b>TCS . ExBlo</b>	[Operation / Status Display / Supervision / TCS]
⬆	<i>Signal: External Blocking</i>

<b>TCS . Not Possible</b>	[Operation / Status Display / Supervision / TCS]
⬆	<i>Not possible because no state indicator assigned to the breaker.</i>



### 9.16.3 CTS

CT Supervision



#### 9.16.3.1 CTS: Device Planning Parameters



<b>CTS . Mode</b>	[Device planning]	
"_"	"_", use  Device planning.	S.3
	<i>CT Supervision, general operation mode</i>	


#### 9.16.3.2 CTS: Global Parameters


<b>CTS . ExBlo1</b>	[Protection Para / Global Prot Para / Supervision / CTS]	
<b>CTS . ExBlo2</b>		
"_"	"_" ... Sys . Internal test state  1..n, Assignment List.	P.2
	<i>External blocking of the module, if blocking is activated (allowed) within a parameter set and if the state of the assigned signal is true.</i>	


#### 9.16.3.3 CTS: Setting Group Parameters

<b>CTS . Function</b>	[Protection Para / Set 1...4 / Supervision / CTS]	
inactive	inactive, active  Mode.	P.2
	<i>Permanent activation or deactivation of module/stage.</i>	


<b>CTS . ExBlo Fc</b>	[Protection Para / Set 1...4 / Supervision / CTS]	
inactive	inactive, active  active/inactive.	P.2
	<i>Activate (allow) or inactivate (disallow) blocking of the module/stage. This parameter is only effective if a signal is assigned to the corresponding global protection parameter. If the signal becomes true, those modules/stages are blocked that are parameterized "ExBlo Fc=active".</i>	


<b>CTS . <math>\Delta I</math></b>	[Protection Para / Set 1...4 / Supervision / CTS]	
0.50In	0.10In ... 1.00In	P.2
	<i>In order to prevent faulty tripping of phase selective protection functions that use the current as tripping criterion. If the difference of the measured earth current and the calculated value <math>I_0</math> is higher than the pick up value <math>\Delta I</math>, an alarm event is generated after expiring of the excitation time. In such a case, a fuse failure, a broken wire or a faulty measuring circuit can be assumed.</i>	

<b>CTS . Alarm delay</b>	[Protection Para / Set 1...4 / Supervision / CTS]	
1.0s	0.0s ... 9999.0s	P.2
	<i>Alarm delay</i>	


<b>CTS . Kd</b>	[Protection Para / Set 1...4 / Supervision / CTS]	
0.00	0.00 ... 0.99	P.2
	<i>Dynamic correction factor for the evaluation of the difference between calculated and measured earth current. This correction factor allows transformer faults, caused by higher currents, to be compensated.</i>	


#### 9.16.3.4 CTS: Input States

<b>CTS . ExBlo1-I</b>	[Operation / Status Display / Supervision / CTS]	
	<i>Module input state: External blocking1</i>	

<b>CTS . ExBlo2-I</b>	[Operation / Status Display / Supervision / CTS]	
	<i>Module input state: External blocking2</i>	

#### 9.16.3.5 CTS: Signals (Output States)

<b>CTS . active</b>	[Operation / Status Display / All Actives]	
	[Operation / Status Display / Supervision / CTS]	
	<i>Signal: active</i>	

<b>CTS . Alarm</b>	[Operation / Status Display / Alarms]	
	[Operation / Status Display / Supervision / CTS]	
	<i>Signal: Alarm Current Transformer Measuring Circuit Supervision</i>	

CTS . **ExBlo**

[Operation / Status Display / Supervision / CTS]

 *Signal: External Blocking*



# 10 Control


Control



<b>Control Page</b>	[Control / Control Page]	
	This item represents a special dialog. (See the Technical Manual for details.)	
	<i>Control Page</i>	

## 10.1 Ctrl: Device Planning Parameters



## 10.2 Ctrl: Global Parameters


<b>Ctrl . Res NonIL</b>	[Control / General Settings]	
single Operation	single Operation, timeout, permanent	C.2
	 NonIL ResetMode.	
	<i>Resetmode Non-Interlocking</i>	

<b>Ctrl . Timeout NonIL</b>	[Control / General Settings]	
60s	2s ... 3600s	C.2
	<i>Timeout Non-Interlocking</i>	


<b>Ctrl . NonIL Assign</b>	[Control / General Settings]	
"_"	"_" ... Sys . Internal test state	C.2
	 1..n, Assignment List.	
	<i>Assignment Non-Interlocking</i>	

## 10.3 Ctrl: Direct Controls


<b>Ctrl . Switching Authority</b>	[Control / General Settings]	
Local	None, Local, Remote, Local and Remote	C.2
	 Switching Authority.	
	<i>Switching Authority</i>	


Ctrl . <b>NonInterl</b>	[Control / General Settings]	
inactive	inactive, active  Mode.	C.2
<input checked="" type="radio"/> <i>DC for Non-Interlocking</i>		


## 10.4 Ctrl: Input States


Ctrl . <b>NonInterl-I</b>	[Operation / Status Display / Control / General Control]
 <i>Non-Interlocking</i>	


## 10.5 Ctrl: Signals (Output States)


Ctrl . <b>Local</b>	[Operation / Status Display / Control / General Control]
 <i>Switching Authority: Local</i>	


Ctrl . <b>Remote</b>	[Operation / Status Display / Control / General Control]
 <i>Switching Authority: Remote</i>	

Ctrl . <b>NonInterl</b>	[Operation / Status Display / Control / General Control]
 <i>Non-Interlocking is active</i>	



Ctrl . <b>SG Indeterm</b>	[Operation / Status Display / Control / General Control]
 <i>(At least one) Switchgear is moving (Position cannot be determined).</i>	

Ctrl . <b>SG Disturb</b>	[Operation / Status Display / Control / General Control]
 <i>(At least one) Switchgear is disturbed.</i>	

Ctrl . <b>CES SAuthority</b>	[Operation / Status Display / Control / General Control]
 <i>Command Execution Supervision: Number of rejected Commands because of missing switching authority.</i>	

Ctrl . <b>CES DoubleOperating</b>	[Operation / Status Display / Control / General Control]
 <i>Command Execution Supervision: Number of rejected Commands because a second switch command is in conflict with a pending one.</i>	

## 10.6 Ctrl: Values

Ctrl . <b>Switching Authority</b>	[Operation / Security / Security States]
Local	None, Local, Remote, Local and Remote  <b>Switching Authority.</b>
 <i>Switching Authority</i>	





## 10.7 SG[1]


Switchgear


### 10.7.1 SG[1]: Global Parameters


<b>SG[1] . OFF incl TripCmd</b>		[Control / SG / SG[1] / General Settings]
active	inactive, active	C.2
	 Mode.	
	<i>The OFF Command includes the OFF Command issued by the Protection module.</i>	
<b>SG[1] . t-Move ON</b>		[Control / SG / SG[1] / General Settings]
0.1s	0.01s ... 100.00s	C.2
	<i>Time to move to the ON Position</i>	
<b>SG[1] . t-Move OFF</b>		[Control / SG / SG[1] / General Settings]
0.1s	0.01s ... 100.00s	C.2
	<i>Time to move to the OFF Position</i>	
<b>SG[1] . t-Dwell</b>		[Control / SG / SG[1] / General Settings]
0s	0s ... 100.00s	C.2
	<i>Dwell time</i>	
<b>SG[1] . t-TripCmd</b>		[Control / SG / SG[1] / Trip Manager]
0.2s	0s ... 300.00s	P.2
	<i>Minimum hold time of the OFF-command (circuit breaker, load break switch)</i>	
<b>SG[1] . Latched</b>		[Control / SG / SG[1] / Trip Manager]
inactive	inactive, active	P.2
	 Mode.	
	<i>Defines whether the Trip Command is latched.</i>	


<b>SG[1] . Ack TripCmd</b>		[Control / SG / SG[1] / Trip Manager]
"_"	"_" ... Sys . Internal test state	P.2
	↳ 1..n, Assignment List.	
	<i>Ack TripCmd</i>	


<b>SG[1] . Off Cmd1</b>		[Control / SG / SG[1] / Trip Manager]
MStart . TripCmd	"_" ... RTD . TripCmd	P.2
	↳ 1..n, Trip Cmds.	
	<i>Off Command to the Circuit Breaker if the state of the assigned signal becomes true.</i>	


<b>SG[1] . Off Cmd2</b>		[Control / SG / SG[1] / Trip Manager]
I[1] . TripCmd	"_" ... RTD . TripCmd	P.2
	↳ 1..n, Trip Cmds.	
	<i>Off Command to the Circuit Breaker if the state of the assigned signal becomes true.</i>	


<b>SG[1] . Off Cmd3</b>		[Control / SG / SG[1] / Trip Manager]
I[2] . TripCmd	"_" ... RTD . TripCmd	P.2
	↳ 1..n, Trip Cmds.	
	<i>Off Command to the Circuit Breaker if the state of the assigned signal becomes true.</i>	


<b>SG[1] . Off Cmd4</b>		[Control / SG / SG[1] / Trip Manager]
I2>[1] . TripCmd	"_" ... RTD . TripCmd	P.2
	↳ 1..n, Trip Cmds.	
	<i>Off Command to the Circuit Breaker if the state of the assigned signal becomes true.</i>	


<b>SG[1] . Off Cmd5</b>		[Control / SG / SG[1] / Trip Manager]
ThR . TripCmd	"_" ... RTD . TripCmd	P.2
	↳ 1..n, Trip Cmds.	
	<i>Off Command to the Circuit Breaker if the state of the assigned signal becomes true.</i>	


<b>SG[1] . Off Cmd6</b>	[Control / SG / SG[1] / Trip Manager]	
Jam[1] . TripCmd	"-" ... RTD . TripCmd ↳ 1..n, Trip Cmds.	P.2
 Off Command to the Circuit Breaker if the state of the assigned signal becomes true.		

<b>SG[1] . Off Cmd7</b>	[Control / SG / SG[1] / Trip Manager]	
I<[1] . TripCmd	"-" ... RTD . TripCmd ↳ 1..n, Trip Cmds.	P.2
 Off Command to the Circuit Breaker if the state of the assigned signal becomes true.		

<b>SG[1] . Off Cmd8</b>	[Control / SG / SG[1] / Trip Manager]	
...		
<b>SG[1] . Off Cmd30</b>	[Control / SG / SG[1] / Trip Manager]	
"-"	"-" ... RTD . TripCmd ↳ 1..n, Trip Cmds.	P.2
 Off Command to the Circuit Breaker if the state of the assigned signal becomes true.		

<b>SG[1] . Aux ON</b>	[Control / SG / SG[1] / Pos Indicatrns Wirng]	
	"-" ... Logics . LE80.Out inverted ↳ 1..n, DI-LogicList.	C.2
 The CB is in ON-position if the state of the assigned signal is true (52a).		


<b>SG[1] . Aux OFF</b>	[Control / SG / SG[1] / Pos Indicatrns Wirng]	
	"-" ... Logics . LE80.Out inverted ↳ 1..n, DI-LogicList.	C.2
 The CB is in OFF-position if the state of the assigned signal is true (52b).		


<b>SG[1] . Ready</b>	[Control / SG / SG[1] / Pos Indicatrns Wirng]	
"_"	"_" ... Logics . LE80.Out inverted ↳ 1..n, DI-LogicList.	C.2
	<i>Circuit breaker is ready for operation if the state of the assigned signal is true. This digital input can be used by some protective elements (if they are available within the device) like Auto Reclosure (AR), e.g. as a trigger signal.</i>	


<b>SG[1] . Removed</b>	[Control / SG / SG[1] / Pos Indicatrns Wirng]	
"_"	"_" ... Logics . LE80.Out inverted ↳ 1..n, DI-LogicList.	C.2
	<i>The withdrawable circuit breaker is Removed</i>	

<b>SG[1] . SCmd ON</b>	[Control / SG / SG[1] / Ex ON/OFF Cmd]	
"_"	"_" ... Logics . LE80.Out inverted ↳ 1..n, DI-LogicList.	C.2
	<i>Switching ON Command, e.g. the state of the Logics or the state of the digital input</i>	


<b>SG[1] . SCmd OFF</b>	[Control / SG / SG[1] / Ex ON/OFF Cmd]	
"_"	"_" ... Logics . LE80.Out inverted ↳ 1..n, DI-LogicList.	C.2
	<i>Switching OFF Command, e.g. the state of the Logics or the state of the digital input</i>	


<b>SG[1] . Interl ON1</b>	[Control / SG / SG[1] / Interlockings]	
<b>SG[1] . Interl ON3</b>		
"_"	"_" ... Sys . Internal test state ↳ 1..n, Assignment List.	C.2
	<i>Interlocking of the ON command</i>	

<b>SG[1] . Interl ON2</b>	[Control / SG / SG[1] / Interlockings]	
MStart . Blo	"_" ... Sys . Internal test state ↳ 1..n, Assignment List.	C.2
	<i>Interlocking of the ON command</i>	

SG[1] . <b>Interl OFF1</b>	[Control / SG / SG[1] / Interlockings]	
SG[1] . <b>Interl OFF2</b>		
SG[1] . <b>Interl OFF3</b>		
"-"	"-" ... Sys . Internal test state  ↳ 1..n, Assignment List.	C.2
 <i>Interlocking of the OFF command</i>		


### 10.7.2 SG[1]: Direct Controls

SG[1] . <b>Ack TripCmd</b>	[Operation / Reset/Acknowledge / Acknowledge]	
inactive	inactive, active  ↳ Mode.	P.1
 <i>Acknowledge Trip Command</i>		

SG[1] . <b>Res SGwear SI SG</b>	[Operation / Reset/Acknowledge / Reset]	
inactive	inactive, active  ↳ Mode.	P.1
 <i>Resetting the slow Switchgear Alarm</i>		

SG[1] . <b>Manipulate Position</b>	[Control / SG / SG[1] / General Settings]	
inactive	inactive, Pos OFF, Pos ON  ↳ Manipulate Position.	C.2
 <i>WARNING! Fake Position - Manual Position Manipulation</i>		

### 10.7.3 SG[1]: Input States

SG[1] . <b>Interl ON1-I</b>	[Operation / Status Display / Control / SG[1]]	
SG[1] . <b>Interl ON2-I</b>		
SG[1] . <b>Interl ON3-I</b>		
 <i>State of the module input: Interlocking of the ON command</i>		

SG[1] . <b>Interl OFF1-I</b>	[Operation / Status Display / Control / SG[1]]
SG[1] . <b>Interl OFF2-I</b>	
SG[1] . <b>Interl OFF3-I</b>	

↓ *State of the module input: Interlocking of the OFF command*

SG[1] . <b>SCmd ON-I</b>	[Operation / Status Display / Control / SG[1]]
--------------------------	--

↓ *State of the module input: Switching ON Command, e.g. the state of the Logics or the state of the digital input*

SG[1] . <b>SCmd OFF-I</b>	[Operation / Status Display / Control / SG[1]]
---------------------------	--

↓ *State of the module input: Switching OFF Command, e.g. the state of the Logics or the state of the digital input*

SG[1] . <b>Aux ON-I</b>	[Operation / Status Display / Control / SG[1]]
-------------------------	--

↓ *Module Input State: Position indicator/check-back signal of the CB (52a)*

SG[1] . <b>Aux OFF-I</b>	[Operation / Status Display / Control / SG[1]]
--------------------------	--

↓ *Module input state: Position indicator/check-back signal of the CB (52b)*

SG[1] . <b>Ready-I</b>	[Operation / Status Display / Control / SG[1]]
------------------------	--

↓ *Module input state: CB ready*

SG[1] . <b>Removed-I</b>	[Operation / Status Display / Control / SG[1]]
--------------------------	--

↓ *State of the module input: The withdrawable circuit breaker is Removed*

SG[1] . <b>Ack TripCmd-I</b>	[Operation / Status Display / Control / SG[1]]
------------------------------	--

↓ *State of the module input: Acknowledgement Signal (for the Trip Command) Module input signal*

### 10.7.4 SG[1]: Signals (Output States)

SG[1] . <b>TripCmd</b>	[Operation / Status Display / TripCmds]
	[Operation / Status Display / Control / SG[1]]

↓ *Signal: Trip Command*

**SG[1] . SI SingleContactInd** [Operation / Status Display / Control / SG[1]]

⤴ *Signal: The Position of the Switchgear is detected by one auxiliary contact (pole) only. Thus indeterminate and disturbed Positions cannot be detected.*

**SG[1] . Pos not ON** [Operation / Status Display / Control / SG[1]]

⤴ *Signal: Pos not ON*

**SG[1] . Pos ON** [Operation / Status Display / Control / SG[1]]

⤴ *Signal: Circuit Breaker is in ON-Position*

**SG[1] . Pos OFF** [Operation / Status Display / Control / SG[1]]

⤴ *Signal: Circuit Breaker is in OFF-Position*

**SG[1] . Pos Indeterm** [Operation / Status Display / Control / SG[1]]

⤴ *Signal: Circuit Breaker is in Indeterminate Position*

**SG[1] . Pos Disturb** [Operation / Status Display / Control / SG[1]]

⤴ *Signal: Circuit Breaker Disturbed - Undefined Breaker Position. The Position Indicators contradict themselves. After expiring of a supervision timer this signal becomes true.*

**SG[1] . Pos** [Operation / Status Display / Control / SG[1]]

⤴ *Signal: Circuit Breaker Position (0 = Indeterminate, 1 = OFF, 2 = ON, 3 = Disturbed)*

**SG[1] . Ready** [Operation / Status Display / Control / SG[1]]

⤴ *Signal: Circuit breaker is ready for operation.*

**SG[1] . t-Dwell** [Operation / Status Display / Control / SG[1]]

⤴ *Signal: Dwell time*

**SG[1] . Removed** [Operation / Status Display / Control / SG[1]]

⤴ *Signal: The withdrawable circuit breaker is Removed*

**SG[1] . Interl ON** [Operation / Status Display / Control / SG[1]]

⤴ *Signal: One or more IL\_On inputs are active.*

**SG[1] . Interl OFF** [Operation / Status Display / Control / SG[1]]

⤴ *Signal: One or more IL\_Off inputs are active.*

<b>SG[1] . CES succesf</b>	[Operation / Status Display / Control / SG[1]]
⬇	<i>Signal: Command Execution Supervision: Switching command executed successfully.</i>
<b>SG[1] . CES Disturbed</b>	[Operation / Status Display / Control / SG[1]]
⬇	<i>Signal: Command Execution Supervision: Switching Command unsuccessful. Switchgear in disturbed position.</i>
<b>SG[1] . CES Fail TripCmd</b>	[Operation / Status Display / Control / SG[1]]
⬇	<i>Signal: Command Execution Supervision: Command execution failed because trip command is pending.</i>
<b>SG[1] . CES SwitchDir</b>	[Operation / Status Display / Control / SG[1]]
⬇	<i>Signal: Command Execution Supervision respectively Switching Direction Control: This signal becomes true, if a switch command is issued even though the switchgear is already in the requested position. Example: A switchgear that is already OFF should be switched OFF again (doubly). The same applies to CLOSE commands.</i>
<b>SG[1] . CES ON d OFF</b>	[Operation / Status Display / Control / SG[1]]
⬇	<i>Signal: Command Execution Supervision: On Command during a pending OFF Command.</i>
<b>SG[1] . CES SG not ready</b>	[Operation / Status Display / Control / SG[1]]
⬇	<i>Signal: Command Execution Supervision: Switchgear not ready</i>
<b>SG[1] . CES Fiel Interl</b>	[Operation / Status Display / Control / SG[1]]
⬇	<i>Signal: Command Execution Supervision: Switching Command not executed because of field interlocking.</i>
<b>SG[1] . CES SG removed</b>	[Operation / Status Display / Control / SG[1]]
⬇	<i>Signal: Command Execution Supervision: Switching Command unsuccessful, Switchgear removed.</i>
<b>SG[1] . Ack TripCmd</b>	[Operation / Status Display / Control / SG[1]]
⬇	<i>Signal: Acknowledge Trip Command</i>
<b>SG[1] . OFF incl TripCmd</b>	[Operation / Status Display / Control / SG[1]]
⬇	<i>Signal: The OFF Command includes the OFF Command issued by the Protection module.</i>
<b>SG[1] . Position Ind manipul</b>	[Operation / Status Display / Control / SG[1]]
⬇	<i>Signal: Position Indicators faked</i>



<b>SG[1] . SGwear Slow SG</b>	[Operation / Status Display / Control / SG[1]]
⬆	<i>Signal: Alarm, the circuit breaker (load-break switch) becomes slower</i>

<b>SG[1] . Res SGwear SI SG</b>	[Operation / Status Display / Control / SG[1]]
⬆	<i>Signal: Resetting the slow Switchgear Alarm</i>

<b>SG[1] . ON Cmd</b>	[Operation / Status Display / Control / SG[1]]
⬆	<i>Signal: ON Command issued to the switchgear. Depending on the setting the signal may include the ON command of the Prot module.</i>

<b>SG[1] . OFF Cmd</b>	[Operation / Status Display / Control / SG[1]]
⬆	<i>Signal: OFF Command issued to the switchgear. Depending on the setting the signal may include the OFF command of the Prot module.</i>








<b>SG[1] . ON Cmd manual</b>	[Operation / Status Display / Control / SG[1]]
⬆	<i>Signal: ON Cmd manual</i>


<b>SG[1] . OFF Cmd manual</b>	[Operation / Status Display / Control / SG[1]]
⬆	<i>Signal: OFF Cmd manual</i>

## 10.7.5 Breaker Wear


Switchgear

### 10.7.5.1 SG[1]: Global Parameters


<b>SG[1] . Operations Alarm</b>		[Control / SG / SG[1] / SG Wear]
9999	1 ... 100000	C.2
	<i>Maximum number of operations. If the operations counter »TripCmd Cr« exceeds this limit then the signal »Operations Alarm« is set.</i>	
<b>SG[1] . Isum Intr Alarm</b>		[Control / SG / SG[1] / SG Wear]
100.00kA	0.00kA ... 2000.00kA	C.2
	<i>Alarm, the Sum (Limit) of interrupting currents has been exceeded.</i>	
<b>SG[1] . Isum Intr ph Alm</b>		[Control / SG / SG[1] / SG Wear]
100.00kA	0.00kA ... 2000.00kA	C.2
	<i>Alarm, the per hour Sum (Limit) of interrupting currents has been exceeded.</i>	
<b>SG[1] . SGwear Curve Fc</b>		[Control / SG / SG[1] / SG Wear]
inactive	inactive, active  active/inactive.	C.2
	<i>The Circuit Breaker (load-break switch) Wear Curve defines the maximum allowed CLOSE/ OPEN cycles depending on the brake currents. If the circuit breaker maintenance curve is exceeded, an alarm will be issued. The breaker maintenance curve is to be taken from the technical data sheet of the breaker manufacturer. By means of the available points this curve is to be replicated.</i>	
<b>SG[1] . WearLevel Alarm</b>		[Control / SG / SG[1] / SG Wear]
80.00%	0.00% ... 100.00%	C.2
	<i>Threshold for the Alarm</i>	
<b>SG[1] . WearLevel Lockout</b>		[Control / SG / SG[1] / SG Wear]
95.00%	0.00% ... 100.00%	C.2
	<i>Threshold for the Lockout Level</i>	

<b>SG[1] . Current1</b>	[Control / SG / SG[1] / SG Wear]	
0.00kA	0.00kA ... 2000.00kA	C.2
 <i>Interrupted Current Level #1</i>		


<b>SG[1] . Count1</b>	[Control / SG / SG[1] / SG Wear]	
10000	1 ... 32000	C.2
 <i>Open Counts Allowed #1</i>		

<b>SG[1] . Current2</b>	[Control / SG / SG[1] / SG Wear]	
1.20kA	0.00kA ... 2000.00kA	C.2
 <i>Interrupted Current Level #2</i>		

<b>SG[1] . Count2</b>	[Control / SG / SG[1] / SG Wear]	
10000	1 ... 32000	C.2
 <i>Open Counts Allowed #2</i>		

<b>SG[1] . Current3</b>	[Control / SG / SG[1] / SG Wear]	
8.00kA	0.00kA ... 2000.00kA	C.2
 <i>Interrupted Current Level #3</i>		


<b>SG[1] . Count3</b>	[Control / SG / SG[1] / SG Wear]	
150	1 ... 32000	C.2
 <i>Open Counts Allowed #3</i>		

<b>SG[1] . Current4</b>	[Control / SG / SG[1] / SG Wear]	
20.00kA	0.00kA ... 2000.00kA	C.2
 <i>Interrupted Current Level #4</i>		


<b>SG[1] . Count4</b>	[Control / SG / SG[1] / SG Wear]	
12	1 ... 32000	C.2
 <i>Open Counts Allowed #4</i>		

<b>SG[1] . Current5</b>	[Control / SG / SG[1] / SG Wear]	
20.00kA	0.00kA ... 2000.00kA	C.2
 <i>Interrupted Current Level #5</i>		


<b>SG[1] . Count5</b>	[Control / SG / SG[1] / SG Wear]	
1	1 ... 32000	C.2
	<i>Open Counts Allowed #5</i>	

<b>SG[1] . Current6</b>	[Control / SG / SG[1] / SG Wear]	
20.00kA	0.00kA ... 2000.00kA	C.2
	<i>Interrupted Current Level #6</i>	


<b>SG[1] . Count6</b>	[Control / SG / SG[1] / SG Wear]	
1	1 ... 32000	C.2
	<i>Open Counts Allowed #6</i>	

<b>SG[1] . Current7</b>	[Control / SG / SG[1] / SG Wear]	
20.00kA	0.00kA ... 2000.00kA	C.2
	<i>Interrupted Current Level #7</i>	


<b>SG[1] . Count7</b>	[Control / SG / SG[1] / SG Wear]	
1	1 ... 32000	C.2
	<i>Open Counts Allowed #7</i>	

<b>SG[1] . Current8</b>	[Control / SG / SG[1] / SG Wear]	
20.00kA	0.00kA ... 2000.00kA	C.2
	<i>Interrupted Current Level #8</i>	

<b>SG[1] . Count8</b>	[Control / SG / SG[1] / SG Wear]	
1	1 ... 32000	C.2
	<i>Open Counts Allowed #8</i>	



<b>SG[1] . Current9</b>	[Control / SG / SG[1] / SG Wear]	
20.00kA	0.00kA ... 2000.00kA	C.2
	<i>Interrupted Current Level #9</i>	



<b>SG[1] . Count9</b>	[Control / SG / SG[1] / SG Wear]	
1	1 ... 32000	C.2
	<i>Open Counts Allowed #9</i>	



<b>SG[1] . Current10</b>	[Control / SG / SG[1] / SG Wear]	
20.00kA	0.00kA ... 2000.00kA	C.2
	<i>Interrupted Current Level #10</i>	



<b>SG[1] . Count10</b>	[Control / SG / SG[1] / SG Wear]	
1	1 ... 32000	C.2
	<i>Open Counts Allowed #10</i>	

### 10.7.5.2 SG[1]: Direct Controls












<b>SG[1] . Res TripCmd Cr</b>	[Operation / Reset/Acknowledge / Reset]	
inactive	inactive, active  Mode.	P.1
	<i>Resetting of the Counter: Total number of trips of the switchgear</i>	

<b>SG[1] . Res Sum trip</b>	[Operation / Reset/Acknowledge / Reset]	
inactive	inactive, active  Mode.	P.1
	<i>Reset summation of the tripping currents</i>	

<b>SG[1] . Res CB OPEN capacity</b>	[Operation / Reset/Acknowledge / Reset]	
inactive	inactive, active  Mode.	P.1
	<i>Reset the CB OPEN capacity.</i> <i>(Remark: A »CB OPEN capacity« value of 100% means that the circuit breaker has to be maintained.)</i>	

<b>SG[1] . Res lsum Intr per hour</b>	[Operation / Reset/Acknowledge / Reset]	
inactive	inactive, active  Mode.	P.1
	<i>Reset of the Sum per hour of interrupting currents.</i>	

### 10.7.5.3 SG[1]: Signals (Output States)

<b>SG[1] . Operations Alarm</b>	[Operation / Status Display / Control / SG[1]]
 <i>Signal: Too many Operations. (The operations counter »TripCmd Cr« has exceeded the limit set at »Operations Alarm«.)</i>	
<b>SG[1] . Isum Intr trip: IL1</b>	[Operation / Status Display / Control / SG[1]]
 <i>Signal: Maximum permissible Summation of the interrupting (tripping) currents exceeded: IL1</i>	
<b>SG[1] . Isum Intr trip: IL2</b>	[Operation / Status Display / Control / SG[1]]
 <i>Signal: Maximum permissible Summation of the interrupting (tripping) currents exceeded: IL2</i>	
<b>SG[1] . Isum Intr trip: IL3</b>	[Operation / Status Display / Control / SG[1]]
 <i>Signal: Maximum permissible Summation of the interrupting (tripping) currents exceeded: IL3</i>	
<b>SG[1] . Isum Intr trip</b>	[Operation / Status Display / Control / SG[1]]
 <i>Signal: Maximum permissible Summation of the interrupting (tripping) currents exceeded in at least one phase.</i>	
<b>SG[1] . Res TripCmd Cr</b>	[Operation / Status Display / Control / SG[1]]
 <i>Signal: Resetting of the Counter: Total number of trips of the switchgear</i>	
<b>SG[1] . Res Sum trip</b>	[Operation / Status Display / Control / SG[1]]
 <i>Signal: Reset summation of the tripping currents</i>	
<b>SG[1] . WearLevel Alarm</b>	[Operation / Status Display / Control / SG[1]]
 <i>Signal: Threshold for the Alarm</i>	
<b>SG[1] . WearLevel Lockout</b>	[Operation / Status Display / Control / SG[1]]
 <i>Signal: Threshold for the Lockout Level</i>	
<b>SG[1] . Res CB OPEN capacity</b>	[Operation / Status Display / Control / SG[1]]
 <i>Signal: Reset of the wear maintenance curve (i. e. of the counter for the Circuit Breaker OPEN capacity.</i>	
<b>SG[1] . Isum Intr ph Alm</b>	[Operation / Status Display / Control / SG[1]]
 <i>Signal: Alarm, the per hour Sum (Limit) of interrupting currents has been exceeded.</i>	

SG[1] . <b>Res Isum Intr ph Alm</b>	[Operation / Status Display / Control / SG[1]]
↓	<i>Signal: Reset of the Alarm, "the per hour Sum (Limit) of interrupting currents has been exceeded".</i>

#### 10.7.5.4 SG[1]: Values

SG[1] . <b>Sum trip IL1</b>	[Operation / History / TotalCr]
SG[1] . <b>Sum trip IL2</b>	[Operation / Count and RevData / Control / SG[1]]
SG[1] . <b>Sum trip IL3</b>	
✎	<i>Summation of the tripping currents phase</i>

SG[1] . <b>Isum Intr per hour</b>	[Operation / Count and RevData / Control / SG[1]]
✎	<i>Sum per hour of interrupting currents.</i>

SG[1] . <b>CB OPEN capacity</b>	[Operation / Count and RevData / Control / SG[1]]
✎	<i>Used capacity of the circuit breaker. (100% means that the circuit breaker has to be maintained.)</i>



#### 10.7.5.5 SG[1]: Counters

SG[1] . <b>TripCmd Cr</b>	[Operation / History / TotalCr]
	[Operation / Count and RevData / Control / SG[1]]
#	<i>Counter: Total number of trips of the switchgear.</i>



# 11 System Alarms



## System Alarms



### 11.1 SysA: Device Planning Parameters

<b>SysA . Mode</b>	[Device planning]	
"_"	"_", use  Mode.	S.3
 <i>general operation mode</i>		

### 11.2 SysA: Global Parameters

<b>SysA . Function</b>	[SysA / General Settings]	
inactive	inactive, active  Mode.	P.2
 <i>Permanent activation or deactivation of module/stage.</i>		

<b>SysA . ExBlo Fc</b>	[SysA / General Settings]	
"_"	"_" ... Sys . Internal test state  1..n, Assignment List.	P.2
 <i>Activate (allow) or inactivate (disallow) blocking of the module/stage. This parameter is only effective if a signal is assigned to the corresponding global protection parameter. If the signal becomes true, those modules/stages are blocked that are parameterized "ExBlo Fc=active".</i>		


<b>SysA . Alarm</b>	[SysA / Demand / Current Demand] [SysA / THD / I THD]	
inactive	inactive, active  active/inactive.	P.2
 <i>Alarm</i>		




<b>SysA . Threshold</b>	[SysA / Demand / Current Demand] [SysA / THD / I THD]
500A	10A ... 500000A <span style="float: right;">P.2</span>
 <i>Threshold (to be entered as primary value)</i>	


<b>SysA . t-Delay</b>	[SysA / Demand / Current Demand] [SysA / THD / I THD]
0min	0min ... 60min <span style="float: right;">P.2</span>
 <i>Tripping Delay</i>	


### 11.3 SysA: Input States


<b>SysA . ExBlo-I</b>	[Operation / Status Display / SysA]
 <i>Module input state: External blocking</i>	


### 11.4 SysA: Signals (Output States)

<b>SysA . active</b>	[Operation / Status Display / SysA]
 <i>Signal: active</i>	

<b>SysA . ExBlo</b>	[Operation / Status Display / SysA]
 <i>Signal: External Blocking</i>	

<b>SysA . Alm Current Demd</b>	[Operation / Status Display / SysA]
 <i>Signal: Alarm averaged demand current</i>	

<b>SysA . Alarm I THD</b>	[Operation / Status Display / SysA]
 <i>Signal: Alarm Total Harmonic Distortion Current</i>	

<b>SysA . Trip Current Demand</b>	[Operation / Status Display / SysA]
 <i>Signal: Trip averaged demand current</i>	

## 11 System Alarms

### 11.4 SysA: Signals (Output States)

SysA . **Trip I THD**


[Operation / Status Display / SysA]

↑ Signal: *Trip Total Harmonic Distortion Current*



## 12 Records

### 12.1 Event rec


The event recorder logs all events like switching operations, change of parameters, alarms, trips, operating mode selections, blockings and state transitions of inputs and outputs.

<b>Event rec</b>	[Operation / Recorders / Event rec]
 This item represents a special dialog. (See the Technical Manual for details.)	
<i>The event recorder logs all events like switching operations, change of parameters, alarms, trips, operating mode selections, blockings and state transitions of inputs and outputs.</i>	

#### 12.1.1 Event rec: Direct Controls


Event rec . <b>Res all rec</b>	[Operation / Reset/Acknowledge / Reset]
inactive	inactive, active  Mode.
	P.1
 <i>Reset all records</i>	

#### 12.1.2 Event rec: Signals (Output States)


Event rec . <b>Res all records</b>	[Operation / Status Display / Recorders / Event rec]
 <i>Signal: All records are being deleted. (Remark: Immediately afterwards, this signal becomes inactive again.)</i>	


## 12.2 Disturb rec


After a trigger event has become true, the disturbance recorder writes analogue and digital tracks


<b>Disturb rec</b>	[Operation / Recorders / Disturb rec]	
	This item represents a special dialog. (See the Technical Manual for details.)	
	<i>After a trigger event has become true, the disturbance recorder writes analogue and digital tracks</i>	


### 12.2.1 Disturb rec: Global Parameters


Disturb rec . <b>Start: 1</b>	[Device Para / Recorders / Disturb rec]	
Prot . Trip	“-” ... Sys . Internal test state  ↳ 1..n, Assignment List.	S.3
	<i>Start recording if the assigned signal is true.</i>	

Disturb rec . <b>Start: 2</b>	[Device Para / Recorders / Disturb rec]	
...		
Disturb rec . <b>Start: 8</b>		
“-”	“-” ... Sys . Internal test state  ↳ 1..n, Assignment List.	S.3
	<i>Start recording if the assigned signal is true.</i>	


Disturb rec . <b>Auto overwriting</b>	[Device Para / Recorders / Disturb rec]	
active	inactive, active  ↳ Mode.	S.3
	<i>If there is no more free memory capacity left, the oldest file will be overwritten.</i>	


Disturb rec . <b>Pre-trigger time</b>	[Device Para / Recorders / Disturb rec]	
20%	0% ... 99%	S.3
	<i>The pre trigger time is set in percent of the »Max file size« value. It corresponds to the part of recording before the onset of the trigger event.</i>	

Disturb rec . <b>Post-trigger time</b>		[Device Para / Recorders / Disturb rec]
20%	0% ... 99%	S.3
	<i>The post trigger time is set in percent of the »Max file size« value. It is the remaining time of the »Max file size«, depending on the »Pre-trigger time« setting and the duration of the trigger event, but at maximum the »Post-trigger time« set here.</i>	


Disturb rec . <b>Max file size</b>		[Device Para / Recorders / Disturb rec]
2s	0.1s ... 15.0s	S.3
	<i>The maximum storage capacity per record, including pre-trigger and post-trigger time. The amount of records depends on the size of each record, on the max. file size (set here), and on the total storage capacity.</i>	

### 12.2.2 Disturb rec: Direct Controls


Disturb rec . <b>Man Trigger</b>		[Operation / Recorders / Man Trigger]
False	False, True	P.1
	 true or not true.	
<input checked="" type="radio"/>	<i>Manual Trigger</i>	


Disturb rec . <b>Res all rec</b>		[Operation / Reset/Acknowledge / Reset]
inactive	inactive, active	P.1
	 Mode.	
<input checked="" type="radio"/>	<i>Reset all records</i>	


### 12.2.3 Disturb rec: Input States


Disturb rec . <b>Start1-I</b>		[Operation / Status Display / Recorders / Disturb rec]
...		
Disturb rec . <b>Start8-I</b>		
	<i>State of the module input:: Trigger event / start recording</i>	


### 12.2.4 Disturb rec: Signals (Output States)


Disturb rec . <b>recording</b>		[Operation / Status Display / Recorders / Disturb rec]
	<i>Signal: Recording</i>	

Disturb rec . <b>memory full</b>		[Operation / Status Display / Recorders / Disturb rec]
	<i>Signal: Memory full</i>	


Disturb rec . <b>Clear fail</b>		[Operation / Status Display / Recorders / Disturb rec]
	<i>Signal: Clear failure in memory</i>	



Disturb rec . <b>Res all records</b>		[Operation / Status Display / Recorders / Disturb rec]
	<i>Signal: All records are being deleted. (Remark: Immediately afterwards, this signal becomes inactive again.)</i>	

Disturb rec . <b>Res all records</b>		[Operation / Status Display / Recorders / Disturb rec]
	<i>Signal: All records are being deleted. (Remark: Immediately afterwards, this signal becomes inactive again.)</i>	

Disturb rec . <b>Man Trigger</b>		[Operation / Status Display / Recorders / Disturb rec]
	<i>Signal: Manual Trigger</i>	


### 12.2.5 Disturb rec: Values

Disturb rec . <b>Rec state</b>		[Operation / Status Display / Recorders / Disturb rec]
Ready	Ready, Recording, Writing file, Trigger Blo	
	 <b>Rec state.</b>	
	<i>Recording state</i>	


Disturb rec . <b>Error code</b>		[Operation / Status Display / Recorders / Disturb rec]
OK	OK, Write err, Clear fail, Calculation err, File not found, Auto overwriting off	
	 <b>Fault.</b>	
	<i>Error code</i>	

## 12.3 Fault rec

The values measured at the time of tripping are saved by the Fault Recorder.



<b>Fault rec</b>	[Operation / Recorders / Fault rec]	
	This item represents a special dialog. (See the Technical Manual for details.) <i>The values measured at the time of tripping are saved by the Fault Recorder.</i>	

### 12.3.1 Fault rec: Global Parameters


Fault rec . <b>Record-Mode</b>	[Device Para / Recorders / Fault rec]	
Trips only	Alarms and Trips, Trips only  Record-Mode.	S.3
	Recorder Mode (Set the behaviour of the recorder)	

Fault rec . <b>t-meas-delay</b>	[Device Para / Recorders / Fault rec]	
0ms	0ms ... 60ms	S.3
	After the Trip, the measurement will be delayed for this time.	

### 12.3.2 Fault rec: Direct Controls


Fault rec . <b>Res all rec</b>	[Operation / Reset/Acknowledge / Reset]	
inactive	inactive, active  Mode.	P.1
	Reset all records	

### 12.3.3 Fault rec: Signals (Output States)



Fault rec . <b>Res all records</b>	[Operation / Status Display / Recorders / Fault rec]	
	Signal: All records are being deleted. (Remark: Immediately afterwards, this signal becomes inactive again.)	



## 12.4 Trend rec



Trend Recorder



<b>Trend rec</b>	[Operation / Recorders / Trend rec]	
	This item represents a special dialog. (See the Technical Manual for details.)	
	<i>Trend Recorder</i>	



### 12.4.1 Trend rec: Global Parameters

<b>Trend rec . Resolution</b>	[Device Para / Recorders / Trend rec]	
15 min	60 min, 30 min, 15 min, 10 min, 5 min	S.3
	 Resolution.	
	<i>Resolution (recording frequency)</i>	


<b>Trend rec . Trend1</b>	[Device Para / Recorders / Trend rec]	
CT . IL1 RMS	"-" ... RTD . Hottest Aux Temp	S.3
	 1..n, TrendRecList.	
	<i>Observed Value1</i>	


<b>Trend rec . Trend2</b>	[Device Para / Recorders / Trend rec]	
CT . IL2 RMS	"-" ... RTD . Hottest Aux Temp	S.3
	 1..n, TrendRecList.	
	<i>Observed Value2</i>	


<b>Trend rec . Trend3</b>	[Device Para / Recorders / Trend rec]	
CT . IL3 RMS	"-" ... RTD . Hottest Aux Temp	S.3
	 1..n, TrendRecList.	
	<i>Observed Value3</i>	


<b>Trend rec . Trend4</b>	[Device Para / Recorders / Trend rec]	
CT . IG meas RMS	"-" ... RTD . Hottest Aux Temp	S.3
	 1..n, TrendRecList.	
	<i>Observed Value4</i>	





Trend rec . <b>Trend5</b>		[Device Para / Recorders / Trend rec]	
"_"	"_" ... RTD . Hottest Aux Temp	S.3	
	↳ 1..n, TrendRecList.		
	<i>Observed Value5</i>		

Trend rec . <b>Trend6</b>		[Device Para / Recorders / Trend rec]	
"_"	"_" ... RTD . Hottest Aux Temp	S.3	
	↳ 1..n, TrendRecList.		
	<i>Observed Value6</i>		


Trend rec . <b>Trend7</b>		[Device Para / Recorders / Trend rec]	
"_"	"_" ... RTD . Hottest Aux Temp	S.3	
	↳ 1..n, TrendRecList.		
	<i>Observed Value7</i>		

Trend rec . <b>Trend8</b>		[Device Para / Recorders / Trend rec]	
"_"	"_" ... RTD . Hottest Aux Temp	S.3	
	↳ 1..n, TrendRecList.		
	<i>Observed Value8</i>		


Trend rec . <b>Trend9</b>		[Device Para / Recorders / Trend rec]	
"_"	"_" ... RTD . Hottest Aux Temp	S.3	
	↳ 1..n, TrendRecList.		
	<i>Observed Value9</i>		

Trend rec . <b>Trend10</b>		[Device Para / Recorders / Trend rec]	
"_"	"_" ... RTD . Hottest Aux Temp	S.3	
	↳ 1..n, TrendRecList.		
	<i>Observed Value10</i>		


### 12.4.2 Trend rec: Direct Controls

Trend rec . <b>Res all rec</b>	[Operation / Reset/Acknowledge / Reset]	
inactive	inactive, active  Mode.	P.1
<input checked="" type="radio"/> <i>Reset all records</i>		

### 12.4.3 Trend rec: Signals (Output States)


Trend rec . <b>Res all records</b>	[Operation / Status Display / Recorders / Trend rec]
 <i>Signal: All records are being deleted. (Remark: Immediately afterwards, this signal becomes inactive again.)</i>	


### 12.4.4 Trend rec: Counters

Trend rec . <b>Max avail Entries</b>	[Operation / Count and RevData / Trend rec]
 <i>Maximum available entries in the current configuration</i>	



## 12.5 Start rec

Startrecorder



<b>Start rec</b>	[Operation / Recorders / Start rec]
 This item represents a special dialog. (See the Technical Manual for details.) <i>Startrecorder</i>	



<b>Statistic rec</b>	[Operation / Recorders / Statistic rec]
 This item represents a special dialog. (See the Technical Manual for details.) <i>Statistic recorder</i>	

### 12.5.1 Start rec: Global Parameters

Start rec . <b>Resolution</b>	[Device Para / Recorders / Start rec]
50ms	50ms, 100ms, 1s S.3  Resolution.
 Resolution (recording frequency)	


### 12.5.2 Start rec: Direct Controls

Start rec . <b>ClearStartRec</b>	[Operation / Reset/Acknowledge / Reset]
inactive	inactive, active S.3  Mode.
 Delete all start recorder records	

Start rec . <b>ClearStatisticRec</b>	[Operation / Reset/Acknowledge / Reset]
inactive	inactive, active S.3  Mode.
 Delete all statistic recorder records (start trending)	

12 Records  
12.5 Start rec

### 12.5.3 Start rec: Signals (Output States)


Start rec . <b>Storing</b>	[Operation / Status Display / Recorders / Start rec]
 <i>Signal: Data are saved</i>	

# 13 Logic

## 13.1 Logics

Logic






### 13.1.1 Logics: Device Planning Parameters


Logics . <b>No of Equations:</b>	[Device planning]	
20	0, 5, 10, 20, 40, 80	S.3
	↳ No of Equations:.	
 <i>Number of required Logic Equations:</i>		

### 13.1.2 Logics ... Logics


Logic

#### 13.1.2.1 Logics: Global Parameters


Logics . <b>LE1.Gate</b>		[Logics / LE 1]	
AND		AND, OR, NAND, NOR  ↳ LE1.Gate.	S.3
	<i>Logic gate</i>		
Logics . <b>LE1.Input1</b> ... Logics . <b>LE1.Input4</b>		[Logics / LE 1]	
"_"		"_" ... Sys . Internal test state  ↳ 1..n, Assignment List.	S.3
	<i>Assignment of the Input Signal</i>		
Logics . <b>LE1.Inverting1</b> ... Logics . <b>LE1.Inverting4</b>		[Logics / LE 1]	
inactive		inactive, active  ↳ Mode.	S.3
	<i>Inverting the input signals.</i>		
Logics . <b>LE1.t-On Delay</b>		[Logics / LE 1]	
0.00s		0.00s ... 36000.00s	S.3
	<i>Switch On Delay</i>		
Logics . <b>LE1.t-Off Delay</b>		[Logics / LE 1]	
0.00s		0.00s ... 36000.00s	S.3
	<i>Switch Off Delay</i>		

Logics . <b>LE1.Reset Latched</b>	[Logics / LE 1]
"_"	"_" ... Sys . Internal test state ↳ 1..n, Assignment List.
 <i>Reset Signal for the Latching</i>	

S.3


Logics . <b>LE1.Inverting Reset</b>	[Logics / LE 1]
inactive	inactive, active ↳ Mode.
 <i>Inverting Reset Signal for the Latching</i>	


S.3

Logics . <b>LE1.Inverting Set</b>	[Logics / LE 1]
inactive	inactive, active ↳ Mode.
 <i>Inverting the Setting Signal for the Latching</i>	


S.3


### 13.1.2.2 Logics: Input States

Logics . <b>LE1.Gate In1-I</b>	[Operation / Status Display / Logics]
...	
Logics . <b>LE1.Gate In4-I</b>	
 <i>State of the module input: Assignment of the Input Signal</i>	

Logics . <b>LE1.Reset Latch-I</b>	[Operation / Status Display / Logics]
 <i>State of the module input: Reset Signal for the Latching</i>	

### 13.1.2.3 Logics: Signals (Output States)

Logics . <b>LE1.Gate Out</b>	[Operation / Status Display / Logics]
 <i>Signal: Output of the logic gate</i>	

Logics . <b>LE1.Timer Out</b>	[Operation / Status Display / Logics]
 <i>Signal: Timer Output</i>	

Logics . <b>LE1.Out</b>	[Operation / Status Display / Logics]
-------------------------	---------------------------------------

⬆	<i>Signal: Latched Output (Q)</i>
---	-----------------------------------


Logics . <b>LE1.Out inverted</b>	[Operation / Status Display / Logics]
----------------------------------	---------------------------------------

⬆	<i>Signal: Negated Latched Output (Q NOT)</i>
---	---




## 14 Self-Supervision


SelfSupervision


<b>Messages</b>	[Operation / Self-Supervision / Messages]
 This item represents a special dialog. (See the Technical Manual for details.)	
<i>Internal messages</i>	


### 14.1 SSV: Direct Controls


<b>SSV . Ack System LED</b>	[Operation / Reset/Acknowledge / Acknowledge]
False	False, True
	↳ true or not true.
 <i>Acknowledge System LED (red/green flashing LED)</i>	P.1

### 14.2 SSV: Signals (Output States)


<b>SSV . System Error</b>	[Operation / Self-Supervision / System State]
 <i>Signal: Device Failure</i>	

<b>SSV . SelfSuperVision Contact</b>	[Operation / Self-Supervision / System State]
 <i>Signal: SelfSuperVision Contact</i>	


<b>SSV . New error</b>	[Operation / Self-Supervision / System State]
 <i>Signal: A new error message has been issued.</i>	

<b>SSV . New warning</b>	[Operation / Self-Supervision / System State]
 <i>Signal: A new warning message has been issued.</i>	

### 14.3 SSV: Counters

<b>SSV . Cr No of free sockets</b>	[Operation / Self-Supervision / System State]
 <i>Counter for network diagnosis. Number of free sockets.</i>	


## 15 Service

- Sys . Reboot:  Tab.


## 15.1 Sgen


Sine wave generator


### 15.1.1 Sgen: Device Planning Parameters


Sgen . <b>Mode</b>	[Device planning]	
use	"-" , use ↳ Mode.	S.3
 Sine wave generator, general operation mode		


### 15.1.2 Sgen: Global Parameters


Sgen . <b>TripCmd Mode</b>	[Service / Test (Prot inhibit) / Sgen / Process]	
No TripCmd	No TripCmd, With TripCmd ↳ TripCmd Mode.	S.3
 Trip Command Mode: Select between two operating modes for the Fault Simulator: "cold simulation" (without tripping the circuit breaker), or "hot simulation" (i.e. the simulation is authorized to trip the circuit breaker)		


Sgen . <b>Ex Start Simulation</b>	[Service / Test (Prot inhibit) / Sgen / Process]	
"_"	"_" ... Sys . Internal test state ↳ 1..n, Assignment List.	S.3
 External Start of Fault Simulation (Using the test parameters)		


Sgen . <b>ExBlo1</b>	[Service / Test (Prot inhibit) / Sgen / Process]	
SG[1] . Pos ON	"_" ... Sys . Internal test state ↳ 1..n, Assignment List.	S.3
 External blocking of the module, if blocking is activated (allowed) within a parameter set and if the state of the assigned signal is true.1		

Sgen . <b>ExBlo2</b>	[Service / Test (Prot inhibit) / Sgen / Process]	
"_"	"_" ... Sys . Internal test state ↳ 1..n, Assignment List.	S.3
 External blocking of the module, if blocking is activated (allowed) within a parameter set and if the state of the assigned signal is true.2		


<b>Sgen . Ex ForcePost</b>	[Service / Test (Prot inhibit) / Sgen / Process]	
"_"	"_" ... Sys . Internal test state ↳ 1..n, Assignment List.	S.3
	<i>Force Post state. Abort simulation.</i>	


<b>Sgen . PreFault</b>	[Service / Test (Prot inhibit) / Sgen / Configuration / Times]	
0.0s	0.00s ... 300.00s	S.3
	<i>Pre Fault Duration</i>	

<b>Sgen . FaultSimulation</b>	[Service / Test (Prot inhibit) / Sgen / Configuration / Times]	
0.0s	0.00s ... 10800.00s	S.3
	<i>Duration of Fault Simulation</i>	


<b>Sgen . PostFault</b>	[Service / Test (Prot inhibit) / Sgen / Configuration / Times]	
0.0s	0.00s ... 300.00s	S.3
	<i>Post Fault Duration</i>	

### 15.1.3 Sgen: Direct Controls

<b>Sgen . Start Simulation</b>	[Service / Test (Prot inhibit) / Sgen / Process]	
inactive	inactive, active ↳ Mode.	S.3
	<i>Start Fault Simulation (Using the test parameters)</i>	

<b>Sgen . Stop Simulation</b>	[Service / Test (Prot inhibit) / Sgen / Process]	
inactive	inactive, active ↳ Mode.	S.3
	<i>Stopp Fault Simulation (Using the test parameters)</i>	

### 15.1.4 Sgen: Input States

<b>Sgen . Ex Start Simulation-I</b>	[Operation / Status Display / Sgen]	
	<i>State of the module input:External Start of Fault Simulation (Using the test parameters)</i>	

Sgen . <b>ExBlo1-I</b>	[Operation / Status Display / Sgen] [Service / Test (Prot inhibit) / Sgen / State]
↓	<i>Module input state: External blocking1</i>

Sgen . <b>ExBlo2-I</b>	[Operation / Status Display / Sgen] [Service / Test (Prot inhibit) / Sgen / State]
↓	<i>Module input state: External blocking2</i>

Sgen . <b>Ex ForcePost-I</b>	[Operation / Status Display / Sgen] [Service / Test (Prot inhibit) / Sgen / State]
↓	<i>State of the module input:Force Post state. Abort simulation.</i>

### 15.1.5 Sgen: Signals (Output States)

Sgen . <b>Manual Start</b>	[Operation / Status Display / Sgen]
↓	<i>Fault Simulation has been started manually.</i>

Sgen . <b>Manual Stop</b>	[Operation / Status Display / Sgen]
↓	<i>Fault Simulation has been stopped manually.</i>



Sgen . <b>Running</b>	[Operation / Status Display / Sgen] [Service / Test (Prot inhibit) / Sgen / State]
↓	<i>Signal; Measuring value simulation is running</i>

Sgen . <b>Started</b>	[Operation / Status Display / Sgen]
↓	<i>Fault Simulation has been started</i>

Sgen . <b>Stopped</b>	[Operation / Status Display / Sgen]
↓	<i>Fault Simulation has been stopped</i>

Sgen . <b>State</b>	[Operation / Status Display / Sgen]
↓	<i>Signal: Wave generation states: 0=Off, 1=PreFault, 2=Fault, 3=PostFault, 4=InitReset</i>







### 15.1.6 Sgen: Values








Sgen . <b>State</b>	[Service / Test (Prot inhibit) / Sgen / State]
Off	Off, PreFault, FaultSimulation, PostFault, Init Res  <b>State.</b>
 <i>Wave generation states: 0=Off, 1=PreFault, 2=Fault, 3=PostFault, 4=InitReset</i>	

## 15.1.7 Sgen


Sine wave generator


### 15.1.7.1 Sgen: Global Parameters


Sgen . <b>IL1</b>	[Service / Test (Prot inhibit) / Sgen / Configuration / PreFault / CT]	
0.0In	0.00In ... 40.00In	S.3
	<i>Current Fundamental Magnitude in Pre State: phase L1</i>	
Sgen . <b>IL2</b>	[Service / Test (Prot inhibit) / Sgen / Configuration / PreFault / CT]	
0.0In	0.00In ... 40.00In	S.3
	<i>Current Fundamental Magnitude in Pre State: phase L2</i>	
Sgen . <b>IL3</b>	[Service / Test (Prot inhibit) / Sgen / Configuration / PreFault / CT]	
0.0In	0.00In ... 40.00In	S.3
	<i>Current Fundamental Magnitude in Pre State: phase L3</i>	
Sgen . <b>IG meas</b>	[Service / Test (Prot inhibit) / Sgen / Configuration / PreFault / CT]	
0.0In	If: slot 3 = Current measuring inputs2 <ul style="list-style-type: none"> <li>• 0.00In ... 2.500In</li> </ul> If: slot 3 ≠ Current measuring inputs2 <ul style="list-style-type: none"> <li>• 0.00In ... 25.00In</li> </ul>	S.3
	<i>Current Fundamental Magnitude in Pre State: IG</i>	
Sgen . <b>phi IL1</b>	[Service / Test (Prot inhibit) / Sgen / Configuration / PreFault / CT]	
0°	-360° ... 360°	S.3
	<i>Start Position respectively Start Angle of the Current Phasor during Pre-Phase:phase L1</i>	
Sgen . <b>phi IL2</b>	[Service / Test (Prot inhibit) / Sgen / Configuration / PreFault / CT]	
240°	-360° ... 360°	S.3
	<i>Start Position respectively Start Angle of the Current Phasor during Pre-Phase:phase L2</i>	


<b>Sgen . phi IL3</b>		[Service / Test (Prot inhibit) / Sgen / Configuration / PreFault / CT]
120°	-360° ... 360°	S.3
 <i>Start Position respectively Start Angle of the Current Phasor during Pre-Phase:phase L3</i>		
<b>Sgen . phi IG meas</b>		[Service / Test (Prot inhibit) / Sgen / Configuration / PreFault / CT]
0°	-360° ... 360°	S.3
 <i>Start Position respectively Start Angle of the Current Phasor during Pre-Phase: IG</i>		
<b>Sgen . IL1</b>		[Service / Test (Prot inhibit) / Sgen / Configuration / FaultSimulation / CT]
0.0In	0.00In ... 40.00In	S.3
 <i>Current Fundamental Magnitude in Fault State: phase L1</i>		
<b>Sgen . IL2</b>		[Service / Test (Prot inhibit) / Sgen / Configuration / FaultSimulation / CT]
0.0In	0.00In ... 40.00In	S.3
 <i>Current Fundamental Magnitude in Fault State: phase L2</i>		
<b>Sgen . IL3</b>		[Service / Test (Prot inhibit) / Sgen / Configuration / FaultSimulation / CT]
0.0In	0.00In ... 40.00In	S.3
 <i>Current Fundamental Magnitude in Fault State: phase L3</i>		
<b>Sgen . IG meas</b>		[Service / Test (Prot inhibit) / Sgen / Configuration / FaultSimulation / CT]
0.0In	If: slot 3 = Current measuring inputs2 • 0.00In ... 2.500In  If: slot 3 ≠ Current measuring inputs2 • 0.00In ... 25.00In	S.3
 <i>Current Fundamental Magnitude in Fault State: IG</i>		
<b>Sgen . phi IL1</b>		[Service / Test (Prot inhibit) / Sgen / Configuration / FaultSimulation / CT]
0°	-360° ... 360°	S.3
 <i>Start Position respectively Start Angle of the Current Phasor during Fault-Phase:phase L1</i>		





<b>Sgen . phi IL2</b>	[Service / Test (Prot inhibit) / Sgen / Configuration / FaultSimulation / CT]	
240°	-360° ... 360°	S.3
	<i>Start Position respectively Start Angle of the Current Phasor during Fault-Phase:phase L2</i>	


<b>Sgen . phi IL3</b>	[Service / Test (Prot inhibit) / Sgen / Configuration / FaultSimulation / CT]	
120°	-360° ... 360°	S.3
	<i>Start Position respectively Start Angle of the Current Phasor during Fault-Phase:phase L3</i>	





<b>Sgen . phi IG meas</b>	[Service / Test (Prot inhibit) / Sgen / Configuration / FaultSimulation / CT]	
0°	-360° ... 360°	S.3
	<i>Start Position respectively Start Angle of the Current Phasor during Fault-Phase: IG</i>	

<b>Sgen . IL1</b>	[Service / Test (Prot inhibit) / Sgen / Configuration / PostFault / CT]	
0.0In	0.00In ... 40.00In	S.3
	<i>Current Fundamental Magnitude during Post phase: phase L1</i>	

<b>Sgen . IL2</b>	[Service / Test (Prot inhibit) / Sgen / Configuration / PostFault / CT]	
0.0In	0.00In ... 40.00In	S.3
	<i>Current Fundamental Magnitude during Post phase: phase L2</i>	

<b>Sgen . IL3</b>	[Service / Test (Prot inhibit) / Sgen / Configuration / PostFault / CT]	
0.0In	0.00In ... 40.00In	S.3
	<i>Current Fundamental Magnitude during Post phase: phase L3</i>	

<b>Sgen . IG meas</b>	[Service / Test (Prot inhibit) / Sgen / Configuration / PostFault / CT]	
0.0In	If: slot 3 = Current measuring inputs2 • 0.00In ... 2.500In  If: slot 3 ≠ Current measuring inputs2 • 0.00In ... 25.00In	S.3
	<i>Current Fundamental Magnitude during Post phase: IG</i>	

<b>Sgen . phi IL1</b>	[Service / Test (Prot inhibit) / Sgen / Configuration / PostFault / CT]	
0°	-360° ... 360°	S.3
	<i>Start Position respectively Start Angle of the Current Phasor during Post phase: phase L1</i>	
<b>Sgen . phi IL2</b>	[Service / Test (Prot inhibit) / Sgen / Configuration / PostFault / CT]	
240°	-360° ... 360°	S.3
	<i>Start Position respectively Start Angle of the Current Phasor during Post phase: phase L2</i>	
<b>Sgen . phi IL3</b>	[Service / Test (Prot inhibit) / Sgen / Configuration / PostFault / CT]	
120°	-360° ... 360°	S.3
	<i>Start Position respectively Start Angle of the Current Phasor during Post phase: phase L3</i>	
<b>Sgen . phi IG meas</b>	[Service / Test (Prot inhibit) / Sgen / Configuration / PostFault / CT]	
0°	-360° ... 360°	S.3
	<i>Start Position respectively Start Angle of the Current Phasor during Post phase: IG</i>	

## 16 Selection Lists

### **Rec state**

Recording state

Selection list referenced by the following parameters:

-  Disturb rec . Rec state

<b>Rec state</b>	<b>Description</b>
<b>Ready</b>	<i>Ready</i>
<b>Recording</b>	<i>Recording</i>
<b>Writing file</b>	<i>Signal: Writing file</i>
<b>Trigger Blo</b>	<i>Trigger signal is still active - wait for fallback. A new record can only be started if and only the trigger signal that started the previous record has fallen back once. Therewith endless records are prevented.</i>

### **Fault**



Selection list referenced by the following parameters:

-  Disturb rec . Error code

<b>Fault</b>	<b>Description</b>
<b>OK</b>	<i>OK</i>
<b>Write err</b>	<i>Signal: Writing error in memory</i>
<b>Clear fail</b>	<i>Signal: Clear failure in memory</i>
<b>Calculation err</b>	<i>Calculation error</i>
<b>File not found</b>	<i>File not found</i>
<b>Auto overwriting off</b>	<i>If there is no more memory available the record is being stopped.</i>

### **State**

Selection list referenced by the following parameters:

-  IEC 61850 . GoosePublisherState
-  IEC 61850 . GooseSubscriberState
-  IEC 61850 . MmsServerState

State	Description
Off	Off
On	On
Error	Error

### State

Selection list referenced by the following parameters:

- ↳ Profibus . Slave State

State	Description
Baud Search	No connection to the PROFIBUS-DP Master
Baud Found	The PROFIBUS DP Slave is connected to the bus. The Slave has not yet been addressed by the Master Device (and it was not yet addressed since the last break of the connection).
PRM OK	The slave was addressed by the master, the parameter setting message was received and is OK, a configuration message is expected from the master.
PRM REQ	The slave is no longer addressed by the master (modified parameters within the master without having the connection stopped, master software is tuned off but lower PROFIBUS layer is still active)
PRM Fault	An Error in the parameter setting message (e.g. wrong PNO identification number)
CFG Fault	Configuration error the number of input/output bytes parameterised in the master does not match the number parametrised in the device (slave).
Clear Data	Master sends a General Control command to clear the data.
Data exchange	Master and slave exchange data.

### Baud rate

Selection list referenced by the following parameters:

- ↳ Profibus . Baud rate

Baud rate	Description
12 Mb/s	12 Mb/s

Baud rate	Description
6 Mb/s	6 Mb/s
3 Mb/s	3 Mb/s
1.5 Mb/s	1.5 Mb/s
0.5 Mb/s	0.5 Mb/s
187500 baud	187500 baud
93750 baud	93750 baud
45450 baud	45450 baud
19200 baud	19200 baud
9600 baud	9600 baud
--	--

### **PNO Id**

PNO Identification Number. GSD Identification Number.

Selection list referenced by the following parameters:

-  Profibus . PNO Id

PNO Id	Description
0C50h	<i>ProdiD for the Config file.</i>

### **Config status**

Status of the user-defined SCADA configuration.\nPossible values:

Selection list referenced by the following parameters:

-  Profibus . Config status

Config status	Description
Changing	<i>New SCADA configuration is being loaded, but not active yet.</i>
OK	<i>The SCADA configuration is active.</i>
Config. not avail.	<i>The user-defined SCADA configuration is not available (e.g. has not been loaded into the device).</i>
Error	<i>Unexpected error. Please contact our service-team.</i>

**Server State**

Server State.



Selection list referenced by the following parameters:

-  **SNTP . Used Server**

<b>Server State</b>	<b>Description</b>
<b>Server1</b>	<i>Server1 used.</i>
<b>Server2</b>	<i>Server2 used.</i>
<b>None</b>	<i>No Server used.</i>

**State**

Selection list referenced by the following parameters:

-  **SNTP . ServerQlty**
-  **SNTP . NetConn**



<b>State</b>	<b>Description</b>
<b>GOOD</b>	<i>GOOD</i>
<b>SUFFICIENT</b>	<i>SUFFICIENT</i>
<b>BAD</b>	<i>BAD</i>
<b>"_"</b>	<i>NO CONNECTION</i>

**Mode**

general operation mode

Selection list referenced by the following parameters:



-  **DI Slot X1 . Inverting 1**
-  **DI Slot X1 . Inverting 1**
-  **BO Slot X2 . Latched**
-  **BO Slot X2 . Inverting**

-  BO Slot X2 . Inverting 1
-  BO Slot X2 . Latched
- [...]

Mode	Description
inactive	<i>inactive</i>
active	<i>active</i>

### **true or not true**

Selection list referenced by the following parameters:



-  Disturb rec . Man Trigger
-  SSV . Ack System LED

true or not true	Description
False	<i>False</i>
True	<i>True</i>

### **Type of passw. def.**

Type of the password definition. This value is directly related to the security-level of the access to the device.

Selection list referenced by the following parameters:

-  Sys . Passw. for USB conn.
-  Sys . Passw.remote net.conn.

Type of passw. def.	Description
disabled	<i>The password disabled.</i>
default	<i>The password is the same as the factory default, i.e. it has not been altered by the user. (However, for devices with a disabled default password the password type is displayed as "disabled", not as "default".)</i>
def. by user	<i>The password has been defined by the user. This corresponds to the highest security-level of the access to the device.</i>

**TLS Certificate**

Type of certificate that the device uses for the encrypted communication. This value is directly related to the security-level of the communication.




Selection list referenced by the following parameters:

-  Sys . TLS Certificate

TLS Certificate	Description
<b>Device-specific</b>	<i>The device uses a device-specific certificate for the encrypted communication. This corresponds to the highest security-level of the communication.</i>
<b>Basic</b>	<i>The device uses a basic certificate for the encrypted communication. Compared with a device-specific certificate, this means a slightly reduced security level.</i>
<b>Corrupt</b>	<i>The certificate for the encrypted communication is corrupt and therefore unusable.</i>

**Switching Authority**

Selection list referenced by the following parameters:

-  Ctrl . Switching Authority
-  Ctrl . Switching Authority
-  Ctrl . Switching Authority

Switching Authority	Description
<b>None</b>	<i>None</i>
<b>Local</b>	<i>Local</i>
<b>Remote</b>	<i>Remote</i>
<b>Local and Remote</b>	<i>Local and Remote</i>

**Config. Device Reset**

If the »C« key is pressed while the device is performing a cold restart a general Reset Dialog appears on the screen. Select which options shall be available with this dialog.

Selection list referenced by the following parameters:

-  HMI . Config. Device Reset



-  HMI . Config. Device Reset
-  HMI . Config. Device Reset
-  HMI . Config. Device Reset

Config. Device Reset	Description
"Fact.def.", "PW rst"	Two Reset Options shall be available: - "Reset to factory defaults", - "Reset passwords".
Only "Fact.defaults"	Only one Reset Option shall be available: - "Reset to factory defaults".  <i>CAUTION: If this option has been chosen and the password should ever get lost then the only chance to recover control is to reset the protection device to factory defaults.</i>
Reset deact.	The Reset Options shall be deactivated.  <i>CAUTION: If this option has been chosen and the password should ever get lost, then the protection device has to be sent to the manufacturer as a service request.</i>

### I>

If the pickup value is exceeded, the module/element starts to time out to trip.

Selection list referenced by the following parameters:

-  I[1] . Mode

I>	Description
"_"	do not use
non directional	non directional

### Earth overcurrent







Selection list referenced by the following parameters:

-  IG[1] . Mode

<b>Earth overcurrent</b>	<b>Description</b>
<b>"_"</b>	<i>do not use</i>
<b>non directional</b>	<i>non directional</i>

**yes/no**

Selection list referenced by the following parameters:

-  Sys . Reboot
-  IG[1] . Superv. only
-  RTD . Windg 1
-  RTD . Windg 2
-  RTD . Windg 3
-  RTD . Windg 4
- [...]

<b>yes/no</b>	<b>Description</b>
<b>no</b>	<i>no</i>
<b>yes</b>	<i>yes</i>

**Mode**

general operation mode

Selection list referenced by the following parameters:

-  Jam[1] . Mode

<b>Mode</b>	<b>Description</b>
<b>"_"</b>	<i>do not use</i>
<b>use</b>	<i>use</i>

**Mode**

general operation mode

Selection list referenced by the following parameters:

- $I<[1]$  . Mode

Mode	Description
"_"	<i>do not use</i>
use	<i>use</i>

**Mode**

general operation mode

Selection list referenced by the following parameters:

- $MLS$  . Mode

Mode	Description
"_"	<i>do not use</i>
use	<i>use</i>

**Device planning**

Selection list referenced by the following parameters:

- $I2>[1]$  . Mode

Device planning	Description
"_"	<i>do not use</i>
use	<i>use</i>

**Device planning**

Selection list referenced by the following parameters:

- $EXP[1]$  . Mode

Device planning	Description
"_"	<i>do not use</i>
use	<i>use</i>

### ***Device planning***

Selection list referenced by the following parameters:

-  RTD . Mode

Device planning	Description
"_"	<i>do not use</i>
use	<i>use</i>

### ***Device planning***

Selection list referenced by the following parameters:

-  CBF . Mode

Device planning	Description
"_"	<i>do not use</i>
use	<i>use</i>

### ***Device planning***

Selection list referenced by the following parameters:

-  TCS . Mode

Device planning	Description
"_"	<i>do not use</i>
use	<i>use</i>

**Device planning**

Selection list referenced by the following parameters:

-  CTS . Mode

Device planning	Description
"_"	<i>do not use</i>
use	<i>use</i>

**Mode**

general operation mode

Selection list referenced by the following parameters:

-  SysA . Mode

Mode	Description
"_"	<i>do not use</i>
use	<i>use</i>

**Used Protocol**

Used SCADA Protocol

Selection list referenced by the following parameters:

-  Scada . Protocol

Used Protocol	Description
"_"	<i>do not use</i>
<b>Modbus RTU</b>	<i>Modbus Protocol RTU</i>
<b>Modbus TCP</b>	<i>Modbus Protocol TCP</i>
<b>Modbus TCP/RTU</b>	<i>Modbus Protocol TCP/RTU</i>
<b>DNP3 RTU</b>	<i>Distributed Network Protocol RTU</i>
<b>DNP3 TCP</b>	<i>Distributed Network Protocol TCP</i>
<b>DNP3 UDP</b>	<i>Distributed Network Protocol UDP</i>
<b>IEC 60870-5-103</b>	<i>IEC 60870-5-103 Protocol</i>

Used Protocol	Description
<b>IEC 60870-5-104</b>	<i>IEC 60870-5-104 Protocol</i>
<b>IEC 61850</b>	<i>IEC 61850 communication</i>
<b>Profibus</b>	<i>Profibus Module</i>

**Mode**

general operation mode

Selection list referenced by the following parameters:

-  IRIG-B . Mode

Mode	Description
<b>"_"</b>	<i>do not use</i>
<b>use</b>	<i>use</i>

**Mode**

general operation mode

Selection list referenced by the following parameters:

-  SNTP . Mode

Mode	Description
<b>"_"</b>	<i>do not use</i>
<b>use</b>	<i>use</i>

**No of Equations:**

Number of required Logic Equations:

Selection list referenced by the following parameters:

-  Logics . No of Equations:

No of Equations:	Description
0	0
5	5
10	10
20	20
40	40
80	80

### **Mode**

general operation mode

Selection list referenced by the following parameters:

-  Sgen . Mode

Mode	Description
"_"	<i>do not use</i>
use	<i>use</i>

### **Scaling**

Display of the measured values as primary, secondary or per unit values

Selection list referenced by the following parameters:

-  Sys . Scaling

Scaling	Description
Per unit values	<i>Per unit values</i>
Primary values	<i>Primary values</i>
Secondary values	<i>Secondary values</i>

### **Units**

Units for the measurement

Selection list referenced by the following parameters:

-  URTD . Temperature Unit

Units	Description
Celsius	<i>Celsius</i>
Fahrenheit	<i>Fahrenheit</i>

**Nom voltage**

Nominal voltage of the digital inputs

Selection list referenced by the following parameters:

-  DI Slot X1 . Nom voltage

Nom voltage	Description
24 VDC	<i>24 VDC</i>
48 VDC	<i>48 VDC</i>
60 VDC	<i>60 VDC</i>
110 VDC	<i>110 VDC</i>
230 VDC	<i>230 VDC</i>
110 VAC	<i>110 VAC</i>
230 VAC	<i>230 VAC</i>

**Debouncing time**

A change of the state of a digital input will only be recognized after the debouncing time has expired (become effective). Thus, transient signals will not be misinterpreted.

Selection list referenced by the following parameters:

-  DI Slot X1 . Debouncing time 1

Debouncing time	Description
no debouncing time	<i>no debouncing time</i>
20 ms	<i>20 ms</i>
50 ms	<i>50 ms</i>



Debouncing time	Description
100 ms	100 ms

### **Nom voltage**

Nominal voltage of the digital inputs

Selection list referenced by the following parameters:

-  DI Slot X1 . Nom voltage

Nom voltage	Description
24 VDC	24 VDC
48 VDC	48 VDC
60 VDC	60 VDC
110 VDC	110 VDC
230 VDC	230 VDC
110 VAC	110 VAC
230 VAC	230 VAC

### **Debouncing time**

A change of the state of a digital input will only be recognized after the debouncing time has expired (become effective). Thus, transient signals will not be misinterpreted.






Selection list referenced by the following parameters:

-  DI Slot X1 . Debouncing time 1

Debouncing time	Description
no debouncing time	no debouncing time
20 ms	20 ms
50 ms	50 ms
100 ms	100 ms

### 1...n Operating Modes

Selection list referenced by the following parameters:







-  BO Slot X2 . Operating Mode
-  BO Slot X2 . Operating Mode
-  BO Slot X2 . Operating Mode
-  BO Slot X2 . Operating Mode
-  BO Slot X2 . Operating Mode

1...n Operating Modes	Description
<b>Normally open (NO)</b>	<i>The working principle of the relay corresponds to a normally open contact.</i>
<b>Normally closed (NC)</b>	<i>The working principle of the relay corresponds to a normally closed contact.</i>

### 1..n, Assignment List

Assignment List

Selection list referenced by the following parameters:

-  BO Slot X2 . Acknowledgement
-  BO Slot X2 . Assignment 1
-  BO Slot X2 . Assignment 2
-  BO Slot X2 . Acknowledgement
-  BO Slot X2 . Assignment 1
-  BO Slot X2 . Assignment 2
- [ ... ]

1..n, Assignment List	Description
<b>"_"</b>	<i>No assignment</i>
Prot . <b>available</b>	<i>Signal: Protection is available</i>
Prot . <b>active</b>	<i>Signal: active</i>
Prot . <b>ExBlo</b>	<i>Signal: External Blocking</i>
Prot . <b>Blo TripCmd</b>	<i>Signal: Trip Command blocked</i>
Prot . <b>ExBlo TripCmd</b>	<i>Signal: External Blocking of the Trip Command</i>
Prot . <b>Alarm L1</b>	<i>Signal: General-Alarm L1</i>

<b>1..n, Assignment List</b>	<b>Description</b>
Prot . <b>Alarm L2</b>	<i>Signal: General-Alarm L2</i>
Prot . <b>Alarm L3</b>	<i>Signal: General-Alarm L3</i>
Prot . <b>Alarm G</b>	<i>Signal: General-Alarm - Earth fault</i>
Prot . <b>Alarm</b>	<i>Signal: General Alarm</i>
Prot . <b>Trip L1</b>	<i>Signal: General Trip L1</i>
Prot . <b>Trip L2</b>	<i>Signal: General Trip L2</i>
Prot . <b>Trip L3</b>	<i>Signal: General Trip L3</i>
Prot . <b>Trip G</b>	<i>Signal: General Trip Ground fault</i>
Prot . <b>Trip</b>	<i>Signal: General Trip</i>
Prot . <b>Res FaultNo a GridFaultNo</b>	<i>Signal: Resetting of fault number and grid fault number.</i>
Prot . <b>ExBlo1-I</b>	<i>Module input state: External blocking1</i>
Prot . <b>ExBlo2-I</b>	<i>Module input state: External blocking2</i>
Prot . <b>ExBlo TripCmd-I</b>	<i>Module input state: External Blocking of the Trip Command</i>
CT . <b>Phase seq. wrong</b>	<i>Signal that the device has detected a phase sequence (L1-L2-L3 / L1-L3-L2) that is different from the one that had been set at [Field settings / General Settings] »Phase Sequence«.</i>
Ctrl . <b>Local</b>	<i>Switching Authority: Local</i>
Ctrl . <b>Remote</b>	<i>Switching Authority: Remote</i>
Ctrl . <b>NonInterl</b>	<i>Non-Interlocking is active</i>
Ctrl . <b>SG Indeterm</b>	<i>(At least one) Switchgear is moving (Position cannot be determined).</i>
Ctrl . <b>SG Disturb</b>	<i>(At least one) Switchgear is disturbed.</i>
Ctrl . <b>NonInterl-I</b>	<i>Non-Interlocking</i>
SG[1] . <b>SI SingleContactInd</b>	<i>Signal: The Position of the Switchgear is detected by one auxiliary contact (pole) only. Thus indeterminate and disturbed Positions cannot be detected.</i>
SG[1] . <b>Pos not ON</b>	<i>Signal: Pos not ON</i>
SG[1] . <b>Pos ON</b>	<i>Signal: Circuit Breaker is in ON-Position</i>
SG[1] . <b>Pos OFF</b>	<i>Signal: Circuit Breaker is in OFF-Position</i>
SG[1] . <b>Pos Indeterm</b>	<i>Signal: Circuit Breaker is in Indeterminate Position</i>
SG[1] . <b>Pos Disturb</b>	<i>Signal: Circuit Breaker Disturbed - Undefined Breaker Position. The Position Indicators contradict themselves. After expiring of a supervision timer this signal becomes true.</i>
SG[1] . <b>Ready</b>	<i>Signal: Circuit breaker is ready for operation.</i>
SG[1] . <b>t-Dwell</b>	<i>Signal: Dwell time</i>

<b>1..n, Assignment List</b>	<b>Description</b>
SG[1] . <b>Removed</b>	<i>Signal: The withdrawable circuit breaker is Removed</i>
SG[1] . <b>Interl ON</b>	<i>Signal: One or more IL_On inputs are active.</i>
SG[1] . <b>Interl OFF</b>	<i>Signal: One or more IL_Off inputs are active.</i>
SG[1] . <b>CES succesf</b>	<i>Signal: Command Execution Supervision: Switching command executed successfully.</i>
SG[1] . <b>CES Disturbed</b>	<i>Signal: Command Execution Supervision: Switching Command unsuccessful. Switchgear in disturbed position.</i>
SG[1] . <b>CES Fail TripCmd</b>	<i>Signal: Command Execution Supervision: Command execution failed because trip command is pending.</i>
SG[1] . <b>CES SwitchDir</b>	<i>Signal: Command Execution Supervision respectively Switching Direction Control: This signal becomes true, if a switch command is issued even though the switchgear is already in the requested position. Example: A switchgear that is already OFF should be switched OFF again (doubly). The same applies to CLOSE commands.</i>
SG[1] . <b>CES ON d OFF</b>	<i>Signal: Command Execution Supervision: On Command during a pending OFF Command.</i>
SG[1] . <b>CES SG not ready</b>	<i>Signal: Command Execution Supervision: Switchgear not ready</i>
SG[1] . <b>CES Fiel Interl</b>	<i>Signal: Command Execution Supervision: Switching Command not executed because of field interlocking.</i>
SG[1] . <b>CES SG removed</b>	<i>Signal: Command Execution Supervision: Switching Command unsuccessful, Switchgear removed.</i>
SG[1] . <b>TripCmd</b>	<i>Signal: Trip Command</i>
SG[1] . <b>Ack TripCmd</b>	<i>Signal: Acknowledge Trip Command</i>
SG[1] . <b>OFF incl TripCmd</b>	<i>Signal: The OFF Command includes the OFF Command issued by the Protection module.</i>
SG[1] . <b>Position Ind manipul</b>	<i>Signal: Position Indicators faked</i>
SG[1] . <b>SGwear Slow SG</b>	<i>Signal: Alarm, the circuit breaker (load-break switch) becomes slower</i>
SG[1] . <b>Res SGwear SI SG</b>	<i>Signal: Resetting the slow Switchgear Alarm</i>
SG[1] . <b>ON Cmd</b>	<i>Signal: ON Command issued to the switchgear. Depending on the setting the signal may include the ON command of the Prot module.</i>
SG[1] . <b>OFF Cmd</b>	<i>Signal: OFF Command issued to the switchgear. Depending on the setting the signal may include the OFF command of the Prot module.</i>
SG[1] . <b>ON Cmd manual</b>	<i>Signal: ON Cmd manual</i>
SG[1] . <b>OFF Cmd manual</b>	<i>Signal: OFF Cmd manual</i>
SG[1] . <b>Aux ON-I</b>	<i>Module Input State: Position indicator/check-back signal of the CB (52a)</i>

<b>1..n, Assignment List</b>	<b>Description</b>
SG[1] . <b>Aux OFF-I</b>	<i>Module input state: Position indicator/check-back signal of the CB (52b)</i>
SG[1] . <b>Ready-I</b>	<i>Module input state: CB ready</i>
SG[1] . <b>Removed-I</b>	<i>State of the module input: The withdrawable circuit breaker is Removed</i>
SG[1] . <b>Ack TripCmd-I</b>	<i>State of the module input: Acknowledgement Signal (for the Trip Command) Module input signal</i>
SG[1] . <b>Interl ON1-I</b>	<i>State of the module input: Interlocking of the ON command</i>
SG[1] . <b>Interl ON2-I</b>	<i>State of the module input: Interlocking of the ON command</i>
SG[1] . <b>Interl ON3-I</b>	<i>State of the module input: Interlocking of the ON command</i>
SG[1] . <b>Interl OFF1-I</b>	<i>State of the module input: Interlocking of the OFF command</i>
SG[1] . <b>Interl OFF2-I</b>	<i>State of the module input: Interlocking of the OFF command</i>
SG[1] . <b>Interl OFF3-I</b>	<i>State of the module input: Interlocking of the OFF command</i>
SG[1] . <b>SCmd ON-I</b>	<i>State of the module input: Switching ON Command, e.g. the state of the Logics or the state of the digital input</i>
SG[1] . <b>SCmd OFF-I</b>	<i>State of the module input: Switching OFF Command, e.g. the state of the Logics or the state of the digital input</i>
SG[1] . <b>Operations Alarm</b>	<i>Signal: Too many Operations. (The operations counter »TripCmd Cr« has exceeded the limit set at »Operations Alarm«.)</i>
SG[1] . <b>Isum Intr trip: IL1</b>	<i>Signal: Maximum permissible Summation of the interrupting (tripping) currents exceeded: IL1</i>
SG[1] . <b>Isum Intr trip: IL2</b>	<i>Signal: Maximum permissible Summation of the interrupting (tripping) currents exceeded: IL2</i>
SG[1] . <b>Isum Intr trip: IL3</b>	<i>Signal: Maximum permissible Summation of the interrupting (tripping) currents exceeded: IL3</i>
SG[1] . <b>Isum Intr trip</b>	<i>Signal: Maximum permissible Summation of the interrupting (tripping) currents exceeded in at least one phase.</i>
SG[1] . <b>Res TripCmd Cr</b>	<i>Signal: Resetting of the Counter: Total number of trips of the switchgear</i>
SG[1] . <b>Res Sum trip</b>	<i>Signal: Reset summation of the tripping currents</i>
SG[1] . <b>WearLevel Alarm</b>	<i>Signal: Threshold for the Alarm</i>
SG[1] . <b>WearLevel Lockout</b>	<i>Signal: Threshold for the Lockout Level</i>
SG[1] . <b>Res CB OPEN capacity</b>	<i>Signal: Reset of the wear maintenance curve (i. e. of the counter for the Circuit Breaker OPEN capacity).</i>
SG[1] . <b>Isum Intr ph Alm</b>	<i>Signal: Alarm, the per hour Sum (Limit) of interrupting currents has been exceeded.</i>
SG[1] . <b>Res Isum Intr ph Alm</b>	<i>Signal: Reset of the Alarm, "the per hour Sum (Limit) of interrupting currents has been exceeded".</i>
MStart . <b>active</b>	<i>Signal: active</i>

<b>1..n, Assignment List</b>	<b>Description</b>
MStart . <b>Blo TripCmd</b>	Signal: Trip Command blocked
MStart . <b>Trip</b>	Signal: Trip
MStart . <b>TripCmd</b>	Signal: Trip Command
MStart . <b>Start</b>	Signal: Motor is in start mode
MStart . <b>Run</b>	Signal: Motor is in run mode
MStart . <b>Stop</b>	Signal: Motor is in stop mode
MStart . <b>Blo</b>	Signal: Motor is blocked for starting or transition to Run mode
MStart . <b>NOCSBlocked</b>	Signal: Motor is prohibited to start due to number of cold start limits
MStart . <b>SPHBlocked</b>	Signal: Motor is prohibited to start due to starts per hour limits
MStart . <b>SPHBlockAlarm</b>	Signal: Motor is prohibited to start due to starts per hour limits, would come active in the next stop
MStart . <b>TBSBlocked</b>	Signal: Motor is prohibited to start due to time between starts limits
MStart . <b>ThermalBlo</b>	Signal: Thermal block
MStart . <b>RemBlockStart</b>	Signal: Motor is prohibited to start due to external blocking through digital input DI
MStart . <b>TransitionTrip</b>	Signal: Start transition fail trip
MStart . <b>ZSSTrip</b>	Signal: Zero speed trip (possible locked rotor)
MStart . <b>INSQSP2STFail</b>	Signal: Fail to transit from stop to start based on reported back time
MStart . <b>INSQSt2RunFail</b>	Signal: Fail to transit from start to run based on reported back time
MStart . <b>LATBlock</b>	Signal: Long acceleration timer enforced
MStart . <b>ColdStartSeq</b>	Signal: Motor cold start sequence flag
MStart . <b>ForcedStart</b>	Signal: Motor being forced to start
MStart . <b>TripPhaseReverse</b>	Signal: Relay tripped because of phase reverse detection
MStart . <b>EmergOverrideDI</b>	Signal: Emergency override start blocking through digital input DI
MStart . <b>EmergOverrideUI</b>	Signal: Emergency override start blocking through front panel
MStart . <b>ABSActive</b>	Signal: Anti-backspin is active. For certain applications, such as pumping a fluid up a pipe, the motor may be driven backward for a period of time after it stops. The anti-backspin timer prevents starting the motor while it is spinning in the reverse direction.
MStart . <b>Blo-GOCStart</b>	Signal: Ground Instantaneous Overcurrent Start Delay. GOC (Instantaneous Overcurrent) elements are blocked for the time programmed under this parameter

<b>1..n, Assignment List</b>	<b>Description</b>
MStart . <b>Blo-IOCStart</b>	<i>Signal: Phase Instantaneous Overcurrent Start Delay. IOC (Instantaneous Overcurrent) elements are blocked for the time programmed under this parameter</i>
MStart . <b>Blo-I&lt;Start</b>	<i>Signal: Underload Start Delay. Underload(Instantaneous Overcurrent) elements are blocked for the time programmed under this parameter</i>
MStart . <b>Blo-JamStart</b>	<i>Signal: JAM Start Delay. JAM(Instantaneous Overcurrent) elements are blocked for the time programmed under this parameter</i>
MStart . <b>Blo-I2&gt;Start</b>	<i>Signal: Motor start block current unbalance signal</i>
MStart . <b>Blo-Generic1</b>	<i>Generic Start Delay. This value can be used to block any protective element.1</i>
MStart . <b>Blo-Generic2</b>	<i>Generic Start Delay. This value can be used to block any protective element.2</i>
MStart . <b>Blo-Generic3</b>	<i>Generic Start Delay. This value can be used to block any protective element.3</i>
MStart . <b>Blo-Generic4</b>	<i>Generic Start Delay. This value can be used to block any protective element.4</i>
MStart . <b>Blo-Generic5</b>	<i>Generic Start Delay. This value can be used to block any protective element.5</i>
MStart . <b>I_Transit</b>	<i>Signal: Current transition signal</i>
MStart . <b>T_Transit</b>	<i>Signal: Time transition signal</i>
MStart . <b>MotorStopBlo</b>	<i>Signal: Motor stop block other protection functions</i>
MStart . <b>Rotating forward</b>	<i>Signal: Rotation Direction forward</i>
MStart . <b>Rotating backward</b>	<i>Signal: Rotation Direction reverse</i>
MStart . <b>ExBlo TripCmd-I</b>	<i>Module input state: External Blocking of the Trip Command</i>
MStart . <b>RemStartBlock-I</b>	<i>State of the module input: Remote Motor Start Blocking</i>
MStart . <b>EmgOvr-I</b>	<i>State of the module input: Emergency Override. Signal has to be active in order to release the thermal capacity of the motor. Please notice that by doing this you run the risk of damaging the motor. "EMGOVR" has to be set to "DI" or "DI or UI" for this input to take effect</i>
MStart . <b>INSQ-I</b>	<i>State of the module input: INcomplete SeQuence</i>
MStart . <b>ZSS-I</b>	<i>State of the module input: Zero Speed Switch</i>
MStart . <b>STPC Blo-I</b>	<i>State of the module input: With this setting a Digital Input keeps the Motor in the RUN mode, even when the motor current drops below STPC (motor stop current).</i>
I[1] . <b>active</b>	<i>Signal: active</i>
I[1] . <b>ExBlo</b>	<i>Signal: External Blocking</i>

<b>1..n, Assignment List</b>	<b>Description</b>
I[1] . <b>Ex rev Interl</b>	Signal: External reverse Interlocking
I[1] . <b>Blo TripCmd</b>	Signal: Trip Command blocked
I[1] . <b>ExBlo TripCmd</b>	Signal: External Blocking of the Trip Command
I[1] . <b>Alarm L1</b>	Signal: Alarm L1
I[1] . <b>Alarm L2</b>	Signal: Alarm L2
I[1] . <b>Alarm L3</b>	Signal: Alarm L3
I[1] . <b>Alarm</b>	Signal: Alarm
I[1] . <b>Trip L1</b>	Signal: General Trip Phase L1
I[1] . <b>Trip L2</b>	Signal: General Trip Phase L2
I[1] . <b>Trip L3</b>	Signal: General Trip Phase L3
I[1] . <b>Trip</b>	Signal: Trip
I[1] . <b>TripCmd</b>	Signal: Trip Command
I[1] . <b>DefaultSet</b>	Signal: Default Parameter Set
I[1] . <b>AdaptSet 1</b>	Signal: Adaptive Parameter 1
I[1] . <b>AdaptSet 2</b>	Signal: Adaptive Parameter 2
I[1] . <b>AdaptSet 3</b>	Signal: Adaptive Parameter 3
I[1] . <b>AdaptSet 4</b>	Signal: Adaptive Parameter 4
I[1] . <b>ExBlo1-I</b>	Module input state: External blocking1
I[1] . <b>ExBlo2-I</b>	Module input state: External blocking2
I[1] . <b>ExBlo TripCmd-I</b>	Module input state: External Blocking of the Trip Command
I[1] . <b>Ex rev Interl-I</b>	Module input state: External reverse interlocking
I[1] . <b>AdaptSet1-I</b>	Module input state: Adaptive Parameter1
I[1] . <b>AdaptSet2-I</b>	Module input state: Adaptive Parameter2
I[1] . <b>AdaptSet3-I</b>	Module input state: Adaptive Parameter3
I[1] . <b>AdaptSet4-I</b>	Module input state: Adaptive Parameter4
I[2] . <b>active</b>	Signal: active
I[2] . <b>ExBlo</b>	Signal: External Blocking
I[2] . <b>Ex rev Interl</b>	Signal: External reverse Interlocking
I[2] . <b>Blo TripCmd</b>	Signal: Trip Command blocked
I[2] . <b>ExBlo TripCmd</b>	Signal: External Blocking of the Trip Command
I[2] . <b>Alarm L1</b>	Signal: Alarm L1
I[2] . <b>Alarm L2</b>	Signal: Alarm L2



<b>1..n, Assignment List</b>	<b>Description</b>
I[2] . <b>Alarm L3</b>	Signal: Alarm L3
I[2] . <b>Alarm</b>	Signal: Alarm
I[2] . <b>Trip L1</b>	Signal: General Trip Phase L1
I[2] . <b>Trip L2</b>	Signal: General Trip Phase L2
I[2] . <b>Trip L3</b>	Signal: General Trip Phase L3
I[2] . <b>Trip</b>	Signal: Trip
I[2] . <b>TripCmd</b>	Signal: Trip Command
I[2] . <b>DefaultSet</b>	Signal: Default Parameter Set
I[2] . <b>AdaptSet 1</b>	Signal: Adaptive Parameter 1
I[2] . <b>AdaptSet 2</b>	Signal: Adaptive Parameter 2
I[2] . <b>AdaptSet 3</b>	Signal: Adaptive Parameter 3
I[2] . <b>AdaptSet 4</b>	Signal: Adaptive Parameter 4
I[2] . <b>ExBlo1-I</b>	Module input state: External blocking1
I[2] . <b>ExBlo2-I</b>	Module input state: External blocking2
I[2] . <b>ExBlo TripCmd-I</b>	Module input state: External Blocking of the Trip Command
I[2] . <b>Ex rev Interl-I</b>	Module input state: External reverse interlocking
I[2] . <b>AdaptSet1-I</b>	Module input state: Adaptive Parameter1
I[2] . <b>AdaptSet2-I</b>	Module input state: Adaptive Parameter2
I[2] . <b>AdaptSet3-I</b>	Module input state: Adaptive Parameter3
I[2] . <b>AdaptSet4-I</b>	Module input state: Adaptive Parameter4
I[3] . <b>active</b>	Signal: active
I[3] . <b>ExBlo</b>	Signal: External Blocking
I[3] . <b>Ex rev Interl</b>	Signal: External reverse Interlocking
I[3] . <b>Blo TripCmd</b>	Signal: Trip Command blocked
I[3] . <b>ExBlo TripCmd</b>	Signal: External Blocking of the Trip Command
I[3] . <b>Alarm L1</b>	Signal: Alarm L1
I[3] . <b>Alarm L2</b>	Signal: Alarm L2
I[3] . <b>Alarm L3</b>	Signal: Alarm L3
I[3] . <b>Alarm</b>	Signal: Alarm
I[3] . <b>Trip L1</b>	Signal: General Trip Phase L1
I[3] . <b>Trip L2</b>	Signal: General Trip Phase L2
I[3] . <b>Trip L3</b>	Signal: General Trip Phase L3

<b>1..n, Assignment List</b>	<b>Description</b>
I[3] . <b>Trip</b>	<i>Signal: Trip</i>
I[3] . <b>TripCmd</b>	<i>Signal: Trip Command</i>
I[3] . <b>DefaultSet</b>	<i>Signal: Default Parameter Set</i>
I[3] . <b>AdaptSet 1</b>	<i>Signal: Adaptive Parameter 1</i>
I[3] . <b>AdaptSet 2</b>	<i>Signal: Adaptive Parameter 2</i>
I[3] . <b>AdaptSet 3</b>	<i>Signal: Adaptive Parameter 3</i>
I[3] . <b>AdaptSet 4</b>	<i>Signal: Adaptive Parameter 4</i>
I[3] . <b>ExBlo1-I</b>	<i>Module input state: External blocking1</i>
I[3] . <b>ExBlo2-I</b>	<i>Module input state: External blocking2</i>
I[3] . <b>ExBlo TripCmd-I</b>	<i>Module input state: External Blocking of the Trip Command</i>
I[3] . <b>Ex rev Interl-I</b>	<i>Module input state: External reverse interlocking</i>
I[3] . <b>AdaptSet1-I</b>	<i>Module input state: Adaptive Parameter1</i>
I[3] . <b>AdaptSet2-I</b>	<i>Module input state: Adaptive Parameter2</i>
I[3] . <b>AdaptSet3-I</b>	<i>Module input state: Adaptive Parameter3</i>
I[3] . <b>AdaptSet4-I</b>	<i>Module input state: Adaptive Parameter4</i>
I[4] . <b>active</b>	<i>Signal: active</i>
I[4] . <b>ExBlo</b>	<i>Signal: External Blocking</i>
I[4] . <b>Ex rev Interl</b>	<i>Signal: External reverse Interlocking</i>
I[4] . <b>Blo TripCmd</b>	<i>Signal: Trip Command blocked</i>
I[4] . <b>ExBlo TripCmd</b>	<i>Signal: External Blocking of the Trip Command</i>
I[4] . <b>Alarm L1</b>	<i>Signal: Alarm L1</i>
I[4] . <b>Alarm L2</b>	<i>Signal: Alarm L2</i>
I[4] . <b>Alarm L3</b>	<i>Signal: Alarm L3</i>
I[4] . <b>Alarm</b>	<i>Signal: Alarm</i>
I[4] . <b>Trip L1</b>	<i>Signal: General Trip Phase L1</i>
I[4] . <b>Trip L2</b>	<i>Signal: General Trip Phase L2</i>
I[4] . <b>Trip L3</b>	<i>Signal: General Trip Phase L3</i>
I[4] . <b>Trip</b>	<i>Signal: Trip</i>
I[4] . <b>TripCmd</b>	<i>Signal: Trip Command</i>
I[4] . <b>DefaultSet</b>	<i>Signal: Default Parameter Set</i>
I[4] . <b>AdaptSet 1</b>	<i>Signal: Adaptive Parameter 1</i>
I[4] . <b>AdaptSet 2</b>	<i>Signal: Adaptive Parameter 2</i>

<b>1..n, Assignment List</b>	<b>Description</b>
I[4] . <b>AdaptSet 3</b>	Signal: Adaptive Parameter 3
I[4] . <b>AdaptSet 4</b>	Signal: Adaptive Parameter 4
I[4] . <b>ExBlo1-I</b>	Module input state: External blocking1
I[4] . <b>ExBlo2-I</b>	Module input state: External blocking2
I[4] . <b>ExBlo TripCmd-I</b>	Module input state: External Blocking of the Trip Command
I[4] . <b>Ex rev Interl-I</b>	Module input state: External reverse interlocking
I[4] . <b>AdaptSet1-I</b>	Module input state: Adaptive Parameter1
I[4] . <b>AdaptSet2-I</b>	Module input state: Adaptive Parameter2
I[4] . <b>AdaptSet3-I</b>	Module input state: Adaptive Parameter3
I[4] . <b>AdaptSet4-I</b>	Module input state: Adaptive Parameter4
I[5] . <b>active</b>	Signal: active
I[5] . <b>ExBlo</b>	Signal: External Blocking
I[5] . <b>Ex rev Interl</b>	Signal: External reverse Interlocking
I[5] . <b>Blo TripCmd</b>	Signal: Trip Command blocked
I[5] . <b>ExBlo TripCmd</b>	Signal: External Blocking of the Trip Command
I[5] . <b>Alarm L1</b>	Signal: Alarm L1
I[5] . <b>Alarm L2</b>	Signal: Alarm L2
I[5] . <b>Alarm L3</b>	Signal: Alarm L3
I[5] . <b>Alarm</b>	Signal: Alarm
I[5] . <b>Trip L1</b>	Signal: General Trip Phase L1
I[5] . <b>Trip L2</b>	Signal: General Trip Phase L2
I[5] . <b>Trip L3</b>	Signal: General Trip Phase L3
I[5] . <b>Trip</b>	Signal: Trip
I[5] . <b>TripCmd</b>	Signal: Trip Command
I[5] . <b>DefaultSet</b>	Signal: Default Parameter Set
I[5] . <b>AdaptSet 1</b>	Signal: Adaptive Parameter 1
I[5] . <b>AdaptSet 2</b>	Signal: Adaptive Parameter 2
I[5] . <b>AdaptSet 3</b>	Signal: Adaptive Parameter 3
I[5] . <b>AdaptSet 4</b>	Signal: Adaptive Parameter 4
I[5] . <b>ExBlo1-I</b>	Module input state: External blocking1
I[5] . <b>ExBlo2-I</b>	Module input state: External blocking2
I[5] . <b>ExBlo TripCmd-I</b>	Module input state: External Blocking of the Trip Command

<b>1..n, Assignment List</b>	<b>Description</b>
I[5] . <b>Ex rev Interl-I</b>	<i>Module input state: External reverse interlocking</i>
I[5] . <b>AdaptSet1-I</b>	<i>Module input state: Adaptive Parameter1</i>
I[5] . <b>AdaptSet2-I</b>	<i>Module input state: Adaptive Parameter2</i>
I[5] . <b>AdaptSet3-I</b>	<i>Module input state: Adaptive Parameter3</i>
I[5] . <b>AdaptSet4-I</b>	<i>Module input state: Adaptive Parameter4</i>
I[6] . <b>active</b>	<i>Signal: active</i>
I[6] . <b>ExBlo</b>	<i>Signal: External Blocking</i>
I[6] . <b>Ex rev Interl</b>	<i>Signal: External reverse Interlocking</i>
I[6] . <b>Blo TripCmd</b>	<i>Signal: Trip Command blocked</i>
I[6] . <b>ExBlo TripCmd</b>	<i>Signal: External Blocking of the Trip Command</i>
I[6] . <b>Alarm L1</b>	<i>Signal: Alarm L1</i>
I[6] . <b>Alarm L2</b>	<i>Signal: Alarm L2</i>
I[6] . <b>Alarm L3</b>	<i>Signal: Alarm L3</i>
I[6] . <b>Alarm</b>	<i>Signal: Alarm</i>
I[6] . <b>Trip L1</b>	<i>Signal: General Trip Phase L1</i>
I[6] . <b>Trip L2</b>	<i>Signal: General Trip Phase L2</i>
I[6] . <b>Trip L3</b>	<i>Signal: General Trip Phase L3</i>
I[6] . <b>Trip</b>	<i>Signal: Trip</i>
I[6] . <b>TripCmd</b>	<i>Signal: Trip Command</i>
I[6] . <b>DefaultSet</b>	<i>Signal: Default Parameter Set</i>
I[6] . <b>AdaptSet 1</b>	<i>Signal: Adaptive Parameter 1</i>
I[6] . <b>AdaptSet 2</b>	<i>Signal: Adaptive Parameter 2</i>
I[6] . <b>AdaptSet 3</b>	<i>Signal: Adaptive Parameter 3</i>
I[6] . <b>AdaptSet 4</b>	<i>Signal: Adaptive Parameter 4</i>
I[6] . <b>ExBlo1-I</b>	<i>Module input state: External blocking1</i>
I[6] . <b>ExBlo2-I</b>	<i>Module input state: External blocking2</i>
I[6] . <b>ExBlo TripCmd-I</b>	<i>Module input state: External Blocking of the Trip Command</i>
I[6] . <b>Ex rev Interl-I</b>	<i>Module input state: External reverse interlocking</i>
I[6] . <b>AdaptSet1-I</b>	<i>Module input state: Adaptive Parameter1</i>
I[6] . <b>AdaptSet2-I</b>	<i>Module input state: Adaptive Parameter2</i>
I[6] . <b>AdaptSet3-I</b>	<i>Module input state: Adaptive Parameter3</i>
I[6] . <b>AdaptSet4-I</b>	<i>Module input state: Adaptive Parameter4</i>

<b>1..n, Assignment List</b>	<b>Description</b>
IG[1] . <b>active</b>	<i>Signal: active</i>
IG[1] . <b>ExBlo</b>	<i>Signal: External Blocking</i>
IG[1] . <b>Ex rev Interl</b>	<i>Signal: External reverse Interlocking</i>
IG[1] . <b>Blo TripCmd</b>	<i>Signal: Trip Command blocked</i>
IG[1] . <b>ExBlo TripCmd</b>	<i>Signal: External Blocking of the Trip Command</i>
IG[1] . <b>Alarm</b>	<i>Signal: Alarm IG</i>
IG[1] . <b>Trip</b>	<i>Signal: Trip</i>
IG[1] . <b>TripCmd</b>	<i>Signal: Trip Command</i>
IG[1] . <b>DefaultSet</b>	<i>Signal: Default Parameter Set</i>
IG[1] . <b>AdaptSet 1</b>	<i>Signal: Adaptive Parameter 1</i>
IG[1] . <b>AdaptSet 2</b>	<i>Signal: Adaptive Parameter 2</i>
IG[1] . <b>AdaptSet 3</b>	<i>Signal: Adaptive Parameter 3</i>
IG[1] . <b>AdaptSet 4</b>	<i>Signal: Adaptive Parameter 4</i>
IG[1] . <b>ExBlo1-I</b>	<i>Module input state: External blocking1</i>
IG[1] . <b>ExBlo2-I</b>	<i>Module input state: External blocking2</i>
IG[1] . <b>ExBlo TripCmd-I</b>	<i>Module input state: External Blocking of the Trip Command</i>
IG[1] . <b>Ex rev Interl-I</b>	<i>Module input state: External reverse interlocking</i>
IG[1] . <b>AdaptSet1-I</b>	<i>Module input state: Adaptive Parameter1</i>
IG[1] . <b>AdaptSet2-I</b>	<i>Module input state: Adaptive Parameter2</i>
IG[1] . <b>AdaptSet3-I</b>	<i>Module input state: Adaptive Parameter3</i>
IG[1] . <b>AdaptSet4-I</b>	<i>Module input state: Adaptive Parameter4</i>
IG[2] . <b>active</b>	<i>Signal: active</i>
IG[2] . <b>ExBlo</b>	<i>Signal: External Blocking</i>
IG[2] . <b>Ex rev Interl</b>	<i>Signal: External reverse Interlocking</i>
IG[2] . <b>Blo TripCmd</b>	<i>Signal: Trip Command blocked</i>
IG[2] . <b>ExBlo TripCmd</b>	<i>Signal: External Blocking of the Trip Command</i>
IG[2] . <b>Alarm</b>	<i>Signal: Alarm IG</i>
IG[2] . <b>Trip</b>	<i>Signal: Trip</i>
IG[2] . <b>TripCmd</b>	<i>Signal: Trip Command</i>
IG[2] . <b>DefaultSet</b>	<i>Signal: Default Parameter Set</i>
IG[2] . <b>AdaptSet 1</b>	<i>Signal: Adaptive Parameter 1</i>
IG[2] . <b>AdaptSet 2</b>	<i>Signal: Adaptive Parameter 2</i>

<b>1..n, Assignment List</b>	<b>Description</b>
IG[2] . <b>AdaptSet 3</b>	<i>Signal: Adaptive Parameter 3</i>
IG[2] . <b>AdaptSet 4</b>	<i>Signal: Adaptive Parameter 4</i>
IG[2] . <b>ExBlo1-I</b>	<i>Module input state: External blocking1</i>
IG[2] . <b>ExBlo2-I</b>	<i>Module input state: External blocking2</i>
IG[2] . <b>ExBlo TripCmd-I</b>	<i>Module input state: External Blocking of the Trip Command</i>
IG[2] . <b>Ex rev Interl-I</b>	<i>Module input state: External reverse interlocking</i>
IG[2] . <b>AdaptSet1-I</b>	<i>Module input state: Adaptive Parameter1</i>
IG[2] . <b>AdaptSet2-I</b>	<i>Module input state: Adaptive Parameter2</i>
IG[2] . <b>AdaptSet3-I</b>	<i>Module input state: Adaptive Parameter3</i>
IG[2] . <b>AdaptSet4-I</b>	<i>Module input state: Adaptive Parameter4</i>
IG[3] . <b>active</b>	<i>Signal: active</i>
IG[3] . <b>ExBlo</b>	<i>Signal: External Blocking</i>
IG[3] . <b>Ex rev Interl</b>	<i>Signal: External reverse Interlocking</i>
IG[3] . <b>Blo TripCmd</b>	<i>Signal: Trip Command blocked</i>
IG[3] . <b>ExBlo TripCmd</b>	<i>Signal: External Blocking of the Trip Command</i>
IG[3] . <b>Alarm</b>	<i>Signal: Alarm IG</i>
IG[3] . <b>Trip</b>	<i>Signal: Trip</i>
IG[3] . <b>TripCmd</b>	<i>Signal: Trip Command</i>
IG[3] . <b>DefaultSet</b>	<i>Signal: Default Parameter Set</i>
IG[3] . <b>AdaptSet 1</b>	<i>Signal: Adaptive Parameter 1</i>
IG[3] . <b>AdaptSet 2</b>	<i>Signal: Adaptive Parameter 2</i>
IG[3] . <b>AdaptSet 3</b>	<i>Signal: Adaptive Parameter 3</i>
IG[3] . <b>AdaptSet 4</b>	<i>Signal: Adaptive Parameter 4</i>
IG[3] . <b>ExBlo1-I</b>	<i>Module input state: External blocking1</i>
IG[3] . <b>ExBlo2-I</b>	<i>Module input state: External blocking2</i>
IG[3] . <b>ExBlo TripCmd-I</b>	<i>Module input state: External Blocking of the Trip Command</i>
IG[3] . <b>Ex rev Interl-I</b>	<i>Module input state: External reverse interlocking</i>
IG[3] . <b>AdaptSet1-I</b>	<i>Module input state: Adaptive Parameter1</i>
IG[3] . <b>AdaptSet2-I</b>	<i>Module input state: Adaptive Parameter2</i>
IG[3] . <b>AdaptSet3-I</b>	<i>Module input state: Adaptive Parameter3</i>
IG[3] . <b>AdaptSet4-I</b>	<i>Module input state: Adaptive Parameter4</i>
IG[4] . <b>active</b>	<i>Signal: active</i>

<b>1..n, Assignment List</b>	<b>Description</b>
IG[4] . <b>ExBlo</b>	<i>Signal: External Blocking</i>
IG[4] . <b>Ex rev Interl</b>	<i>Signal: External reverse Interlocking</i>
IG[4] . <b>Blo TripCmd</b>	<i>Signal: Trip Command blocked</i>
IG[4] . <b>ExBlo TripCmd</b>	<i>Signal: External Blocking of the Trip Command</i>
IG[4] . <b>Alarm</b>	<i>Signal: Alarm IG</i>
IG[4] . <b>Trip</b>	<i>Signal: Trip</i>
IG[4] . <b>TripCmd</b>	<i>Signal: Trip Command</i>
IG[4] . <b>DefaultSet</b>	<i>Signal: Default Parameter Set</i>
IG[4] . <b>AdaptSet 1</b>	<i>Signal: Adaptive Parameter 1</i>
IG[4] . <b>AdaptSet 2</b>	<i>Signal: Adaptive Parameter 2</i>
IG[4] . <b>AdaptSet 3</b>	<i>Signal: Adaptive Parameter 3</i>
IG[4] . <b>AdaptSet 4</b>	<i>Signal: Adaptive Parameter 4</i>
IG[4] . <b>ExBlo1-I</b>	<i>Module input state: External blocking1</i>
IG[4] . <b>ExBlo2-I</b>	<i>Module input state: External blocking2</i>
IG[4] . <b>ExBlo TripCmd-I</b>	<i>Module input state: External Blocking of the Trip Command</i>
IG[4] . <b>Ex rev Interl-I</b>	<i>Module input state: External reverse interlocking</i>
IG[4] . <b>AdaptSet1-I</b>	<i>Module input state: Adaptive Parameter1</i>
IG[4] . <b>AdaptSet2-I</b>	<i>Module input state: Adaptive Parameter2</i>
IG[4] . <b>AdaptSet3-I</b>	<i>Module input state: Adaptive Parameter3</i>
IG[4] . <b>AdaptSet4-I</b>	<i>Module input state: Adaptive Parameter4</i>
ThR . <b>Alarm Pickup</b>	<i>Signal: Alarm Pickup</i>
ThR . <b>Alarm Timeout</b>	<i>Signal: Alarm Timeout</i>
ThR . <b>RTD effective</b>	<p><i>This state becomes true if the following conditions are all fulfilled:</i></p> <ul style="list-style-type: none"> <li><i>- the state "Load above SF" is true,</i></li> <li><i>- RTD functionality is active,</i></li> <li><i>- for at least one temperature a valid value above 0°C is being displayed.</i></li> </ul>
ThR . <b>Load above SF</b>	<i>"Load above Service Factor": If the current exceeds the set value of "UTC" ("Ultimate trip threshold") then the used thermal capacity counts up and the state "Load above SF" is becoming true. If the current is below the "UTC" value this state is false.</i>
ThR . <b>active</b>	<i>Signal: active</i>
ThR . <b>ExBlo</b>	<i>Signal: External Blocking</i>

<b>1..n, Assignment List</b>	<b>Description</b>
ThR . <b>Blo TripCmd</b>	<i>Signal: Trip Command blocked</i>
ThR . <b>ExBlo TripCmd</b>	<i>Signal: External Blocking of the Trip Command</i>
ThR . <b>Alarm</b>	<i>Signal: Alarm</i>
ThR . <b>Trip</b>	<i>Signal: Trip</i>
ThR . <b>TripCmd</b>	<i>Signal: Trip Command</i>
ThR . <b>ExBlo1-I</b>	<i>Module input state: External blocking</i>
ThR . <b>ExBlo2-I</b>	<i>Module input state: External blocking</i>
ThR . <b>ExBlo TripCmd-I</b>	<i>Module input state: External Blocking of the Trip Command</i>
Jam[1] . <b>active</b>	<i>Signal: active</i>
Jam[1] . <b>ExBlo</b>	<i>Signal: External Blocking</i>
Jam[1] . <b>Blo TripCmd</b>	<i>Signal: Trip Command blocked</i>
Jam[1] . <b>ExBlo TripCmd</b>	<i>Signal: External Blocking of the Trip Command</i>
Jam[1] . <b>Alarm</b>	<i>Signal: Alarm</i>
Jam[1] . <b>Trip</b>	<i>Signal: Trip</i>
Jam[1] . <b>TripCmd</b>	<i>Signal: Trip Command</i>
Jam[1] . <b>ExBlo1-I</b>	<i>Module input state: External blocking1</i>
Jam[1] . <b>ExBlo2-I</b>	<i>Module input state: External blocking2</i>
Jam[1] . <b>ExBlo TripCmd-I</b>	<i>Module input state: External Blocking of the Trip Command</i>
Jam[2] . <b>active</b>	<i>Signal: active</i>
Jam[2] . <b>ExBlo</b>	<i>Signal: External Blocking</i>
Jam[2] . <b>Blo TripCmd</b>	<i>Signal: Trip Command blocked</i>
Jam[2] . <b>ExBlo TripCmd</b>	<i>Signal: External Blocking of the Trip Command</i>
Jam[2] . <b>Alarm</b>	<i>Signal: Alarm</i>
Jam[2] . <b>Trip</b>	<i>Signal: Trip</i>
Jam[2] . <b>TripCmd</b>	<i>Signal: Trip Command</i>
Jam[2] . <b>ExBlo1-I</b>	<i>Module input state: External blocking1</i>
Jam[2] . <b>ExBlo2-I</b>	<i>Module input state: External blocking2</i>
Jam[2] . <b>ExBlo TripCmd-I</b>	<i>Module input state: External Blocking of the Trip Command</i>
I<[1] . <b>active</b>	<i>Signal: active</i>
I<[1] . <b>ExBlo</b>	<i>Signal: External Blocking</i>
I<[1] . <b>Blo TripCmd</b>	<i>Signal: Trip Command blocked</i>
I<[1] . <b>ExBlo TripCmd</b>	<i>Signal: External Blocking of the Trip Command</i>



<b>1..n, Assignment List</b>	<b>Description</b>
I<[1] . <b>Alarm</b>	Signal: Alarm
I<[1] . <b>Trip</b>	Signal: Trip
I<[1] . <b>TripCmd</b>	Signal: Trip Command
I<[1] . <b>ExBlo1-I</b>	Module input state: External blocking1
I<[1] . <b>ExBlo2-I</b>	Module input state: External blocking2
I<[1] . <b>ExBlo TripCmd-I</b>	Module input state: External Blocking of the Trip Command
I<[2] . <b>active</b>	Signal: active
I<[2] . <b>ExBlo</b>	Signal: External Blocking
I<[2] . <b>Blo TripCmd</b>	Signal: Trip Command blocked
I<[2] . <b>ExBlo TripCmd</b>	Signal: External Blocking of the Trip Command
I<[2] . <b>Alarm</b>	Signal: Alarm
I<[2] . <b>Trip</b>	Signal: Trip
I<[2] . <b>TripCmd</b>	Signal: Trip Command
I<[2] . <b>ExBlo1-I</b>	Module input state: External blocking1
I<[2] . <b>ExBlo2-I</b>	Module input state: External blocking2
I<[2] . <b>ExBlo TripCmd-I</b>	Module input state: External Blocking of the Trip Command
I<[3] . <b>active</b>	Signal: active
I<[3] . <b>ExBlo</b>	Signal: External Blocking
I<[3] . <b>Blo TripCmd</b>	Signal: Trip Command blocked
I<[3] . <b>ExBlo TripCmd</b>	Signal: External Blocking of the Trip Command
I<[3] . <b>Alarm</b>	Signal: Alarm
I<[3] . <b>Trip</b>	Signal: Trip
I<[3] . <b>TripCmd</b>	Signal: Trip Command
I<[3] . <b>ExBlo1-I</b>	Module input state: External blocking1
I<[3] . <b>ExBlo2-I</b>	Module input state: External blocking2
I<[3] . <b>ExBlo TripCmd-I</b>	Module input state: External Blocking of the Trip Command
MLS . <b>active</b>	Signal: active
MLS . <b>ExBlo</b>	Signal: External Blocking
MLS . <b>Alarm</b>	Signal: Alarm
MLS . <b>Trip</b>	Signal: Trip
MLS . <b>ExBlo1-I</b>	Module input state: External blocking1
MLS . <b>ExBlo2-I</b>	Module input state: External blocking2

<b>1..n, Assignment List</b>	<b>Description</b>
I2>[1] . <b>active</b>	Signal: active
I2>[1] . <b>ExBlo</b>	Signal: External Blocking
I2>[1] . <b>Blo TripCmd</b>	Signal: Trip Command blocked
I2>[1] . <b>ExBlo TripCmd</b>	Signal: External Blocking of the Trip Command
I2>[1] . <b>Alarm</b>	Signal: Alarm Negative Sequence
I2>[1] . <b>Trip</b>	Signal: Trip
I2>[1] . <b>TripCmd</b>	Signal: Trip Command
I2>[1] . <b>ExBlo1-I</b>	Module input state: External blocking1
I2>[1] . <b>ExBlo2-I</b>	Module input state: External blocking2
I2>[1] . <b>ExBlo TripCmd-I</b>	Module input state: External Blocking of the Trip Command
I2>[2] . <b>active</b>	Signal: active
I2>[2] . <b>ExBlo</b>	Signal: External Blocking
I2>[2] . <b>Blo TripCmd</b>	Signal: Trip Command blocked
I2>[2] . <b>ExBlo TripCmd</b>	Signal: External Blocking of the Trip Command
I2>[2] . <b>Alarm</b>	Signal: Alarm Negative Sequence
I2>[2] . <b>Trip</b>	Signal: Trip
I2>[2] . <b>TripCmd</b>	Signal: Trip Command
I2>[2] . <b>ExBlo1-I</b>	Module input state: External blocking1
I2>[2] . <b>ExBlo2-I</b>	Module input state: External blocking2
I2>[2] . <b>ExBlo TripCmd-I</b>	Module input state: External Blocking of the Trip Command
ExP[1] . <b>active</b>	Signal: active
ExP[1] . <b>ExBlo</b>	Signal: External Blocking
ExP[1] . <b>Blo TripCmd</b>	Signal: Trip Command blocked
ExP[1] . <b>ExBlo TripCmd</b>	Signal: External Blocking of the Trip Command
ExP[1] . <b>Alarm</b>	Signal: Alarm
ExP[1] . <b>Trip</b>	Signal: Trip
ExP[1] . <b>TripCmd</b>	Signal: Trip Command
ExP[1] . <b>ExBlo1-I</b>	Module input state: External blocking1
ExP[1] . <b>ExBlo2-I</b>	Module input state: External blocking2
ExP[1] . <b>ExBlo TripCmd-I</b>	Module input state: External Blocking of the Trip Command
ExP[1] . <b>Alarm-I</b>	Module input state: Alarm
ExP[1] . <b>Trip-I</b>	Module input state: Trip

<b>1..n, Assignment List</b>	<b>Description</b>
ExP[2] . <b>active</b>	<i>Signal: active</i>
ExP[2] . <b>ExBlo</b>	<i>Signal: External Blocking</i>
ExP[2] . <b>Blo TripCmd</b>	<i>Signal: Trip Command blocked</i>
ExP[2] . <b>ExBlo TripCmd</b>	<i>Signal: External Blocking of the Trip Command</i>
ExP[2] . <b>Alarm</b>	<i>Signal: Alarm</i>
ExP[2] . <b>Trip</b>	<i>Signal: Trip</i>
ExP[2] . <b>TripCmd</b>	<i>Signal: Trip Command</i>
ExP[2] . <b>ExBlo1-I</b>	<i>Module input state: External blocking1</i>
ExP[2] . <b>ExBlo2-I</b>	<i>Module input state: External blocking2</i>
ExP[2] . <b>ExBlo TripCmd-I</b>	<i>Module input state: External Blocking of the Trip Command</i>
ExP[2] . <b>Alarm-I</b>	<i>Module input state: Alarm</i>
ExP[2] . <b>Trip-I</b>	<i>Module input state: Trip</i>
ExP[3] . <b>active</b>	<i>Signal: active</i>
ExP[3] . <b>ExBlo</b>	<i>Signal: External Blocking</i>
ExP[3] . <b>Blo TripCmd</b>	<i>Signal: Trip Command blocked</i>
ExP[3] . <b>ExBlo TripCmd</b>	<i>Signal: External Blocking of the Trip Command</i>
ExP[3] . <b>Alarm</b>	<i>Signal: Alarm</i>
ExP[3] . <b>Trip</b>	<i>Signal: Trip</i>
ExP[3] . <b>TripCmd</b>	<i>Signal: Trip Command</i>
ExP[3] . <b>ExBlo1-I</b>	<i>Module input state: External blocking1</i>
ExP[3] . <b>ExBlo2-I</b>	<i>Module input state: External blocking2</i>
ExP[3] . <b>ExBlo TripCmd-I</b>	<i>Module input state: External Blocking of the Trip Command</i>
ExP[3] . <b>Alarm-I</b>	<i>Module input state: Alarm</i>
ExP[3] . <b>Trip-I</b>	<i>Module input state: Trip</i>
ExP[4] . <b>active</b>	<i>Signal: active</i>
ExP[4] . <b>ExBlo</b>	<i>Signal: External Blocking</i>
ExP[4] . <b>Blo TripCmd</b>	<i>Signal: Trip Command blocked</i>
ExP[4] . <b>ExBlo TripCmd</b>	<i>Signal: External Blocking of the Trip Command</i>
ExP[4] . <b>Alarm</b>	<i>Signal: Alarm</i>
ExP[4] . <b>Trip</b>	<i>Signal: Trip</i>
ExP[4] . <b>TripCmd</b>	<i>Signal: Trip Command</i>
ExP[4] . <b>ExBlo1-I</b>	<i>Module input state: External blocking1</i>

<b>1..n, Assignment List</b>	<b>Description</b>
Exp[4] . <b>ExBlo2-I</b>	<i>Module input state: External blocking2</i>
Exp[4] . <b>ExBlo TripCmd-I</b>	<i>Module input state: External Blocking of the Trip Command</i>
Exp[4] . <b>Alarm-I</b>	<i>Module input state: Alarm</i>
Exp[4] . <b>Trip-I</b>	<i>Module input state: Trip</i>
URTD . <b>Windg1 Superv</b>	<i>Signal: Windg1, Channel Supervision. The value "1" reports a detected channel failure. (The value "0" means that this RTD channel is healthy.)</i>
URTD . <b>Windg2 Superv</b>	<i>Signal: Windg2, Channel Supervision. The value "1" reports a detected channel failure. (The value "0" means that this RTD channel is healthy.)</i>
URTD . <b>Windg3 Superv</b>	<i>Signal: Windg3, Channel Supervision. The value "1" reports a detected channel failure. (The value "0" means that this RTD channel is healthy.)</i>
URTD . <b>Windg4 Superv</b>	<i>Signal: Windg4, Channel Supervision. The value "1" reports a detected channel failure. (The value "0" means that this RTD channel is healthy.)</i>
URTD . <b>Windg5 Superv</b>	<i>Signal: Windg5, Channel Supervision. The value "1" reports a detected channel failure. (The value "0" means that this RTD channel is healthy.)</i>
URTD . <b>Windg6 Superv</b>	<i>Signal: Windg6, Channel Supervision. The value "1" reports a detected channel failure. (The value "0" means that this RTD channel is healthy.)</i>
URTD . <b>MotBear1 Superv</b>	<i>Signal: MotBear1, Channel Supervision. The value "1" reports a detected channel failure. (The value "0" means that this RTD channel is healthy.)</i>
URTD . <b>MotBear2 Superv</b>	<i>Signal: MotBear2, Channel Supervision. The value "1" reports a detected channel failure. (The value "0" means that this RTD channel is healthy.)</i>
URTD . <b>LoadBear1 Superv</b>	<i>Signal: LoadBear1, Channel Supervision. The value "1" reports a detected channel failure. (The value "0" means that this RTD channel is healthy.)</i>
URTD . <b>LoadBear2 Superv</b>	<i>Signal: LoadBear2, Channel Supervision. The value "1" reports a detected channel failure. (The value "0" means that this RTD channel is healthy.)</i>
URTD . <b>Aux1 Superv</b>	<i>Signal: Aux1, Channel Supervision. The value "1" reports a detected channel failure. (The value "0" means that this RTD channel is healthy.)</i>
URTD . <b>Aux2 Superv</b>	<i>Signal: Aux2, Channel Supervision. The value "1" reports a detected channel failure. (The value "0" means that this RTD channel is healthy.)</i>
URTD . <b>Superv</b>	<i>Signal: URTD Channel Supervision. The value "1" reports a detected channel failure. (The value "0" means that all RTD channels are healthy.)</i>
URTD . <b>Connection active</b>	<i>Signal: There is an active connection between the Temperature Detector (URTD) and the protective relay.</i>
URTD . <b>Outs forced</b>	<i>Signal: The State of at least one Relay Output has been set by force. That means that the state of at least one Relay is forced and hence does not show the state of the assigned signals.</i>
RTD . <b>active</b>	<i>Signal: active</i>

<b>1..n, Assignment List</b>	<b>Description</b>
RTD . <b>ExBlo</b>	<i>Signal: External Blocking</i>
RTD . <b>Blo TripCmd</b>	<i>Signal: Trip Command blocked</i>
RTD . <b>ExBlo TripCmd</b>	<i>Signal: External Blocking of the Trip Command</i>
RTD . <b>Alarm</b>	<i>Alarm RTD Temperature Protection</i>
RTD . <b>Trip</b>	<i>Signal: Trip</i>
RTD . <b>TripCmd</b>	<i>Signal: Trip Command</i>
RTD . <b>Windg 1 Trip</b>	<i>Winding 1 Signal: Trip</i>
RTD . <b>Windg 1 Alarm</b>	<i>Winding 1 Alarm RTD Temperature Protection</i>
RTD . <b>Windg 1 Timeout Alarm</b>	<i>Winding 1 Timeout Alarm</i>
RTD . <b>Windg 1 Invalid</b>	<i>Winding 1 Signal: Invalid Temperature Measurement Value (e.g caused by an defective or interrupted RTD Measurement)</i>
RTD . <b>Windg 2 Trip</b>	<i>Winding 2 Signal: Trip</i>
RTD . <b>Windg 2 Alarm</b>	<i>Winding 2 Alarm RTD Temperature Protection</i>
RTD . <b>Windg 2 Timeout Alarm</b>	<i>Winding 2 Timeout Alarm</i>
RTD . <b>Windg 2 Invalid</b>	<i>Winding 2 Signal: Invalid Temperature Measurement Value (e.g caused by an defective or interrupted RTD Measurement)</i>
RTD . <b>Windg 3 Trip</b>	<i>Winding 3 Signal: Trip</i>
RTD . <b>Windg 3 Alarm</b>	<i>Winding 3 Alarm RTD Temperature Protection</i>
RTD . <b>Windg 3 Timeout Alarm</b>	<i>Winding 3 Timeout Alarm</i>
RTD . <b>Windg 3 Invalid</b>	<i>Winding 3 Signal: Invalid Temperature Measurement Value (e.g caused by an defective or interrupted RTD Measurement)</i>
RTD . <b>Windg 4 Trip</b>	<i>Winding 4 Signal: Trip</i>
RTD . <b>Windg 4 Alarm</b>	<i>Winding 4 Alarm RTD Temperature Protection</i>
RTD . <b>Windg 4 Timeout Alarm</b>	<i>Winding 4 Timeout Alarm</i>
RTD . <b>Windg 4 Invalid</b>	<i>Winding 4 Signal: Invalid Temperature Measurement Value (e.g caused by an defective or interrupted RTD Measurement)</i>
RTD . <b>Windg 5 Trip</b>	<i>Winding 5 Signal: Trip</i>
RTD . <b>Windg 5 Alarm</b>	<i>Winding 5 Alarm RTD Temperature Protection</i>
RTD . <b>Windg 5 Timeout Alarm</b>	<i>Winding 5 Timeout Alarm</i>
RTD . <b>Windg 5 Invalid</b>	<i>Winding 5 Signal: Invalid Temperature Measurement Value (e.g caused by an defective or interrupted RTD Measurement)</i>

<b>1..n, Assignment List</b>	<b>Description</b>
RTD . <b>Windg 6 Trip</b>	<i>Winding 6 Signal: Trip</i>
RTD . <b>Windg 6 Alarm</b>	<i>Winding 6 Alarm RTD Temperature Protection</i>
RTD . <b>Windg 6 Timeout Alarm</b>	<i>Winding 6 Timeout Alarm</i>
RTD . <b>Windg 6 Invalid</b>	<i>Winding 6 Signal: Invalid Temperature Measurement Value (e.g caused by an defective or interrupted RTD Measurement)</i>
RTD . <b>MotBear 1 Trip</b>	<i>Motor Bearing 1 Signal: Trip</i>
RTD . <b>MotBear 1 Alarm</b>	<i>Motor Bearing 1 Alarm RTD Temperature Protection</i>
RTD . <b>MotBear 1 Timeout Alarm</b>	<i>Motor Bearing 1 Timeout Alarm</i>
RTD . <b>MotBear 1 Invalid</b>	<i>Motor Bearing 1 Signal: Invalid Temperature Measurement Value (e.g caused by an defective or interrupted RTD Measurement)</i>
RTD . <b>MotBear 2 Trip</b>	<i>Motor Bearing 2 Signal: Trip</i>
RTD . <b>MotBear 2 Alarm</b>	<i>Motor Bearing 2 Alarm RTD Temperature Protection</i>
RTD . <b>MotBear 2 Timeout Alarm</b>	<i>Motor Bearing 2 Timeout Alarm</i>
RTD . <b>MotBear 2 Invalid</b>	<i>Motor Bearing 2 Signal: Invalid Temperature Measurement Value (e.g caused by an defective or interrupted RTD Measurement)</i>
RTD . <b>LoadBear 1 Trip</b>	<i>Load Bearing 1 Signal: Trip</i>
RTD . <b>LoadBear 1 Alarm</b>	<i>Load Bearing 1 Alarm RTD Temperature Protection</i>
RTD . <b>LoadBear 1 Timeout Alarm</b>	<i>Load Bearing 1 Timeout Alarm</i>
RTD . <b>LoadBear 1 Invalid</b>	<i>Load Bearing 1 Signal: Invalid Temperature Measurement Value (e.g caused by an defective or interrupted RTD Measurement)</i>
RTD . <b>LoadBear 2 Trip</b>	<i>Load Bearing 2 Signal: Trip</i>
RTD . <b>LoadBear 2 Alarm</b>	<i>Load Bearing 2 Alarm RTD Temperature Protection</i>
RTD . <b>LoadBear 2 Timeout Alarm</b>	<i>Load Bearing 2 Timeout Alarm</i>
RTD . <b>LoadBear 2 Invalid</b>	<i>Load Bearing 2 Signal: Invalid Temperature Measurement Value (e.g caused by an defective or interrupted RTD Measurement)</i>
RTD . <b>Aux1 Trip</b>	<i>Auxiliary 1 Signal: Trip</i>
RTD . <b>Aux1 Alarm</b>	<i>Auxiliary 1 Alarm RTD Temperature Protection</i>
RTD . <b>Aux1 Timeout Alarm</b>	<i>Auxiliary 1 Timeout Alarm</i>
RTD . <b>Aux1 Invalid</b>	<i>Auxiliary 1 Signal: Invalid Temperature Measurement Value (e.g caused by an defective or interrupted RTD Measurement)</i>
RTD . <b>Aux2 Trip</b>	<i>Auxiliary 2 Signal: Trip</i>

<b>1..n, Assignment List</b>	<b>Description</b>
RTD . <b>Aux2 Alarm</b>	<i>Auxiliary 2 Alarm RTD Temperature Protection</i>
RTD . <b>Aux2 Timeout Alarm</b>	<i>Auxiliary 2 Timeout Alarm</i>
RTD . <b>Aux2 Invalid</b>	<i>Auxiliary 2 Signal: Invalid Temperature Measurement Value (e.g caused by an defective or interrupted RTD Measurement)</i>
RTD . <b>Trip WD Group</b>	<i>Trip all Windings</i>
RTD . <b>Alarm WD Group</b>	<i>Alarm all Windings</i>
RTD . <b>TimeoutAlmWDGrp</b>	<i>Timeout Alarm all Windings</i>
RTD . <b>Windg Group Invalid</b>	<i>Winding Group Signal: Invalid Temperature Measurement Value (e.g caused by an defective or interrupted RTD Measurement)</i>
RTD . <b>Trip MB Group</b>	<i>Trip all Motor Bearings</i>
RTD . <b>Alarm MB Group</b>	<i>Alarm all Motor Bearings</i>
RTD . <b>TimeoutAlmMBGrp</b>	<i>Timeout Alarm all Motor Bearings</i>
RTD . <b>MotBear Group Invalid</b>	<i>Motor Bearing Group Signal: Invalid Temperature Measurement Value (e.g caused by an defective or interrupted RTD Measurement)</i>
RTD . <b>Trip LB Group</b>	<i>Trip all Load Bearings</i>
RTD . <b>Alarm LB Group</b>	<i>Alarm all Load Bearings</i>
RTD . <b>TimeoutAlmLBGrp</b>	<i>Timeout Alarm all Load Bearings</i>
RTD . <b>LoadBear Group Invalid</b>	<i>Load Bearing Group Signal: Invalid Temperature Measurement Value (e.g caused by an defective or interrupted RTD Measurement)</i>
RTD . <b>Trip Any Group</b>	<i>Trip Any Group</i>
RTD . <b>Alarm Any Group</b>	<i>Alarm Any Group</i>
RTD . <b>TimeoutAlmAnyGrp</b>	<i>Timeout Alarm Any Group</i>
RTD . <b>Trip Group 1</b>	<i>Trip Group 1</i>
RTD . <b>Trip Group 2</b>	<i>Trip Group 2</i>
RTD . <b>Timeout Alarm</b>	<i>Alarm timeout expired</i>
RTD . <b>Trip Aux Group</b>	<i>Trip Auxiliary Group</i>
RTD . <b>Alarm Aux Group</b>	<i>Alarm Auxiliary Group</i>
RTD . <b>TimeoutAlmAuxGrp</b>	<i>Timeout Alarm Auxiliary Group</i>
RTD . <b>AuxGrpInvalid</b>	<i>Invalid Auxiliary Group</i>
RTD . <b>ExBlo1-I</b>	<i>Module input state: External blocking1</i>
RTD . <b>ExBlo2-I</b>	<i>Module input state: External blocking2</i>

<b>1..n, Assignment List</b>	<b>Description</b>
RTD . <b>ExBlo TripCmd-I</b>	<i>Module input state: External Blocking of the Trip Command</i>
CBF . <b>active</b>	<i>Signal: active</i>
CBF . <b>ExBlo</b>	<i>Signal: External Blocking</i>
CBF . <b>Waiting for Trigger</b>	<i>Waiting for Trigger</i>
CBF . <b>running</b>	<i>Signal: CBF-Module started</i>
CBF . <b>Alarm</b>	<i>Signal: Circuit Breaker Failure</i>
CBF . <b>Lockout</b>	<i>Signal: Lockout</i>
CBF . <b>Res Lockout</b>	<i>Signal: Reset Lockout</i>
CBF . <b>ExBlo1-I</b>	<i>Module input state: External blocking1</i>
CBF . <b>ExBlo2-I</b>	<i>Module input state: External blocking2</i>
CBF . <b>Trigger1-I</b>	<i>Module Input: Trigger that will start the CBF</i>
CBF . <b>Trigger2-I</b>	<i>Module Input: Trigger that will start the CBF</i>
CBF . <b>Trigger3-I</b>	<i>Module Input: Trigger that will start the CBF</i>
TCS . <b>active</b>	<i>Signal: active</i>
TCS . <b>ExBlo</b>	<i>Signal: External Blocking</i>
TCS . <b>Alarm</b>	<i>Signal: Alarm Trip Circuit Supervision</i>
TCS . <b>Not Possible</b>	<i>Not possible because no state indicator assigned to the breaker.</i>
TCS . <b>Aux ON-I</b>	<i>Module Input State: Position indicator/check-back signal of the CB (52a)</i>
TCS . <b>Aux OFF-I</b>	<i>Module input state: Position indicator/check-back signal of the CB (52b)</i>
TCS . <b>ExBlo1-I</b>	<i>Module input state: External blocking1</i>
TCS . <b>ExBlo2-I</b>	<i>Module input state: External blocking2</i>
CTS . <b>active</b>	<i>Signal: active</i>
CTS . <b>ExBlo</b>	<i>Signal: External Blocking</i>
CTS . <b>Alarm</b>	<i>Signal: Alarm Current Transformer Measuring Circuit Supervision</i>
CTS . <b>ExBlo1-I</b>	<i>Module input state: External blocking1</i>
CTS . <b>ExBlo2-I</b>	<i>Module input state: External blocking2</i>
SysA . <b>active</b>	<i>Signal: active</i>
SysA . <b>ExBlo</b>	<i>Signal: External Blocking</i>
SysA . <b>Alm Current Demd</b>	<i>Signal: Alarm averaged demand current</i>
SysA . <b>Alarm I THD</b>	<i>Signal: Alarm Total Harmonic Distortion Current</i>



<b>1..n, Assignment List</b>	<b>Description</b>
SysA . <b>Trip Current Demand</b>	Signal: Trip averaged demand current
SysA . <b>Trip I THD</b>	Signal: Trip Total Harmonic Distortion Current
SysA . <b>ExBlo-I</b>	Module input state: External blocking
DI Slot X1 . <b>DI 1</b>	Signal: Digital Input
DI Slot X1 . <b>DI 2</b>	Signal: Digital Input
DI Slot X1 . <b>DI 3</b>	Signal: Digital Input
DI Slot X1 . <b>DI 4</b>	Signal: Digital Input
DI Slot X1 . <b>DI 5</b>	Signal: Digital Input
DI Slot X1 . <b>DI 6</b>	Signal: Digital Input
DI Slot X1 . <b>DI 7</b>	Signal: Digital Input
DI Slot X1 . <b>DI 8</b>	Signal: Digital Input
DI Slot X1 . <b>DI 1</b>	Signal: Digital Input
DI Slot X1 . <b>DI 2</b>	Signal: Digital Input
DI Slot X1 . <b>DI 3</b>	Signal: Digital Input
DI Slot X1 . <b>DI 4</b>	Signal: Digital Input
BO Slot X2 . <b>BO 1</b>	Signal: Binary Output Relay
BO Slot X2 . <b>BO 2</b>	Signal: Binary Output Relay
BO Slot X2 . <b>BO 3</b>	Signal: Binary Output Relay
BO Slot X2 . <b>BO 4</b>	Signal: Binary Output Relay
BO Slot X2 . <b>BO 5</b>	Signal: Binary Output Relay
BO Slot X2 . <b>DISARMED!</b>	Signal: CAUTION! RELAYS DISARMED in order to safely perform maintenance while eliminating the risk of taking an entire process off-line. (Note: The Self Supervision Contact cannot be disarmed). YOU MUST ENSURE that the relays are ARMED AGAIN after maintenance
BO Slot X2 . <b>Outs forced</b>	Signal: The State of at least one Relay Output has been set by force. That means that the state of at least one Relay is forced and hence does not show the state of the assigned signals.
BO Slot X2 . <b>BO 1</b>	Signal: Binary Output Relay
BO Slot X2 . <b>BO 2</b>	Signal: Binary Output Relay
BO Slot X2 . <b>BO 3</b>	Signal: Binary Output Relay
BO Slot X2 . <b>DISARMED!</b>	Signal: CAUTION! RELAYS DISARMED in order to safely perform maintenance while eliminating the risk of taking an entire process off-line. (Note: The Self Supervision Contact cannot be disarmed). YOU MUST ENSURE that the relays are ARMED AGAIN after maintenance

<b>1..n, Assignment List</b>	<b>Description</b>
BO Slot X2 . <b>Outs forced</b>	<i>Signal: The State of at least one Relay Output has been set by force. That means that the state of at least one Relay is forced and hence does not show the state of the assigned signals.</i>
AnOut[1] . <b>Force Mode</b>	<i>For commissioning purposes or for maintenance, Analog Outputs can be set by force. By means of this function the normal Analog Outputs can be overwritten (forced).</i>
Event rec . <b>Res all records</b>	<i>Signal: All records are being deleted. (Remark: Immediately afterwards, this signal becomes inactive again.)</i>
Disturb rec . <b>recording</b>	<i>Signal: Recording</i>
Disturb rec . <b>memory full</b>	<i>Signal: Memory full</i>
Disturb rec . <b>Clear fail</b>	<i>Signal: Clear failure in memory</i>
Disturb rec . <b>Res all records</b>	<i>Signal: All records are being deleted. (Remark: Immediately afterwards, this signal becomes inactive again.)</i>
Disturb rec . <b>Res all records</b>	<i>Signal: All records are being deleted. (Remark: Immediately afterwards, this signal becomes inactive again.)</i>
Disturb rec . <b>Man Trigger</b>	<i>Signal: Manual Trigger</i>
Disturb rec . <b>Start1-I</b>	<i>State of the module input:: Trigger event / start recording</i>
Disturb rec . <b>Start2-I</b>	<i>State of the module input:: Trigger event / start recording</i>
Disturb rec . <b>Start3-I</b>	<i>State of the module input:: Trigger event / start recording</i>
Disturb rec . <b>Start4-I</b>	<i>State of the module input:: Trigger event / start recording</i>
Disturb rec . <b>Start5-I</b>	<i>State of the module input:: Trigger event / start recording</i>
Disturb rec . <b>Start6-I</b>	<i>State of the module input:: Trigger event / start recording</i>
Disturb rec . <b>Start7-I</b>	<i>State of the module input:: Trigger event / start recording</i>
Disturb rec . <b>Start8-I</b>	<i>State of the module input:: Trigger event / start recording</i>
Fault rec . <b>Res all records</b>	<i>Signal: All records are being deleted. (Remark: Immediately afterwards, this signal becomes inactive again.)</i>
Trend rec . <b>Res all records</b>	<i>Signal: All records are being deleted. (Remark: Immediately afterwards, this signal becomes inactive again.)</i>
Start rec . <b>Storing</b>	<i>Signal: Data are saved</i>
SSV . <b>System Error</b>	<i>Signal: Device Failure</i>
SSV . <b>SelfSuperVision Contact</b>	<i>Signal: SelfSuperVision Contact</i>
SSV . <b>New error</b>	<i>Signal: A new error message has been issued.</i>
SSV . <b>New warning</b>	<i>Signal: A new warning message has been issued.</i>
Syslog . <b>active</b>	<i>Signal: active</i>

<b>1..n, Assignment List</b>	<b>Description</b>
Sys . <b>Smart view via USB</b>	<i>Information whether or not the Smart view access via the USB interface is activated (allowed).</i>
Sys . <b>Smart view via Eth</b>	<i>Information whether or not the Smart view access via the Ethernet interface is activated (allowed).</i>
Scada . <b>SCADA connected</b>	<i>At least one SCADA System is connected to the device.</i>
Scada . <b>SCADA not connected</b>	<i>No SCADA System is connected to the device</i>
DNP3 . <b>busy</b>	<i>This message is set if the protocol is started. It will be reset if the protocol is shut down.</i>
DNP3 . <b>ready</b>	<i>The message will be set if the protocol is successfully started and ready for data exchange.</i>
DNP3 . <b>active</b>	<i>The communication with the Master (SCADA) is active.</i>  <i>Note that for TCP/UDP, this state is permanently "Low" unless »DataLink confirm« is set to "Always".</i>
DNP3 . <b>BinaryOutput0</b>	<i>Virtual Digital Output (DNP). This corresponds to a virtual binary input of the protective device.</i>
DNP3 . <b>BinaryOutput1</b>	<i>Virtual Digital Output (DNP). This corresponds to a virtual binary input of the protective device.</i>
DNP3 . <b>BinaryOutput2</b>	<i>Virtual Digital Output (DNP). This corresponds to a virtual binary input of the protective device.</i>
DNP3 . <b>BinaryOutput3</b>	<i>Virtual Digital Output (DNP). This corresponds to a virtual binary input of the protective device.</i>
DNP3 . <b>BinaryOutput4</b>	<i>Virtual Digital Output (DNP). This corresponds to a virtual binary input of the protective device.</i>
DNP3 . <b>BinaryOutput5</b>	<i>Virtual Digital Output (DNP). This corresponds to a virtual binary input of the protective device.</i>
DNP3 . <b>BinaryOutput6</b>	<i>Virtual Digital Output (DNP). This corresponds to a virtual binary input of the protective device.</i>
DNP3 . <b>BinaryOutput7</b>	<i>Virtual Digital Output (DNP). This corresponds to a virtual binary input of the protective device.</i>
DNP3 . <b>BinaryOutput8</b>	<i>Virtual Digital Output (DNP). This corresponds to a virtual binary input of the protective device.</i>
DNP3 . <b>BinaryOutput9</b>	<i>Virtual Digital Output (DNP). This corresponds to a virtual binary input of the protective device.</i>
DNP3 . <b>BinaryOutput10</b>	<i>Virtual Digital Output (DNP). This corresponds to a virtual binary input of the protective device.</i>
DNP3 . <b>BinaryOutput11</b>	<i>Virtual Digital Output (DNP). This corresponds to a virtual binary input of the protective device.</i>

<b>1..n, Assignment List</b>	<b>Description</b>
DNP3 . <b>BinaryOutput12</b>	<i>Virtual Digital Output (DNP). This corresponds to a virtual binary input of the protective device.</i>
DNP3 . <b>BinaryOutput13</b>	<i>Virtual Digital Output (DNP). This corresponds to a virtual binary input of the protective device.</i>
DNP3 . <b>BinaryOutput14</b>	<i>Virtual Digital Output (DNP). This corresponds to a virtual binary input of the protective device.</i>
DNP3 . <b>BinaryOutput15</b>	<i>Virtual Digital Output (DNP). This corresponds to a virtual binary input of the protective device.</i>
DNP3 . <b>BinaryOutput16</b>	<i>Virtual Digital Output (DNP). This corresponds to a virtual binary input of the protective device.</i>
DNP3 . <b>BinaryOutput17</b>	<i>Virtual Digital Output (DNP). This corresponds to a virtual binary input of the protective device.</i>
DNP3 . <b>BinaryOutput18</b>	<i>Virtual Digital Output (DNP). This corresponds to a virtual binary input of the protective device.</i>
DNP3 . <b>BinaryOutput19</b>	<i>Virtual Digital Output (DNP). This corresponds to a virtual binary input of the protective device.</i>
DNP3 . <b>BinaryOutput20</b>	<i>Virtual Digital Output (DNP). This corresponds to a virtual binary input of the protective device.</i>
DNP3 . <b>BinaryOutput21</b>	<i>Virtual Digital Output (DNP). This corresponds to a virtual binary input of the protective device.</i>
DNP3 . <b>BinaryOutput22</b>	<i>Virtual Digital Output (DNP). This corresponds to a virtual binary input of the protective device.</i>
DNP3 . <b>BinaryOutput23</b>	<i>Virtual Digital Output (DNP). This corresponds to a virtual binary input of the protective device.</i>
DNP3 . <b>BinaryOutput24</b>	<i>Virtual Digital Output (DNP). This corresponds to a virtual binary input of the protective device.</i>
DNP3 . <b>BinaryOutput25</b>	<i>Virtual Digital Output (DNP). This corresponds to a virtual binary input of the protective device.</i>
DNP3 . <b>BinaryOutput26</b>	<i>Virtual Digital Output (DNP). This corresponds to a virtual binary input of the protective device.</i>
DNP3 . <b>BinaryOutput27</b>	<i>Virtual Digital Output (DNP). This corresponds to a virtual binary input of the protective device.</i>
DNP3 . <b>BinaryOutput28</b>	<i>Virtual Digital Output (DNP). This corresponds to a virtual binary input of the protective device.</i>
DNP3 . <b>BinaryOutput29</b>	<i>Virtual Digital Output (DNP). This corresponds to a virtual binary input of the protective device.</i>
DNP3 . <b>BinaryOutput30</b>	<i>Virtual Digital Output (DNP). This corresponds to a virtual binary input of the protective device.</i>
DNP3 . <b>BinaryOutput31</b>	<i>Virtual Digital Output (DNP). This corresponds to a virtual binary input of the protective device.</i>

<b>1..n, Assignment List</b>	<b>Description</b>
DNP3 . <b>BinaryInput0-I</b>	<i>Virtual Digital Input (DNP). This corresponds to a virtual binary output of the protective device.</i>
DNP3 . <b>BinaryInput1-I</b>	<i>Virtual Digital Input (DNP). This corresponds to a virtual binary output of the protective device.</i>
DNP3 . <b>BinaryInput2-I</b>	<i>Virtual Digital Input (DNP). This corresponds to a virtual binary output of the protective device.</i>
DNP3 . <b>BinaryInput3-I</b>	<i>Virtual Digital Input (DNP). This corresponds to a virtual binary output of the protective device.</i>
DNP3 . <b>BinaryInput4-I</b>	<i>Virtual Digital Input (DNP). This corresponds to a virtual binary output of the protective device.</i>
DNP3 . <b>BinaryInput5-I</b>	<i>Virtual Digital Input (DNP). This corresponds to a virtual binary output of the protective device.</i>
DNP3 . <b>BinaryInput6-I</b>	<i>Virtual Digital Input (DNP). This corresponds to a virtual binary output of the protective device.</i>
DNP3 . <b>BinaryInput7-I</b>	<i>Virtual Digital Input (DNP). This corresponds to a virtual binary output of the protective device.</i>
DNP3 . <b>BinaryInput8-I</b>	<i>Virtual Digital Input (DNP). This corresponds to a virtual binary output of the protective device.</i>
DNP3 . <b>BinaryInput9-I</b>	<i>Virtual Digital Input (DNP). This corresponds to a virtual binary output of the protective device.</i>
DNP3 . <b>BinaryInput10-I</b>	<i>Virtual Digital Input (DNP). This corresponds to a virtual binary output of the protective device.</i>
DNP3 . <b>BinaryInput11-I</b>	<i>Virtual Digital Input (DNP). This corresponds to a virtual binary output of the protective device.</i>
DNP3 . <b>BinaryInput12-I</b>	<i>Virtual Digital Input (DNP). This corresponds to a virtual binary output of the protective device.</i>
DNP3 . <b>BinaryInput13-I</b>	<i>Virtual Digital Input (DNP). This corresponds to a virtual binary output of the protective device.</i>
DNP3 . <b>BinaryInput14-I</b>	<i>Virtual Digital Input (DNP). This corresponds to a virtual binary output of the protective device.</i>
DNP3 . <b>BinaryInput15-I</b>	<i>Virtual Digital Input (DNP). This corresponds to a virtual binary output of the protective device.</i>
DNP3 . <b>BinaryInput16-I</b>	<i>Virtual Digital Input (DNP). This corresponds to a virtual binary output of the protective device.</i>
DNP3 . <b>BinaryInput17-I</b>	<i>Virtual Digital Input (DNP). This corresponds to a virtual binary output of the protective device.</i>
DNP3 . <b>BinaryInput18-I</b>	<i>Virtual Digital Input (DNP). This corresponds to a virtual binary output of the protective device.</i>
DNP3 . <b>BinaryInput19-I</b>	<i>Virtual Digital Input (DNP). This corresponds to a virtual binary output of the protective device.</i>

<b>1..n, Assignment List</b>	<b>Description</b>
DNP3 . <b>BinaryInput20-I</b>	<i>Virtual Digital Input (DNP). This corresponds to a virtual binary output of the protective device.</i>
DNP3 . <b>BinaryInput21-I</b>	<i>Virtual Digital Input (DNP). This corresponds to a virtual binary output of the protective device.</i>
DNP3 . <b>BinaryInput22-I</b>	<i>Virtual Digital Input (DNP). This corresponds to a virtual binary output of the protective device.</i>
DNP3 . <b>BinaryInput23-I</b>	<i>Virtual Digital Input (DNP). This corresponds to a virtual binary output of the protective device.</i>
DNP3 . <b>BinaryInput24-I</b>	<i>Virtual Digital Input (DNP). This corresponds to a virtual binary output of the protective device.</i>
DNP3 . <b>BinaryInput25-I</b>	<i>Virtual Digital Input (DNP). This corresponds to a virtual binary output of the protective device.</i>
DNP3 . <b>BinaryInput26-I</b>	<i>Virtual Digital Input (DNP). This corresponds to a virtual binary output of the protective device.</i>
DNP3 . <b>BinaryInput27-I</b>	<i>Virtual Digital Input (DNP). This corresponds to a virtual binary output of the protective device.</i>
DNP3 . <b>BinaryInput28-I</b>	<i>Virtual Digital Input (DNP). This corresponds to a virtual binary output of the protective device.</i>
DNP3 . <b>BinaryInput29-I</b>	<i>Virtual Digital Input (DNP). This corresponds to a virtual binary output of the protective device.</i>
DNP3 . <b>BinaryInput30-I</b>	<i>Virtual Digital Input (DNP). This corresponds to a virtual binary output of the protective device.</i>
DNP3 . <b>BinaryInput31-I</b>	<i>Virtual Digital Input (DNP). This corresponds to a virtual binary output of the protective device.</i>
DNP3 . <b>BinaryInput32-I</b>	<i>Virtual Digital Input (DNP). This corresponds to a virtual binary output of the protective device.</i>
DNP3 . <b>BinaryInput33-I</b>	<i>Virtual Digital Input (DNP). This corresponds to a virtual binary output of the protective device.</i>
DNP3 . <b>BinaryInput34-I</b>	<i>Virtual Digital Input (DNP). This corresponds to a virtual binary output of the protective device.</i>
DNP3 . <b>BinaryInput35-I</b>	<i>Virtual Digital Input (DNP). This corresponds to a virtual binary output of the protective device.</i>
DNP3 . <b>BinaryInput36-I</b>	<i>Virtual Digital Input (DNP). This corresponds to a virtual binary output of the protective device.</i>
DNP3 . <b>BinaryInput37-I</b>	<i>Virtual Digital Input (DNP). This corresponds to a virtual binary output of the protective device.</i>
DNP3 . <b>BinaryInput38-I</b>	<i>Virtual Digital Input (DNP). This corresponds to a virtual binary output of the protective device.</i>
DNP3 . <b>BinaryInput39-I</b>	<i>Virtual Digital Input (DNP). This corresponds to a virtual binary output of the protective device.</i>

<b>1..n, Assignment List</b>	<b>Description</b>
DNP3 . <b>BinaryInput40-I</b>	<i>Virtual Digital Input (DNP). This corresponds to a virtual binary output of the protective device.</i>
DNP3 . <b>BinaryInput41-I</b>	<i>Virtual Digital Input (DNP). This corresponds to a virtual binary output of the protective device.</i>
DNP3 . <b>BinaryInput42-I</b>	<i>Virtual Digital Input (DNP). This corresponds to a virtual binary output of the protective device.</i>
DNP3 . <b>BinaryInput43-I</b>	<i>Virtual Digital Input (DNP). This corresponds to a virtual binary output of the protective device.</i>
DNP3 . <b>BinaryInput44-I</b>	<i>Virtual Digital Input (DNP). This corresponds to a virtual binary output of the protective device.</i>
DNP3 . <b>BinaryInput45-I</b>	<i>Virtual Digital Input (DNP). This corresponds to a virtual binary output of the protective device.</i>
DNP3 . <b>BinaryInput46-I</b>	<i>Virtual Digital Input (DNP). This corresponds to a virtual binary output of the protective device.</i>
DNP3 . <b>BinaryInput47-I</b>	<i>Virtual Digital Input (DNP). This corresponds to a virtual binary output of the protective device.</i>
DNP3 . <b>BinaryInput48-I</b>	<i>Virtual Digital Input (DNP). This corresponds to a virtual binary output of the protective device.</i>
DNP3 . <b>BinaryInput49-I</b>	<i>Virtual Digital Input (DNP). This corresponds to a virtual binary output of the protective device.</i>
DNP3 . <b>BinaryInput50-I</b>	<i>Virtual Digital Input (DNP). This corresponds to a virtual binary output of the protective device.</i>
DNP3 . <b>BinaryInput51-I</b>	<i>Virtual Digital Input (DNP). This corresponds to a virtual binary output of the protective device.</i>
DNP3 . <b>BinaryInput52-I</b>	<i>Virtual Digital Input (DNP). This corresponds to a virtual binary output of the protective device.</i>
DNP3 . <b>BinaryInput53-I</b>	<i>Virtual Digital Input (DNP). This corresponds to a virtual binary output of the protective device.</i>
DNP3 . <b>BinaryInput54-I</b>	<i>Virtual Digital Input (DNP). This corresponds to a virtual binary output of the protective device.</i>
DNP3 . <b>BinaryInput55-I</b>	<i>Virtual Digital Input (DNP). This corresponds to a virtual binary output of the protective device.</i>
DNP3 . <b>BinaryInput56-I</b>	<i>Virtual Digital Input (DNP). This corresponds to a virtual binary output of the protective device.</i>
DNP3 . <b>BinaryInput57-I</b>	<i>Virtual Digital Input (DNP). This corresponds to a virtual binary output of the protective device.</i>
DNP3 . <b>BinaryInput58-I</b>	<i>Virtual Digital Input (DNP). This corresponds to a virtual binary output of the protective device.</i>
DNP3 . <b>BinaryInput59-I</b>	<i>Virtual Digital Input (DNP). This corresponds to a virtual binary output of the protective device.</i>

<b>1..n, Assignment List</b>	<b>Description</b>
DNP3 . <b>BinaryInput60-I</b>	<i>Virtual Digital Input (DNP). This corresponds to a virtual binary output of the protective device.</i>
DNP3 . <b>BinaryInput61-I</b>	<i>Virtual Digital Input (DNP). This corresponds to a virtual binary output of the protective device.</i>
DNP3 . <b>BinaryInput62-I</b>	<i>Virtual Digital Input (DNP). This corresponds to a virtual binary output of the protective device.</i>
DNP3 . <b>BinaryInput63-I</b>	<i>Virtual Digital Input (DNP). This corresponds to a virtual binary output of the protective device.</i>
Modbus . <b>Transmission RTU</b>	<i>Signal: SCADA active</i>
Modbus . <b>Transmission TCP</b>	<i>Signal: SCADA active</i>
Modbus . <b>Scada Cmd 1</b>	<i>Scada Command</i>
Modbus . <b>Scada Cmd 2</b>	<i>Scada Command</i>
Modbus . <b>Scada Cmd 3</b>	<i>Scada Command</i>
Modbus . <b>Scada Cmd 4</b>	<i>Scada Command</i>
Modbus . <b>Scada Cmd 5</b>	<i>Scada Command</i>
Modbus . <b>Scada Cmd 6</b>	<i>Scada Command</i>
Modbus . <b>Scada Cmd 7</b>	<i>Scada Command</i>
Modbus . <b>Scada Cmd 8</b>	<i>Scada Command</i>
Modbus . <b>Scada Cmd 9</b>	<i>Scada Command</i>
Modbus . <b>Scada Cmd 10</b>	<i>Scada Command</i>
Modbus . <b>Scada Cmd 11</b>	<i>Scada Command</i>
Modbus . <b>Scada Cmd 12</b>	<i>Scada Command</i>
Modbus . <b>Scada Cmd 13</b>	<i>Scada Command</i>
Modbus . <b>Scada Cmd 14</b>	<i>Scada Command</i>
Modbus . <b>Scada Cmd 15</b>	<i>Scada Command</i>
Modbus . <b>Scada Cmd 16</b>	<i>Scada Command</i>
Modbus . <b>Config Bin Inp1-I</b>	<i>State of the module input: Config Bin Inp</i>
Modbus . <b>Config Bin Inp2-I</b>	<i>State of the module input: Config Bin Inp</i>
Modbus . <b>Config Bin Inp3-I</b>	<i>State of the module input: Config Bin Inp</i>
Modbus . <b>Config Bin Inp4-I</b>	<i>State of the module input: Config Bin Inp</i>



<b>1..n, Assignment List</b>	<b>Description</b>
Modbus . <b>Config Bin Inp5-I</b>	<i>State of the module input: Config Bin Inp</i>
Modbus . <b>Config Bin Inp6-I</b>	<i>State of the module input: Config Bin Inp</i>
Modbus . <b>Config Bin Inp7-I</b>	<i>State of the module input: Config Bin Inp</i>
Modbus . <b>Config Bin Inp8-I</b>	<i>State of the module input: Config Bin Inp</i>
Modbus . <b>Config Bin Inp9-I</b>	<i>State of the module input: Config Bin Inp</i>
Modbus . <b>Config Bin Inp10-I</b>	<i>State of the module input: Config Bin Inp</i>
Modbus . <b>Config Bin Inp11-I</b>	<i>State of the module input: Config Bin Inp</i>
Modbus . <b>Config Bin Inp12-I</b>	<i>State of the module input: Config Bin Inp</i>
Modbus . <b>Config Bin Inp13-I</b>	<i>State of the module input: Config Bin Inp</i>
Modbus . <b>Config Bin Inp14-I</b>	<i>State of the module input: Config Bin Inp</i>
Modbus . <b>Config Bin Inp15-I</b>	<i>State of the module input: Config Bin Inp</i>
Modbus . <b>Config Bin Inp16-I</b>	<i>State of the module input: Config Bin Inp</i>
Modbus . <b>Config Bin Inp17-I</b>	<i>State of the module input: Config Bin Inp</i>
Modbus . <b>Config Bin Inp18-I</b>	<i>State of the module input: Config Bin Inp</i>
Modbus . <b>Config Bin Inp19-I</b>	<i>State of the module input: Config Bin Inp</i>
Modbus . <b>Config Bin Inp20-I</b>	<i>State of the module input: Config Bin Inp</i>
Modbus . <b>Config Bin Inp21-I</b>	<i>State of the module input: Config Bin Inp</i>
Modbus . <b>Config Bin Inp22-I</b>	<i>State of the module input: Config Bin Inp</i>
Modbus . <b>Config Bin Inp23-I</b>	<i>State of the module input: Config Bin Inp</i>
Modbus . <b>Config Bin Inp24-I</b>	<i>State of the module input: Config Bin Inp</i>

<b>1..n, Assignment List</b>	<b>Description</b>
Modbus . <b>Config Bin Inp25-I</b>	<i>State of the module input: Config Bin Inp</i>
Modbus . <b>Config Bin Inp26-I</b>	<i>State of the module input: Config Bin Inp</i>
Modbus . <b>Config Bin Inp27-I</b>	<i>State of the module input: Config Bin Inp</i>
Modbus . <b>Config Bin Inp28-I</b>	<i>State of the module input: Config Bin Inp</i>
Modbus . <b>Config Bin Inp29-I</b>	<i>State of the module input: Config Bin Inp</i>
Modbus . <b>Config Bin Inp30-I</b>	<i>State of the module input: Config Bin Inp</i>
Modbus . <b>Config Bin Inp31-I</b>	<i>State of the module input: Config Bin Inp</i>
Modbus . <b>Config Bin Inp32-I</b>	<i>State of the module input: Config Bin Inp</i>
IEC 61850 . <b>MMS Client connected</b>	<i>At least one MMS client is connected to the device</i>
IEC 61850 . <b>All Goose Subscriber active</b>	<i>All Goose subscriber in the device are working</i>
IEC 61850 . <b>GOSINGGIO1.Ind1.stVal</b>	<i>Signal: Virtual Input (IEC61850 GGIO Ind): State</i>
IEC 61850 . <b>GOSINGGIO1.Ind2.stVal</b>	<i>Signal: Virtual Input (IEC61850 GGIO Ind): State</i>
IEC 61850 . <b>GOSINGGIO1.Ind3.stVal</b>	<i>Signal: Virtual Input (IEC61850 GGIO Ind): State</i>
IEC 61850 . <b>GOSINGGIO1.Ind4.stVal</b>	<i>Signal: Virtual Input (IEC61850 GGIO Ind): State</i>
IEC 61850 . <b>GOSINGGIO1.Ind5.stVal</b>	<i>Signal: Virtual Input (IEC61850 GGIO Ind): State</i>
IEC 61850 . <b>GOSINGGIO1.Ind6.stVal</b>	<i>Signal: Virtual Input (IEC61850 GGIO Ind): State</i>
IEC 61850 . <b>GOSINGGIO1.Ind7.stVal</b>	<i>Signal: Virtual Input (IEC61850 GGIO Ind): State</i>
IEC 61850 . <b>GOSINGGIO1.Ind8.stVal</b>	<i>Signal: Virtual Input (IEC61850 GGIO Ind): State</i>
IEC 61850 . <b>GOSINGGIO1.Ind9.stVal</b>	<i>Signal: Virtual Input (IEC61850 GGIO Ind): State</i>
IEC 61850 . <b>GOSINGGIO1.Ind10.stVal</b>	<i>Signal: Virtual Input (IEC61850 GGIO Ind): State</i>

<b>1..n, Assignment List</b>	<b>Description</b>
IEC 61850 . <b>GOSINGGIO1.Ind11.stVal</b>	<i>Signal: Virtual Input (IEC61850 GGIO Ind): State</i>
IEC 61850 . <b>GOSINGGIO1.Ind12.stVal</b>	<i>Signal: Virtual Input (IEC61850 GGIO Ind): State</i>
IEC 61850 . <b>GOSINGGIO1.Ind13.stVal</b>	<i>Signal: Virtual Input (IEC61850 GGIO Ind): State</i>
IEC 61850 . <b>GOSINGGIO1.Ind14.stVal</b>	<i>Signal: Virtual Input (IEC61850 GGIO Ind): State</i>
IEC 61850 . <b>GOSINGGIO1.Ind15.stVal</b>	<i>Signal: Virtual Input (IEC61850 GGIO Ind): State</i>
IEC 61850 . <b>GOSINGGIO1.Ind16.stVal</b>	<i>Signal: Virtual Input (IEC61850 GGIO Ind): State</i>
IEC 61850 . <b>GOSINGGIO1.Ind17.stVal</b>	<i>Signal: Virtual Input (IEC61850 GGIO Ind): State</i>
IEC 61850 . <b>GOSINGGIO1.Ind18.stVal</b>	<i>Signal: Virtual Input (IEC61850 GGIO Ind): State</i>
IEC 61850 . <b>GOSINGGIO1.Ind19.stVal</b>	<i>Signal: Virtual Input (IEC61850 GGIO Ind): State</i>
IEC 61850 . <b>GOSINGGIO1.Ind20.stVal</b>	<i>Signal: Virtual Input (IEC61850 GGIO Ind): State</i>
IEC 61850 . <b>GOSINGGIO1.Ind21.stVal</b>	<i>Signal: Virtual Input (IEC61850 GGIO Ind): State</i>
IEC 61850 . <b>GOSINGGIO1.Ind22.stVal</b>	<i>Signal: Virtual Input (IEC61850 GGIO Ind): State</i>
IEC 61850 . <b>GOSINGGIO1.Ind23.stVal</b>	<i>Signal: Virtual Input (IEC61850 GGIO Ind): State</i>
IEC 61850 . <b>GOSINGGIO1.Ind24.stVal</b>	<i>Signal: Virtual Input (IEC61850 GGIO Ind): State</i>
IEC 61850 . <b>GOSINGGIO1.Ind25.stVal</b>	<i>Signal: Virtual Input (IEC61850 GGIO Ind): State</i>
IEC 61850 . <b>GOSINGGIO1.Ind26.stVal</b>	<i>Signal: Virtual Input (IEC61850 GGIO Ind): State</i>
IEC 61850 . <b>GOSINGGIO1.Ind27.stVal</b>	<i>Signal: Virtual Input (IEC61850 GGIO Ind): State</i>
IEC 61850 . <b>GOSINGGIO1.Ind28.stVal</b>	<i>Signal: Virtual Input (IEC61850 GGIO Ind): State</i>
IEC 61850 . <b>GOSINGGIO1.Ind29.stVal</b>	<i>Signal: Virtual Input (IEC61850 GGIO Ind): State</i>
IEC 61850 . <b>GOSINGGIO1.Ind30.stVal</b>	<i>Signal: Virtual Input (IEC61850 GGIO Ind): State</i>

<b>1..n, Assignment List</b>	<b>Description</b>
IEC 61850 . <b>GOSINGGIO1.Ind31.stVal</b>	<i>Signal: Virtual Input (IEC61850 GGIO Ind): State</i>
IEC 61850 . <b>GOSINGGIO1.Ind32.stVal</b>	<i>Signal: Virtual Input (IEC61850 GGIO Ind): State</i>
IEC 61850 . <b>GOSINGGIO2.Ind1.stVal</b>	<i>Signal: Virtual Input (IEC61850 GGIO Ind): State</i>
IEC 61850 . <b>GOSINGGIO2.Ind2.stVal</b>	<i>Signal: Virtual Input (IEC61850 GGIO Ind): State</i>
IEC 61850 . <b>GOSINGGIO2.Ind3.stVal</b>	<i>Signal: Virtual Input (IEC61850 GGIO Ind): State</i>
IEC 61850 . <b>GOSINGGIO2.Ind4.stVal</b>	<i>Signal: Virtual Input (IEC61850 GGIO Ind): State</i>
IEC 61850 . <b>GOSINGGIO2.Ind5.stVal</b>	<i>Signal: Virtual Input (IEC61850 GGIO Ind): State</i>
IEC 61850 . <b>GOSINGGIO2.Ind6.stVal</b>	<i>Signal: Virtual Input (IEC61850 GGIO Ind): State</i>
IEC 61850 . <b>GOSINGGIO2.Ind7.stVal</b>	<i>Signal: Virtual Input (IEC61850 GGIO Ind): State</i>
IEC 61850 . <b>GOSINGGIO2.Ind8.stVal</b>	<i>Signal: Virtual Input (IEC61850 GGIO Ind): State</i>
IEC 61850 . <b>GOSINGGIO2.Ind9.stVal</b>	<i>Signal: Virtual Input (IEC61850 GGIO Ind): State</i>
IEC 61850 . <b>GOSINGGIO2.Ind10.stVal</b>	<i>Signal: Virtual Input (IEC61850 GGIO Ind): State</i>
IEC 61850 . <b>GOSINGGIO2.Ind11.stVal</b>	<i>Signal: Virtual Input (IEC61850 GGIO Ind): State</i>
IEC 61850 . <b>GOSINGGIO2.Ind12.stVal</b>	<i>Signal: Virtual Input (IEC61850 GGIO Ind): State</i>
IEC 61850 . <b>GOSINGGIO2.Ind13.stVal</b>	<i>Signal: Virtual Input (IEC61850 GGIO Ind): State</i>
IEC 61850 . <b>GOSINGGIO2.Ind14.stVal</b>	<i>Signal: Virtual Input (IEC61850 GGIO Ind): State</i>
IEC 61850 . <b>GOSINGGIO2.Ind15.stVal</b>	<i>Signal: Virtual Input (IEC61850 GGIO Ind): State</i>
IEC 61850 . <b>GOSINGGIO2.Ind16.stVal</b>	<i>Signal: Virtual Input (IEC61850 GGIO Ind): State</i>
IEC 61850 . <b>GOSINGGIO2.Ind17.stVal</b>	<i>Signal: Virtual Input (IEC61850 GGIO Ind): State</i>
IEC 61850 . <b>GOSINGGIO2.Ind18.stVal</b>	<i>Signal: Virtual Input (IEC61850 GGIO Ind): State</i>

<b>1..n, Assignment List</b>	<b>Description</b>
IEC 61850 . <b>GOSINGGIO2.Ind19.stVal</b>	<i>Signal: Virtual Input (IEC61850 GGIO Ind): State</i>
IEC 61850 . <b>GOSINGGIO2.Ind20.stVal</b>	<i>Signal: Virtual Input (IEC61850 GGIO Ind): State</i>
IEC 61850 . <b>GOSINGGIO2.Ind21.stVal</b>	<i>Signal: Virtual Input (IEC61850 GGIO Ind): State</i>
IEC 61850 . <b>GOSINGGIO2.Ind22.stVal</b>	<i>Signal: Virtual Input (IEC61850 GGIO Ind): State</i>
IEC 61850 . <b>GOSINGGIO2.Ind23.stVal</b>	<i>Signal: Virtual Input (IEC61850 GGIO Ind): State</i>
IEC 61850 . <b>GOSINGGIO2.Ind24.stVal</b>	<i>Signal: Virtual Input (IEC61850 GGIO Ind): State</i>
IEC 61850 . <b>GOSINGGIO2.Ind25.stVal</b>	<i>Signal: Virtual Input (IEC61850 GGIO Ind): State</i>
IEC 61850 . <b>GOSINGGIO2.Ind26.stVal</b>	<i>Signal: Virtual Input (IEC61850 GGIO Ind): State</i>
IEC 61850 . <b>GOSINGGIO2.Ind27.stVal</b>	<i>Signal: Virtual Input (IEC61850 GGIO Ind): State</i>
IEC 61850 . <b>GOSINGGIO2.Ind28.stVal</b>	<i>Signal: Virtual Input (IEC61850 GGIO Ind): State</i>
IEC 61850 . <b>GOSINGGIO2.Ind29.stVal</b>	<i>Signal: Virtual Input (IEC61850 GGIO Ind): State</i>
IEC 61850 . <b>GOSINGGIO2.Ind30.stVal</b>	<i>Signal: Virtual Input (IEC61850 GGIO Ind): State</i>
IEC 61850 . <b>GOSINGGIO2.Ind31.stVal</b>	<i>Signal: Virtual Input (IEC61850 GGIO Ind): State</i>
IEC 61850 . <b>GOSINGGIO2.Ind32.stVal</b>	<i>Signal: Virtual Input (IEC61850 GGIO Ind): State</i>
IEC 61850 . <b>GOSINGGIO1.Ind1.q</b>	<i>Signal: Virtual Input (IEC61850 GGIO Ind): Self-Supervision of the GGIO Input</i>
IEC 61850 . <b>GOSINGGIO1.Ind2.q</b>	<i>Signal: Virtual Input (IEC61850 GGIO Ind): Self-Supervision of the GGIO Input</i>
IEC 61850 . <b>GOSINGGIO1.Ind3.q</b>	<i>Signal: Virtual Input (IEC61850 GGIO Ind): Self-Supervision of the GGIO Input</i>
IEC 61850 . <b>GOSINGGIO1.Ind4.q</b>	<i>Signal: Virtual Input (IEC61850 GGIO Ind): Self-Supervision of the GGIO Input</i>
IEC 61850 . <b>GOSINGGIO1.Ind5.q</b>	<i>Signal: Virtual Input (IEC61850 GGIO Ind): Self-Supervision of the GGIO Input</i>
IEC 61850 . <b>GOSINGGIO1.Ind6.q</b>	<i>Signal: Virtual Input (IEC61850 GGIO Ind): Self-Supervision of the GGIO Input</i>

<b>1..n, Assignment List</b>	<b>Description</b>
IEC 61850 . <b>GOSINGGIO1.Ind7.q</b>	<i>Signal: Virtual Input (IEC61850 GGIO Ind): Self-Supervision of the GGIO Input</i>
IEC 61850 . <b>GOSINGGIO1.Ind8.q</b>	<i>Signal: Virtual Input (IEC61850 GGIO Ind): Self-Supervision of the GGIO Input</i>
IEC 61850 . <b>GOSINGGIO1.Ind9.q</b>	<i>Signal: Virtual Input (IEC61850 GGIO Ind): Self-Supervision of the GGIO Input</i>
IEC 61850 . <b>GOSINGGIO1.Ind10.q</b>	<i>Signal: Virtual Input (IEC61850 GGIO Ind): Self-Supervision of the GGIO Input</i>
IEC 61850 . <b>GOSINGGIO1.Ind11.q</b>	<i>Signal: Virtual Input (IEC61850 GGIO Ind): Self-Supervision of the GGIO Input</i>
IEC 61850 . <b>GOSINGGIO1.Ind12.q</b>	<i>Signal: Virtual Input (IEC61850 GGIO Ind): Self-Supervision of the GGIO Input</i>
IEC 61850 . <b>GOSINGGIO1.Ind13.q</b>	<i>Signal: Virtual Input (IEC61850 GGIO Ind): Self-Supervision of the GGIO Input</i>
IEC 61850 . <b>GOSINGGIO1.Ind14.q</b>	<i>Signal: Virtual Input (IEC61850 GGIO Ind): Self-Supervision of the GGIO Input</i>
IEC 61850 . <b>GOSINGGIO1.Ind15.q</b>	<i>Signal: Virtual Input (IEC61850 GGIO Ind): Self-Supervision of the GGIO Input</i>
IEC 61850 . <b>GOSINGGIO1.Ind16.q</b>	<i>Signal: Virtual Input (IEC61850 GGIO Ind): Self-Supervision of the GGIO Input</i>
IEC 61850 . <b>GOSINGGIO1.Ind17.q</b>	<i>Signal: Virtual Input (IEC61850 GGIO Ind): Self-Supervision of the GGIO Input</i>
IEC 61850 . <b>GOSINGGIO1.Ind18.q</b>	<i>Signal: Virtual Input (IEC61850 GGIO Ind): Self-Supervision of the GGIO Input</i>
IEC 61850 . <b>GOSINGGIO1.Ind19.q</b>	<i>Signal: Virtual Input (IEC61850 GGIO Ind): Self-Supervision of the GGIO Input</i>
IEC 61850 . <b>GOSINGGIO1.Ind20.q</b>	<i>Signal: Virtual Input (IEC61850 GGIO Ind): Self-Supervision of the GGIO Input</i>
IEC 61850 . <b>GOSINGGIO1.Ind21.q</b>	<i>Signal: Virtual Input (IEC61850 GGIO Ind): Self-Supervision of the GGIO Input</i>
IEC 61850 . <b>GOSINGGIO1.Ind22.q</b>	<i>Signal: Virtual Input (IEC61850 GGIO Ind): Self-Supervision of the GGIO Input</i>
IEC 61850 . <b>GOSINGGIO1.Ind23.q</b>	<i>Signal: Virtual Input (IEC61850 GGIO Ind): Self-Supervision of the GGIO Input</i>
IEC 61850 . <b>GOSINGGIO1.Ind24.q</b>	<i>Signal: Virtual Input (IEC61850 GGIO Ind): Self-Supervision of the GGIO Input</i>
IEC 61850 . <b>GOSINGGIO1.Ind25.q</b>	<i>Signal: Virtual Input (IEC61850 GGIO Ind): Self-Supervision of the GGIO Input</i>
IEC 61850 . <b>GOSINGGIO1.Ind26.q</b>	<i>Signal: Virtual Input (IEC61850 GGIO Ind): Self-Supervision of the GGIO Input</i>

<b>1..n, Assignment List</b>	<b>Description</b>
IEC 61850 . <b>GOSINGGIO1.Ind27.q</b>	<i>Signal: Virtual Input (IEC61850 GGIO Ind): Self-Supervision of the GGIO Input</i>
IEC 61850 . <b>GOSINGGIO1.Ind28.q</b>	<i>Signal: Virtual Input (IEC61850 GGIO Ind): Self-Supervision of the GGIO Input</i>
IEC 61850 . <b>GOSINGGIO1.Ind29.q</b>	<i>Signal: Virtual Input (IEC61850 GGIO Ind): Self-Supervision of the GGIO Input</i>
IEC 61850 . <b>GOSINGGIO1.Ind30.q</b>	<i>Signal: Virtual Input (IEC61850 GGIO Ind): Self-Supervision of the GGIO Input</i>
IEC 61850 . <b>GOSINGGIO1.Ind31.q</b>	<i>Signal: Virtual Input (IEC61850 GGIO Ind): Self-Supervision of the GGIO Input</i>
IEC 61850 . <b>GOSINGGIO1.Ind32.q</b>	<i>Signal: Virtual Input (IEC61850 GGIO Ind): Self-Supervision of the GGIO Input</i>
IEC 61850 . <b>GOSINGGIO2.Ind1.q</b>	<i>Signal: Virtual Input (IEC61850 GGIO Ind): Self-Supervision of the GGIO Input</i>
IEC 61850 . <b>GOSINGGIO2.Ind2.q</b>	<i>Signal: Virtual Input (IEC61850 GGIO Ind): Self-Supervision of the GGIO Input</i>
IEC 61850 . <b>GOSINGGIO2.Ind3.q</b>	<i>Signal: Virtual Input (IEC61850 GGIO Ind): Self-Supervision of the GGIO Input</i>
IEC 61850 . <b>GOSINGGIO2.Ind4.q</b>	<i>Signal: Virtual Input (IEC61850 GGIO Ind): Self-Supervision of the GGIO Input</i>
IEC 61850 . <b>GOSINGGIO2.Ind5.q</b>	<i>Signal: Virtual Input (IEC61850 GGIO Ind): Self-Supervision of the GGIO Input</i>
IEC 61850 . <b>GOSINGGIO2.Ind6.q</b>	<i>Signal: Virtual Input (IEC61850 GGIO Ind): Self-Supervision of the GGIO Input</i>
IEC 61850 . <b>GOSINGGIO2.Ind7.q</b>	<i>Signal: Virtual Input (IEC61850 GGIO Ind): Self-Supervision of the GGIO Input</i>
IEC 61850 . <b>GOSINGGIO2.Ind8.q</b>	<i>Signal: Virtual Input (IEC61850 GGIO Ind): Self-Supervision of the GGIO Input</i>
IEC 61850 . <b>GOSINGGIO2.Ind9.q</b>	<i>Signal: Virtual Input (IEC61850 GGIO Ind): Self-Supervision of the GGIO Input</i>
IEC 61850 . <b>GOSINGGIO2.Ind10.q</b>	<i>Signal: Virtual Input (IEC61850 GGIO Ind): Self-Supervision of the GGIO Input</i>
IEC 61850 . <b>GOSINGGIO2.Ind11.q</b>	<i>Signal: Virtual Input (IEC61850 GGIO Ind): Self-Supervision of the GGIO Input</i>
IEC 61850 . <b>GOSINGGIO2.Ind12.q</b>	<i>Signal: Virtual Input (IEC61850 GGIO Ind): Self-Supervision of the GGIO Input</i>
IEC 61850 . <b>GOSINGGIO2.Ind13.q</b>	<i>Signal: Virtual Input (IEC61850 GGIO Ind): Self-Supervision of the GGIO Input</i>
IEC 61850 . <b>GOSINGGIO2.Ind14.q</b>	<i>Signal: Virtual Input (IEC61850 GGIO Ind): Self-Supervision of the GGIO Input</i>

<b>1..n, Assignment List</b>	<b>Description</b>
IEC 61850 . <b>GOSINGGIO2.Ind15.q</b>	<i>Signal: Virtual Input (IEC61850 GGIO Ind): Self-Supervision of the GGIO Input</i>
IEC 61850 . <b>GOSINGGIO2.Ind16.q</b>	<i>Signal: Virtual Input (IEC61850 GGIO Ind): Self-Supervision of the GGIO Input</i>
IEC 61850 . <b>GOSINGGIO2.Ind17.q</b>	<i>Signal: Virtual Input (IEC61850 GGIO Ind): Self-Supervision of the GGIO Input</i>
IEC 61850 . <b>GOSINGGIO2.Ind18.q</b>	<i>Signal: Virtual Input (IEC61850 GGIO Ind): Self-Supervision of the GGIO Input</i>
IEC 61850 . <b>GOSINGGIO2.Ind19.q</b>	<i>Signal: Virtual Input (IEC61850 GGIO Ind): Self-Supervision of the GGIO Input</i>
IEC 61850 . <b>GOSINGGIO2.Ind20.q</b>	<i>Signal: Virtual Input (IEC61850 GGIO Ind): Self-Supervision of the GGIO Input</i>
IEC 61850 . <b>GOSINGGIO2.Ind21.q</b>	<i>Signal: Virtual Input (IEC61850 GGIO Ind): Self-Supervision of the GGIO Input</i>
IEC 61850 . <b>GOSINGGIO2.Ind22.q</b>	<i>Signal: Virtual Input (IEC61850 GGIO Ind): Self-Supervision of the GGIO Input</i>
IEC 61850 . <b>GOSINGGIO2.Ind23.q</b>	<i>Signal: Virtual Input (IEC61850 GGIO Ind): Self-Supervision of the GGIO Input</i>
IEC 61850 . <b>GOSINGGIO2.Ind24.q</b>	<i>Signal: Virtual Input (IEC61850 GGIO Ind): Self-Supervision of the GGIO Input</i>
IEC 61850 . <b>GOSINGGIO2.Ind25.q</b>	<i>Signal: Virtual Input (IEC61850 GGIO Ind): Self-Supervision of the GGIO Input</i>
IEC 61850 . <b>GOSINGGIO2.Ind26.q</b>	<i>Signal: Virtual Input (IEC61850 GGIO Ind): Self-Supervision of the GGIO Input</i>
IEC 61850 . <b>GOSINGGIO2.Ind27.q</b>	<i>Signal: Virtual Input (IEC61850 GGIO Ind): Self-Supervision of the GGIO Input</i>
IEC 61850 . <b>GOSINGGIO2.Ind28.q</b>	<i>Signal: Virtual Input (IEC61850 GGIO Ind): Self-Supervision of the GGIO Input</i>
IEC 61850 . <b>GOSINGGIO2.Ind29.q</b>	<i>Signal: Virtual Input (IEC61850 GGIO Ind): Self-Supervision of the GGIO Input</i>
IEC 61850 . <b>GOSINGGIO2.Ind30.q</b>	<i>Signal: Virtual Input (IEC61850 GGIO Ind): Self-Supervision of the GGIO Input</i>
IEC 61850 . <b>GOSINGGIO2.Ind31.q</b>	<i>Signal: Virtual Input (IEC61850 GGIO Ind): Self-Supervision of the GGIO Input</i>
IEC 61850 . <b>GOSINGGIO2.Ind32.q</b>	<i>Signal: Virtual Input (IEC61850 GGIO Ind): Self-Supervision of the GGIO Input</i>
IEC 61850 . <b>SPCSO1</b>	<i>Status bit that can be set by clients like e.g. SCADA (Single Point Controllable Status Output).</i>
IEC 61850 . <b>SPCSO2</b>	<i>Status bit that can be set by clients like e.g. SCADA (Single Point Controllable Status Output).</i>



<b>1..n, Assignment List</b>	<b>Description</b>
IEC 61850 . <b>SPCSO3</b>	<i>Status bit that can be set by clients like e.g. SCADA (Single Point Controllable Status Output).</i>
IEC 61850 . <b>SPCSO4</b>	<i>Status bit that can be set by clients like e.g. SCADA (Single Point Controllable Status Output).</i>
IEC 61850 . <b>SPCSO5</b>	<i>Status bit that can be set by clients like e.g. SCADA (Single Point Controllable Status Output).</i>
IEC 61850 . <b>SPCSO6</b>	<i>Status bit that can be set by clients like e.g. SCADA (Single Point Controllable Status Output).</i>
IEC 61850 . <b>SPCSO7</b>	<i>Status bit that can be set by clients like e.g. SCADA (Single Point Controllable Status Output).</i>
IEC 61850 . <b>SPCSO8</b>	<i>Status bit that can be set by clients like e.g. SCADA (Single Point Controllable Status Output).</i>
IEC 61850 . <b>SPCSO9</b>	<i>Status bit that can be set by clients like e.g. SCADA (Single Point Controllable Status Output).</i>
IEC 61850 . <b>SPCSO10</b>	<i>Status bit that can be set by clients like e.g. SCADA (Single Point Controllable Status Output).</i>
IEC 61850 . <b>SPCSO11</b>	<i>Status bit that can be set by clients like e.g. SCADA (Single Point Controllable Status Output).</i>
IEC 61850 . <b>SPCSO12</b>	<i>Status bit that can be set by clients like e.g. SCADA (Single Point Controllable Status Output).</i>
IEC 61850 . <b>SPCSO13</b>	<i>Status bit that can be set by clients like e.g. SCADA (Single Point Controllable Status Output).</i>
IEC 61850 . <b>SPCSO14</b>	<i>Status bit that can be set by clients like e.g. SCADA (Single Point Controllable Status Output).</i>
IEC 61850 . <b>SPCSO15</b>	<i>Status bit that can be set by clients like e.g. SCADA (Single Point Controllable Status Output).</i>
IEC 61850 . <b>SPCSO16</b>	<i>Status bit that can be set by clients like e.g. SCADA (Single Point Controllable Status Output).</i>
IEC 61850 . <b>SPCSO17</b>	<i>Status bit that can be set by clients like e.g. SCADA (Single Point Controllable Status Output).</i>
IEC 61850 . <b>SPCSO18</b>	<i>Status bit that can be set by clients like e.g. SCADA (Single Point Controllable Status Output).</i>
IEC 61850 . <b>SPCSO19</b>	<i>Status bit that can be set by clients like e.g. SCADA (Single Point Controllable Status Output).</i>
IEC 61850 . <b>SPCSO20</b>	<i>Status bit that can be set by clients like e.g. SCADA (Single Point Controllable Status Output).</i>
IEC 61850 . <b>SPCSO21</b>	<i>Status bit that can be set by clients like e.g. SCADA (Single Point Controllable Status Output).</i>
IEC 61850 . <b>SPCSO22</b>	<i>Status bit that can be set by clients like e.g. SCADA (Single Point Controllable Status Output).</i>

<b>1..n, Assignment List</b>	<b>Description</b>
IEC 61850 . <b>SPCSO23</b>	<i>Status bit that can be set by clients like e.g. SCADA (Single Point Controllable Status Output).</i>
IEC 61850 . <b>SPCSO24</b>	<i>Status bit that can be set by clients like e.g. SCADA (Single Point Controllable Status Output).</i>
IEC 61850 . <b>SPCSO25</b>	<i>Status bit that can be set by clients like e.g. SCADA (Single Point Controllable Status Output).</i>
IEC 61850 . <b>SPCSO26</b>	<i>Status bit that can be set by clients like e.g. SCADA (Single Point Controllable Status Output).</i>
IEC 61850 . <b>SPCSO27</b>	<i>Status bit that can be set by clients like e.g. SCADA (Single Point Controllable Status Output).</i>
IEC 61850 . <b>SPCSO28</b>	<i>Status bit that can be set by clients like e.g. SCADA (Single Point Controllable Status Output).</i>
IEC 61850 . <b>SPCSO29</b>	<i>Status bit that can be set by clients like e.g. SCADA (Single Point Controllable Status Output).</i>
IEC 61850 . <b>SPCSO30</b>	<i>Status bit that can be set by clients like e.g. SCADA (Single Point Controllable Status Output).</i>
IEC 61850 . <b>SPCSO31</b>	<i>Status bit that can be set by clients like e.g. SCADA (Single Point Controllable Status Output).</i>
IEC 61850 . <b>SPCSO32</b>	<i>Status bit that can be set by clients like e.g. SCADA (Single Point Controllable Status Output).</i>
IEC103 . <b>Scada Cmd 1</b>	<i>Scada Command</i>
IEC103 . <b>Scada Cmd 2</b>	<i>Scada Command</i>
IEC103 . <b>Scada Cmd 3</b>	<i>Scada Command</i>
IEC103 . <b>Scada Cmd 4</b>	<i>Scada Command</i>
IEC103 . <b>Scada Cmd 5</b>	<i>Scada Command</i>
IEC103 . <b>Scada Cmd 6</b>	<i>Scada Command</i>
IEC103 . <b>Scada Cmd 7</b>	<i>Scada Command</i>
IEC103 . <b>Scada Cmd 8</b>	<i>Scada Command</i>
IEC103 . <b>Scada Cmd 9</b>	<i>Scada Command</i>
IEC103 . <b>Scada Cmd 10</b>	<i>Scada Command</i>
IEC103 . <b>Transmission</b>	<i>Signal: SCADA active</i>
IEC103 . <b>Failure Event lost</b>	<i>Failure event lost</i>
IEC103 . <b>Test mode active</b>	<i>Signal: IEC103 communication has been switched over into Test Mode.</i>
IEC103 . <b>Block MD active</b>	<i>Signal: The blocking of IEC103 transmission in monitor direction has been activated.</i>

<b>1..n, Assignment List</b>	<b>Description</b>
IEC103 . <b>Ex activate test mode-I</b>	<i>Module input state: Test Mode of the IEC103 communication.</i>
IEC103 . <b>Ex activate Block MD-I</b>	<i>Module input state: Activation of the blocking of IEC103 transmission in monitor direction.</i>
IEC104 . <b>busy</b>	<i>This message is set if the protocol is started. It will be reset if the protocol is shut down.</i>
IEC104 . <b>ready</b>	<i>The message will be set if the protocol is successfully started and ready for data exchange.</i>
IEC104 . <b>Transmission</b>	<i>Signal: SCADA active</i>
IEC104 . <b>Failure Event lost</b>	<i>Failure event lost</i>
IEC104 . <b>Scada Cmd 1</b>	<i>Scada Command</i>
IEC104 . <b>Scada Cmd 2</b>	<i>Scada Command</i>
IEC104 . <b>Scada Cmd 3</b>	<i>Scada Command</i>
IEC104 . <b>Scada Cmd 4</b>	<i>Scada Command</i>
IEC104 . <b>Scada Cmd 5</b>	<i>Scada Command</i>
IEC104 . <b>Scada Cmd 6</b>	<i>Scada Command</i>
IEC104 . <b>Scada Cmd 7</b>	<i>Scada Command</i>
IEC104 . <b>Scada Cmd 8</b>	<i>Scada Command</i>
IEC104 . <b>Scada Cmd 9</b>	<i>Scada Command</i>
IEC104 . <b>Scada Cmd 10</b>	<i>Scada Command</i>
IEC104 . <b>Scada Cmd 11</b>	<i>Scada Command</i>
IEC104 . <b>Scada Cmd 12</b>	<i>Scada Command</i>
IEC104 . <b>Scada Cmd 13</b>	<i>Scada Command</i>
IEC104 . <b>Scada Cmd 14</b>	<i>Scada Command</i>
IEC104 . <b>Scada Cmd 15</b>	<i>Scada Command</i>
IEC104 . <b>Scada Cmd 16</b>	<i>Scada Command</i>
Profibus . <b>Data OK</b>	<i>Data within the Input field are OK (Yes=1)</i>
Profibus . <b>SubModul Err</b>	<i>Assignable Signal, Failure in Sub-Module, Communication Failure.</i>
Profibus . <b>Connection active</b>	<i>Connection active</i>
Profibus . <b>Scada Cmd 1</b>	<i>Scada Command</i>
Profibus . <b>Scada Cmd 2</b>	<i>Scada Command</i>
Profibus . <b>Scada Cmd 3</b>	<i>Scada Command</i>

<b>1..n, Assignment List</b>	<b>Description</b>
Profibus . <b>Scada Cmd 4</b>	<i>Scada Command</i>
Profibus . <b>Scada Cmd 5</b>	<i>Scada Command</i>
Profibus . <b>Scada Cmd 6</b>	<i>Scada Command</i>
Profibus . <b>Scada Cmd 7</b>	<i>Scada Command</i>
Profibus . <b>Scada Cmd 8</b>	<i>Scada Command</i>
Profibus . <b>Scada Cmd 9</b>	<i>Scada Command</i>
Profibus . <b>Scada Cmd 10</b>	<i>Scada Command</i>
Profibus . <b>Scada Cmd 11</b>	<i>Scada Command</i>
Profibus . <b>Scada Cmd 12</b>	<i>Scada Command</i>
Profibus . <b>Scada Cmd 13</b>	<i>Scada Command</i>
Profibus . <b>Scada Cmd 14</b>	<i>Scada Command</i>
Profibus . <b>Scada Cmd 15</b>	<i>Scada Command</i>
Profibus . <b>Scada Cmd 16</b>	<i>Scada Command</i>
IRIG-B . <b>IRIG-B active</b>	<i>Signal: If there is no valid IRIG-B signal for 60 sec, IRIG-B is regarded as inactive.</i>
IRIG-B . <b>High-Low Invert</b>	<i>Signal: The High and Low signals of the IRIG-B are inverted. This does NOT mean that the wiring is faulty. If the wiring is faulty no IRIG-B signal will be detected.</i>
IRIG-B . <b>Control Signal1</b>	<i>Signal: IRIG-B Control Signal. The external IRIG-B generator can set these signals. They can be used for further control procedures inside the device (e.g. logic funtions).</i>
IRIG-B . <b>Control Signal2</b>	<i>Signal: IRIG-B Control Signal. The external IRIG-B generator can set these signals. They can be used for further control procedures inside the device (e.g. logic funtions).</i>
IRIG-B . <b>Control Signal3</b>	<i>Signal: IRIG-B Control Signal. The external IRIG-B generator can set these signals. They can be used for further control procedures inside the device (e.g. logic funtions).</i>
IRIG-B . <b>Control Signal4</b>	<i>Signal: IRIG-B Control Signal. The external IRIG-B generator can set these signals. They can be used for further control procedures inside the device (e.g. logic funtions).</i>
IRIG-B . <b>Control Signal5</b>	<i>Signal: IRIG-B Control Signal. The external IRIG-B generator can set these signals. They can be used for further control procedures inside the device (e.g. logic funtions).</i>
IRIG-B . <b>Control Signal6</b>	<i>Signal: IRIG-B Control Signal. The external IRIG-B generator can set these signals. They can be used for further control procedures inside the device (e.g. logic funtions).</i>
IRIG-B . <b>Control Signal7</b>	<i>Signal: IRIG-B Control Signal. The external IRIG-B generator can set these signals. They can be used for further control procedures inside the device (e.g. logic funtions).</i>

<b>1..n, Assignment List</b>	<b>Description</b>
IRIG-B . <b>Control Signal8</b>	<i>Signal: IRIG-B Control Signal. The external IRIG-B generator can set these signals. They can be used for further control procedures inside the device (e.g. logic funtions).</i>
IRIG-B . <b>Control Signal9</b>	<i>Signal: IRIG-B Control Signal. The external IRIG-B generator can set these signals. They can be used for further control procedures inside the device (e.g. logic funtions).</i>
IRIG-B . <b>Control Signal10</b>	<i>Signal: IRIG-B Control Signal. The external IRIG-B generator can set these signals. They can be used for further control procedures inside the device (e.g. logic funtions).</i>
IRIG-B . <b>Control Signal11</b>	<i>Signal: IRIG-B Control Signal. The external IRIG-B generator can set these signals. They can be used for further control procedures inside the device (e.g. logic funtions).</i>
IRIG-B . <b>Control Signal12</b>	<i>Signal: IRIG-B Control Signal. The external IRIG-B generator can set these signals. They can be used for further control procedures inside the device (e.g. logic funtions).</i>
IRIG-B . <b>Control Signal13</b>	<i>Signal: IRIG-B Control Signal. The external IRIG-B generator can set these signals. They can be used for further control procedures inside the device (e.g. logic funtions).</i>
IRIG-B . <b>Control Signal14</b>	<i>Signal: IRIG-B Control Signal. The external IRIG-B generator can set these signals. They can be used for further control procedures inside the device (e.g. logic funtions).</i>
IRIG-B . <b>Control Signal15</b>	<i>Signal: IRIG-B Control Signal. The external IRIG-B generator can set these signals. They can be used for further control procedures inside the device (e.g. logic funtions).</i>
IRIG-B . <b>Control Signal16</b>	<i>Signal: IRIG-B Control Signal. The external IRIG-B generator can set these signals. They can be used for further control procedures inside the device (e.g. logic funtions).</i>
IRIG-B . <b>Control Signal17</b>	<i>Signal: IRIG-B Control Signal. The external IRIG-B generator can set these signals. They can be used for further control procedures inside the device (e.g. logic funtions).</i>
IRIG-B . <b>Control Signal18</b>	<i>Signal: IRIG-B Control Signal. The external IRIG-B generator can set these signals. They can be used for further control procedures inside the device (e.g. logic funtions).</i>
SNTP . <b>SNTP active</b>	<i>Signal: If there is no valid SNTP signal for 120 sec, SNTP is regarded as inactive.</i>
TimeSync . <b>synchronized</b>	<i>Clock is synchronized.</i>
Statistics . <b>ResFc all</b>	<i>Signal: Resetting of all Statistic values (Current Demand, Power Demand, Min, Max)</i>
Statistics . <b>ResFc I Demand</b>	<i>Signal: Resetting of Statistics - Current Demand (avg, peak avg)</i>
Statistics . <b>ResFc Max</b>	<i>Signal: Resetting of all Maximum values</i>
Statistics . <b>ResFc Min</b>	<i>Signal: Resetting of all Minimum values</i>

<b>1..n, Assignment List</b>	<b>Description</b>
Statistics . <b>StartFc I Demand-I</b>	<i>State of the module input: Start of the Statistics of the Current Demand</i>
Logics . <b>LE1.Gate Out</b>	<i>Signal: Output of the logic gate</i>
Logics . <b>LE1.Timer Out</b>	<i>Signal: Timer Output</i>
Logics . <b>LE1.Out</b>	<i>Signal: Latched Output (Q)</i>
Logics . <b>LE1.Out inverted</b>	<i>Signal: Negated Latched Output (Q NOT)</i>
Logics . <b>LE1.Gate In1-I</b>	<i>State of the module input: Assignment of the Input Signal</i>
Logics . <b>LE1.Gate In2-I</b>	<i>State of the module input: Assignment of the Input Signal</i>
Logics . <b>LE1.Gate In3-I</b>	<i>State of the module input: Assignment of the Input Signal</i>
Logics . <b>LE1.Gate In4-I</b>	<i>State of the module input: Assignment of the Input Signal</i>
Logics . <b>LE1.Reset Latch-I</b>	<i>State of the module input: Reset Signal for the Latching</i>
Logics . <b>LE2.Gate Out</b>	<i>Signal: Output of the logic gate</i>
Logics . <b>LE2.Timer Out</b>	<i>Signal: Timer Output</i>
Logics . <b>LE2.Out</b>	<i>Signal: Latched Output (Q)</i>
Logics . <b>LE2.Out inverted</b>	<i>Signal: Negated Latched Output (Q NOT)</i>
Logics . <b>LE2.Gate In1-I</b>	<i>State of the module input: Assignment of the Input Signal</i>
Logics . <b>LE2.Gate In2-I</b>	<i>State of the module input: Assignment of the Input Signal</i>
Logics . <b>LE2.Gate In3-I</b>	<i>State of the module input: Assignment of the Input Signal</i>
Logics . <b>LE2.Gate In4-I</b>	<i>State of the module input: Assignment of the Input Signal</i>
Logics . <b>LE2.Reset Latch-I</b>	<i>State of the module input: Reset Signal for the Latching</i>
Logics . <b>LE3.Gate Out</b>	<i>Signal: Output of the logic gate</i>
Logics . <b>LE3.Timer Out</b>	<i>Signal: Timer Output</i>
Logics . <b>LE3.Out</b>	<i>Signal: Latched Output (Q)</i>
Logics . <b>LE3.Out inverted</b>	<i>Signal: Negated Latched Output (Q NOT)</i>
Logics . <b>LE3.Gate In1-I</b>	<i>State of the module input: Assignment of the Input Signal</i>
Logics . <b>LE3.Gate In2-I</b>	<i>State of the module input: Assignment of the Input Signal</i>
Logics . <b>LE3.Gate In3-I</b>	<i>State of the module input: Assignment of the Input Signal</i>
Logics . <b>LE3.Gate In4-I</b>	<i>State of the module input: Assignment of the Input Signal</i>
Logics . <b>LE3.Reset Latch-I</b>	<i>State of the module input: Reset Signal for the Latching</i>

<b>1..n, Assignment List</b>	<b>Description</b>
Logics . <b>LE4.Gate Out</b>	<i>Signal: Output of the logic gate</i>
Logics . <b>LE4.Timer Out</b>	<i>Signal: Timer Output</i>
Logics . <b>LE4.Out</b>	<i>Signal: Latched Output (Q)</i>
Logics . <b>LE4.Out inverted</b>	<i>Signal: Negated Latched Output (Q NOT)</i>
Logics . <b>LE4.Gate In1-I</b>	<i>State of the module input: Assignment of the Input Signal</i>
Logics . <b>LE4.Gate In2-I</b>	<i>State of the module input: Assignment of the Input Signal</i>
Logics . <b>LE4.Gate In3-I</b>	<i>State of the module input: Assignment of the Input Signal</i>
Logics . <b>LE4.Gate In4-I</b>	<i>State of the module input: Assignment of the Input Signal</i>
Logics . <b>LE4.Reset Latch-I</b>	<i>State of the module input: Reset Signal for the Latching</i>
Logics . <b>LE5.Gate Out</b>	<i>Signal: Output of the logic gate</i>
Logics . <b>LE5.Timer Out</b>	<i>Signal: Timer Output</i>
Logics . <b>LE5.Out</b>	<i>Signal: Latched Output (Q)</i>
Logics . <b>LE5.Out inverted</b>	<i>Signal: Negated Latched Output (Q NOT)</i>
Logics . <b>LE5.Gate In1-I</b>	<i>State of the module input: Assignment of the Input Signal</i>
Logics . <b>LE5.Gate In2-I</b>	<i>State of the module input: Assignment of the Input Signal</i>
Logics . <b>LE5.Gate In3-I</b>	<i>State of the module input: Assignment of the Input Signal</i>
Logics . <b>LE5.Gate In4-I</b>	<i>State of the module input: Assignment of the Input Signal</i>
Logics . <b>LE5.Reset Latch-I</b>	<i>State of the module input: Reset Signal for the Latching</i>
Logics . <b>LE6.Gate Out</b>	<i>Signal: Output of the logic gate</i>
Logics . <b>LE6.Timer Out</b>	<i>Signal: Timer Output</i>
Logics . <b>LE6.Out</b>	<i>Signal: Latched Output (Q)</i>
Logics . <b>LE6.Out inverted</b>	<i>Signal: Negated Latched Output (Q NOT)</i>
Logics . <b>LE6.Gate In1-I</b>	<i>State of the module input: Assignment of the Input Signal</i>
Logics . <b>LE6.Gate In2-I</b>	<i>State of the module input: Assignment of the Input Signal</i>
Logics . <b>LE6.Gate In3-I</b>	<i>State of the module input: Assignment of the Input Signal</i>
Logics . <b>LE6.Gate In4-I</b>	<i>State of the module input: Assignment of the Input Signal</i>
Logics . <b>LE6.Reset Latch-I</b>	<i>State of the module input: Reset Signal for the Latching</i>
Logics . <b>LE7.Gate Out</b>	<i>Signal: Output of the logic gate</i>

<b>1..n, Assignment List</b>	<b>Description</b>
Logics . <b>LE7.Timer Out</b>	<i>Signal: Timer Output</i>
Logics . <b>LE7.Out</b>	<i>Signal: Latched Output (Q)</i>
Logics . <b>LE7.Out inverted</b>	<i>Signal: Negated Latched Output (Q NOT)</i>
Logics . <b>LE7.Gate In1-I</b>	<i>State of the module input: Assignment of the Input Signal</i>
Logics . <b>LE7.Gate In2-I</b>	<i>State of the module input: Assignment of the Input Signal</i>
Logics . <b>LE7.Gate In3-I</b>	<i>State of the module input: Assignment of the Input Signal</i>
Logics . <b>LE7.Gate In4-I</b>	<i>State of the module input: Assignment of the Input Signal</i>
Logics . <b>LE7.Reset Latch-I</b>	<i>State of the module input: Reset Signal for the Latching</i>
Logics . <b>LE8.Gate Out</b>	<i>Signal: Output of the logic gate</i>
Logics . <b>LE8.Timer Out</b>	<i>Signal: Timer Output</i>
Logics . <b>LE8.Out</b>	<i>Signal: Latched Output (Q)</i>
Logics . <b>LE8.Out inverted</b>	<i>Signal: Negated Latched Output (Q NOT)</i>
Logics . <b>LE8.Gate In1-I</b>	<i>State of the module input: Assignment of the Input Signal</i>
Logics . <b>LE8.Gate In2-I</b>	<i>State of the module input: Assignment of the Input Signal</i>
Logics . <b>LE8.Gate In3-I</b>	<i>State of the module input: Assignment of the Input Signal</i>
Logics . <b>LE8.Gate In4-I</b>	<i>State of the module input: Assignment of the Input Signal</i>
Logics . <b>LE8.Reset Latch-I</b>	<i>State of the module input: Reset Signal for the Latching</i>
Logics . <b>LE9.Gate Out</b>	<i>Signal: Output of the logic gate</i>
Logics . <b>LE9.Timer Out</b>	<i>Signal: Timer Output</i>
Logics . <b>LE9.Out</b>	<i>Signal: Latched Output (Q)</i>
Logics . <b>LE9.Out inverted</b>	<i>Signal: Negated Latched Output (Q NOT)</i>
Logics . <b>LE9.Gate In1-I</b>	<i>State of the module input: Assignment of the Input Signal</i>
Logics . <b>LE9.Gate In2-I</b>	<i>State of the module input: Assignment of the Input Signal</i>
Logics . <b>LE9.Gate In3-I</b>	<i>State of the module input: Assignment of the Input Signal</i>
Logics . <b>LE9.Gate In4-I</b>	<i>State of the module input: Assignment of the Input Signal</i>
Logics . <b>LE9.Reset Latch-I</b>	<i>State of the module input: Reset Signal for the Latching</i>
Logics . <b>LE10.Gate Out</b>	<i>Signal: Output of the logic gate</i>
Logics . <b>LE10.Timer Out</b>	<i>Signal: Timer Output</i>



<b>1..n, Assignment List</b>	<b>Description</b>
Logics . <b>LE10.Out</b>	<i>Signal: Latched Output (Q)</i>
Logics . <b>LE10.Out inverted</b>	<i>Signal: Negated Latched Output (Q NOT)</i>
Logics . <b>LE10.Gate In1-I</b>	<i>State of the module input: Assignment of the Input Signal</i>
Logics . <b>LE10.Gate In2-I</b>	<i>State of the module input: Assignment of the Input Signal</i>
Logics . <b>LE10.Gate In3-I</b>	<i>State of the module input: Assignment of the Input Signal</i>
Logics . <b>LE10.Gate In4-I</b>	<i>State of the module input: Assignment of the Input Signal</i>
Logics . <b>LE10.Reset Latch-I</b>	<i>State of the module input: Reset Signal for the Latching</i>
Logics . <b>LE11.Gate Out</b>	<i>Signal: Output of the logic gate</i>
Logics . <b>LE11.Timer Out</b>	<i>Signal: Timer Output</i>
Logics . <b>LE11.Out</b>	<i>Signal: Latched Output (Q)</i>
Logics . <b>LE11.Out inverted</b>	<i>Signal: Negated Latched Output (Q NOT)</i>
Logics . <b>LE11.Gate In1-I</b>	<i>State of the module input: Assignment of the Input Signal</i>
Logics . <b>LE11.Gate In2-I</b>	<i>State of the module input: Assignment of the Input Signal</i>
Logics . <b>LE11.Gate In3-I</b>	<i>State of the module input: Assignment of the Input Signal</i>
Logics . <b>LE11.Gate In4-I</b>	<i>State of the module input: Assignment of the Input Signal</i>
Logics . <b>LE11.Reset Latch-I</b>	<i>State of the module input: Reset Signal for the Latching</i>
Logics . <b>LE12.Gate Out</b>	<i>Signal: Output of the logic gate</i>
Logics . <b>LE12.Timer Out</b>	<i>Signal: Timer Output</i>
Logics . <b>LE12.Out</b>	<i>Signal: Latched Output (Q)</i>
Logics . <b>LE12.Out inverted</b>	<i>Signal: Negated Latched Output (Q NOT)</i>
Logics . <b>LE12.Gate In1-I</b>	<i>State of the module input: Assignment of the Input Signal</i>
Logics . <b>LE12.Gate In2-I</b>	<i>State of the module input: Assignment of the Input Signal</i>
Logics . <b>LE12.Gate In3-I</b>	<i>State of the module input: Assignment of the Input Signal</i>
Logics . <b>LE12.Gate In4-I</b>	<i>State of the module input: Assignment of the Input Signal</i>
Logics . <b>LE12.Reset Latch-I</b>	<i>State of the module input: Reset Signal for the Latching</i>
Logics . <b>LE13.Gate Out</b>	<i>Signal: Output of the logic gate</i>
Logics . <b>LE13.Timer Out</b>	<i>Signal: Timer Output</i>
Logics . <b>LE13.Out</b>	<i>Signal: Latched Output (Q)</i>

<b>1..n, Assignment List</b>	<b>Description</b>
Logics . <b>LE13.Out inverted</b>	<i>Signal: Negated Latched Output (Q NOT)</i>
Logics . <b>LE13.Gate In1-I</b>	<i>State of the module input: Assignment of the Input Signal</i>
Logics . <b>LE13.Gate In2-I</b>	<i>State of the module input: Assignment of the Input Signal</i>
Logics . <b>LE13.Gate In3-I</b>	<i>State of the module input: Assignment of the Input Signal</i>
Logics . <b>LE13.Gate In4-I</b>	<i>State of the module input: Assignment of the Input Signal</i>
Logics . <b>LE13.Reset Latch-I</b>	<i>State of the module input: Reset Signal for the Latching</i>
Logics . <b>LE14.Gate Out</b>	<i>Signal: Output of the logic gate</i>
Logics . <b>LE14.Timer Out</b>	<i>Signal: Timer Output</i>
Logics . <b>LE14.Out</b>	<i>Signal: Latched Output (Q)</i>
Logics . <b>LE14.Out inverted</b>	<i>Signal: Negated Latched Output (Q NOT)</i>
Logics . <b>LE14.Gate In1-I</b>	<i>State of the module input: Assignment of the Input Signal</i>
Logics . <b>LE14.Gate In2-I</b>	<i>State of the module input: Assignment of the Input Signal</i>
Logics . <b>LE14.Gate In3-I</b>	<i>State of the module input: Assignment of the Input Signal</i>
Logics . <b>LE14.Gate In4-I</b>	<i>State of the module input: Assignment of the Input Signal</i>
Logics . <b>LE14.Reset Latch-I</b>	<i>State of the module input: Reset Signal for the Latching</i>
Logics . <b>LE15.Gate Out</b>	<i>Signal: Output of the logic gate</i>
Logics . <b>LE15.Timer Out</b>	<i>Signal: Timer Output</i>
Logics . <b>LE15.Out</b>	<i>Signal: Latched Output (Q)</i>
Logics . <b>LE15.Out inverted</b>	<i>Signal: Negated Latched Output (Q NOT)</i>
Logics . <b>LE15.Gate In1-I</b>	<i>State of the module input: Assignment of the Input Signal</i>
Logics . <b>LE15.Gate In2-I</b>	<i>State of the module input: Assignment of the Input Signal</i>
Logics . <b>LE15.Gate In3-I</b>	<i>State of the module input: Assignment of the Input Signal</i>
Logics . <b>LE15.Gate In4-I</b>	<i>State of the module input: Assignment of the Input Signal</i>
Logics . <b>LE15.Reset Latch-I</b>	<i>State of the module input: Reset Signal for the Latching</i>
Logics . <b>LE16.Gate Out</b>	<i>Signal: Output of the logic gate</i>
Logics . <b>LE16.Timer Out</b>	<i>Signal: Timer Output</i>
Logics . <b>LE16.Out</b>	<i>Signal: Latched Output (Q)</i>
Logics . <b>LE16.Out inverted</b>	<i>Signal: Negated Latched Output (Q NOT)</i>

<b>1..n, Assignment List</b>	<b>Description</b>
Logics . <b>LE16.Gate In1-I</b>	<i>State of the module input: Assignment of the Input Signal</i>
Logics . <b>LE16.Gate In2-I</b>	<i>State of the module input: Assignment of the Input Signal</i>
Logics . <b>LE16.Gate In3-I</b>	<i>State of the module input: Assignment of the Input Signal</i>
Logics . <b>LE16.Gate In4-I</b>	<i>State of the module input: Assignment of the Input Signal</i>
Logics . <b>LE16.Reset Latch-I</b>	<i>State of the module input: Reset Signal for the Latching</i>
Logics . <b>LE17.Gate Out</b>	<i>Signal: Output of the logic gate</i>
Logics . <b>LE17.Timer Out</b>	<i>Signal: Timer Output</i>
Logics . <b>LE17.Out</b>	<i>Signal: Latched Output (Q)</i>
Logics . <b>LE17.Out inverted</b>	<i>Signal: Negated Latched Output (Q NOT)</i>
Logics . <b>LE17.Gate In1-I</b>	<i>State of the module input: Assignment of the Input Signal</i>
Logics . <b>LE17.Gate In2-I</b>	<i>State of the module input: Assignment of the Input Signal</i>
Logics . <b>LE17.Gate In3-I</b>	<i>State of the module input: Assignment of the Input Signal</i>
Logics . <b>LE17.Gate In4-I</b>	<i>State of the module input: Assignment of the Input Signal</i>
Logics . <b>LE17.Reset Latch-I</b>	<i>State of the module input: Reset Signal for the Latching</i>
Logics . <b>LE18.Gate Out</b>	<i>Signal: Output of the logic gate</i>
Logics . <b>LE18.Timer Out</b>	<i>Signal: Timer Output</i>
Logics . <b>LE18.Out</b>	<i>Signal: Latched Output (Q)</i>
Logics . <b>LE18.Out inverted</b>	<i>Signal: Negated Latched Output (Q NOT)</i>
Logics . <b>LE18.Gate In1-I</b>	<i>State of the module input: Assignment of the Input Signal</i>
Logics . <b>LE18.Gate In2-I</b>	<i>State of the module input: Assignment of the Input Signal</i>
Logics . <b>LE18.Gate In3-I</b>	<i>State of the module input: Assignment of the Input Signal</i>
Logics . <b>LE18.Gate In4-I</b>	<i>State of the module input: Assignment of the Input Signal</i>
Logics . <b>LE18.Reset Latch-I</b>	<i>State of the module input: Reset Signal for the Latching</i>
Logics . <b>LE19.Gate Out</b>	<i>Signal: Output of the logic gate</i>
Logics . <b>LE19.Timer Out</b>	<i>Signal: Timer Output</i>
Logics . <b>LE19.Out</b>	<i>Signal: Latched Output (Q)</i>
Logics . <b>LE19.Out inverted</b>	<i>Signal: Negated Latched Output (Q NOT)</i>
Logics . <b>LE19.Gate In1-I</b>	<i>State of the module input: Assignment of the Input Signal</i>

<b>1..n, Assignment List</b>	<b>Description</b>
Logics . <b>LE19.Gate In2-I</b>	<i>State of the module input: Assignment of the Input Signal</i>
Logics . <b>LE19.Gate In3-I</b>	<i>State of the module input: Assignment of the Input Signal</i>
Logics . <b>LE19.Gate In4-I</b>	<i>State of the module input: Assignment of the Input Signal</i>
Logics . <b>LE19.Reset Latch-I</b>	<i>State of the module input: Reset Signal for the Latching</i>
Logics . <b>LE20.Gate Out</b>	<i>Signal: Output of the logic gate</i>
Logics . <b>LE20.Timer Out</b>	<i>Signal: Timer Output</i>
Logics . <b>LE20.Out</b>	<i>Signal: Latched Output (Q)</i>
Logics . <b>LE20.Out inverted</b>	<i>Signal: Negated Latched Output (Q NOT)</i>
Logics . <b>LE20.Gate In1-I</b>	<i>State of the module input: Assignment of the Input Signal</i>
Logics . <b>LE20.Gate In2-I</b>	<i>State of the module input: Assignment of the Input Signal</i>
Logics . <b>LE20.Gate In3-I</b>	<i>State of the module input: Assignment of the Input Signal</i>
Logics . <b>LE20.Gate In4-I</b>	<i>State of the module input: Assignment of the Input Signal</i>
Logics . <b>LE20.Reset Latch-I</b>	<i>State of the module input: Reset Signal for the Latching</i>
Logics . <b>LE21.Gate Out</b>	<i>Signal: Output of the logic gate</i>
Logics . <b>LE21.Timer Out</b>	<i>Signal: Timer Output</i>
Logics . <b>LE21.Out</b>	<i>Signal: Latched Output (Q)</i>
Logics . <b>LE21.Out inverted</b>	<i>Signal: Negated Latched Output (Q NOT)</i>
Logics . <b>LE21.Gate In1-I</b>	<i>State of the module input: Assignment of the Input Signal</i>
Logics . <b>LE21.Gate In2-I</b>	<i>State of the module input: Assignment of the Input Signal</i>
Logics . <b>LE21.Gate In3-I</b>	<i>State of the module input: Assignment of the Input Signal</i>
Logics . <b>LE21.Gate In4-I</b>	<i>State of the module input: Assignment of the Input Signal</i>
Logics . <b>LE21.Reset Latch-I</b>	<i>State of the module input: Reset Signal for the Latching</i>
Logics . <b>LE22.Gate Out</b>	<i>Signal: Output of the logic gate</i>
Logics . <b>LE22.Timer Out</b>	<i>Signal: Timer Output</i>
Logics . <b>LE22.Out</b>	<i>Signal: Latched Output (Q)</i>
Logics . <b>LE22.Out inverted</b>	<i>Signal: Negated Latched Output (Q NOT)</i>
Logics . <b>LE22.Gate In1-I</b>	<i>State of the module input: Assignment of the Input Signal</i>
Logics . <b>LE22.Gate In2-I</b>	<i>State of the module input: Assignment of the Input Signal</i>

<b>1..n, Assignment List</b>	<b>Description</b>
Logics . <b>LE22.Gate In3-I</b>	<i>State of the module input: Assignment of the Input Signal</i>
Logics . <b>LE22.Gate In4-I</b>	<i>State of the module input: Assignment of the Input Signal</i>
Logics . <b>LE22.Reset Latch-I</b>	<i>State of the module input: Reset Signal for the Latching</i>
Logics . <b>LE23.Gate Out</b>	<i>Signal: Output of the logic gate</i>
Logics . <b>LE23.Timer Out</b>	<i>Signal: Timer Output</i>
Logics . <b>LE23.Out</b>	<i>Signal: Latched Output (Q)</i>
Logics . <b>LE23.Out inverted</b>	<i>Signal: Negated Latched Output (Q NOT)</i>
Logics . <b>LE23.Gate In1-I</b>	<i>State of the module input: Assignment of the Input Signal</i>
Logics . <b>LE23.Gate In2-I</b>	<i>State of the module input: Assignment of the Input Signal</i>
Logics . <b>LE23.Gate In3-I</b>	<i>State of the module input: Assignment of the Input Signal</i>
Logics . <b>LE23.Gate In4-I</b>	<i>State of the module input: Assignment of the Input Signal</i>
Logics . <b>LE23.Reset Latch-I</b>	<i>State of the module input: Reset Signal for the Latching</i>
Logics . <b>LE24.Gate Out</b>	<i>Signal: Output of the logic gate</i>
Logics . <b>LE24.Timer Out</b>	<i>Signal: Timer Output</i>
Logics . <b>LE24.Out</b>	<i>Signal: Latched Output (Q)</i>
Logics . <b>LE24.Out inverted</b>	<i>Signal: Negated Latched Output (Q NOT)</i>
Logics . <b>LE24.Gate In1-I</b>	<i>State of the module input: Assignment of the Input Signal</i>
Logics . <b>LE24.Gate In2-I</b>	<i>State of the module input: Assignment of the Input Signal</i>
Logics . <b>LE24.Gate In3-I</b>	<i>State of the module input: Assignment of the Input Signal</i>
Logics . <b>LE24.Gate In4-I</b>	<i>State of the module input: Assignment of the Input Signal</i>
Logics . <b>LE24.Reset Latch-I</b>	<i>State of the module input: Reset Signal for the Latching</i>
Logics . <b>LE25.Gate Out</b>	<i>Signal: Output of the logic gate</i>
Logics . <b>LE25.Timer Out</b>	<i>Signal: Timer Output</i>
Logics . <b>LE25.Out</b>	<i>Signal: Latched Output (Q)</i>
Logics . <b>LE25.Out inverted</b>	<i>Signal: Negated Latched Output (Q NOT)</i>
Logics . <b>LE25.Gate In1-I</b>	<i>State of the module input: Assignment of the Input Signal</i>
Logics . <b>LE25.Gate In2-I</b>	<i>State of the module input: Assignment of the Input Signal</i>
Logics . <b>LE25.Gate In3-I</b>	<i>State of the module input: Assignment of the Input Signal</i>

<b>1..n, Assignment List</b>	<b>Description</b>
Logics . <b>LE25.Gate In4-I</b>	<i>State of the module input: Assignment of the Input Signal</i>
Logics . <b>LE25.Reset Latch-I</b>	<i>State of the module input: Reset Signal for the Latching</i>
Logics . <b>LE26.Gate Out</b>	<i>Signal: Output of the logic gate</i>
Logics . <b>LE26.Timer Out</b>	<i>Signal: Timer Output</i>
Logics . <b>LE26.Out</b>	<i>Signal: Latched Output (Q)</i>
Logics . <b>LE26.Out inverted</b>	<i>Signal: Negated Latched Output (Q NOT)</i>
Logics . <b>LE26.Gate In1-I</b>	<i>State of the module input: Assignment of the Input Signal</i>
Logics . <b>LE26.Gate In2-I</b>	<i>State of the module input: Assignment of the Input Signal</i>
Logics . <b>LE26.Gate In3-I</b>	<i>State of the module input: Assignment of the Input Signal</i>
Logics . <b>LE26.Gate In4-I</b>	<i>State of the module input: Assignment of the Input Signal</i>
Logics . <b>LE26.Reset Latch-I</b>	<i>State of the module input: Reset Signal for the Latching</i>
Logics . <b>LE27.Gate Out</b>	<i>Signal: Output of the logic gate</i>
Logics . <b>LE27.Timer Out</b>	<i>Signal: Timer Output</i>
Logics . <b>LE27.Out</b>	<i>Signal: Latched Output (Q)</i>
Logics . <b>LE27.Out inverted</b>	<i>Signal: Negated Latched Output (Q NOT)</i>
Logics . <b>LE27.Gate In1-I</b>	<i>State of the module input: Assignment of the Input Signal</i>
Logics . <b>LE27.Gate In2-I</b>	<i>State of the module input: Assignment of the Input Signal</i>
Logics . <b>LE27.Gate In3-I</b>	<i>State of the module input: Assignment of the Input Signal</i>
Logics . <b>LE27.Gate In4-I</b>	<i>State of the module input: Assignment of the Input Signal</i>
Logics . <b>LE27.Reset Latch-I</b>	<i>State of the module input: Reset Signal for the Latching</i>
Logics . <b>LE28.Gate Out</b>	<i>Signal: Output of the logic gate</i>
Logics . <b>LE28.Timer Out</b>	<i>Signal: Timer Output</i>
Logics . <b>LE28.Out</b>	<i>Signal: Latched Output (Q)</i>
Logics . <b>LE28.Out inverted</b>	<i>Signal: Negated Latched Output (Q NOT)</i>
Logics . <b>LE28.Gate In1-I</b>	<i>State of the module input: Assignment of the Input Signal</i>
Logics . <b>LE28.Gate In2-I</b>	<i>State of the module input: Assignment of the Input Signal</i>
Logics . <b>LE28.Gate In3-I</b>	<i>State of the module input: Assignment of the Input Signal</i>
Logics . <b>LE28.Gate In4-I</b>	<i>State of the module input: Assignment of the Input Signal</i>

<b>1..n, Assignment List</b>	<b>Description</b>
Logics . <b>LE28.Reset Latch-I</b>	<i>State of the module input: Reset Signal for the Latching</i>
Logics . <b>LE29.Gate Out</b>	<i>Signal: Output of the logic gate</i>
Logics . <b>LE29.Timer Out</b>	<i>Signal: Timer Output</i>
Logics . <b>LE29.Out</b>	<i>Signal: Latched Output (Q)</i>
Logics . <b>LE29.Out inverted</b>	<i>Signal: Negated Latched Output (Q NOT)</i>
Logics . <b>LE29.Gate In1-I</b>	<i>State of the module input: Assignment of the Input Signal</i>
Logics . <b>LE29.Gate In2-I</b>	<i>State of the module input: Assignment of the Input Signal</i>
Logics . <b>LE29.Gate In3-I</b>	<i>State of the module input: Assignment of the Input Signal</i>
Logics . <b>LE29.Gate In4-I</b>	<i>State of the module input: Assignment of the Input Signal</i>
Logics . <b>LE29.Reset Latch-I</b>	<i>State of the module input: Reset Signal for the Latching</i>
Logics . <b>LE30.Gate Out</b>	<i>Signal: Output of the logic gate</i>
Logics . <b>LE30.Timer Out</b>	<i>Signal: Timer Output</i>
Logics . <b>LE30.Out</b>	<i>Signal: Latched Output (Q)</i>
Logics . <b>LE30.Out inverted</b>	<i>Signal: Negated Latched Output (Q NOT)</i>
Logics . <b>LE30.Gate In1-I</b>	<i>State of the module input: Assignment of the Input Signal</i>
Logics . <b>LE30.Gate In2-I</b>	<i>State of the module input: Assignment of the Input Signal</i>
Logics . <b>LE30.Gate In3-I</b>	<i>State of the module input: Assignment of the Input Signal</i>
Logics . <b>LE30.Gate In4-I</b>	<i>State of the module input: Assignment of the Input Signal</i>
Logics . <b>LE30.Reset Latch-I</b>	<i>State of the module input: Reset Signal for the Latching</i>
Logics . <b>LE31.Gate Out</b>	<i>Signal: Output of the logic gate</i>
Logics . <b>LE31.Timer Out</b>	<i>Signal: Timer Output</i>
Logics . <b>LE31.Out</b>	<i>Signal: Latched Output (Q)</i>
Logics . <b>LE31.Out inverted</b>	<i>Signal: Negated Latched Output (Q NOT)</i>
Logics . <b>LE31.Gate In1-I</b>	<i>State of the module input: Assignment of the Input Signal</i>
Logics . <b>LE31.Gate In2-I</b>	<i>State of the module input: Assignment of the Input Signal</i>
Logics . <b>LE31.Gate In3-I</b>	<i>State of the module input: Assignment of the Input Signal</i>
Logics . <b>LE31.Gate In4-I</b>	<i>State of the module input: Assignment of the Input Signal</i>
Logics . <b>LE31.Reset Latch-I</b>	<i>State of the module input: Reset Signal for the Latching</i>

<b>1..n, Assignment List</b>	<b>Description</b>
Logics . <b>LE32.Gate Out</b>	<i>Signal: Output of the logic gate</i>
Logics . <b>LE32.Timer Out</b>	<i>Signal: Timer Output</i>
Logics . <b>LE32.Out</b>	<i>Signal: Latched Output (Q)</i>
Logics . <b>LE32.Out inverted</b>	<i>Signal: Negated Latched Output (Q NOT)</i>
Logics . <b>LE32.Gate In1-I</b>	<i>State of the module input: Assignment of the Input Signal</i>
Logics . <b>LE32.Gate In2-I</b>	<i>State of the module input: Assignment of the Input Signal</i>
Logics . <b>LE32.Gate In3-I</b>	<i>State of the module input: Assignment of the Input Signal</i>
Logics . <b>LE32.Gate In4-I</b>	<i>State of the module input: Assignment of the Input Signal</i>
Logics . <b>LE32.Reset Latch-I</b>	<i>State of the module input: Reset Signal for the Latching</i>
Logics . <b>LE33.Gate Out</b>	<i>Signal: Output of the logic gate</i>
Logics . <b>LE33.Timer Out</b>	<i>Signal: Timer Output</i>
Logics . <b>LE33.Out</b>	<i>Signal: Latched Output (Q)</i>
Logics . <b>LE33.Out inverted</b>	<i>Signal: Negated Latched Output (Q NOT)</i>
Logics . <b>LE33.Gate In1-I</b>	<i>State of the module input: Assignment of the Input Signal</i>
Logics . <b>LE33.Gate In2-I</b>	<i>State of the module input: Assignment of the Input Signal</i>
Logics . <b>LE33.Gate In3-I</b>	<i>State of the module input: Assignment of the Input Signal</i>
Logics . <b>LE33.Gate In4-I</b>	<i>State of the module input: Assignment of the Input Signal</i>
Logics . <b>LE33.Reset Latch-I</b>	<i>State of the module input: Reset Signal for the Latching</i>
Logics . <b>LE34.Gate Out</b>	<i>Signal: Output of the logic gate</i>
Logics . <b>LE34.Timer Out</b>	<i>Signal: Timer Output</i>
Logics . <b>LE34.Out</b>	<i>Signal: Latched Output (Q)</i>
Logics . <b>LE34.Out inverted</b>	<i>Signal: Negated Latched Output (Q NOT)</i>
Logics . <b>LE34.Gate In1-I</b>	<i>State of the module input: Assignment of the Input Signal</i>
Logics . <b>LE34.Gate In2-I</b>	<i>State of the module input: Assignment of the Input Signal</i>
Logics . <b>LE34.Gate In3-I</b>	<i>State of the module input: Assignment of the Input Signal</i>
Logics . <b>LE34.Gate In4-I</b>	<i>State of the module input: Assignment of the Input Signal</i>
Logics . <b>LE34.Reset Latch-I</b>	<i>State of the module input: Reset Signal for the Latching</i>
Logics . <b>LE35.Gate Out</b>	<i>Signal: Output of the logic gate</i>



<b>1..n, Assignment List</b>	<b>Description</b>
Logics . <b>LE35.Timer Out</b>	<i>Signal: Timer Output</i>
Logics . <b>LE35.Out</b>	<i>Signal: Latched Output (Q)</i>
Logics . <b>LE35.Out inverted</b>	<i>Signal: Negated Latched Output (Q NOT)</i>
Logics . <b>LE35.Gate In1-I</b>	<i>State of the module input: Assignment of the Input Signal</i>
Logics . <b>LE35.Gate In2-I</b>	<i>State of the module input: Assignment of the Input Signal</i>
Logics . <b>LE35.Gate In3-I</b>	<i>State of the module input: Assignment of the Input Signal</i>
Logics . <b>LE35.Gate In4-I</b>	<i>State of the module input: Assignment of the Input Signal</i>
Logics . <b>LE35.Reset Latch-I</b>	<i>State of the module input: Reset Signal for the Latching</i>
Logics . <b>LE36.Gate Out</b>	<i>Signal: Output of the logic gate</i>
Logics . <b>LE36.Timer Out</b>	<i>Signal: Timer Output</i>
Logics . <b>LE36.Out</b>	<i>Signal: Latched Output (Q)</i>
Logics . <b>LE36.Out inverted</b>	<i>Signal: Negated Latched Output (Q NOT)</i>
Logics . <b>LE36.Gate In1-I</b>	<i>State of the module input: Assignment of the Input Signal</i>
Logics . <b>LE36.Gate In2-I</b>	<i>State of the module input: Assignment of the Input Signal</i>
Logics . <b>LE36.Gate In3-I</b>	<i>State of the module input: Assignment of the Input Signal</i>
Logics . <b>LE36.Gate In4-I</b>	<i>State of the module input: Assignment of the Input Signal</i>
Logics . <b>LE36.Reset Latch-I</b>	<i>State of the module input: Reset Signal for the Latching</i>
Logics . <b>LE37.Gate Out</b>	<i>Signal: Output of the logic gate</i>
Logics . <b>LE37.Timer Out</b>	<i>Signal: Timer Output</i>
Logics . <b>LE37.Out</b>	<i>Signal: Latched Output (Q)</i>
Logics . <b>LE37.Out inverted</b>	<i>Signal: Negated Latched Output (Q NOT)</i>
Logics . <b>LE37.Gate In1-I</b>	<i>State of the module input: Assignment of the Input Signal</i>
Logics . <b>LE37.Gate In2-I</b>	<i>State of the module input: Assignment of the Input Signal</i>
Logics . <b>LE37.Gate In3-I</b>	<i>State of the module input: Assignment of the Input Signal</i>
Logics . <b>LE37.Gate In4-I</b>	<i>State of the module input: Assignment of the Input Signal</i>
Logics . <b>LE37.Reset Latch-I</b>	<i>State of the module input: Reset Signal for the Latching</i>
Logics . <b>LE38.Gate Out</b>	<i>Signal: Output of the logic gate</i>
Logics . <b>LE38.Timer Out</b>	<i>Signal: Timer Output</i>

<b>1..n, Assignment List</b>	<b>Description</b>
Logics . <b>LE38.Out</b>	<i>Signal: Latched Output (Q)</i>
Logics . <b>LE38.Out inverted</b>	<i>Signal: Negated Latched Output (Q NOT)</i>
Logics . <b>LE38.Gate In1-I</b>	<i>State of the module input: Assignment of the Input Signal</i>
Logics . <b>LE38.Gate In2-I</b>	<i>State of the module input: Assignment of the Input Signal</i>
Logics . <b>LE38.Gate In3-I</b>	<i>State of the module input: Assignment of the Input Signal</i>
Logics . <b>LE38.Gate In4-I</b>	<i>State of the module input: Assignment of the Input Signal</i>
Logics . <b>LE38.Reset Latch-I</b>	<i>State of the module input: Reset Signal for the Latching</i>
Logics . <b>LE39.Gate Out</b>	<i>Signal: Output of the logic gate</i>
Logics . <b>LE39.Timer Out</b>	<i>Signal: Timer Output</i>
Logics . <b>LE39.Out</b>	<i>Signal: Latched Output (Q)</i>
Logics . <b>LE39.Out inverted</b>	<i>Signal: Negated Latched Output (Q NOT)</i>
Logics . <b>LE39.Gate In1-I</b>	<i>State of the module input: Assignment of the Input Signal</i>
Logics . <b>LE39.Gate In2-I</b>	<i>State of the module input: Assignment of the Input Signal</i>
Logics . <b>LE39.Gate In3-I</b>	<i>State of the module input: Assignment of the Input Signal</i>
Logics . <b>LE39.Gate In4-I</b>	<i>State of the module input: Assignment of the Input Signal</i>
Logics . <b>LE39.Reset Latch-I</b>	<i>State of the module input: Reset Signal for the Latching</i>
Logics . <b>LE40.Gate Out</b>	<i>Signal: Output of the logic gate</i>
Logics . <b>LE40.Timer Out</b>	<i>Signal: Timer Output</i>
Logics . <b>LE40.Out</b>	<i>Signal: Latched Output (Q)</i>
Logics . <b>LE40.Out inverted</b>	<i>Signal: Negated Latched Output (Q NOT)</i>
Logics . <b>LE40.Gate In1-I</b>	<i>State of the module input: Assignment of the Input Signal</i>
Logics . <b>LE40.Gate In2-I</b>	<i>State of the module input: Assignment of the Input Signal</i>
Logics . <b>LE40.Gate In3-I</b>	<i>State of the module input: Assignment of the Input Signal</i>
Logics . <b>LE40.Gate In4-I</b>	<i>State of the module input: Assignment of the Input Signal</i>
Logics . <b>LE40.Reset Latch-I</b>	<i>State of the module input: Reset Signal for the Latching</i>
Logics . <b>LE41.Gate Out</b>	<i>Signal: Output of the logic gate</i>
Logics . <b>LE41.Timer Out</b>	<i>Signal: Timer Output</i>
Logics . <b>LE41.Out</b>	<i>Signal: Latched Output (Q)</i>

<b>1..n, Assignment List</b>	<b>Description</b>
Logics . <b>LE41.Out inverted</b>	<i>Signal: Negated Latched Output (Q NOT)</i>
Logics . <b>LE41.Gate In1-I</b>	<i>State of the module input: Assignment of the Input Signal</i>
Logics . <b>LE41.Gate In2-I</b>	<i>State of the module input: Assignment of the Input Signal</i>
Logics . <b>LE41.Gate In3-I</b>	<i>State of the module input: Assignment of the Input Signal</i>
Logics . <b>LE41.Gate In4-I</b>	<i>State of the module input: Assignment of the Input Signal</i>
Logics . <b>LE41.Reset Latch-I</b>	<i>State of the module input: Reset Signal for the Latching</i>
Logics . <b>LE42.Gate Out</b>	<i>Signal: Output of the logic gate</i>
Logics . <b>LE42.Timer Out</b>	<i>Signal: Timer Output</i>
Logics . <b>LE42.Out</b>	<i>Signal: Latched Output (Q)</i>
Logics . <b>LE42.Out inverted</b>	<i>Signal: Negated Latched Output (Q NOT)</i>
Logics . <b>LE42.Gate In1-I</b>	<i>State of the module input: Assignment of the Input Signal</i>
Logics . <b>LE42.Gate In2-I</b>	<i>State of the module input: Assignment of the Input Signal</i>
Logics . <b>LE42.Gate In3-I</b>	<i>State of the module input: Assignment of the Input Signal</i>
Logics . <b>LE42.Gate In4-I</b>	<i>State of the module input: Assignment of the Input Signal</i>
Logics . <b>LE42.Reset Latch-I</b>	<i>State of the module input: Reset Signal for the Latching</i>
Logics . <b>LE43.Gate Out</b>	<i>Signal: Output of the logic gate</i>
Logics . <b>LE43.Timer Out</b>	<i>Signal: Timer Output</i>
Logics . <b>LE43.Out</b>	<i>Signal: Latched Output (Q)</i>
Logics . <b>LE43.Out inverted</b>	<i>Signal: Negated Latched Output (Q NOT)</i>
Logics . <b>LE43.Gate In1-I</b>	<i>State of the module input: Assignment of the Input Signal</i>
Logics . <b>LE43.Gate In2-I</b>	<i>State of the module input: Assignment of the Input Signal</i>
Logics . <b>LE43.Gate In3-I</b>	<i>State of the module input: Assignment of the Input Signal</i>
Logics . <b>LE43.Gate In4-I</b>	<i>State of the module input: Assignment of the Input Signal</i>
Logics . <b>LE43.Reset Latch-I</b>	<i>State of the module input: Reset Signal for the Latching</i>
Logics . <b>LE44.Gate Out</b>	<i>Signal: Output of the logic gate</i>
Logics . <b>LE44.Timer Out</b>	<i>Signal: Timer Output</i>
Logics . <b>LE44.Out</b>	<i>Signal: Latched Output (Q)</i>
Logics . <b>LE44.Out inverted</b>	<i>Signal: Negated Latched Output (Q NOT)</i>

<b>1..n, Assignment List</b>	<b>Description</b>
Logics . <b>LE44.Gate In1-I</b>	<i>State of the module input: Assignment of the Input Signal</i>
Logics . <b>LE44.Gate In2-I</b>	<i>State of the module input: Assignment of the Input Signal</i>
Logics . <b>LE44.Gate In3-I</b>	<i>State of the module input: Assignment of the Input Signal</i>
Logics . <b>LE44.Gate In4-I</b>	<i>State of the module input: Assignment of the Input Signal</i>
Logics . <b>LE44.Reset Latch-I</b>	<i>State of the module input: Reset Signal for the Latching</i>
Logics . <b>LE45.Gate Out</b>	<i>Signal: Output of the logic gate</i>
Logics . <b>LE45.Timer Out</b>	<i>Signal: Timer Output</i>
Logics . <b>LE45.Out</b>	<i>Signal: Latched Output (Q)</i>
Logics . <b>LE45.Out inverted</b>	<i>Signal: Negated Latched Output (Q NOT)</i>
Logics . <b>LE45.Gate In1-I</b>	<i>State of the module input: Assignment of the Input Signal</i>
Logics . <b>LE45.Gate In2-I</b>	<i>State of the module input: Assignment of the Input Signal</i>
Logics . <b>LE45.Gate In3-I</b>	<i>State of the module input: Assignment of the Input Signal</i>
Logics . <b>LE45.Gate In4-I</b>	<i>State of the module input: Assignment of the Input Signal</i>
Logics . <b>LE45.Reset Latch-I</b>	<i>State of the module input: Reset Signal for the Latching</i>
Logics . <b>LE46.Gate Out</b>	<i>Signal: Output of the logic gate</i>
Logics . <b>LE46.Timer Out</b>	<i>Signal: Timer Output</i>
Logics . <b>LE46.Out</b>	<i>Signal: Latched Output (Q)</i>
Logics . <b>LE46.Out inverted</b>	<i>Signal: Negated Latched Output (Q NOT)</i>
Logics . <b>LE46.Gate In1-I</b>	<i>State of the module input: Assignment of the Input Signal</i>
Logics . <b>LE46.Gate In2-I</b>	<i>State of the module input: Assignment of the Input Signal</i>
Logics . <b>LE46.Gate In3-I</b>	<i>State of the module input: Assignment of the Input Signal</i>
Logics . <b>LE46.Gate In4-I</b>	<i>State of the module input: Assignment of the Input Signal</i>
Logics . <b>LE46.Reset Latch-I</b>	<i>State of the module input: Reset Signal for the Latching</i>
Logics . <b>LE47.Gate Out</b>	<i>Signal: Output of the logic gate</i>
Logics . <b>LE47.Timer Out</b>	<i>Signal: Timer Output</i>
Logics . <b>LE47.Out</b>	<i>Signal: Latched Output (Q)</i>
Logics . <b>LE47.Out inverted</b>	<i>Signal: Negated Latched Output (Q NOT)</i>
Logics . <b>LE47.Gate In1-I</b>	<i>State of the module input: Assignment of the Input Signal</i>

<b>1..n, Assignment List</b>	<b>Description</b>
Logics . <b>LE47.Gate In2-I</b>	<i>State of the module input: Assignment of the Input Signal</i>
Logics . <b>LE47.Gate In3-I</b>	<i>State of the module input: Assignment of the Input Signal</i>
Logics . <b>LE47.Gate In4-I</b>	<i>State of the module input: Assignment of the Input Signal</i>
Logics . <b>LE47.Reset Latch-I</b>	<i>State of the module input: Reset Signal for the Latching</i>
Logics . <b>LE48.Gate Out</b>	<i>Signal: Output of the logic gate</i>
Logics . <b>LE48.Timer Out</b>	<i>Signal: Timer Output</i>
Logics . <b>LE48.Out</b>	<i>Signal: Latched Output (Q)</i>
Logics . <b>LE48.Out inverted</b>	<i>Signal: Negated Latched Output (Q NOT)</i>
Logics . <b>LE48.Gate In1-I</b>	<i>State of the module input: Assignment of the Input Signal</i>
Logics . <b>LE48.Gate In2-I</b>	<i>State of the module input: Assignment of the Input Signal</i>
Logics . <b>LE48.Gate In3-I</b>	<i>State of the module input: Assignment of the Input Signal</i>
Logics . <b>LE48.Gate In4-I</b>	<i>State of the module input: Assignment of the Input Signal</i>
Logics . <b>LE48.Reset Latch-I</b>	<i>State of the module input: Reset Signal for the Latching</i>
Logics . <b>LE49.Gate Out</b>	<i>Signal: Output of the logic gate</i>
Logics . <b>LE49.Timer Out</b>	<i>Signal: Timer Output</i>
Logics . <b>LE49.Out</b>	<i>Signal: Latched Output (Q)</i>
Logics . <b>LE49.Out inverted</b>	<i>Signal: Negated Latched Output (Q NOT)</i>
Logics . <b>LE49.Gate In1-I</b>	<i>State of the module input: Assignment of the Input Signal</i>
Logics . <b>LE49.Gate In2-I</b>	<i>State of the module input: Assignment of the Input Signal</i>
Logics . <b>LE49.Gate In3-I</b>	<i>State of the module input: Assignment of the Input Signal</i>
Logics . <b>LE49.Gate In4-I</b>	<i>State of the module input: Assignment of the Input Signal</i>
Logics . <b>LE49.Reset Latch-I</b>	<i>State of the module input: Reset Signal for the Latching</i>
Logics . <b>LE50.Gate Out</b>	<i>Signal: Output of the logic gate</i>
Logics . <b>LE50.Timer Out</b>	<i>Signal: Timer Output</i>
Logics . <b>LE50.Out</b>	<i>Signal: Latched Output (Q)</i>
Logics . <b>LE50.Out inverted</b>	<i>Signal: Negated Latched Output (Q NOT)</i>
Logics . <b>LE50.Gate In1-I</b>	<i>State of the module input: Assignment of the Input Signal</i>
Logics . <b>LE50.Gate In2-I</b>	<i>State of the module input: Assignment of the Input Signal</i>

<b>1..n, Assignment List</b>	<b>Description</b>
Logics . <b>LE50.Gate In3-I</b>	<i>State of the module input: Assignment of the Input Signal</i>
Logics . <b>LE50.Gate In4-I</b>	<i>State of the module input: Assignment of the Input Signal</i>
Logics . <b>LE50.Reset Latch-I</b>	<i>State of the module input: Reset Signal for the Latching</i>
Logics . <b>LE51.Gate Out</b>	<i>Signal: Output of the logic gate</i>
Logics . <b>LE51.Timer Out</b>	<i>Signal: Timer Output</i>
Logics . <b>LE51.Out</b>	<i>Signal: Latched Output (Q)</i>
Logics . <b>LE51.Out inverted</b>	<i>Signal: Negated Latched Output (Q NOT)</i>
Logics . <b>LE51.Gate In1-I</b>	<i>State of the module input: Assignment of the Input Signal</i>
Logics . <b>LE51.Gate In2-I</b>	<i>State of the module input: Assignment of the Input Signal</i>
Logics . <b>LE51.Gate In3-I</b>	<i>State of the module input: Assignment of the Input Signal</i>
Logics . <b>LE51.Gate In4-I</b>	<i>State of the module input: Assignment of the Input Signal</i>
Logics . <b>LE51.Reset Latch-I</b>	<i>State of the module input: Reset Signal for the Latching</i>
Logics . <b>LE52.Gate Out</b>	<i>Signal: Output of the logic gate</i>
Logics . <b>LE52.Timer Out</b>	<i>Signal: Timer Output</i>
Logics . <b>LE52.Out</b>	<i>Signal: Latched Output (Q)</i>
Logics . <b>LE52.Out inverted</b>	<i>Signal: Negated Latched Output (Q NOT)</i>
Logics . <b>LE52.Gate In1-I</b>	<i>State of the module input: Assignment of the Input Signal</i>
Logics . <b>LE52.Gate In2-I</b>	<i>State of the module input: Assignment of the Input Signal</i>
Logics . <b>LE52.Gate In3-I</b>	<i>State of the module input: Assignment of the Input Signal</i>
Logics . <b>LE52.Gate In4-I</b>	<i>State of the module input: Assignment of the Input Signal</i>
Logics . <b>LE52.Reset Latch-I</b>	<i>State of the module input: Reset Signal for the Latching</i>
Logics . <b>LE53.Gate Out</b>	<i>Signal: Output of the logic gate</i>
Logics . <b>LE53.Timer Out</b>	<i>Signal: Timer Output</i>
Logics . <b>LE53.Out</b>	<i>Signal: Latched Output (Q)</i>
Logics . <b>LE53.Out inverted</b>	<i>Signal: Negated Latched Output (Q NOT)</i>
Logics . <b>LE53.Gate In1-I</b>	<i>State of the module input: Assignment of the Input Signal</i>
Logics . <b>LE53.Gate In2-I</b>	<i>State of the module input: Assignment of the Input Signal</i>
Logics . <b>LE53.Gate In3-I</b>	<i>State of the module input: Assignment of the Input Signal</i>

<b>1..n, Assignment List</b>	<b>Description</b>
Logics . <b>LE53.Gate In4-I</b>	<i>State of the module input: Assignment of the Input Signal</i>
Logics . <b>LE53.Reset Latch-I</b>	<i>State of the module input: Reset Signal for the Latching</i>
Logics . <b>LE54.Gate Out</b>	<i>Signal: Output of the logic gate</i>
Logics . <b>LE54.Timer Out</b>	<i>Signal: Timer Output</i>
Logics . <b>LE54.Out</b>	<i>Signal: Latched Output (Q)</i>
Logics . <b>LE54.Out inverted</b>	<i>Signal: Negated Latched Output (Q NOT)</i>
Logics . <b>LE54.Gate In1-I</b>	<i>State of the module input: Assignment of the Input Signal</i>
Logics . <b>LE54.Gate In2-I</b>	<i>State of the module input: Assignment of the Input Signal</i>
Logics . <b>LE54.Gate In3-I</b>	<i>State of the module input: Assignment of the Input Signal</i>
Logics . <b>LE54.Gate In4-I</b>	<i>State of the module input: Assignment of the Input Signal</i>
Logics . <b>LE54.Reset Latch-I</b>	<i>State of the module input: Reset Signal for the Latching</i>
Logics . <b>LE55.Gate Out</b>	<i>Signal: Output of the logic gate</i>
Logics . <b>LE55.Timer Out</b>	<i>Signal: Timer Output</i>
Logics . <b>LE55.Out</b>	<i>Signal: Latched Output (Q)</i>
Logics . <b>LE55.Out inverted</b>	<i>Signal: Negated Latched Output (Q NOT)</i>
Logics . <b>LE55.Gate In1-I</b>	<i>State of the module input: Assignment of the Input Signal</i>
Logics . <b>LE55.Gate In2-I</b>	<i>State of the module input: Assignment of the Input Signal</i>
Logics . <b>LE55.Gate In3-I</b>	<i>State of the module input: Assignment of the Input Signal</i>
Logics . <b>LE55.Gate In4-I</b>	<i>State of the module input: Assignment of the Input Signal</i>
Logics . <b>LE55.Reset Latch-I</b>	<i>State of the module input: Reset Signal for the Latching</i>
Logics . <b>LE56.Gate Out</b>	<i>Signal: Output of the logic gate</i>
Logics . <b>LE56.Timer Out</b>	<i>Signal: Timer Output</i>
Logics . <b>LE56.Out</b>	<i>Signal: Latched Output (Q)</i>
Logics . <b>LE56.Out inverted</b>	<i>Signal: Negated Latched Output (Q NOT)</i>
Logics . <b>LE56.Gate In1-I</b>	<i>State of the module input: Assignment of the Input Signal</i>
Logics . <b>LE56.Gate In2-I</b>	<i>State of the module input: Assignment of the Input Signal</i>
Logics . <b>LE56.Gate In3-I</b>	<i>State of the module input: Assignment of the Input Signal</i>
Logics . <b>LE56.Gate In4-I</b>	<i>State of the module input: Assignment of the Input Signal</i>

<b>1..n, Assignment List</b>	<b>Description</b>
Logics . <b>LE56.Reset Latch-I</b>	<i>State of the module input: Reset Signal for the Latching</i>
Logics . <b>LE57.Gate Out</b>	<i>Signal: Output of the logic gate</i>
Logics . <b>LE57.Timer Out</b>	<i>Signal: Timer Output</i>
Logics . <b>LE57.Out</b>	<i>Signal: Latched Output (Q)</i>
Logics . <b>LE57.Out inverted</b>	<i>Signal: Negated Latched Output (Q NOT)</i>
Logics . <b>LE57.Gate In1-I</b>	<i>State of the module input: Assignment of the Input Signal</i>
Logics . <b>LE57.Gate In2-I</b>	<i>State of the module input: Assignment of the Input Signal</i>
Logics . <b>LE57.Gate In3-I</b>	<i>State of the module input: Assignment of the Input Signal</i>
Logics . <b>LE57.Gate In4-I</b>	<i>State of the module input: Assignment of the Input Signal</i>
Logics . <b>LE57.Reset Latch-I</b>	<i>State of the module input: Reset Signal for the Latching</i>
Logics . <b>LE58.Gate Out</b>	<i>Signal: Output of the logic gate</i>
Logics . <b>LE58.Timer Out</b>	<i>Signal: Timer Output</i>
Logics . <b>LE58.Out</b>	<i>Signal: Latched Output (Q)</i>
Logics . <b>LE58.Out inverted</b>	<i>Signal: Negated Latched Output (Q NOT)</i>
Logics . <b>LE58.Gate In1-I</b>	<i>State of the module input: Assignment of the Input Signal</i>
Logics . <b>LE58.Gate In2-I</b>	<i>State of the module input: Assignment of the Input Signal</i>
Logics . <b>LE58.Gate In3-I</b>	<i>State of the module input: Assignment of the Input Signal</i>
Logics . <b>LE58.Gate In4-I</b>	<i>State of the module input: Assignment of the Input Signal</i>
Logics . <b>LE58.Reset Latch-I</b>	<i>State of the module input: Reset Signal for the Latching</i>
Logics . <b>LE59.Gate Out</b>	<i>Signal: Output of the logic gate</i>
Logics . <b>LE59.Timer Out</b>	<i>Signal: Timer Output</i>
Logics . <b>LE59.Out</b>	<i>Signal: Latched Output (Q)</i>
Logics . <b>LE59.Out inverted</b>	<i>Signal: Negated Latched Output (Q NOT)</i>
Logics . <b>LE59.Gate In1-I</b>	<i>State of the module input: Assignment of the Input Signal</i>
Logics . <b>LE59.Gate In2-I</b>	<i>State of the module input: Assignment of the Input Signal</i>
Logics . <b>LE59.Gate In3-I</b>	<i>State of the module input: Assignment of the Input Signal</i>
Logics . <b>LE59.Gate In4-I</b>	<i>State of the module input: Assignment of the Input Signal</i>
Logics . <b>LE59.Reset Latch-I</b>	<i>State of the module input: Reset Signal for the Latching</i>



<b>1..n, Assignment List</b>	<b>Description</b>
Logics . <b>LE60.Gate Out</b>	<i>Signal: Output of the logic gate</i>
Logics . <b>LE60.Timer Out</b>	<i>Signal: Timer Output</i>
Logics . <b>LE60.Out</b>	<i>Signal: Latched Output (Q)</i>
Logics . <b>LE60.Out inverted</b>	<i>Signal: Negated Latched Output (Q NOT)</i>
Logics . <b>LE60.Gate In1-I</b>	<i>State of the module input: Assignment of the Input Signal</i>
Logics . <b>LE60.Gate In2-I</b>	<i>State of the module input: Assignment of the Input Signal</i>
Logics . <b>LE60.Gate In3-I</b>	<i>State of the module input: Assignment of the Input Signal</i>
Logics . <b>LE60.Gate In4-I</b>	<i>State of the module input: Assignment of the Input Signal</i>
Logics . <b>LE60.Reset Latch-I</b>	<i>State of the module input: Reset Signal for the Latching</i>
Logics . <b>LE61.Gate Out</b>	<i>Signal: Output of the logic gate</i>
Logics . <b>LE61.Timer Out</b>	<i>Signal: Timer Output</i>
Logics . <b>LE61.Out</b>	<i>Signal: Latched Output (Q)</i>
Logics . <b>LE61.Out inverted</b>	<i>Signal: Negated Latched Output (Q NOT)</i>
Logics . <b>LE61.Gate In1-I</b>	<i>State of the module input: Assignment of the Input Signal</i>
Logics . <b>LE61.Gate In2-I</b>	<i>State of the module input: Assignment of the Input Signal</i>
Logics . <b>LE61.Gate In3-I</b>	<i>State of the module input: Assignment of the Input Signal</i>
Logics . <b>LE61.Gate In4-I</b>	<i>State of the module input: Assignment of the Input Signal</i>
Logics . <b>LE61.Reset Latch-I</b>	<i>State of the module input: Reset Signal for the Latching</i>
Logics . <b>LE62.Gate Out</b>	<i>Signal: Output of the logic gate</i>
Logics . <b>LE62.Timer Out</b>	<i>Signal: Timer Output</i>
Logics . <b>LE62.Out</b>	<i>Signal: Latched Output (Q)</i>
Logics . <b>LE62.Out inverted</b>	<i>Signal: Negated Latched Output (Q NOT)</i>
Logics . <b>LE62.Gate In1-I</b>	<i>State of the module input: Assignment of the Input Signal</i>
Logics . <b>LE62.Gate In2-I</b>	<i>State of the module input: Assignment of the Input Signal</i>
Logics . <b>LE62.Gate In3-I</b>	<i>State of the module input: Assignment of the Input Signal</i>
Logics . <b>LE62.Gate In4-I</b>	<i>State of the module input: Assignment of the Input Signal</i>
Logics . <b>LE62.Reset Latch-I</b>	<i>State of the module input: Reset Signal for the Latching</i>
Logics . <b>LE63.Gate Out</b>	<i>Signal: Output of the logic gate</i>

<b>1..n, Assignment List</b>	<b>Description</b>
Logics . <b>LE63.Timer Out</b>	<i>Signal: Timer Output</i>
Logics . <b>LE63.Out</b>	<i>Signal: Latched Output (Q)</i>
Logics . <b>LE63.Out inverted</b>	<i>Signal: Negated Latched Output (Q NOT)</i>
Logics . <b>LE63.Gate In1-I</b>	<i>State of the module input: Assignment of the Input Signal</i>
Logics . <b>LE63.Gate In2-I</b>	<i>State of the module input: Assignment of the Input Signal</i>
Logics . <b>LE63.Gate In3-I</b>	<i>State of the module input: Assignment of the Input Signal</i>
Logics . <b>LE63.Gate In4-I</b>	<i>State of the module input: Assignment of the Input Signal</i>
Logics . <b>LE63.Reset Latch-I</b>	<i>State of the module input: Reset Signal for the Latching</i>
Logics . <b>LE64.Gate Out</b>	<i>Signal: Output of the logic gate</i>
Logics . <b>LE64.Timer Out</b>	<i>Signal: Timer Output</i>
Logics . <b>LE64.Out</b>	<i>Signal: Latched Output (Q)</i>
Logics . <b>LE64.Out inverted</b>	<i>Signal: Negated Latched Output (Q NOT)</i>
Logics . <b>LE64.Gate In1-I</b>	<i>State of the module input: Assignment of the Input Signal</i>
Logics . <b>LE64.Gate In2-I</b>	<i>State of the module input: Assignment of the Input Signal</i>
Logics . <b>LE64.Gate In3-I</b>	<i>State of the module input: Assignment of the Input Signal</i>
Logics . <b>LE64.Gate In4-I</b>	<i>State of the module input: Assignment of the Input Signal</i>
Logics . <b>LE64.Reset Latch-I</b>	<i>State of the module input: Reset Signal for the Latching</i>
Logics . <b>LE65.Gate Out</b>	<i>Signal: Output of the logic gate</i>
Logics . <b>LE65.Timer Out</b>	<i>Signal: Timer Output</i>
Logics . <b>LE65.Out</b>	<i>Signal: Latched Output (Q)</i>
Logics . <b>LE65.Out inverted</b>	<i>Signal: Negated Latched Output (Q NOT)</i>
Logics . <b>LE65.Gate In1-I</b>	<i>State of the module input: Assignment of the Input Signal</i>
Logics . <b>LE65.Gate In2-I</b>	<i>State of the module input: Assignment of the Input Signal</i>
Logics . <b>LE65.Gate In3-I</b>	<i>State of the module input: Assignment of the Input Signal</i>
Logics . <b>LE65.Gate In4-I</b>	<i>State of the module input: Assignment of the Input Signal</i>
Logics . <b>LE65.Reset Latch-I</b>	<i>State of the module input: Reset Signal for the Latching</i>
Logics . <b>LE66.Gate Out</b>	<i>Signal: Output of the logic gate</i>
Logics . <b>LE66.Timer Out</b>	<i>Signal: Timer Output</i>

<b>1..n, Assignment List</b>	<b>Description</b>
Logics . <b>LE66.Out</b>	<i>Signal: Latched Output (Q)</i>
Logics . <b>LE66.Out inverted</b>	<i>Signal: Negated Latched Output (Q NOT)</i>
Logics . <b>LE66.Gate In1-I</b>	<i>State of the module input: Assignment of the Input Signal</i>
Logics . <b>LE66.Gate In2-I</b>	<i>State of the module input: Assignment of the Input Signal</i>
Logics . <b>LE66.Gate In3-I</b>	<i>State of the module input: Assignment of the Input Signal</i>
Logics . <b>LE66.Gate In4-I</b>	<i>State of the module input: Assignment of the Input Signal</i>
Logics . <b>LE66.Reset Latch-I</b>	<i>State of the module input: Reset Signal for the Latching</i>
Logics . <b>LE67.Gate Out</b>	<i>Signal: Output of the logic gate</i>
Logics . <b>LE67.Timer Out</b>	<i>Signal: Timer Output</i>
Logics . <b>LE67.Out</b>	<i>Signal: Latched Output (Q)</i>
Logics . <b>LE67.Out inverted</b>	<i>Signal: Negated Latched Output (Q NOT)</i>
Logics . <b>LE67.Gate In1-I</b>	<i>State of the module input: Assignment of the Input Signal</i>
Logics . <b>LE67.Gate In2-I</b>	<i>State of the module input: Assignment of the Input Signal</i>
Logics . <b>LE67.Gate In3-I</b>	<i>State of the module input: Assignment of the Input Signal</i>
Logics . <b>LE67.Gate In4-I</b>	<i>State of the module input: Assignment of the Input Signal</i>
Logics . <b>LE67.Reset Latch-I</b>	<i>State of the module input: Reset Signal for the Latching</i>
Logics . <b>LE68.Gate Out</b>	<i>Signal: Output of the logic gate</i>
Logics . <b>LE68.Timer Out</b>	<i>Signal: Timer Output</i>
Logics . <b>LE68.Out</b>	<i>Signal: Latched Output (Q)</i>
Logics . <b>LE68.Out inverted</b>	<i>Signal: Negated Latched Output (Q NOT)</i>
Logics . <b>LE68.Gate In1-I</b>	<i>State of the module input: Assignment of the Input Signal</i>
Logics . <b>LE68.Gate In2-I</b>	<i>State of the module input: Assignment of the Input Signal</i>
Logics . <b>LE68.Gate In3-I</b>	<i>State of the module input: Assignment of the Input Signal</i>
Logics . <b>LE68.Gate In4-I</b>	<i>State of the module input: Assignment of the Input Signal</i>
Logics . <b>LE68.Reset Latch-I</b>	<i>State of the module input: Reset Signal for the Latching</i>
Logics . <b>LE69.Gate Out</b>	<i>Signal: Output of the logic gate</i>
Logics . <b>LE69.Timer Out</b>	<i>Signal: Timer Output</i>
Logics . <b>LE69.Out</b>	<i>Signal: Latched Output (Q)</i>

<b>1..n, Assignment List</b>	<b>Description</b>
Logics . <b>LE69.Out inverted</b>	<i>Signal: Negated Latched Output (Q NOT)</i>
Logics . <b>LE69.Gate In1-I</b>	<i>State of the module input: Assignment of the Input Signal</i>
Logics . <b>LE69.Gate In2-I</b>	<i>State of the module input: Assignment of the Input Signal</i>
Logics . <b>LE69.Gate In3-I</b>	<i>State of the module input: Assignment of the Input Signal</i>
Logics . <b>LE69.Gate In4-I</b>	<i>State of the module input: Assignment of the Input Signal</i>
Logics . <b>LE69.Reset Latch-I</b>	<i>State of the module input: Reset Signal for the Latching</i>
Logics . <b>LE70.Gate Out</b>	<i>Signal: Output of the logic gate</i>
Logics . <b>LE70.Timer Out</b>	<i>Signal: Timer Output</i>
Logics . <b>LE70.Out</b>	<i>Signal: Latched Output (Q)</i>
Logics . <b>LE70.Out inverted</b>	<i>Signal: Negated Latched Output (Q NOT)</i>
Logics . <b>LE70.Gate In1-I</b>	<i>State of the module input: Assignment of the Input Signal</i>
Logics . <b>LE70.Gate In2-I</b>	<i>State of the module input: Assignment of the Input Signal</i>
Logics . <b>LE70.Gate In3-I</b>	<i>State of the module input: Assignment of the Input Signal</i>
Logics . <b>LE70.Gate In4-I</b>	<i>State of the module input: Assignment of the Input Signal</i>
Logics . <b>LE70.Reset Latch-I</b>	<i>State of the module input: Reset Signal for the Latching</i>
Logics . <b>LE71.Gate Out</b>	<i>Signal: Output of the logic gate</i>
Logics . <b>LE71.Timer Out</b>	<i>Signal: Timer Output</i>
Logics . <b>LE71.Out</b>	<i>Signal: Latched Output (Q)</i>
Logics . <b>LE71.Out inverted</b>	<i>Signal: Negated Latched Output (Q NOT)</i>
Logics . <b>LE71.Gate In1-I</b>	<i>State of the module input: Assignment of the Input Signal</i>
Logics . <b>LE71.Gate In2-I</b>	<i>State of the module input: Assignment of the Input Signal</i>
Logics . <b>LE71.Gate In3-I</b>	<i>State of the module input: Assignment of the Input Signal</i>
Logics . <b>LE71.Gate In4-I</b>	<i>State of the module input: Assignment of the Input Signal</i>
Logics . <b>LE71.Reset Latch-I</b>	<i>State of the module input: Reset Signal for the Latching</i>
Logics . <b>LE72.Gate Out</b>	<i>Signal: Output of the logic gate</i>
Logics . <b>LE72.Timer Out</b>	<i>Signal: Timer Output</i>
Logics . <b>LE72.Out</b>	<i>Signal: Latched Output (Q)</i>
Logics . <b>LE72.Out inverted</b>	<i>Signal: Negated Latched Output (Q NOT)</i>

<b>1..n, Assignment List</b>	<b>Description</b>
Logics . <b>LE72.Gate In1-I</b>	<i>State of the module input: Assignment of the Input Signal</i>
Logics . <b>LE72.Gate In2-I</b>	<i>State of the module input: Assignment of the Input Signal</i>
Logics . <b>LE72.Gate In3-I</b>	<i>State of the module input: Assignment of the Input Signal</i>
Logics . <b>LE72.Gate In4-I</b>	<i>State of the module input: Assignment of the Input Signal</i>
Logics . <b>LE72.Reset Latch-I</b>	<i>State of the module input: Reset Signal for the Latching</i>
Logics . <b>LE73.Gate Out</b>	<i>Signal: Output of the logic gate</i>
Logics . <b>LE73.Timer Out</b>	<i>Signal: Timer Output</i>
Logics . <b>LE73.Out</b>	<i>Signal: Latched Output (Q)</i>
Logics . <b>LE73.Out inverted</b>	<i>Signal: Negated Latched Output (Q NOT)</i>
Logics . <b>LE73.Gate In1-I</b>	<i>State of the module input: Assignment of the Input Signal</i>
Logics . <b>LE73.Gate In2-I</b>	<i>State of the module input: Assignment of the Input Signal</i>
Logics . <b>LE73.Gate In3-I</b>	<i>State of the module input: Assignment of the Input Signal</i>
Logics . <b>LE73.Gate In4-I</b>	<i>State of the module input: Assignment of the Input Signal</i>
Logics . <b>LE73.Reset Latch-I</b>	<i>State of the module input: Reset Signal for the Latching</i>
Logics . <b>LE74.Gate Out</b>	<i>Signal: Output of the logic gate</i>
Logics . <b>LE74.Timer Out</b>	<i>Signal: Timer Output</i>
Logics . <b>LE74.Out</b>	<i>Signal: Latched Output (Q)</i>
Logics . <b>LE74.Out inverted</b>	<i>Signal: Negated Latched Output (Q NOT)</i>
Logics . <b>LE74.Gate In1-I</b>	<i>State of the module input: Assignment of the Input Signal</i>
Logics . <b>LE74.Gate In2-I</b>	<i>State of the module input: Assignment of the Input Signal</i>
Logics . <b>LE74.Gate In3-I</b>	<i>State of the module input: Assignment of the Input Signal</i>
Logics . <b>LE74.Gate In4-I</b>	<i>State of the module input: Assignment of the Input Signal</i>
Logics . <b>LE74.Reset Latch-I</b>	<i>State of the module input: Reset Signal for the Latching</i>
Logics . <b>LE75.Gate Out</b>	<i>Signal: Output of the logic gate</i>
Logics . <b>LE75.Timer Out</b>	<i>Signal: Timer Output</i>
Logics . <b>LE75.Out</b>	<i>Signal: Latched Output (Q)</i>
Logics . <b>LE75.Out inverted</b>	<i>Signal: Negated Latched Output (Q NOT)</i>
Logics . <b>LE75.Gate In1-I</b>	<i>State of the module input: Assignment of the Input Signal</i>

<b>1..n, Assignment List</b>	<b>Description</b>
Logics . <b>LE75.Gate In2-I</b>	<i>State of the module input: Assignment of the Input Signal</i>
Logics . <b>LE75.Gate In3-I</b>	<i>State of the module input: Assignment of the Input Signal</i>
Logics . <b>LE75.Gate In4-I</b>	<i>State of the module input: Assignment of the Input Signal</i>
Logics . <b>LE75.Reset Latch-I</b>	<i>State of the module input: Reset Signal for the Latching</i>
Logics . <b>LE76.Gate Out</b>	<i>Signal: Output of the logic gate</i>
Logics . <b>LE76.Timer Out</b>	<i>Signal: Timer Output</i>
Logics . <b>LE76.Out</b>	<i>Signal: Latched Output (Q)</i>
Logics . <b>LE76.Out inverted</b>	<i>Signal: Negated Latched Output (Q NOT)</i>
Logics . <b>LE76.Gate In1-I</b>	<i>State of the module input: Assignment of the Input Signal</i>
Logics . <b>LE76.Gate In2-I</b>	<i>State of the module input: Assignment of the Input Signal</i>
Logics . <b>LE76.Gate In3-I</b>	<i>State of the module input: Assignment of the Input Signal</i>
Logics . <b>LE76.Gate In4-I</b>	<i>State of the module input: Assignment of the Input Signal</i>
Logics . <b>LE76.Reset Latch-I</b>	<i>State of the module input: Reset Signal for the Latching</i>
Logics . <b>LE77.Gate Out</b>	<i>Signal: Output of the logic gate</i>
Logics . <b>LE77.Timer Out</b>	<i>Signal: Timer Output</i>
Logics . <b>LE77.Out</b>	<i>Signal: Latched Output (Q)</i>
Logics . <b>LE77.Out inverted</b>	<i>Signal: Negated Latched Output (Q NOT)</i>
Logics . <b>LE77.Gate In1-I</b>	<i>State of the module input: Assignment of the Input Signal</i>
Logics . <b>LE77.Gate In2-I</b>	<i>State of the module input: Assignment of the Input Signal</i>
Logics . <b>LE77.Gate In3-I</b>	<i>State of the module input: Assignment of the Input Signal</i>
Logics . <b>LE77.Gate In4-I</b>	<i>State of the module input: Assignment of the Input Signal</i>
Logics . <b>LE77.Reset Latch-I</b>	<i>State of the module input: Reset Signal for the Latching</i>
Logics . <b>LE78.Gate Out</b>	<i>Signal: Output of the logic gate</i>
Logics . <b>LE78.Timer Out</b>	<i>Signal: Timer Output</i>
Logics . <b>LE78.Out</b>	<i>Signal: Latched Output (Q)</i>
Logics . <b>LE78.Out inverted</b>	<i>Signal: Negated Latched Output (Q NOT)</i>
Logics . <b>LE78.Gate In1-I</b>	<i>State of the module input: Assignment of the Input Signal</i>
Logics . <b>LE78.Gate In2-I</b>	<i>State of the module input: Assignment of the Input Signal</i>

<b>1..n, Assignment List</b>	<b>Description</b>
Logics . <b>LE78.Gate In3-I</b>	<i>State of the module input: Assignment of the Input Signal</i>
Logics . <b>LE78.Gate In4-I</b>	<i>State of the module input: Assignment of the Input Signal</i>
Logics . <b>LE78.Reset Latch-I</b>	<i>State of the module input: Reset Signal for the Latching</i>
Logics . <b>LE79.Gate Out</b>	<i>Signal: Output of the logic gate</i>
Logics . <b>LE79.Timer Out</b>	<i>Signal: Timer Output</i>
Logics . <b>LE79.Out</b>	<i>Signal: Latched Output (Q)</i>
Logics . <b>LE79.Out inverted</b>	<i>Signal: Negated Latched Output (Q NOT)</i>
Logics . <b>LE79.Gate In1-I</b>	<i>State of the module input: Assignment of the Input Signal</i>
Logics . <b>LE79.Gate In2-I</b>	<i>State of the module input: Assignment of the Input Signal</i>
Logics . <b>LE79.Gate In3-I</b>	<i>State of the module input: Assignment of the Input Signal</i>
Logics . <b>LE79.Gate In4-I</b>	<i>State of the module input: Assignment of the Input Signal</i>
Logics . <b>LE79.Reset Latch-I</b>	<i>State of the module input: Reset Signal for the Latching</i>
Logics . <b>LE80.Gate Out</b>	<i>Signal: Output of the logic gate</i>
Logics . <b>LE80.Timer Out</b>	<i>Signal: Timer Output</i>
Logics . <b>LE80.Out</b>	<i>Signal: Latched Output (Q)</i>
Logics . <b>LE80.Out inverted</b>	<i>Signal: Negated Latched Output (Q NOT)</i>
Logics . <b>LE80.Gate In1-I</b>	<i>State of the module input: Assignment of the Input Signal</i>
Logics . <b>LE80.Gate In2-I</b>	<i>State of the module input: Assignment of the Input Signal</i>
Logics . <b>LE80.Gate In3-I</b>	<i>State of the module input: Assignment of the Input Signal</i>
Logics . <b>LE80.Gate In4-I</b>	<i>State of the module input: Assignment of the Input Signal</i>
Logics . <b>LE80.Reset Latch-I</b>	<i>State of the module input: Reset Signal for the Latching</i>
Sgen . <b>Manual Start</b>	<i>Fault Simulation has been started manually.</i>
Sgen . <b>Manual Stop</b>	<i>Fault Simulation has been stopped manually.</i>
Sgen . <b>Running</b>	<i>Signal; Measuring value simulation is running</i>
Sgen . <b>Started</b>	<i>Fault Simulation has been started</i>
Sgen . <b>Stopped</b>	<i>Fault Simulation has been stopped</i>
Sgen . <b>Ex Start Simulation-I</b>	<i>State of the module input: External Start of Fault Simulation (Using the test parameters)</i>
Sgen . <b>ExBlo1-I</b>	<i>Module input state: External blocking1</i>




<b>1..n, Assignment List</b>	<b>Description</b>
Sgen . <b>ExBlo2-I</b>	<i>Module input state: External blocking2</i>
Sgen . <b>Ex ForcePost-I</b>	<i>State of the module input:Force Post state. Abort simulation.</i>
Sys . <b>PS 1</b>	<i>Signal: The currently active Parameter Set is PS 1</i>
Sys . <b>PS 2</b>	<i>Signal: The currently active Parameter Set is PS 2</i>
Sys . <b>PS 3</b>	<i>Signal: The currently active Parameter Set is PS 3</i>
Sys . <b>PS 4</b>	<i>Signal: The currently active Parameter Set is PS 4</i>
Sys . <b>PSS manual</b>	<i>Signal: Manual Switch over of a Parameter Set</i>
Sys . <b>PSS via Scada</b>	<i>Signal: Parameter Set Switch via Scada. Write into this output byte the integer of the parameter set that should become active (e.g. 4 =&gt; Switch onto parameter set 4).</i>
Sys . <b>PSS via Inp fct</b>	<i>Signal: Parameter Set Switch via input function</i>
Sys . <b>min 1 param changed</b>	<i>Signal: At least one parameter has been changed</i>
Sys . <b>Setting Lock Bypass</b>	<i>Signal: Short-period unlock of the Setting Lock</i>
Sys . <b>Ack LED</b>	<i>Signal: LEDs acknowledgement</i>
Sys . <b>Ack BO</b>	<i>Signal: Acknowledgement of the Binary Outputs</i>
Sys . <b>Ack Scada</b>	<i>Signal: Acknowledge latched SCADA signals</i>
Sys . <b>Ack TripCmd</b>	<i>Signal: Reset Trip Command</i>
Sys . <b>Ack LED-HMI</b>	<i>Signal: LEDs acknowledgement :HMI</i>
Sys . <b>Ack BO-HMI</b>	<i>Signal: Acknowledgement of the Binary Outputs :HMI</i>
Sys . <b>Ack Scada-HMI</b>	<i>Signal: Acknowledge latched SCADA signals :HMI</i>
Sys . <b>Ack TripCmd-HMI</b>	<i>Signal: Reset Trip Command :HMI</i>
Sys . <b>Ack LED-Sca</b>	<i>Signal: LEDs acknowledgement :SCADA</i>
Sys . <b>Ack BO-Sca</b>	<i>Signal: Acknowledgement of the Binary Outputs :SCADA</i>
Sys . <b>Ack Counter-Sca</b>	<i>Signal: Reset of all Counters :SCADA</i>
Sys . <b>Ack Scada-Sca</b>	<i>Signal: Acknowledge latched SCADA signals :SCADA</i>
Sys . <b>Ack TripCmd-Sca</b>	<i>Signal: Reset Trip Command :SCADA</i>
Sys . <b>Res OperationsCr</b>	<i>Signal:: Res OperationsCr</i>
Sys . <b>Res AlarmCr</b>	<i>Signal:: Res AlarmCr</i>
Sys . <b>Res TripCmdCr</b>	<i>Signal:: Res TripCmdCr</i>
Sys . <b>Res TotalCr</b>	<i>Signal:: Res TotalCr</i>
Sys . <b>Ack LED-I</b>	<i>Module input state: LEDs acknowledgement by digital input</i>



<b>1..n, Assignment List</b>	<b>Description</b>
Sys . <b>Ack BO-I</b>	<i>Module input state: Acknowledgement of the binary Output Relays</i>
Sys . <b>Ack Scada-I</b>	<i>Module input state: Acknowledge latched SCADA signals.</i>
Sys . <b>PS1-I</b>	<i>State of the module input respectively of the signal, that should activate this Parameter Setting Group.</i>
Sys . <b>PS2-I</b>	<i>State of the module input respectively of the signal, that should activate this Parameter Setting Group.</i>
Sys . <b>PS3-I</b>	<i>State of the module input respectively of the signal, that should activate this Parameter Setting Group.</i>
Sys . <b>PS4-I</b>	<i>State of the module input respectively of the signal, that should activate this Parameter Setting Group.</i>
Sys . <b>Internal test state</b>	<i>Auxiliary state for testing purposes.</i>

### **1...n Operating Modes**

Selection list referenced by the following parameters:

-  BO Slot X2 . Operating Mode
-  BO Slot X2 . Operating Mode
-  BO Slot X2 . Operating Mode

<b>1...n Operating Modes</b>	<b>Description</b>
<b>Normally open (NO)</b>	<i>The working principle of the relay corresponds to a normally open contact.</i>
<b>Normally closed (NC)</b>	<i>The working principle of the relay corresponds to a normally closed contact.</i>

### **1..n, AnalogOutputList**

Selection list referenced by the following parameters:

-  AnOut[1] . Assignment

<b>1..n, AnalogOutputList</b>	<b>Description</b>
<b>"_"</b>	<i>No assignment</i>
CT . <b>IL1 RMS</b>	<i>Measured value: Phase current (RMS)</i>
CT . <b>IL2 RMS</b>	<i>Measured value: Phase current (RMS)</i>

<b>1..n, AnalogOutputList</b>	<b>Description</b>
CT . <b>IL3 RMS</b>	<i>Measured value: Phase current (RMS)</i>
CT . <b>IG meas RMS</b>	<i>Measured value (measured): IG (RMS)</i>
CT . <b>IG calc RMS</b>	<i>Measured value (calculated): IG (RMS)</i>
CT . <b>I1</b>	<i>Measured value (calculated): Positive phase sequence current (fundamental)</i>
CT . <b>I2</b>	<i>Measured value (calculated): Unbalanced load current (fundamental)</i>
CT . <b>%IL1 THD</b>	<i>Measured value (calculated): IL1 Total Harmonic Distortion</i>
CT . <b>%IL2 THD</b>	<i>Measured value (calculated): IL2 Total Harmonic Distortion</i>
CT . <b>%IL3 THD</b>	<i>Measured value (calculated): IL3 Total Harmonic Distortion</i>
CT . <b>IL1 THD</b>	<i>Measured value (calculated): IL1 Total Harmonic Current</i>
CT . <b>IL2 THD</b>	<i>Measured value (calculated): IL2 Total Harmonic Current</i>
CT . <b>IL3 THD</b>	<i>Measured value (calculated): IL3 Total Harmonic Current</i>
MStart . <b>IL1 Ib</b>	<i>Measured value: Phase current as multiple of Ib</i>
MStart . <b>IL2 Ib</b>	<i>Measured value: Phase current as multiple of Ib</i>
MStart . <b>IL3 Ib</b>	<i>Measured value: Phase current as multiple of Ib</i>
MStart . <b>I3 P (%Ib) avg</b>	<i>Average RMS current of all 3 phases as percentages of Ib</i>
MStart . <b>I3P Fla Demand</b>	<i>RMS current of all 3 phases calculated in a fixed demand window as percentages of Ib</i>
ThR . <b>I2T Used</b>	<i>Thermal capacity used.</i>
ThR . <b>I2T Remained</b>	<i>Thermal capacity remained.</i>
URTD . <b>Windg1</b>	<i>Winding 1</i>
URTD . <b>Windg2</b>	<i>Winding 2</i>
URTD . <b>Windg3</b>	<i>Winding 3</i>
URTD . <b>Windg4</b>	<i>Winding 4</i>
URTD . <b>Windg5</b>	<i>Winding 5</i>
URTD . <b>Windg6</b>	<i>Winding 6</i>
URTD . <b>MotBear1</b>	<i>Motor Bearing 1</i>
URTD . <b>MotBear2</b>	<i>Motor Bearing 2</i>
URTD . <b>LoadBear1</b>	<i>Load Bearing 1</i>
URTD . <b>LoadBear2</b>	<i>Load Bearing 2</i>
URTD . <b>Aux1</b>	<i>Auxiliary1</i>
URTD . <b>Aux2</b>	<i>Auxiliary2</i>
URTD . <b>RTD Max</b>	<i>Maximum temperature of all channels.</i>

1..n, AnalogOutputList	Description
RTD . <b>HottestWindingTemp</b>	<i>Hottest motor winding temperature in degrees C.</i>
RTD . <b>Hottest MotBearTemp</b>	<i>Hottest motor bearing temperature in degrees C.</i>

### **Type of Output**

Type of Output: Select the output range and type

Selection list referenced by the following parameters:

-  AnOut[1] . Range

Type of Output	Description
<b>0...20mA</b>	<i>0...20mA</i>
<b>4...20mA</b>	<i>4...20mA</i>

### **Mode**

general operation mode







Selection list referenced by the following parameters:

-  LEDs group A . Latched
-  LEDs group A . Latched
-  LEDs group A . Latched
-  LEDs group A . Latched
-  LEDs group A . Latched
-  LEDs group A . Latched
- *[...]*

Mode	Description
<b>inactive</b>	<i>inactive</i>
<b>active</b>	<i>active</i>
<b>active, ack. by alarm</b>	<i>Latching of LEDs is active, but will be acknowledged (reset) automatically (by a protection function) in case of a new alarm.</i>

**LED active color**

Selection list referenced by the following parameters:

-  LEDs group A . LED active color
-  LEDs group A . LED inactive color
-  LEDs group A . LED active color
-  LEDs group A . LED inactive color
-  LEDs group A . LED active color
-  LEDs group A . LED inactive color
- [...]

LED active color	Description
green	<i>green</i>
red	<i>red</i>
red flash	<i>red flashing</i>
green flash	<i>green blinking</i>
“_”	<i>No assignment</i>

**Ack via »C« key**

Select which acknowledgeable elements can be reset via pressing the »C« key.

Selection list referenced by the following parameters:

-  Sys . Ack via »C« key

Ack via »C« key	Description
<b>Nothing</b>	<i>No elements can be simply reset via pressing the »C« key for a long time (ca. 1 second). This has the consequence that pressing the »C« key is only a shortcut to the Acknowledge menu, from which the user has to select the elements to be reset.</i>
<b>Ack LEDs w/o passw.</b>	<i>All LEDs are acknowledged (reset) via pressing the »C« key for ca. 1 second. No password has to be entered for this. The reset activity can be recognized from the fact that it always includes an LED test, i.e. all LEDs flash in red color for a second, then flash in green color for a second.</i>
<b>Ack LEDs</b>	<i>All LEDs are reset via pressing the »C« key (for ca. 1 second). The reset activity can be recognized from the fact that it always includes an LED</i>

<b>Ack via »C« key</b>	<b>Description</b>
	<i>test, i.e. all LEDs flash in red color for a second, then flash in green color for a second.</i>
<b>Ack LEDs and relays</b>	<i>All LEDs and all acknowledgeable binary output relays are reset via pressing the »C« key (for ca. 1 second). The reset activity can be recognized from the fact that it always includes an LED test, i.e. all LEDs flash in red color for a second, then flash in green color for a second.</i>
<b>Ack Everything</b>	<p><i>All acknowledgeable elements are reset via pressing the »C« key (for ca. 1 second):</i></p> <ul style="list-style-type: none"> <li>- <i>All LEDs, and</i></li> <li>- <i>all binary output relays, and</i></li> <li>- <i>all latched SCADA signals, and</i></li> <li>- <i>the Trip command.</i></li> </ul> <p><i>The reset activity can be recognized from the fact that it always includes an LED test, i.e. all LEDs flash in red color for a second, then flash in green color for a second.</i></p>

**Duration**

Recording time

Selection list referenced by the following parameters:

-  [Statistics . Start I Demand via:](#)

<b>Duration</b>	<b>Description</b>
<b>Duration</b>	<i>Recording time</i>
<b>StartFct</b>	<i>Start function</i>

**Duration**

Recording time

Selection list referenced by the following parameters:

-  [Statistics . Duration I Demand](#)

<b>Duration</b>	<b>Description</b>
<b>2 s</b>	<i>s</i>

<b>Duration</b>	<b>Description</b>
<b>5 s</b>	<i>s</i>
<b>10 s</b>	<i>s</i>
<b>15 s</b>	<i>seconds</i>
<b>30 s</b>	<i>seconds</i>
<b>1 min</b>	<i>minute</i>
<b>5 min</b>	<i>minute</i>
<b>10 min</b>	<i>minute</i>
<b>15 min</b>	<i>minute</i>
<b>30 min</b>	<i>minute</i>
<b>1 h</b>	<i>Hours</i>
<b>2 h</b>	<i>Hours</i>
<b>6 h</b>	<i>Hours</i>
<b>12 h</b>	<i>Hours</i>
<b>1 d</b>	<i>days</i>
<b>2 d</b>	<i>days</i>
<b>5 d</b>	<i>days</i>
<b>7 d</b>	<i>days</i>
<b>10 d</b>	<i>days</i>
<b>30 d</b>	<i>days</i>

### **Window configuration**

Selection list referenced by the following parameters:

-  **Statistics . Window I Demand**

<b>Window configuration</b>	<b>Description</b>
<b>sliding</b>	<i>Moving mean: Continuously the newest measuring value is added and the oldest measuring value is removed from the moving mean (average value).</i>
<b>fixed</b>	<i>The average value is calculated for a fixed window.</i>

### **Selection**

Selection list referenced by the following parameters:

-  HMI . Menu language

<b>Selection</b>	<b>Description</b>
<b>English</b>	<i>English</i>
<b>German</b>	<i>German</i>
<b>Russian</b>	<i>Russian</i>
<b>Polish</b>	<i>Polish</i>
<b>French</b>	<i>French</i>
<b>Portuguese</b>	<i>Portuguese</i>
<b>Spanish</b>	<i>Spanish</i>
<b>Romanian</b>	<i>Romanian</i>

### **Record-Mode**

Recorder Mode (Set the behaviour of the recorder)

Selection list referenced by the following parameters:

-  Fault rec . Record-Mode

<b>Record-Mode</b>	<b>Description</b>
<b>Alarms and Trips</b>	<i>A recording is started in case of an alarm or a trip.</i>
<b>Trips only</b>	<i>A recording is started only in case of a trip.</i>

### **Resolution**

Resolution (recording frequency)

Selection list referenced by the following parameters:

-  Start rec . Resolution

<b>Resolution</b>	<b>Description</b>
<b>50ms</b>	<i>The resolution is: 50ms</i>
<b>100ms</b>	<i>The resolution is: 100ms</i>

Resolution	Description
1s	The resolution is: 1s

**Resolution**

Resolution (recording frequency)







Selection list referenced by the following parameters:

-  Trend rec . Resolution

Resolution	Description
60 min	Add next entry: 60 min
30 min	Add next entry: 30 min
15 min	Add next entry: 15 min
10 min	Add next entry: 10 min
5 min	Add next entry: 5 min

**1..n, TrendRecList**

Selection list referenced by the following parameters:

-  DNP3 . Analog value 0
-  Modbus . Mapped Meas 1
-  Trend rec . Trend1
-  Trend rec . Trend2
-  Trend rec . Trend3
-  Trend rec . Trend4
- [...]

1..n, TrendRecList	Description
“_”	No assignment
CT . IL1	Measured value: Phase current (fundamental)
CT . IL2	Measured value: Phase current (fundamental)
CT . IL3	Measured value: Phase current (fundamental)



<b>1..n, TrendRecList</b>	<b>Description</b>
CT . <b>IG meas</b>	<i>Measured value (measured): IG (fundamental)</i>
CT . <b>IG calc</b>	<i>Measured value (calculated): IG (fundamental)</i>
CT . <b>IL1 RMS</b>	<i>Measured value: Phase current (RMS)</i>
CT . <b>IL2 RMS</b>	<i>Measured value: Phase current (RMS)</i>
CT . <b>IL3 RMS</b>	<i>Measured value: Phase current (RMS)</i>
CT . <b>IG meas RMS</b>	<i>Measured value (measured): IG (RMS)</i>
CT . <b>IG calc RMS</b>	<i>Measured value (calculated): IG (RMS)</i>
CT . <b>I0</b>	<i>Measured value (calculated): Zero current (fundamental)</i>
CT . <b>I1</b>	<i>Measured value (calculated): Positive phase sequence current (fundamental)</i>
CT . <b>I2</b>	<i>Measured value (calculated): Unbalanced load current (fundamental)</i>
CT . <b>%(I2/I1)</b>	<i>Measured value (calculated): I2/I1, phase sequence will be taken into account automatically.</i>
CT . <b>%(I2/I1) max</b>	<i>Measured value (calculated): I2/I1 maximum value, phase sequence will be taken into account automatically</i>
CT . <b>IL1 avg RMS</b>	<i>IL1 average value (RMS)</i>
CT . <b>IL2 avg RMS</b>	<i>IL2 average value (RMS)</i>
CT . <b>IL3 avg RMS</b>	<i>IL3 average value (RMS)</i>
CT . <b>IL1 THD</b>	<i>Measured value (calculated): IL1 Total Harmonic Current</i>
CT . <b>IL2 THD</b>	<i>Measured value (calculated): IL2 Total Harmonic Current</i>
CT . <b>IL3 THD</b>	<i>Measured value (calculated): IL3 Total Harmonic Current</i>
MStart . <b>IL1 Ib</b>	<i>Measured value: Phase current as multiple of Ib</i>
ThR . <b>I2T Used</b>	<i>Thermal capacity used.</i>
URTD . <b>Windg1</b>	<i>Winding 1</i>
URTD . <b>Windg1 max</b>	<i>Winding1 Maximum Value</i>
URTD . <b>Windg2</b>	<i>Winding 2</i>
URTD . <b>Windg2 max</b>	<i>Winding2 Maximum Value</i>
URTD . <b>Windg3</b>	<i>Winding 3</i>
URTD . <b>Windg3 max</b>	<i>Winding3 Maximum Value</i>
URTD . <b>Windg4</b>	<i>Winding 4</i>
URTD . <b>Windg4 max</b>	<i>Winding4 Maximum Value</i>
URTD . <b>Windg5</b>	<i>Winding 5</i>
URTD . <b>Windg5 max</b>	<i>Winding5 Maximum Value</i>

<b>1..n, TrendRecList</b>	<b>Description</b>
URTD . <b>Windg6</b>	<i>Winding 6</i>
URTD . <b>Windg6 max</b>	<i>Winding6 Maximum Value</i>
URTD . <b>MotBear1</b>	<i>Motor Bearing 1</i>
URTD . <b>MotBear1 max</b>	<i>Motor Bearing1 Maximum Value</i>
URTD . <b>MotBear2</b>	<i>Motor Bearing 2</i>
URTD . <b>MotBear2 max</b>	<i>Motor Bearing2 Maximum Value</i>
URTD . <b>LoadBear1</b>	<i>Load Bearing 1</i>
URTD . <b>LoadBear1 max</b>	<i>Load Bearing1 Maximum Value</i>
URTD . <b>LoadBear2</b>	<i>Load Bearing 2</i>
URTD . <b>LoadBear2 max</b>	<i>Load Bearing2 Maximum Value</i>
URTD . <b>Aux1</b>	<i>Auxiliary1</i>
URTD . <b>Aux1 max</b>	<i>Auxiliary1 Maximum Value</i>
URTD . <b>Aux2</b>	<i>Auxiliary2</i>
URTD . <b>Aux2 max</b>	<i>Auxiliary2 Maximum Value</i>
URTD . <b>RTD Max</b>	<i>Maximum temperature of all channels.</i>
RTD . <b>HottestWindingTemp</b>	<i>Hottest motor winding temperature in degrees C.</i>
RTD . <b>Hottest MotBearTemp</b>	<i>Hottest motor bearing temperature in degrees C.</i>
RTD . <b>Hottest LoadBearTemp</b>	<i>Hottest load bearing temperature in degrees C.</i>
RTD . <b>Hottest Aux Temp</b>	<i>Hottest Auxiliary temperature in degrees C.</i>

**1..n, OnOffList**


Selection list referenced by the following parameters:

-  IEC 61850 . Function

<b>1..n, OnOffList</b>	<b>Description</b>
<b>inactive</b>	<i>inactive</i>
<b>active</b>	<i>active</i>

**Baud rate**

Selection list referenced by the following parameters:

-  DNP3 . Baud rate

Baud rate	Description
1200	1200
2400	2400
4800	4800
9600	9600
19200	19200
38400	38400
57600	57600
115200	115200

**Byte Frame**

Selection list referenced by the following parameters:

-  DNP3 . Frame Layout

Byte Frame	Description
8E1	8 data bits, even parity, 1 stopbit.
8O1	8 data bits, odd, 1 stopbit.
8N1	8 data bits, no parity, 1 stopbit.
8N2	8 data bits, no parity, 2 stopbits.

**Optical rest position**

Selection list referenced by the following parameters:

-  DNP3 . Optical rest position

Optical rest position	Description
Light off	Light off
Light on	Light on

**Communication Start Variants**

Selection list referenced by the following parameters:

-  DNP3 . DataLink confirm

Communication Start Variants	Description
<b>Never</b>	<i>Option Never is recommended</i>
<b>Always</b>	<i>If this variable is set to Always then LinkLayer needs to establish a connection before sending any Frame.</i>
<b>On_Large</b>	<i>If set to On_Large then a connection needs to be established before sending the first Frame of a multi Term Message</i>

**\_AL\_ResponseType\_k**

\_AL\_ResponseType\_h

Selection list referenced by the following parameters:

-  DNP3 . AppLink confirm

<u>_AL_ResponseType_k</u>	Description
<b>Never</b>	<i>Never</i>
<b>Always</b>	<i>Always</i>
<b>Event</b>	<i>Event</i>

**1..n, Assignment List**

Assignment List

Selection list referenced by the following parameters:

-  DNP3 . DoubleBitInput 0

1..n, Assignment List	Description
<b>"_"</b>	<i>No assignment</i>
<b>SG[1] . Pos</b>	<i>Signal: Circuit Breaker Position (0 = Indeterminate, 1 = OFF, 2 = ON, 3 = Disturbed)</i>

**1..n, Assignment List**

Assignment List

Selection list referenced by the following parameters:

-  DNP3 . BinaryCounter 0

<b>1..n, Assignment List</b>	<b>Description</b>
<b>"_"</b>	<i>No assignment</i>
<b>Prot . FaultNo</b>	<i>Fault number</i>
<b>Prot . No. of Grid Fault</b>	<i>Number of grid fault: A grid fault, e.g. a short circuit, might cause several faults with trip and autoreclosing; in this case, the fault number counts each fault, but the grid fault number remains the same.</i>
<b>SG[1] . TripCmd Cr</b>	<i>Counter: Total number of trips of the switchgear.</i>
<b>MStart . StartPerHour</b>	<i>StartPerHour</i>
<b>MStart . SPH Release</b>	<i>In case that the Motor is blocked by a SPH blocking, this timer needs to be expired before the blocking is released and the next motor start is permitted. The next Motor Start will increment the SPH counter again.</i>
<b>MStart . ColdStartPermit</b>	<i>Number of cold starts remaining</i>
<b>MStart . OCNT</b>	<i>Motor Operation count since last reset.</i>
<b>MStart . RunTime</b>	<i>Motor Operation time since last reset.</i>
<b>MStart . nEmrgOvr</b>	<i>Number of emergency overrides since last reset.</i>
<b>MStart . TRunTime</b>	<i>Motor Operation (Motor run time) time since last reset.</i>
<b>MStart . TOCS</b>	<i>Total Motor Operation count since last reset.</i>
<b>MStart . nTRNTrips</b>	<i>Number of transition trips since last reset.</i>
<b>MStart . nRevTrips</b>	<i>Number of reverse spinning trips since last reset.</i>
<b>MStart . nZSWTrips</b>	<i>Number of zero speed switch trips since last reset.</i>
<b>MStart . nISQT</b>	<i>Number of incomplete sequence trips since last reset.</i>
<b>MStart . nSPHBlocks</b>	<i>Number of start per hour blocks since last reset.</i>
<b>MStart . nTBSBlocks</b>	<i>Number of time between start blocks since last reset.</i>
<b>Sys . Operating hours Cr</b>	<i>Operating hours counter of the protective device</i>
<b>Sys . Hours Counter</b>	<i>Hours Counter</i>

**Scale Factor**

Multiplier in order to convert float values into integer.

Selection list referenced by the following parameters:

-  DNP3 . Scale Factor 0

Scale Factor	Description
<b>0.001</b>	<i>0.001</i>
<b>0.01</b>	<i>0.01</i>
<b>0.1</b>	<i>0.1</i>
<b>1</b>	<i>1</i>
<b>10</b>	<i>10</i>
<b>100</b>	<i>100</i>
<b>1000</b>	<i>1000</i>
<b>10000</b>	<i>10000</i>
<b>100000</b>	<i>100000</i>
<b>1000000</b>	<i>1000000</i>

**Optical rest position**

Selection list referenced by the following parameters:

-  Modbus . Optical rest position

Optical rest position	Description
<b>Light off</b>	<i>Light off</i>
<b>Light on</b>	<i>Light on</i>

**Port selection**

Selection list referenced by the following parameters:

-  Modbus . TCP Port Config

Port selection	Description
<b>Default</b>	<i>Default Port</i>

Port selection	Description
Private	Private Port

### **Baud rate**

Selection list referenced by the following parameters:

-  Modbus . Baud rate

Baud rate	Description
1200	1200
2400	2400
4800	4800
9600	9600
19200	19200
38400	38400

### **Byte Frame**

Selection list referenced by the following parameters:

-  Modbus . Physical Settings

Byte Frame	Description
8E1	8 data bits, even parity, 1 stopbit.
8O1	8 data bits, odd, 1 stopbit.
8N1	8 data bits, no parity, 1 stopbit.
8N2	8 data bits, no parity, 2 stopbits.

### **Type of SCADA mapping**

This setting decides whether the communication protocol shall use the default mapping of data objects, or some user-defined mapping that has been loaded from a \*.HptSMap file.

Selection list referenced by the following parameters:


-  Modbus . Type of SCADA mapping

Type of SCADA mapping	Description
<b>Standard</b>	<i>Default mapping of data objects</i>
<b>User-defined</b>	<i>User-defined mapping of data objects</i>

**Config status**

Status of the user-defined SCADA configuration.\nPossible values:

Selection list referenced by the following parameters:

-  Modbus . Config status

Config status	Description
<b>Changing</b>	<i>New SCADA configuration is being loaded, but not active yet.</i>
<b>OK</b>	<i>The SCADA configuration is active.</i>
<b>Config. not avail.</b>	<i>The user-defined SCADA configuration is not available (e.g. has not been loaded into the device).</i>
<b>Error</b>	<i>Unexpected error. Please contact our service-team.</i>

**Baud rate**

Selection list referenced by the following parameters:

-  IEC103 . Baud rate

Baud rate	Description
<b>1200</b>	<i>1200</i>
<b>2400</b>	<i>2400</i>
<b>4800</b>	<i>4800</i>
<b>9600</b>	<i>9600</i>
<b>19200</b>	<i>19200</i>
<b>38400</b>	<i>38400</i>
<b>57600</b>	<i>57600</i>



### **Byte Frame**

Selection list referenced by the following parameters:

-  IEC103 . Physical Settings

<b>Byte Frame</b>	<b>Description</b>
<b>8E1</b>	<i>8 data bits, even parity, 1 stopbit.</i>
<b>8O1</b>	<i>8 data bits, odd, 1 stopbit.</i>
<b>8N1</b>	<i>8 data bits, no parity, 1 stopbit.</i>
<b>8N2</b>	<i>8 data bits, no parity, 2 stopbits.</i>

### **Timezone**

Selection whether the timestamps in IEC103 messages shall be given as UTC or local time. (“Local time” always includes the actual daylight saving settings.)

Selection list referenced by the following parameters:

-  IEC103 . Timezone

<b>Timezone</b>	<b>Description</b>
<b>UTC</b>	<i>UTC</i>
<b>Local Time</b>	<i>Local time according to the »Time Zones« setting (in Device Parameters) (incl. daylight saving settings).</i>

### **Optical rest position**

Selection list referenced by the following parameters:

-  IEC103 . Optical rest position

<b>Optical rest position</b>	<b>Description</b>
<b>Light off</b>	<i>Light off</i>
<b>Light on</b>	<i>Light on</i>

**Port selection**

Selection list referenced by the following parameters:

-  IEC104 . TCP Port Config

Port selection	Description
Default	Default Port
Private	Private Port

**Timezone**

Selection whether the timestamps in the transmitted communication telegrams shall be given as UTC or local time. (“Local time” always includes the actual daylight saving settings.)

Selection list referenced by the following parameters:

-  IEC104 . Timezone

Timezone	Description
UTC	UTC
Local Time	Local time according to the »Time Zones« setting (in Device Parameters) (incl. daylight saving settings).

**Type of SCADA mapping**

This setting decides whether the communication protocol shall use the default mapping of data objects, or some user-defined mapping that has been loaded from a \*.HptSMap file.

Selection list referenced by the following parameters:

-  IEC104 . Type of SCADA mapping

Type of SCADA mapping	Description
Standard	Default mapping of data objects
User-defined	User-defined mapping of data objects

### Config status

Status of the user-defined SCADA configuration.\nPossible values:

Selection list referenced by the following parameters:

-  IEC104 . Config status

Config status	Description
<b>Changing</b>	<i>New SCADA configuration is being loaded, but not active yet.</i>
<b>OK</b>	<i>The SCADA configuration is active.</i>
<b>Config. not avail.</b>	<i>The user-defined SCADA configuration is not available (e.g. has not been loaded into the device).</i>
<b>Error</b>	<i>Unexpected error. Please contact our service-team.</i>

### Type of SCADA mapping

This setting decides whether the communication protocol shall use the default mapping of data objects, or some user-defined mapping that has been loaded from a \*.HptSMap file.

Selection list referenced by the following parameters:

-  Profibus . Type of SCADA mapping

Type of SCADA mapping	Description
<b>Standard</b>	<i>Default mapping of data objects</i>
<b>User-defined</b>	<i>User-defined mapping of data objects</i>

### Time Zones

Selection list referenced by the following parameters:

-  TimeSync . Time Zones



Time Zones	Description
<b>UTC+14 Kiritimati</b>	<i>UTC+14 Kiritimati</i>
<b>UTC+13 Rawaki</b>	<i>UTC+13 Rawaki</i>
<b>UTC+12.75 Chatham Island</b>	<i>UTC+12.75 Chatham Island</i>

<b>Time Zones</b>	<b>Description</b>
<b>UTC+12 Wellington</b>	<i>UTC+12 Wellington</i>
<b>UTC+11.5 Kingston</b>	<i>UTC+11.5 Kingston</i>
<b>UTC+11 Port Vila</b>	<i>UTC+11 Port Vila</i>
<b>UTC+10.5 Lord Howe Island</b>	<i>UTC+10.5 Lord Howe Island</i>
<b>UTC+10 Sydney</b>	<i>UTC+10 Sydney</i>
<b>UTC+9.5 Adelaide</b>	<i>UTC+9.5 Adelaide</i>
<b>UTC+9 Tokyo</b>	<i>UTC+9 Tokyo</i>
<b>UTC+8 Hong Kong</b>	<i>UTC+8 Hong Kong</i>
<b>UTC+7 Bangkok</b>	<i>UTC+7 Bangkok</i>
<b>UTC+6.5 Rangoon</b>	<i>UTC+6.5 Rangoon</i>
<b>UTC+6 Colombo</b>	<i>UTC+6 Colombo</i>
<b>UTC+5.75 Kathmandu</b>	<i>UTC+5.75 Kathmandu</i>
<b>UTC+5.5 New Delhi</b>	<i>UTC+5.5 New Delhi</i>
<b>UTC+5 Islamabad</b>	<i>UTC+5 Islamabad</i>
<b>UTC+4.5 Kabul</b>	<i>UTC+4.5 Kabul</i>
<b>UTC+4 Abu Dhabi</b>	<i>UTC+4 Abu Dhabi</i>
<b>UTC+3.5 Tehran</b>	<i>UTC+3.5 Tehran</i>
<b>UTC+3 Moscow</b>	<i>UTC+3 Moscow</i>
<b>UTC+2 Athens</b>	<i>UTC+2 Athens</i>
<b>UTC+1 Berlin</b>	<i>UTC+1 Berlin</i>
<b>UTC+0 London</b>	<i>UTC+0 London</i>
<b>UTC-1 Azores</b>	<i>UTC-1 Azores</i>
<b>UTC-2 Fern. d. Noronha</b>	<i>UTC-2 Fern. d. Noronha</i>
<b>UTC-3 Buenos Aires</b>	<i>UTC-3 Buenos Aires</i>
<b>UTC-3.5 St. John's</b>	<i>UTC-3.5 St. John's</i>
<b>UTC-4 Santiago</b>	<i>UTC-4 Santiago</i>
<b>UTC-5 New York</b>	<i>UTC-5 New York</i>
<b>UTC-6 Chicago</b>	<i>UTC-6 Chicago</i>
<b>UTC-7 Salt Lake City</b>	<i>UTC-7 Salt Lake City</i>
<b>UTC-8 Los Angeles</b>	<i>UTC-8 Los Angeles</i>
<b>UTC-9 Anchorage</b>	<i>UTC-9 Anchorage</i>

<b>Time Zones</b>	<b>Description</b>
<b>UTC-9.5 Taiohae</b>	<i>UTC-9.5 Taiohae</i>
<b>UTC-10 Honolulu</b>	<i>UTC-10 Honolulu</i>
<b>UTC-11 Midway Islands</b>	<i>UTC-11 Midway Islands</i>

### ***Month of clock change***



Selection list referenced by the following parameters:

-  TimeSync . Summertime m
-  TimeSync . Wintertime m

<b>Month of clock change</b>	<b>Description</b>
<b>January</b>	<i>January</i>
<b>February</b>	<i>February</i>
<b>March</b>	<i>March</i>
<b>April</b>	<i>April</i>
<b>May</b>	<i>May</i>
<b>June</b>	<i>June</i>
<b>July</b>	<i>July</i>
<b>August</b>	<i>August</i>
<b>September</b>	<i>September</i>
<b>October</b>	<i>October</i>
<b>November</b>	<i>November</i>
<b>December</b>	<i>December</i>

### ***Date***

Selection list referenced by the following parameters:



-  TimeSync . Summertime d
-  TimeSync . Wintertime d

Date	Description
<b>Sunday</b>	<i>Sunday</i>
<b>Monday</b>	<i>Monday</i>
<b>Tuesday</b>	<i>Tuesday</i>
<b>Wednesday</b>	<i>Wednesday</i>
<b>Thursday</b>	<i>Thursday</i>
<b>Friday</b>	<i>Friday</i>
<b>Saturday</b>	<i>Saturday</i>
<b>General day</b>	<i>General day: Examples: first day of month, last day of month</i>

**Day of clock change**

Day of Time Saving change

Selection list referenced by the following parameters:

-  TimeSync . Summertime w
-  TimeSync . Wintertime w

Day of clock change	Description
<b>First</b>	<i>First week of the month</i>
<b>Second</b>	<i>Second week of the month</i>
<b>Third</b>	<i>Third week of the month</i>
<b>Fourth</b>	<i>Fourth week of the month</i>
<b>Last</b>	<i>Last week of the month</i>

**Used Protocol**

Selection list referenced by the following parameters:

-  TimeSync . TimeSync

Used Protocol	Description
<b>"_"</b>	-
IRIG-B . <b>IRIG-B</b>	<i>IRIG-B-Module</i>

Used Protocol	Description
SNTP . <b>SNTP</b>	<i>SNTP-Module</i>
Modbus . <b>Modbus</b>	<i>Modbus Protocol</i>
IEC103 . <b>IEC 60870-5-103</b>	<i>IEC 60870-5-103 Protocol</i>
IEC104 . <b>IEC104</b>	<i>IEC 60870-5-104 communication</i>
DNP3 . <b>DNP3</b>	<i>Distributed Network Protocol</i>

### **IRIG-B00X**

Determination of the Type: IRIG-B00X. IRIG-B types differ in types of included “Coded Expressions” (year, control-functions, straight-binary-seconds).

Selection list referenced by the following parameters:

-  IRIG-B . IRIG-B00X

IRIG-B00X	Description
<b>IRIGB-000</b>	<i>Please refer to: IRIG STANDARD 200-04</i>
<b>IRIGB-001</b>	<i>Please refer to: IRIG STANDARD 200-04</i>
<b>IRIGB-002</b>	<i>Please refer to: IRIG STANDARD 200-04</i>
<b>IRIGB-003</b>	<i>Please refer to: IRIG STANDARD 200-04</i>
<b>IRIGB-004</b>	<i>Please refer to: IRIG STANDARD 200-04</i>
<b>IRIGB-005</b>	<i>Please refer to: IRIG STANDARD 200-04</i>
<b>IRIGB-006</b>	<i>Please refer to: IRIG STANDARD 200-04</i>
<b>IRIGB-007</b>	<i>Please refer to: IRIG STANDARD 200-04</i>

Selection list referenced by the following parameters:

-  Sys . DM version

	Description
<b>3.6.b</b>	<i>Version</i>

**Phase Sequence**

Phase Sequence direction

Selection list referenced by the following parameters:

-  Field Para . Phase Sequence

Phase Sequence	Description
ABC	<i>rotating clockwise</i>
ACB	<i>Counter-clockwise phase sequence. Positive and negative phase sequence are exchanged and MTA is turned for 180°.</i>

**fN**

Selection list referenced by the following parameters:

-  Field Para . f

fN	Description
50	<i>Rated frequency</i>
60	<i>Rated frequency</i>

Selection list referenced by the following parameters:

-  Sys . Program Mode

	Description
<b>Either Motor Stopped or Running</b>	<i>Either Motor Stopped or Running</i>
<b>Motor Stop</b>	<i>Motor Stopped</i>

**Motor Stop**

Motor Stopped



Motor Stop	Description
MStart . <b>Stop</b>	<i>Signal: Motor is in stop mode</i>



**Ratio prim/sec**

w\_prim/w\_sec



Selection list referenced by the following parameters:

-  CT . CT sec
-  CT . ECT sec

Ratio prim/sec	Description
1	<i>Rated value of the secondary side of the current transformers.</i>
5	<i>Rated value of the secondary side of the current transformers.</i>

**Polarity**







Selection list referenced by the following parameters:

-  CT . CT dir
-  CT . ECT dir

Polarity	Description
0	0
180	<i>180 degree polarity correction (wiring faults)</i>

**active/inactive**

Selection list referenced by the following parameters:

-  BO Slot X2 . DISARMED Ctrl
-  BO Slot X2 . DISARMED Ctrl
-  Prot . ExBlo Fc
-  Prot . ExBlo TripCmd Fc
-  MStart . Reversing
-  MStart . ExBlo TripCmd Fc
- [ ... ]

<b>active/inactive</b>	<b>Description</b>
<b>inactive</b>	<i>inactive</i>
<b>active</b>	<i>active</i>

**1..n, TRN List**

Motor operation mode transition criteria options

Selection list referenced by the following parameters:

-  MStart . TRN Criteria

<b>1..n, TRN List</b>	<b>Description</b>
<b>TRN I</b>	<i>Transition on current only</i>
<b>TRN TIME</b>	<i>Transition on time only</i>
<b>TRN T and I</b>	<i>Transition on current AND time</i>
<b>TRN T or I</b>	<i>Transition on current OR time</i>

**1..n, InSq**

Incomplete sequence report starting options

Selection list referenced by the following parameters:

-  MStart . INSQReportFrom

<b>1..n, InSq</b>	<b>Description</b>
<b>inactive</b>	<i>inactive</i>
<b>InSq Start2Run</b>	<i>INSQ reporting from start-to-run</i>
<b>InSq Stop2Start</b>	<i>INSQ reporting from stop-to-start</i>

**1..n, Zero speed**

Zero speed switch trip function

Selection list referenced by the following parameters:

-  MStart . ZSS

<b>1..n, Zero speed</b>	<b>Description</b>
<b>inactive</b>	<i>inactive</i>
<b>active</b>	<i>active</i>

### **EmgOvr**

Emergency override options

Selection list referenced by the following parameters:







-  MStart . EmgOvr

<b>EmgOvr</b>	<b>Description</b>
<b>inactive</b>	<i>inactive</i>
<b>DI</b>	<i>Enable emergency override from digital input DI</i>
<b>HMI</b>	<i>Enable emergency override from HMI</i>
<b>DI or HMI</b>	<i>Enable emergency override from digital (DI) input or front panel (HMI)</i>

### **1..n, Dig Inputs**

List of Digital Inputs that are available for the detection of the Circuit Breaker Position.

Selection list referenced by the following parameters:

-  MStart . RemStartBlock
-  MStart . EmgOvr
-  MStart . INSQ
-  MStart . ZSS
-  MStart . STPC Blo
-  TCS . Input 1
- *[...]*






<b>1..n, Dig Inputs</b>	<b>Description</b>
<b>"_"</b>	<i>No assignment</i>
DI Slot X1 . <b>DI 1</b>	<i>Signal: Digital Input</i>
DI Slot X1 . <b>DI 2</b>	<i>Signal: Digital Input</i>

<b>1..n, Dig Inputs</b>	<b>Description</b>
DI Slot X1 . <b>DI 3</b>	<i>Signal: Digital Input</i>
DI Slot X1 . <b>DI 4</b>	<i>Signal: Digital Input</i>
DI Slot X1 . <b>DI 5</b>	<i>Signal: Digital Input</i>
DI Slot X1 . <b>DI 6</b>	<i>Signal: Digital Input</i>
DI Slot X1 . <b>DI 7</b>	<i>Signal: Digital Input</i>
DI Slot X1 . <b>DI 8</b>	<i>Signal: Digital Input</i>
DI Slot X1 . <b>DI 1</b>	<i>Signal: Digital Input</i>
DI Slot X1 . <b>DI 2</b>	<i>Signal: Digital Input</i>
DI Slot X1 . <b>DI 3</b>	<i>Signal: Digital Input</i>
DI Slot X1 . <b>DI 4</b>	<i>Signal: Digital Input</i>

**1..n, Trip Cmds**

List of available Trip Commands

Selection list referenced by the following parameters:

-  I[1] . ExBlo dur. Mot.Strt
-  IG[1] . ExBlo dur. Mot.Strt
-  Jam[1] . ExBlo dur. Mot.Strt
-  I<[1] . ExBlo dur. Mot.Strt
-  I2>[1] . ExBlo dur. Mot.Strt







<b>1..n, Trip Cmds</b>	<b>Description</b>
<b>"_"</b>	<i>No assignment</i>
MStart . <b>Blo-GOCStart</b>	<i>Signal: Ground Instantaneous Overcurrent Start Delay. GOC (Instantaneous Overcurrent) elements are blocked for the time programmed under this parameter</i>
MStart . <b>Blo-IOCStart</b>	<i>Signal: Phase Instantaneous Overcurrent Start Delay. IOC (Instantaneous Overcurrent) elements are blocked for the time programmed under this parameter</i>
MStart . <b>Blo-I&lt;Start</b>	<i>Signal: Underload Start Delay. Underload(Instantaneous Overcurrent) elements are blocked for the time programmed under this parameter</i>
MStart . <b>Blo-JamStart</b>	<i>Signal: JAM Start Delay. JAM(Instantaneous Overcurrent) elements are blocked for the time programmed under this parameter</i>
MStart . <b>Blo-I2&gt;Start</b>	<i>Signal: Motor start block current unbalance signal</i>

<b>1..n, Trip Cmds</b>	<b>Description</b>
MStart . <b>Blo-Generic1</b>	<i>Generic Start Delay. This value can be used to block any protective element.1</i>
MStart . <b>Blo-Generic2</b>	<i>Generic Start Delay. This value can be used to block any protective element.2</i>
MStart . <b>Blo-Generic3</b>	<i>Generic Start Delay. This value can be used to block any protective element.3</i>
MStart . <b>Blo-Generic4</b>	<i>Generic Start Delay. This value can be used to block any protective element.4</i>
MStart . <b>Blo-Generic5</b>	<i>Generic Start Delay. This value can be used to block any protective element.5</i>
MStart . <b>Blo-U2&gt;</b>	<i>Signal: Motor start block voltage unbalance signal.</i>
MStart . <b>Blo-UnderV Start</b>	<i>Signal: Undervoltage Start Delay. Undervoltage elements are blocked for the time programmed under this parameter</i>
MStart . <b>Block-OverVStart</b>	<i>Signal: Overvoltage Start Delay. Overvoltage elements are blocked for the time programmed under this parameter</i>
MStart . <b>Blo-PowerStart</b>	<i>Signal: Power Start Delay. Power elements are blocked for the time programmed under this parameter</i>
MStart . <b>Blo-PFacStart</b>	<i>Signal: Power Factor Start Delay. Power Factor elements are blocked for the time programmed under this parameter</i>
MStart . <b>Blo-FrqStart</b>	<i>Signal: Frequency Start Delay. Frequency elements are blocked for the time programmed under this parameter</i>

### **AdaptSet**

Adaptive Parameters

Selection list referenced by the following parameters:

-  I[1] . AdaptSet 1
-  I[1] . AdaptSet 2
-  I[1] . AdaptSet 3
-  I[1] . AdaptSet 4
-  IG[1] . AdaptSet 1
-  IG[1] . AdaptSet 2
- [ ... ]

<b>AdaptSet</b>	<b>Description</b>
<b>"_"</b>	<i>No assignment</i>

<b>AdaptSet</b>	<b>Description</b>
Exp[1] . <b>Alarm</b>	<i>Signal: Alarm</i>
Exp[2] . <b>Alarm</b>	<i>Signal: Alarm</i>
Exp[3] . <b>Alarm</b>	<i>Signal: Alarm</i>
Exp[4] . <b>Alarm</b>	<i>Signal: Alarm</i>
<b>CTS . Alarm</b>	<i>Signal: Alarm Current Transformer Measuring Circuit Supervision</i>
DI Slot X1 . <b>DI 1</b>	<i>Signal: Digital Input</i>
DI Slot X1 . <b>DI 2</b>	<i>Signal: Digital Input</i>
DI Slot X1 . <b>DI 3</b>	<i>Signal: Digital Input</i>
DI Slot X1 . <b>DI 4</b>	<i>Signal: Digital Input</i>
DI Slot X1 . <b>DI 5</b>	<i>Signal: Digital Input</i>
DI Slot X1 . <b>DI 6</b>	<i>Signal: Digital Input</i>
DI Slot X1 . <b>DI 7</b>	<i>Signal: Digital Input</i>
DI Slot X1 . <b>DI 8</b>	<i>Signal: Digital Input</i>
DI Slot X1 . <b>DI 1</b>	<i>Signal: Digital Input</i>
DI Slot X1 . <b>DI 2</b>	<i>Signal: Digital Input</i>
DI Slot X1 . <b>DI 3</b>	<i>Signal: Digital Input</i>
DI Slot X1 . <b>DI 4</b>	<i>Signal: Digital Input</i>
Modbus . <b>Scada Cmd 1</b>	<i>Scada Command</i>
Modbus . <b>Scada Cmd 2</b>	<i>Scada Command</i>
Modbus . <b>Scada Cmd 3</b>	<i>Scada Command</i>
Modbus . <b>Scada Cmd 4</b>	<i>Scada Command</i>
Modbus . <b>Scada Cmd 5</b>	<i>Scada Command</i>
Modbus . <b>Scada Cmd 6</b>	<i>Scada Command</i>
Modbus . <b>Scada Cmd 7</b>	<i>Scada Command</i>
Modbus . <b>Scada Cmd 8</b>	<i>Scada Command</i>
Modbus . <b>Scada Cmd 9</b>	<i>Scada Command</i>
Modbus . <b>Scada Cmd 10</b>	<i>Scada Command</i>
Modbus . <b>Scada Cmd 11</b>	<i>Scada Command</i>
Modbus . <b>Scada Cmd 12</b>	<i>Scada Command</i>
Modbus . <b>Scada Cmd 13</b>	<i>Scada Command</i>
Modbus . <b>Scada Cmd 14</b>	<i>Scada Command</i>
Modbus . <b>Scada Cmd 15</b>	<i>Scada Command</i>

<b>AdaptSet</b>	<b>Description</b>
Modbus . <b>Scada Cmd 16</b>	<i>Scada Command</i>
IEC 61850 . <b>GOSINGGIO1.Ind1.stVal</b>	<i>Signal: Virtual Input (IEC61850 GGIO Ind): State</i>
IEC 61850 . <b>GOSINGGIO1.Ind2.stVal</b>	<i>Signal: Virtual Input (IEC61850 GGIO Ind): State</i>
IEC 61850 . <b>GOSINGGIO1.Ind3.stVal</b>	<i>Signal: Virtual Input (IEC61850 GGIO Ind): State</i>
IEC 61850 . <b>GOSINGGIO1.Ind4.stVal</b>	<i>Signal: Virtual Input (IEC61850 GGIO Ind): State</i>
IEC 61850 . <b>GOSINGGIO1.Ind5.stVal</b>	<i>Signal: Virtual Input (IEC61850 GGIO Ind): State</i>
IEC 61850 . <b>GOSINGGIO1.Ind6.stVal</b>	<i>Signal: Virtual Input (IEC61850 GGIO Ind): State</i>
IEC 61850 . <b>GOSINGGIO1.Ind7.stVal</b>	<i>Signal: Virtual Input (IEC61850 GGIO Ind): State</i>
IEC 61850 . <b>GOSINGGIO1.Ind8.stVal</b>	<i>Signal: Virtual Input (IEC61850 GGIO Ind): State</i>
IEC 61850 . <b>GOSINGGIO1.Ind9.stVal</b>	<i>Signal: Virtual Input (IEC61850 GGIO Ind): State</i>
IEC 61850 . <b>GOSINGGIO1.Ind10.stVal</b>	<i>Signal: Virtual Input (IEC61850 GGIO Ind): State</i>
IEC 61850 . <b>GOSINGGIO1.Ind11.stVal</b>	<i>Signal: Virtual Input (IEC61850 GGIO Ind): State</i>
IEC 61850 . <b>GOSINGGIO1.Ind12.stVal</b>	<i>Signal: Virtual Input (IEC61850 GGIO Ind): State</i>
IEC 61850 . <b>GOSINGGIO1.Ind13.stVal</b>	<i>Signal: Virtual Input (IEC61850 GGIO Ind): State</i>
IEC 61850 . <b>GOSINGGIO1.Ind14.stVal</b>	<i>Signal: Virtual Input (IEC61850 GGIO Ind): State</i>
IEC 61850 . <b>GOSINGGIO1.Ind15.stVal</b>	<i>Signal: Virtual Input (IEC61850 GGIO Ind): State</i>
IEC 61850 . <b>GOSINGGIO1.Ind16.stVal</b>	<i>Signal: Virtual Input (IEC61850 GGIO Ind): State</i>
IEC 61850 . <b>GOSINGGIO1.Ind17.stVal</b>	<i>Signal: Virtual Input (IEC61850 GGIO Ind): State</i>
IEC 61850 . <b>GOSINGGIO1.Ind18.stVal</b>	<i>Signal: Virtual Input (IEC61850 GGIO Ind): State</i>
IEC 61850 . <b>GOSINGGIO1.Ind19.stVal</b>	<i>Signal: Virtual Input (IEC61850 GGIO Ind): State</i>
IEC 61850 . <b>GOSINGGIO1.Ind20.stVal</b>	<i>Signal: Virtual Input (IEC61850 GGIO Ind): State</i>

<b>AdaptSet</b>	<b>Description</b>
IEC 61850 . <b>GOSINGGIO1.Ind21.stVal</b>	<i>Signal: Virtual Input (IEC61850 GGIO Ind): State</i>
IEC 61850 . <b>GOSINGGIO1.Ind22.stVal</b>	<i>Signal: Virtual Input (IEC61850 GGIO Ind): State</i>
IEC 61850 . <b>GOSINGGIO1.Ind23.stVal</b>	<i>Signal: Virtual Input (IEC61850 GGIO Ind): State</i>
IEC 61850 . <b>GOSINGGIO1.Ind24.stVal</b>	<i>Signal: Virtual Input (IEC61850 GGIO Ind): State</i>
IEC 61850 . <b>GOSINGGIO1.Ind25.stVal</b>	<i>Signal: Virtual Input (IEC61850 GGIO Ind): State</i>
IEC 61850 . <b>GOSINGGIO1.Ind26.stVal</b>	<i>Signal: Virtual Input (IEC61850 GGIO Ind): State</i>
IEC 61850 . <b>GOSINGGIO1.Ind27.stVal</b>	<i>Signal: Virtual Input (IEC61850 GGIO Ind): State</i>
IEC 61850 . <b>GOSINGGIO1.Ind28.stVal</b>	<i>Signal: Virtual Input (IEC61850 GGIO Ind): State</i>
IEC 61850 . <b>GOSINGGIO1.Ind29.stVal</b>	<i>Signal: Virtual Input (IEC61850 GGIO Ind): State</i>
IEC 61850 . <b>GOSINGGIO1.Ind30.stVal</b>	<i>Signal: Virtual Input (IEC61850 GGIO Ind): State</i>
IEC 61850 . <b>GOSINGGIO1.Ind31.stVal</b>	<i>Signal: Virtual Input (IEC61850 GGIO Ind): State</i>
IEC 61850 . <b>GOSINGGIO1.Ind32.stVal</b>	<i>Signal: Virtual Input (IEC61850 GGIO Ind): State</i>
IEC 61850 . <b>SPCSO1</b>	<i>Status bit that can be set by clients like e.g. SCADA (Single Point Controllable Status Output).</i>
IEC 61850 . <b>SPCSO2</b>	<i>Status bit that can be set by clients like e.g. SCADA (Single Point Controllable Status Output).</i>
IEC 61850 . <b>SPCSO3</b>	<i>Status bit that can be set by clients like e.g. SCADA (Single Point Controllable Status Output).</i>
IEC 61850 . <b>SPCSO4</b>	<i>Status bit that can be set by clients like e.g. SCADA (Single Point Controllable Status Output).</i>
IEC 61850 . <b>SPCSO5</b>	<i>Status bit that can be set by clients like e.g. SCADA (Single Point Controllable Status Output).</i>
IEC 61850 . <b>SPCSO6</b>	<i>Status bit that can be set by clients like e.g. SCADA (Single Point Controllable Status Output).</i>
IEC 61850 . <b>SPCSO7</b>	<i>Status bit that can be set by clients like e.g. SCADA (Single Point Controllable Status Output).</i>
IEC 61850 . <b>SPCSO8</b>	<i>Status bit that can be set by clients like e.g. SCADA (Single Point Controllable Status Output).</i>



<b>AdaptSet</b>	<b>Description</b>
IEC 61850 . <b>SPCSO9</b>	<i>Status bit that can be set by clients like e.g. SCADA (Single Point Controllable Status Output).</i>
IEC 61850 . <b>SPCSO10</b>	<i>Status bit that can be set by clients like e.g. SCADA (Single Point Controllable Status Output).</i>
IEC 61850 . <b>SPCSO11</b>	<i>Status bit that can be set by clients like e.g. SCADA (Single Point Controllable Status Output).</i>
IEC 61850 . <b>SPCSO12</b>	<i>Status bit that can be set by clients like e.g. SCADA (Single Point Controllable Status Output).</i>
IEC 61850 . <b>SPCSO13</b>	<i>Status bit that can be set by clients like e.g. SCADA (Single Point Controllable Status Output).</i>
IEC 61850 . <b>SPCSO14</b>	<i>Status bit that can be set by clients like e.g. SCADA (Single Point Controllable Status Output).</i>
IEC 61850 . <b>SPCSO15</b>	<i>Status bit that can be set by clients like e.g. SCADA (Single Point Controllable Status Output).</i>
IEC 61850 . <b>SPCSO16</b>	<i>Status bit that can be set by clients like e.g. SCADA (Single Point Controllable Status Output).</i>
IEC103 . <b>Scada Cmd 1</b>	<i>Scada Command</i>
IEC103 . <b>Scada Cmd 2</b>	<i>Scada Command</i>
IEC103 . <b>Scada Cmd 3</b>	<i>Scada Command</i>
IEC103 . <b>Scada Cmd 4</b>	<i>Scada Command</i>
IEC103 . <b>Scada Cmd 5</b>	<i>Scada Command</i>
IEC103 . <b>Scada Cmd 6</b>	<i>Scada Command</i>
IEC103 . <b>Scada Cmd 7</b>	<i>Scada Command</i>
IEC103 . <b>Scada Cmd 8</b>	<i>Scada Command</i>
IEC103 . <b>Scada Cmd 9</b>	<i>Scada Command</i>
IEC103 . <b>Scada Cmd 10</b>	<i>Scada Command</i>
IEC104 . <b>Scada Cmd 1</b>	<i>Scada Command</i>
IEC104 . <b>Scada Cmd 2</b>	<i>Scada Command</i>
IEC104 . <b>Scada Cmd 3</b>	<i>Scada Command</i>
IEC104 . <b>Scada Cmd 4</b>	<i>Scada Command</i>
IEC104 . <b>Scada Cmd 5</b>	<i>Scada Command</i>
IEC104 . <b>Scada Cmd 6</b>	<i>Scada Command</i>
IEC104 . <b>Scada Cmd 7</b>	<i>Scada Command</i>
IEC104 . <b>Scada Cmd 8</b>	<i>Scada Command</i>
IEC104 . <b>Scada Cmd 9</b>	<i>Scada Command</i>

<b>AdaptSet</b>	<b>Description</b>
IEC104 . <b>Scada Cmd 10</b>	<i>Scada Command</i>
IEC104 . <b>Scada Cmd 11</b>	<i>Scada Command</i>
IEC104 . <b>Scada Cmd 12</b>	<i>Scada Command</i>
IEC104 . <b>Scada Cmd 13</b>	<i>Scada Command</i>
IEC104 . <b>Scada Cmd 14</b>	<i>Scada Command</i>
IEC104 . <b>Scada Cmd 15</b>	<i>Scada Command</i>
IEC104 . <b>Scada Cmd 16</b>	<i>Scada Command</i>
Profibus . <b>Scada Cmd 1</b>	<i>Scada Command</i>
Profibus . <b>Scada Cmd 2</b>	<i>Scada Command</i>
Profibus . <b>Scada Cmd 3</b>	<i>Scada Command</i>
Profibus . <b>Scada Cmd 4</b>	<i>Scada Command</i>
Profibus . <b>Scada Cmd 5</b>	<i>Scada Command</i>
Profibus . <b>Scada Cmd 6</b>	<i>Scada Command</i>
Profibus . <b>Scada Cmd 7</b>	<i>Scada Command</i>
Profibus . <b>Scada Cmd 8</b>	<i>Scada Command</i>
Profibus . <b>Scada Cmd 9</b>	<i>Scada Command</i>
Profibus . <b>Scada Cmd 10</b>	<i>Scada Command</i>
Profibus . <b>Scada Cmd 11</b>	<i>Scada Command</i>
Profibus . <b>Scada Cmd 12</b>	<i>Scada Command</i>
Profibus . <b>Scada Cmd 13</b>	<i>Scada Command</i>
Profibus . <b>Scada Cmd 14</b>	<i>Scada Command</i>
Profibus . <b>Scada Cmd 15</b>	<i>Scada Command</i>
Profibus . <b>Scada Cmd 16</b>	<i>Scada Command</i>
Logics . <b>LE1.Gate Out</b>	<i>Signal: Output of the logic gate</i>
Logics . <b>LE1.Timer Out</b>	<i>Signal: Timer Output</i>
Logics . <b>LE1.Out</b>	<i>Signal: Latched Output (Q)</i>
Logics . <b>LE1.Out inverted</b>	<i>Signal: Negated Latched Output (Q NOT)</i>
Logics . <b>LE2.Gate Out</b>	<i>Signal: Output of the logic gate</i>
Logics . <b>LE2.Timer Out</b>	<i>Signal: Timer Output</i>
Logics . <b>LE2.Out</b>	<i>Signal: Latched Output (Q)</i>
Logics . <b>LE2.Out inverted</b>	<i>Signal: Negated Latched Output (Q NOT)</i>

<b>AdaptSet</b>	<b>Description</b>
Logics . <b>LE3.Gate Out</b>	<i>Signal: Output of the logic gate</i>
Logics . <b>LE3.Timer Out</b>	<i>Signal: Timer Output</i>
Logics . <b>LE3.Out</b>	<i>Signal: Latched Output (Q)</i>
Logics . <b>LE3.Out inverted</b>	<i>Signal: Negated Latched Output (Q NOT)</i>
Logics . <b>LE4.Gate Out</b>	<i>Signal: Output of the logic gate</i>
Logics . <b>LE4.Timer Out</b>	<i>Signal: Timer Output</i>
Logics . <b>LE4.Out</b>	<i>Signal: Latched Output (Q)</i>
Logics . <b>LE4.Out inverted</b>	<i>Signal: Negated Latched Output (Q NOT)</i>
Logics . <b>LE5.Gate Out</b>	<i>Signal: Output of the logic gate</i>
Logics . <b>LE5.Timer Out</b>	<i>Signal: Timer Output</i>
Logics . <b>LE5.Out</b>	<i>Signal: Latched Output (Q)</i>
Logics . <b>LE5.Out inverted</b>	<i>Signal: Negated Latched Output (Q NOT)</i>
Logics . <b>LE6.Gate Out</b>	<i>Signal: Output of the logic gate</i>
Logics . <b>LE6.Timer Out</b>	<i>Signal: Timer Output</i>
Logics . <b>LE6.Out</b>	<i>Signal: Latched Output (Q)</i>
Logics . <b>LE6.Out inverted</b>	<i>Signal: Negated Latched Output (Q NOT)</i>
Logics . <b>LE7.Gate Out</b>	<i>Signal: Output of the logic gate</i>
Logics . <b>LE7.Timer Out</b>	<i>Signal: Timer Output</i>
Logics . <b>LE7.Out</b>	<i>Signal: Latched Output (Q)</i>
Logics . <b>LE7.Out inverted</b>	<i>Signal: Negated Latched Output (Q NOT)</i>
Logics . <b>LE8.Gate Out</b>	<i>Signal: Output of the logic gate</i>
Logics . <b>LE8.Timer Out</b>	<i>Signal: Timer Output</i>
Logics . <b>LE8.Out</b>	<i>Signal: Latched Output (Q)</i>
Logics . <b>LE8.Out inverted</b>	<i>Signal: Negated Latched Output (Q NOT)</i>
Logics . <b>LE9.Gate Out</b>	<i>Signal: Output of the logic gate</i>
Logics . <b>LE9.Timer Out</b>	<i>Signal: Timer Output</i>
Logics . <b>LE9.Out</b>	<i>Signal: Latched Output (Q)</i>
Logics . <b>LE9.Out inverted</b>	<i>Signal: Negated Latched Output (Q NOT)</i>

<b>AdaptSet</b>	<b>Description</b>
Logics . <b>LE10.Gate Out</b>	<i>Signal: Output of the logic gate</i>
Logics . <b>LE10.Timer Out</b>	<i>Signal: Timer Output</i>
Logics . <b>LE10.Out</b>	<i>Signal: Latched Output (Q)</i>
Logics . <b>LE10.Out inverted</b>	<i>Signal: Negated Latched Output (Q NOT)</i>
Logics . <b>LE11.Gate Out</b>	<i>Signal: Output of the logic gate</i>
Logics . <b>LE11.Timer Out</b>	<i>Signal: Timer Output</i>
Logics . <b>LE11.Out</b>	<i>Signal: Latched Output (Q)</i>
Logics . <b>LE11.Out inverted</b>	<i>Signal: Negated Latched Output (Q NOT)</i>
Logics . <b>LE12.Gate Out</b>	<i>Signal: Output of the logic gate</i>
Logics . <b>LE12.Timer Out</b>	<i>Signal: Timer Output</i>
Logics . <b>LE12.Out</b>	<i>Signal: Latched Output (Q)</i>
Logics . <b>LE12.Out inverted</b>	<i>Signal: Negated Latched Output (Q NOT)</i>
Logics . <b>LE13.Gate Out</b>	<i>Signal: Output of the logic gate</i>
Logics . <b>LE13.Timer Out</b>	<i>Signal: Timer Output</i>
Logics . <b>LE13.Out</b>	<i>Signal: Latched Output (Q)</i>
Logics . <b>LE13.Out inverted</b>	<i>Signal: Negated Latched Output (Q NOT)</i>
Logics . <b>LE14.Gate Out</b>	<i>Signal: Output of the logic gate</i>
Logics . <b>LE14.Timer Out</b>	<i>Signal: Timer Output</i>
Logics . <b>LE14.Out</b>	<i>Signal: Latched Output (Q)</i>
Logics . <b>LE14.Out inverted</b>	<i>Signal: Negated Latched Output (Q NOT)</i>
Logics . <b>LE15.Gate Out</b>	<i>Signal: Output of the logic gate</i>
Logics . <b>LE15.Timer Out</b>	<i>Signal: Timer Output</i>
Logics . <b>LE15.Out</b>	<i>Signal: Latched Output (Q)</i>
Logics . <b>LE15.Out inverted</b>	<i>Signal: Negated Latched Output (Q NOT)</i>
Logics . <b>LE16.Gate Out</b>	<i>Signal: Output of the logic gate</i>
Logics . <b>LE16.Timer Out</b>	<i>Signal: Timer Output</i>
Logics . <b>LE16.Out</b>	<i>Signal: Latched Output (Q)</i>
Logics . <b>LE16.Out inverted</b>	<i>Signal: Negated Latched Output (Q NOT)</i>

<b>AdaptSet</b>	<b>Description</b>
Logics . <b>LE17.Gate Out</b>	<i>Signal: Output of the logic gate</i>
Logics . <b>LE17.Timer Out</b>	<i>Signal: Timer Output</i>
Logics . <b>LE17.Out</b>	<i>Signal: Latched Output (Q)</i>
Logics . <b>LE17.Out inverted</b>	<i>Signal: Negated Latched Output (Q NOT)</i>
Logics . <b>LE18.Gate Out</b>	<i>Signal: Output of the logic gate</i>
Logics . <b>LE18.Timer Out</b>	<i>Signal: Timer Output</i>
Logics . <b>LE18.Out</b>	<i>Signal: Latched Output (Q)</i>
Logics . <b>LE18.Out inverted</b>	<i>Signal: Negated Latched Output (Q NOT)</i>
Logics . <b>LE19.Gate Out</b>	<i>Signal: Output of the logic gate</i>
Logics . <b>LE19.Timer Out</b>	<i>Signal: Timer Output</i>
Logics . <b>LE19.Out</b>	<i>Signal: Latched Output (Q)</i>
Logics . <b>LE19.Out inverted</b>	<i>Signal: Negated Latched Output (Q NOT)</i>
Logics . <b>LE20.Gate Out</b>	<i>Signal: Output of the logic gate</i>
Logics . <b>LE20.Timer Out</b>	<i>Signal: Timer Output</i>
Logics . <b>LE20.Out</b>	<i>Signal: Latched Output (Q)</i>
Logics . <b>LE20.Out inverted</b>	<i>Signal: Negated Latched Output (Q NOT)</i>
Logics . <b>LE21.Gate Out</b>	<i>Signal: Output of the logic gate</i>
Logics . <b>LE21.Timer Out</b>	<i>Signal: Timer Output</i>
Logics . <b>LE21.Out</b>	<i>Signal: Latched Output (Q)</i>
Logics . <b>LE21.Out inverted</b>	<i>Signal: Negated Latched Output (Q NOT)</i>
Logics . <b>LE22.Gate Out</b>	<i>Signal: Output of the logic gate</i>
Logics . <b>LE22.Timer Out</b>	<i>Signal: Timer Output</i>
Logics . <b>LE22.Out</b>	<i>Signal: Latched Output (Q)</i>
Logics . <b>LE22.Out inverted</b>	<i>Signal: Negated Latched Output (Q NOT)</i>
Logics . <b>LE23.Gate Out</b>	<i>Signal: Output of the logic gate</i>
Logics . <b>LE23.Timer Out</b>	<i>Signal: Timer Output</i>
Logics . <b>LE23.Out</b>	<i>Signal: Latched Output (Q)</i>
Logics . <b>LE23.Out inverted</b>	<i>Signal: Negated Latched Output (Q NOT)</i>

<b>AdaptSet</b>	<b>Description</b>
Logics . <b>LE24.Gate Out</b>	<i>Signal: Output of the logic gate</i>
Logics . <b>LE24.Timer Out</b>	<i>Signal: Timer Output</i>
Logics . <b>LE24.Out</b>	<i>Signal: Latched Output (Q)</i>
Logics . <b>LE24.Out inverted</b>	<i>Signal: Negated Latched Output (Q NOT)</i>
Logics . <b>LE25.Gate Out</b>	<i>Signal: Output of the logic gate</i>
Logics . <b>LE25.Timer Out</b>	<i>Signal: Timer Output</i>
Logics . <b>LE25.Out</b>	<i>Signal: Latched Output (Q)</i>
Logics . <b>LE25.Out inverted</b>	<i>Signal: Negated Latched Output (Q NOT)</i>
Logics . <b>LE26.Gate Out</b>	<i>Signal: Output of the logic gate</i>
Logics . <b>LE26.Timer Out</b>	<i>Signal: Timer Output</i>
Logics . <b>LE26.Out</b>	<i>Signal: Latched Output (Q)</i>
Logics . <b>LE26.Out inverted</b>	<i>Signal: Negated Latched Output (Q NOT)</i>
Logics . <b>LE27.Gate Out</b>	<i>Signal: Output of the logic gate</i>
Logics . <b>LE27.Timer Out</b>	<i>Signal: Timer Output</i>
Logics . <b>LE27.Out</b>	<i>Signal: Latched Output (Q)</i>
Logics . <b>LE27.Out inverted</b>	<i>Signal: Negated Latched Output (Q NOT)</i>
Logics . <b>LE28.Gate Out</b>	<i>Signal: Output of the logic gate</i>
Logics . <b>LE28.Timer Out</b>	<i>Signal: Timer Output</i>
Logics . <b>LE28.Out</b>	<i>Signal: Latched Output (Q)</i>
Logics . <b>LE28.Out inverted</b>	<i>Signal: Negated Latched Output (Q NOT)</i>
Logics . <b>LE29.Gate Out</b>	<i>Signal: Output of the logic gate</i>
Logics . <b>LE29.Timer Out</b>	<i>Signal: Timer Output</i>
Logics . <b>LE29.Out</b>	<i>Signal: Latched Output (Q)</i>
Logics . <b>LE29.Out inverted</b>	<i>Signal: Negated Latched Output (Q NOT)</i>
Logics . <b>LE30.Gate Out</b>	<i>Signal: Output of the logic gate</i>
Logics . <b>LE30.Timer Out</b>	<i>Signal: Timer Output</i>
Logics . <b>LE30.Out</b>	<i>Signal: Latched Output (Q)</i>
Logics . <b>LE30.Out inverted</b>	<i>Signal: Negated Latched Output (Q NOT)</i>

<b>AdaptSet</b>	<b>Description</b>
Logics . <b>LE31.Gate Out</b>	<i>Signal: Output of the logic gate</i>
Logics . <b>LE31.Timer Out</b>	<i>Signal: Timer Output</i>
Logics . <b>LE31.Out</b>	<i>Signal: Latched Output (Q)</i>
Logics . <b>LE31.Out inverted</b>	<i>Signal: Negated Latched Output (Q NOT)</i>
Logics . <b>LE32.Gate Out</b>	<i>Signal: Output of the logic gate</i>
Logics . <b>LE32.Timer Out</b>	<i>Signal: Timer Output</i>
Logics . <b>LE32.Out</b>	<i>Signal: Latched Output (Q)</i>
Logics . <b>LE32.Out inverted</b>	<i>Signal: Negated Latched Output (Q NOT)</i>
Logics . <b>LE33.Gate Out</b>	<i>Signal: Output of the logic gate</i>
Logics . <b>LE33.Timer Out</b>	<i>Signal: Timer Output</i>
Logics . <b>LE33.Out</b>	<i>Signal: Latched Output (Q)</i>
Logics . <b>LE33.Out inverted</b>	<i>Signal: Negated Latched Output (Q NOT)</i>
Logics . <b>LE34.Gate Out</b>	<i>Signal: Output of the logic gate</i>
Logics . <b>LE34.Timer Out</b>	<i>Signal: Timer Output</i>
Logics . <b>LE34.Out</b>	<i>Signal: Latched Output (Q)</i>
Logics . <b>LE34.Out inverted</b>	<i>Signal: Negated Latched Output (Q NOT)</i>
Logics . <b>LE35.Gate Out</b>	<i>Signal: Output of the logic gate</i>
Logics . <b>LE35.Timer Out</b>	<i>Signal: Timer Output</i>
Logics . <b>LE35.Out</b>	<i>Signal: Latched Output (Q)</i>
Logics . <b>LE35.Out inverted</b>	<i>Signal: Negated Latched Output (Q NOT)</i>
Logics . <b>LE36.Gate Out</b>	<i>Signal: Output of the logic gate</i>
Logics . <b>LE36.Timer Out</b>	<i>Signal: Timer Output</i>
Logics . <b>LE36.Out</b>	<i>Signal: Latched Output (Q)</i>
Logics . <b>LE36.Out inverted</b>	<i>Signal: Negated Latched Output (Q NOT)</i>
Logics . <b>LE37.Gate Out</b>	<i>Signal: Output of the logic gate</i>
Logics . <b>LE37.Timer Out</b>	<i>Signal: Timer Output</i>
Logics . <b>LE37.Out</b>	<i>Signal: Latched Output (Q)</i>
Logics . <b>LE37.Out inverted</b>	<i>Signal: Negated Latched Output (Q NOT)</i>

<b>AdaptSet</b>	<b>Description</b>
Logics . <b>LE38.Gate Out</b>	<i>Signal: Output of the logic gate</i>
Logics . <b>LE38.Timer Out</b>	<i>Signal: Timer Output</i>
Logics . <b>LE38.Out</b>	<i>Signal: Latched Output (Q)</i>
Logics . <b>LE38.Out inverted</b>	<i>Signal: Negated Latched Output (Q NOT)</i>
Logics . <b>LE39.Gate Out</b>	<i>Signal: Output of the logic gate</i>
Logics . <b>LE39.Timer Out</b>	<i>Signal: Timer Output</i>
Logics . <b>LE39.Out</b>	<i>Signal: Latched Output (Q)</i>
Logics . <b>LE39.Out inverted</b>	<i>Signal: Negated Latched Output (Q NOT)</i>
Logics . <b>LE40.Gate Out</b>	<i>Signal: Output of the logic gate</i>
Logics . <b>LE40.Timer Out</b>	<i>Signal: Timer Output</i>
Logics . <b>LE40.Out</b>	<i>Signal: Latched Output (Q)</i>
Logics . <b>LE40.Out inverted</b>	<i>Signal: Negated Latched Output (Q NOT)</i>
Logics . <b>LE41.Gate Out</b>	<i>Signal: Output of the logic gate</i>
Logics . <b>LE41.Timer Out</b>	<i>Signal: Timer Output</i>
Logics . <b>LE41.Out</b>	<i>Signal: Latched Output (Q)</i>
Logics . <b>LE41.Out inverted</b>	<i>Signal: Negated Latched Output (Q NOT)</i>
Logics . <b>LE42.Gate Out</b>	<i>Signal: Output of the logic gate</i>
Logics . <b>LE42.Timer Out</b>	<i>Signal: Timer Output</i>
Logics . <b>LE42.Out</b>	<i>Signal: Latched Output (Q)</i>
Logics . <b>LE42.Out inverted</b>	<i>Signal: Negated Latched Output (Q NOT)</i>
Logics . <b>LE43.Gate Out</b>	<i>Signal: Output of the logic gate</i>
Logics . <b>LE43.Timer Out</b>	<i>Signal: Timer Output</i>
Logics . <b>LE43.Out</b>	<i>Signal: Latched Output (Q)</i>
Logics . <b>LE43.Out inverted</b>	<i>Signal: Negated Latched Output (Q NOT)</i>
Logics . <b>LE44.Gate Out</b>	<i>Signal: Output of the logic gate</i>
Logics . <b>LE44.Timer Out</b>	<i>Signal: Timer Output</i>
Logics . <b>LE44.Out</b>	<i>Signal: Latched Output (Q)</i>
Logics . <b>LE44.Out inverted</b>	<i>Signal: Negated Latched Output (Q NOT)</i>



<b>AdaptSet</b>	<b>Description</b>
Logics . <b>LE45.Gate Out</b>	<i>Signal: Output of the logic gate</i>
Logics . <b>LE45.Timer Out</b>	<i>Signal: Timer Output</i>
Logics . <b>LE45.Out</b>	<i>Signal: Latched Output (Q)</i>
Logics . <b>LE45.Out inverted</b>	<i>Signal: Negated Latched Output (Q NOT)</i>
Logics . <b>LE46.Gate Out</b>	<i>Signal: Output of the logic gate</i>
Logics . <b>LE46.Timer Out</b>	<i>Signal: Timer Output</i>
Logics . <b>LE46.Out</b>	<i>Signal: Latched Output (Q)</i>
Logics . <b>LE46.Out inverted</b>	<i>Signal: Negated Latched Output (Q NOT)</i>
Logics . <b>LE47.Gate Out</b>	<i>Signal: Output of the logic gate</i>
Logics . <b>LE47.Timer Out</b>	<i>Signal: Timer Output</i>
Logics . <b>LE47.Out</b>	<i>Signal: Latched Output (Q)</i>
Logics . <b>LE47.Out inverted</b>	<i>Signal: Negated Latched Output (Q NOT)</i>
Logics . <b>LE48.Gate Out</b>	<i>Signal: Output of the logic gate</i>
Logics . <b>LE48.Timer Out</b>	<i>Signal: Timer Output</i>
Logics . <b>LE48.Out</b>	<i>Signal: Latched Output (Q)</i>
Logics . <b>LE48.Out inverted</b>	<i>Signal: Negated Latched Output (Q NOT)</i>
Logics . <b>LE49.Gate Out</b>	<i>Signal: Output of the logic gate</i>
Logics . <b>LE49.Timer Out</b>	<i>Signal: Timer Output</i>
Logics . <b>LE49.Out</b>	<i>Signal: Latched Output (Q)</i>
Logics . <b>LE49.Out inverted</b>	<i>Signal: Negated Latched Output (Q NOT)</i>
Logics . <b>LE50.Gate Out</b>	<i>Signal: Output of the logic gate</i>
Logics . <b>LE50.Timer Out</b>	<i>Signal: Timer Output</i>
Logics . <b>LE50.Out</b>	<i>Signal: Latched Output (Q)</i>
Logics . <b>LE50.Out inverted</b>	<i>Signal: Negated Latched Output (Q NOT)</i>
Logics . <b>LE51.Gate Out</b>	<i>Signal: Output of the logic gate</i>
Logics . <b>LE51.Timer Out</b>	<i>Signal: Timer Output</i>
Logics . <b>LE51.Out</b>	<i>Signal: Latched Output (Q)</i>
Logics . <b>LE51.Out inverted</b>	<i>Signal: Negated Latched Output (Q NOT)</i>

<b>AdaptSet</b>	<b>Description</b>
Logics . <b>LE52.Gate Out</b>	<i>Signal: Output of the logic gate</i>
Logics . <b>LE52.Timer Out</b>	<i>Signal: Timer Output</i>
Logics . <b>LE52.Out</b>	<i>Signal: Latched Output (Q)</i>
Logics . <b>LE52.Out inverted</b>	<i>Signal: Negated Latched Output (Q NOT)</i>
Logics . <b>LE53.Gate Out</b>	<i>Signal: Output of the logic gate</i>
Logics . <b>LE53.Timer Out</b>	<i>Signal: Timer Output</i>
Logics . <b>LE53.Out</b>	<i>Signal: Latched Output (Q)</i>
Logics . <b>LE53.Out inverted</b>	<i>Signal: Negated Latched Output (Q NOT)</i>
Logics . <b>LE54.Gate Out</b>	<i>Signal: Output of the logic gate</i>
Logics . <b>LE54.Timer Out</b>	<i>Signal: Timer Output</i>
Logics . <b>LE54.Out</b>	<i>Signal: Latched Output (Q)</i>
Logics . <b>LE54.Out inverted</b>	<i>Signal: Negated Latched Output (Q NOT)</i>
Logics . <b>LE55.Gate Out</b>	<i>Signal: Output of the logic gate</i>
Logics . <b>LE55.Timer Out</b>	<i>Signal: Timer Output</i>
Logics . <b>LE55.Out</b>	<i>Signal: Latched Output (Q)</i>
Logics . <b>LE55.Out inverted</b>	<i>Signal: Negated Latched Output (Q NOT)</i>
Logics . <b>LE56.Gate Out</b>	<i>Signal: Output of the logic gate</i>
Logics . <b>LE56.Timer Out</b>	<i>Signal: Timer Output</i>
Logics . <b>LE56.Out</b>	<i>Signal: Latched Output (Q)</i>
Logics . <b>LE56.Out inverted</b>	<i>Signal: Negated Latched Output (Q NOT)</i>
Logics . <b>LE57.Gate Out</b>	<i>Signal: Output of the logic gate</i>
Logics . <b>LE57.Timer Out</b>	<i>Signal: Timer Output</i>
Logics . <b>LE57.Out</b>	<i>Signal: Latched Output (Q)</i>
Logics . <b>LE57.Out inverted</b>	<i>Signal: Negated Latched Output (Q NOT)</i>
Logics . <b>LE58.Gate Out</b>	<i>Signal: Output of the logic gate</i>
Logics . <b>LE58.Timer Out</b>	<i>Signal: Timer Output</i>
Logics . <b>LE58.Out</b>	<i>Signal: Latched Output (Q)</i>
Logics . <b>LE58.Out inverted</b>	<i>Signal: Negated Latched Output (Q NOT)</i>

<b>AdaptSet</b>	<b>Description</b>
Logics . <b>LE59.Gate Out</b>	<i>Signal: Output of the logic gate</i>
Logics . <b>LE59.Timer Out</b>	<i>Signal: Timer Output</i>
Logics . <b>LE59.Out</b>	<i>Signal: Latched Output (Q)</i>
Logics . <b>LE59.Out inverted</b>	<i>Signal: Negated Latched Output (Q NOT)</i>
Logics . <b>LE60.Gate Out</b>	<i>Signal: Output of the logic gate</i>
Logics . <b>LE60.Timer Out</b>	<i>Signal: Timer Output</i>
Logics . <b>LE60.Out</b>	<i>Signal: Latched Output (Q)</i>
Logics . <b>LE60.Out inverted</b>	<i>Signal: Negated Latched Output (Q NOT)</i>
Logics . <b>LE61.Gate Out</b>	<i>Signal: Output of the logic gate</i>
Logics . <b>LE61.Timer Out</b>	<i>Signal: Timer Output</i>
Logics . <b>LE61.Out</b>	<i>Signal: Latched Output (Q)</i>
Logics . <b>LE61.Out inverted</b>	<i>Signal: Negated Latched Output (Q NOT)</i>
Logics . <b>LE62.Gate Out</b>	<i>Signal: Output of the logic gate</i>
Logics . <b>LE62.Timer Out</b>	<i>Signal: Timer Output</i>
Logics . <b>LE62.Out</b>	<i>Signal: Latched Output (Q)</i>
Logics . <b>LE62.Out inverted</b>	<i>Signal: Negated Latched Output (Q NOT)</i>
Logics . <b>LE63.Gate Out</b>	<i>Signal: Output of the logic gate</i>
Logics . <b>LE63.Timer Out</b>	<i>Signal: Timer Output</i>
Logics . <b>LE63.Out</b>	<i>Signal: Latched Output (Q)</i>
Logics . <b>LE63.Out inverted</b>	<i>Signal: Negated Latched Output (Q NOT)</i>
Logics . <b>LE64.Gate Out</b>	<i>Signal: Output of the logic gate</i>
Logics . <b>LE64.Timer Out</b>	<i>Signal: Timer Output</i>
Logics . <b>LE64.Out</b>	<i>Signal: Latched Output (Q)</i>
Logics . <b>LE64.Out inverted</b>	<i>Signal: Negated Latched Output (Q NOT)</i>
Logics . <b>LE65.Gate Out</b>	<i>Signal: Output of the logic gate</i>
Logics . <b>LE65.Timer Out</b>	<i>Signal: Timer Output</i>
Logics . <b>LE65.Out</b>	<i>Signal: Latched Output (Q)</i>
Logics . <b>LE65.Out inverted</b>	<i>Signal: Negated Latched Output (Q NOT)</i>

<b>AdaptSet</b>	<b>Description</b>
Logics . <b>LE66.Gate Out</b>	<i>Signal: Output of the logic gate</i>
Logics . <b>LE66.Timer Out</b>	<i>Signal: Timer Output</i>
Logics . <b>LE66.Out</b>	<i>Signal: Latched Output (Q)</i>
Logics . <b>LE66.Out inverted</b>	<i>Signal: Negated Latched Output (Q NOT)</i>
Logics . <b>LE67.Gate Out</b>	<i>Signal: Output of the logic gate</i>
Logics . <b>LE67.Timer Out</b>	<i>Signal: Timer Output</i>
Logics . <b>LE67.Out</b>	<i>Signal: Latched Output (Q)</i>
Logics . <b>LE67.Out inverted</b>	<i>Signal: Negated Latched Output (Q NOT)</i>
Logics . <b>LE68.Gate Out</b>	<i>Signal: Output of the logic gate</i>
Logics . <b>LE68.Timer Out</b>	<i>Signal: Timer Output</i>
Logics . <b>LE68.Out</b>	<i>Signal: Latched Output (Q)</i>
Logics . <b>LE68.Out inverted</b>	<i>Signal: Negated Latched Output (Q NOT)</i>
Logics . <b>LE69.Gate Out</b>	<i>Signal: Output of the logic gate</i>
Logics . <b>LE69.Timer Out</b>	<i>Signal: Timer Output</i>
Logics . <b>LE69.Out</b>	<i>Signal: Latched Output (Q)</i>
Logics . <b>LE69.Out inverted</b>	<i>Signal: Negated Latched Output (Q NOT)</i>
Logics . <b>LE70.Gate Out</b>	<i>Signal: Output of the logic gate</i>
Logics . <b>LE70.Timer Out</b>	<i>Signal: Timer Output</i>
Logics . <b>LE70.Out</b>	<i>Signal: Latched Output (Q)</i>
Logics . <b>LE70.Out inverted</b>	<i>Signal: Negated Latched Output (Q NOT)</i>
Logics . <b>LE71.Gate Out</b>	<i>Signal: Output of the logic gate</i>
Logics . <b>LE71.Timer Out</b>	<i>Signal: Timer Output</i>
Logics . <b>LE71.Out</b>	<i>Signal: Latched Output (Q)</i>
Logics . <b>LE71.Out inverted</b>	<i>Signal: Negated Latched Output (Q NOT)</i>
Logics . <b>LE72.Gate Out</b>	<i>Signal: Output of the logic gate</i>
Logics . <b>LE72.Timer Out</b>	<i>Signal: Timer Output</i>
Logics . <b>LE72.Out</b>	<i>Signal: Latched Output (Q)</i>
Logics . <b>LE72.Out inverted</b>	<i>Signal: Negated Latched Output (Q NOT)</i>

<b>AdaptSet</b>	<b>Description</b>
Logics . <b>LE73.Gate Out</b>	<i>Signal: Output of the logic gate</i>
Logics . <b>LE73.Timer Out</b>	<i>Signal: Timer Output</i>
Logics . <b>LE73.Out</b>	<i>Signal: Latched Output (Q)</i>
Logics . <b>LE73.Out inverted</b>	<i>Signal: Negated Latched Output (Q NOT)</i>
Logics . <b>LE74.Gate Out</b>	<i>Signal: Output of the logic gate</i>
Logics . <b>LE74.Timer Out</b>	<i>Signal: Timer Output</i>
Logics . <b>LE74.Out</b>	<i>Signal: Latched Output (Q)</i>
Logics . <b>LE74.Out inverted</b>	<i>Signal: Negated Latched Output (Q NOT)</i>
Logics . <b>LE75.Gate Out</b>	<i>Signal: Output of the logic gate</i>
Logics . <b>LE75.Timer Out</b>	<i>Signal: Timer Output</i>
Logics . <b>LE75.Out</b>	<i>Signal: Latched Output (Q)</i>
Logics . <b>LE75.Out inverted</b>	<i>Signal: Negated Latched Output (Q NOT)</i>
Logics . <b>LE76.Gate Out</b>	<i>Signal: Output of the logic gate</i>
Logics . <b>LE76.Timer Out</b>	<i>Signal: Timer Output</i>
Logics . <b>LE76.Out</b>	<i>Signal: Latched Output (Q)</i>
Logics . <b>LE76.Out inverted</b>	<i>Signal: Negated Latched Output (Q NOT)</i>
Logics . <b>LE77.Gate Out</b>	<i>Signal: Output of the logic gate</i>
Logics . <b>LE77.Timer Out</b>	<i>Signal: Timer Output</i>
Logics . <b>LE77.Out</b>	<i>Signal: Latched Output (Q)</i>
Logics . <b>LE77.Out inverted</b>	<i>Signal: Negated Latched Output (Q NOT)</i>
Logics . <b>LE78.Gate Out</b>	<i>Signal: Output of the logic gate</i>
Logics . <b>LE78.Timer Out</b>	<i>Signal: Timer Output</i>
Logics . <b>LE78.Out</b>	<i>Signal: Latched Output (Q)</i>
Logics . <b>LE78.Out inverted</b>	<i>Signal: Negated Latched Output (Q NOT)</i>
Logics . <b>LE79.Gate Out</b>	<i>Signal: Output of the logic gate</i>
Logics . <b>LE79.Timer Out</b>	<i>Signal: Timer Output</i>
Logics . <b>LE79.Out</b>	<i>Signal: Latched Output (Q)</i>
Logics . <b>LE79.Out inverted</b>	<i>Signal: Negated Latched Output (Q NOT)</i>

AdaptSet	Description
Logics . <b>LE80.Gate Out</b>	Signal: Output of the logic gate
Logics . <b>LE80.Timer Out</b>	Signal: Timer Output
Logics . <b>LE80.Out</b>	Signal: Latched Output (Q)
Logics . <b>LE80.Out inverted</b>	Signal: Negated Latched Output (Q NOT)

### **TripCmd Selection**

This parameter determines if the final trip of the RTD module is issued by the default way or by the voting groups.

Selection list referenced by the following parameters:

-  RTD . TripCmd Selection

TripCmd Selection	Description
<b>Trip</b>	Default RTD Trip
<b>Voting Trip</b>	Voting Trip. Trip if one of the voting groups has a pending/active trip.

### **Scheme**

Via this selection menu, the BF supervision scheme is to be selected.

Selection list referenced by the following parameters:

-  CBF . Scheme

Scheme	Description
<b>50BF</b>	A Breaker Failure is detected, if the measured currents do not fall below a settable threshold within a settable time interval.
<b>CB Pos</b>	A Circuit Breaker Failure is detected after a CB open command, if the Position Contacts of the Circuit Breaker do not allow the conclusion that the Breaker is now in the Open Position within a settable time interval.
<b>50BF and CB Pos</b>	A Circuit Breaker Failure is detected if the evaluation of the Position Indicators or the evaluation of the current measurement indicate that the CB Off-Command was not executed. This scheme is called "Minimal Current Scheme" according to IEEEC37.119.

### Trigger

Determining the trigger mode for the Breaker Failure. The selection will pickup the Breaker Failure as well as the assignments (Trigger 1, Trigger 2, Trigger 3). They are OR connected.

Selection list referenced by the following parameters:

-  CBF . Trigger

Trigger	Description
- . -	<i>no assignment</i>
<b>All Trips</b>	<i>All trip signals that are assigned to this breaker (within the trip manager) will start the BF module.</i>
<b>External Trips</b>	<i>All external trips that are assigned to this breaker (within the trip manager) will start the BF module.</i>
<b>Current Trips</b>	<i>All current trips that are assigned to this breaker (within the trip manager) will start the BF module.</i>

### External Trips

All external trips that are assigned to this breaker (within the trip manager) will start the BF module.

External Trips	Description
"_"	<i>No assignment</i>
ExP[1] . <b>TripCmd</b>	<i>Signal: Trip Command</i>
ExP[2] . <b>TripCmd</b>	<i>Signal: Trip Command</i>
ExP[3] . <b>TripCmd</b>	<i>Signal: Trip Command</i>
ExP[4] . <b>TripCmd</b>	<i>Signal: Trip Command</i>

### Current Trips

All current trips that are assigned to this breaker (within the trip manager) will start the BF module.

Current Trips	Description
"_"	<i>No assignment</i>
I[1] . <b>TripCmd</b>	<i>Signal: Trip Command</i>
I[2] . <b>TripCmd</b>	<i>Signal: Trip Command</i>

<b>Current Trips</b>	<b>Description</b>
I[3] . <b>TripCmd</b>	<i>Signal: Trip Command</i>
I[4] . <b>TripCmd</b>	<i>Signal: Trip Command</i>
I[5] . <b>TripCmd</b>	<i>Signal: Trip Command</i>
I[6] . <b>TripCmd</b>	<i>Signal: Trip Command</i>
IG[1] . <b>TripCmd</b>	<i>Signal: Trip Command</i>
IG[2] . <b>TripCmd</b>	<i>Signal: Trip Command</i>
IG[3] . <b>TripCmd</b>	<i>Signal: Trip Command</i>
IG[4] . <b>TripCmd</b>	<i>Signal: Trip Command</i>
ThR . <b>TripCmd</b>	<i>Signal: Trip Command</i>
Jam[1] . <b>TripCmd</b>	<i>Signal: Trip Command</i>
Jam[2] . <b>TripCmd</b>	<i>Signal: Trip Command</i>
I<[1] . <b>TripCmd</b>	<i>Signal: Trip Command</i>
I<[2] . <b>TripCmd</b>	<i>Signal: Trip Command</i>
I<[3] . <b>TripCmd</b>	<i>Signal: Trip Command</i>
I2>[1] . <b>TripCmd</b>	<i>Signal: Trip Command</i>
I2>[2] . <b>TripCmd</b>	<i>Signal: Trip Command</i>

### **Trigger**

Determining the trigger mode for the Breaker Failure. The selection will pickup the Breaker Failure as well as the assignments (Trigger 1, Trigger 2, Trigger 3). They are OR connected.

Selection list referenced by the following parameters:

-  CBF . Trigger1

<b>Trigger</b>	<b>Description</b>
"_"	<i>No assignment</i>
MStart . <b>TripCmd</b>	<i>Signal: Trip Command</i>
I[1] . <b>TripCmd</b>	<i>Signal: Trip Command</i>
I[2] . <b>TripCmd</b>	<i>Signal: Trip Command</i>
I[3] . <b>TripCmd</b>	<i>Signal: Trip Command</i>
I[4] . <b>TripCmd</b>	<i>Signal: Trip Command</i>



<b>Trigger</b>	<b>Description</b>
I[5] . <b>TripCmd</b>	<i>Signal: Trip Command</i>
I[6] . <b>TripCmd</b>	<i>Signal: Trip Command</i>
IG[1] . <b>TripCmd</b>	<i>Signal: Trip Command</i>
IG[2] . <b>TripCmd</b>	<i>Signal: Trip Command</i>
IG[3] . <b>TripCmd</b>	<i>Signal: Trip Command</i>
IG[4] . <b>TripCmd</b>	<i>Signal: Trip Command</i>
ThR . <b>TripCmd</b>	<i>Signal: Trip Command</i>
Jam[1] . <b>TripCmd</b>	<i>Signal: Trip Command</i>
Jam[2] . <b>TripCmd</b>	<i>Signal: Trip Command</i>
I<[1] . <b>TripCmd</b>	<i>Signal: Trip Command</i>
I<[2] . <b>TripCmd</b>	<i>Signal: Trip Command</i>
I<[3] . <b>TripCmd</b>	<i>Signal: Trip Command</i>
I2>[1] . <b>TripCmd</b>	<i>Signal: Trip Command</i>
I2>[2] . <b>TripCmd</b>	<i>Signal: Trip Command</i>
ExP[1] . <b>TripCmd</b>	<i>Signal: Trip Command</i>
ExP[2] . <b>TripCmd</b>	<i>Signal: Trip Command</i>
ExP[3] . <b>TripCmd</b>	<i>Signal: Trip Command</i>
ExP[4] . <b>TripCmd</b>	<i>Signal: Trip Command</i>
RTD . <b>TripCmd</b>	<i>Signal: Trip Command</i>
DI Slot X1 . <b>DI 1</b>	<i>Signal: Digital Input</i>
DI Slot X1 . <b>DI 2</b>	<i>Signal: Digital Input</i>
DI Slot X1 . <b>DI 3</b>	<i>Signal: Digital Input</i>
DI Slot X1 . <b>DI 4</b>	<i>Signal: Digital Input</i>
DI Slot X1 . <b>DI 5</b>	<i>Signal: Digital Input</i>
DI Slot X1 . <b>DI 6</b>	<i>Signal: Digital Input</i>
DI Slot X1 . <b>DI 7</b>	<i>Signal: Digital Input</i>
DI Slot X1 . <b>DI 8</b>	<i>Signal: Digital Input</i>
DI Slot X1 . <b>DI 1</b>	<i>Signal: Digital Input</i>
DI Slot X1 . <b>DI 2</b>	<i>Signal: Digital Input</i>
DI Slot X1 . <b>DI 3</b>	<i>Signal: Digital Input</i>
DI Slot X1 . <b>DI 4</b>	<i>Signal: Digital Input</i>
Logics . <b>LE1.Gate Out</b>	<i>Signal: Output of the logic gate</i>

<b>Trigger</b>	<b>Description</b>
Logics . <b>LE1.Timer Out</b>	<i>Signal: Timer Output</i>
Logics . <b>LE1.Out</b>	<i>Signal: Latched Output (Q)</i>
Logics . <b>LE1.Out inverted</b>	<i>Signal: Negated Latched Output (Q NOT)</i>
Logics . <b>LE2.Gate Out</b>	<i>Signal: Output of the logic gate</i>
Logics . <b>LE2.Timer Out</b>	<i>Signal: Timer Output</i>
Logics . <b>LE2.Out</b>	<i>Signal: Latched Output (Q)</i>
Logics . <b>LE2.Out inverted</b>	<i>Signal: Negated Latched Output (Q NOT)</i>
Logics . <b>LE3.Gate Out</b>	<i>Signal: Output of the logic gate</i>
Logics . <b>LE3.Timer Out</b>	<i>Signal: Timer Output</i>
Logics . <b>LE3.Out</b>	<i>Signal: Latched Output (Q)</i>
Logics . <b>LE3.Out inverted</b>	<i>Signal: Negated Latched Output (Q NOT)</i>
Logics . <b>LE4.Gate Out</b>	<i>Signal: Output of the logic gate</i>
Logics . <b>LE4.Timer Out</b>	<i>Signal: Timer Output</i>
Logics . <b>LE4.Out</b>	<i>Signal: Latched Output (Q)</i>
Logics . <b>LE4.Out inverted</b>	<i>Signal: Negated Latched Output (Q NOT)</i>
Logics . <b>LE5.Gate Out</b>	<i>Signal: Output of the logic gate</i>
Logics . <b>LE5.Timer Out</b>	<i>Signal: Timer Output</i>
Logics . <b>LE5.Out</b>	<i>Signal: Latched Output (Q)</i>
Logics . <b>LE5.Out inverted</b>	<i>Signal: Negated Latched Output (Q NOT)</i>
Logics . <b>LE6.Gate Out</b>	<i>Signal: Output of the logic gate</i>
Logics . <b>LE6.Timer Out</b>	<i>Signal: Timer Output</i>
Logics . <b>LE6.Out</b>	<i>Signal: Latched Output (Q)</i>
Logics . <b>LE6.Out inverted</b>	<i>Signal: Negated Latched Output (Q NOT)</i>
Logics . <b>LE7.Gate Out</b>	<i>Signal: Output of the logic gate</i>
Logics . <b>LE7.Timer Out</b>	<i>Signal: Timer Output</i>
Logics . <b>LE7.Out</b>	<i>Signal: Latched Output (Q)</i>
Logics . <b>LE7.Out inverted</b>	<i>Signal: Negated Latched Output (Q NOT)</i>
Logics . <b>LE8.Gate Out</b>	<i>Signal: Output of the logic gate</i>

<b>Trigger</b>	<b>Description</b>
Logics . <b>LE8.Timer Out</b>	<i>Signal: Timer Output</i>
Logics . <b>LE8.Out</b>	<i>Signal: Latched Output (Q)</i>
Logics . <b>LE8.Out inverted</b>	<i>Signal: Negated Latched Output (Q NOT)</i>
Logics . <b>LE9.Gate Out</b>	<i>Signal: Output of the logic gate</i>
Logics . <b>LE9.Timer Out</b>	<i>Signal: Timer Output</i>
Logics . <b>LE9.Out</b>	<i>Signal: Latched Output (Q)</i>
Logics . <b>LE9.Out inverted</b>	<i>Signal: Negated Latched Output (Q NOT)</i>
Logics . <b>LE10.Gate Out</b>	<i>Signal: Output of the logic gate</i>
Logics . <b>LE10.Timer Out</b>	<i>Signal: Timer Output</i>
Logics . <b>LE10.Out</b>	<i>Signal: Latched Output (Q)</i>
Logics . <b>LE10.Out inverted</b>	<i>Signal: Negated Latched Output (Q NOT)</i>
Logics . <b>LE11.Gate Out</b>	<i>Signal: Output of the logic gate</i>
Logics . <b>LE11.Timer Out</b>	<i>Signal: Timer Output</i>
Logics . <b>LE11.Out</b>	<i>Signal: Latched Output (Q)</i>
Logics . <b>LE11.Out inverted</b>	<i>Signal: Negated Latched Output (Q NOT)</i>
Logics . <b>LE12.Gate Out</b>	<i>Signal: Output of the logic gate</i>
Logics . <b>LE12.Timer Out</b>	<i>Signal: Timer Output</i>
Logics . <b>LE12.Out</b>	<i>Signal: Latched Output (Q)</i>
Logics . <b>LE12.Out inverted</b>	<i>Signal: Negated Latched Output (Q NOT)</i>
Logics . <b>LE13.Gate Out</b>	<i>Signal: Output of the logic gate</i>
Logics . <b>LE13.Timer Out</b>	<i>Signal: Timer Output</i>
Logics . <b>LE13.Out</b>	<i>Signal: Latched Output (Q)</i>
Logics . <b>LE13.Out inverted</b>	<i>Signal: Negated Latched Output (Q NOT)</i>
Logics . <b>LE14.Gate Out</b>	<i>Signal: Output of the logic gate</i>
Logics . <b>LE14.Timer Out</b>	<i>Signal: Timer Output</i>
Logics . <b>LE14.Out</b>	<i>Signal: Latched Output (Q)</i>
Logics . <b>LE14.Out inverted</b>	<i>Signal: Negated Latched Output (Q NOT)</i>
Logics . <b>LE15.Gate Out</b>	<i>Signal: Output of the logic gate</i>

<b>Trigger</b>	<b>Description</b>
Logics . <b>LE15.Timer Out</b>	<i>Signal: Timer Output</i>
Logics . <b>LE15.Out</b>	<i>Signal: Latched Output (Q)</i>
Logics . <b>LE15.Out inverted</b>	<i>Signal: Negated Latched Output (Q NOT)</i>
Logics . <b>LE16.Gate Out</b>	<i>Signal: Output of the logic gate</i>
Logics . <b>LE16.Timer Out</b>	<i>Signal: Timer Output</i>
Logics . <b>LE16.Out</b>	<i>Signal: Latched Output (Q)</i>
Logics . <b>LE16.Out inverted</b>	<i>Signal: Negated Latched Output (Q NOT)</i>
Logics . <b>LE17.Gate Out</b>	<i>Signal: Output of the logic gate</i>
Logics . <b>LE17.Timer Out</b>	<i>Signal: Timer Output</i>
Logics . <b>LE17.Out</b>	<i>Signal: Latched Output (Q)</i>
Logics . <b>LE17.Out inverted</b>	<i>Signal: Negated Latched Output (Q NOT)</i>
Logics . <b>LE18.Gate Out</b>	<i>Signal: Output of the logic gate</i>
Logics . <b>LE18.Timer Out</b>	<i>Signal: Timer Output</i>
Logics . <b>LE18.Out</b>	<i>Signal: Latched Output (Q)</i>
Logics . <b>LE18.Out inverted</b>	<i>Signal: Negated Latched Output (Q NOT)</i>
Logics . <b>LE19.Gate Out</b>	<i>Signal: Output of the logic gate</i>
Logics . <b>LE19.Timer Out</b>	<i>Signal: Timer Output</i>
Logics . <b>LE19.Out</b>	<i>Signal: Latched Output (Q)</i>
Logics . <b>LE19.Out inverted</b>	<i>Signal: Negated Latched Output (Q NOT)</i>
Logics . <b>LE20.Gate Out</b>	<i>Signal: Output of the logic gate</i>
Logics . <b>LE20.Timer Out</b>	<i>Signal: Timer Output</i>
Logics . <b>LE20.Out</b>	<i>Signal: Latched Output (Q)</i>
Logics . <b>LE20.Out inverted</b>	<i>Signal: Negated Latched Output (Q NOT)</i>
Logics . <b>LE21.Gate Out</b>	<i>Signal: Output of the logic gate</i>
Logics . <b>LE21.Timer Out</b>	<i>Signal: Timer Output</i>
Logics . <b>LE21.Out</b>	<i>Signal: Latched Output (Q)</i>
Logics . <b>LE21.Out inverted</b>	<i>Signal: Negated Latched Output (Q NOT)</i>
Logics . <b>LE22.Gate Out</b>	<i>Signal: Output of the logic gate</i>

<b>Trigger</b>	<b>Description</b>
Logics . <b>LE22.Timer Out</b>	<i>Signal: Timer Output</i>
Logics . <b>LE22.Out</b>	<i>Signal: Latched Output (Q)</i>
Logics . <b>LE22.Out inverted</b>	<i>Signal: Negated Latched Output (Q NOT)</i>
Logics . <b>LE23.Gate Out</b>	<i>Signal: Output of the logic gate</i>
Logics . <b>LE23.Timer Out</b>	<i>Signal: Timer Output</i>
Logics . <b>LE23.Out</b>	<i>Signal: Latched Output (Q)</i>
Logics . <b>LE23.Out inverted</b>	<i>Signal: Negated Latched Output (Q NOT)</i>
Logics . <b>LE24.Gate Out</b>	<i>Signal: Output of the logic gate</i>
Logics . <b>LE24.Timer Out</b>	<i>Signal: Timer Output</i>
Logics . <b>LE24.Out</b>	<i>Signal: Latched Output (Q)</i>
Logics . <b>LE24.Out inverted</b>	<i>Signal: Negated Latched Output (Q NOT)</i>
Logics . <b>LE25.Gate Out</b>	<i>Signal: Output of the logic gate</i>
Logics . <b>LE25.Timer Out</b>	<i>Signal: Timer Output</i>
Logics . <b>LE25.Out</b>	<i>Signal: Latched Output (Q)</i>
Logics . <b>LE25.Out inverted</b>	<i>Signal: Negated Latched Output (Q NOT)</i>
Logics . <b>LE26.Gate Out</b>	<i>Signal: Output of the logic gate</i>
Logics . <b>LE26.Timer Out</b>	<i>Signal: Timer Output</i>
Logics . <b>LE26.Out</b>	<i>Signal: Latched Output (Q)</i>
Logics . <b>LE26.Out inverted</b>	<i>Signal: Negated Latched Output (Q NOT)</i>
Logics . <b>LE27.Gate Out</b>	<i>Signal: Output of the logic gate</i>
Logics . <b>LE27.Timer Out</b>	<i>Signal: Timer Output</i>
Logics . <b>LE27.Out</b>	<i>Signal: Latched Output (Q)</i>
Logics . <b>LE27.Out inverted</b>	<i>Signal: Negated Latched Output (Q NOT)</i>
Logics . <b>LE28.Gate Out</b>	<i>Signal: Output of the logic gate</i>
Logics . <b>LE28.Timer Out</b>	<i>Signal: Timer Output</i>
Logics . <b>LE28.Out</b>	<i>Signal: Latched Output (Q)</i>
Logics . <b>LE28.Out inverted</b>	<i>Signal: Negated Latched Output (Q NOT)</i>
Logics . <b>LE29.Gate Out</b>	<i>Signal: Output of the logic gate</i>

<b>Trigger</b>	<b>Description</b>
Logics . <b>LE29.Timer Out</b>	<i>Signal: Timer Output</i>
Logics . <b>LE29.Out</b>	<i>Signal: Latched Output (Q)</i>
Logics . <b>LE29.Out inverted</b>	<i>Signal: Negated Latched Output (Q NOT)</i>
Logics . <b>LE30.Gate Out</b>	<i>Signal: Output of the logic gate</i>
Logics . <b>LE30.Timer Out</b>	<i>Signal: Timer Output</i>
Logics . <b>LE30.Out</b>	<i>Signal: Latched Output (Q)</i>
Logics . <b>LE30.Out inverted</b>	<i>Signal: Negated Latched Output (Q NOT)</i>
Logics . <b>LE31.Gate Out</b>	<i>Signal: Output of the logic gate</i>
Logics . <b>LE31.Timer Out</b>	<i>Signal: Timer Output</i>
Logics . <b>LE31.Out</b>	<i>Signal: Latched Output (Q)</i>
Logics . <b>LE31.Out inverted</b>	<i>Signal: Negated Latched Output (Q NOT)</i>
Logics . <b>LE32.Gate Out</b>	<i>Signal: Output of the logic gate</i>
Logics . <b>LE32.Timer Out</b>	<i>Signal: Timer Output</i>
Logics . <b>LE32.Out</b>	<i>Signal: Latched Output (Q)</i>
Logics . <b>LE32.Out inverted</b>	<i>Signal: Negated Latched Output (Q NOT)</i>
Logics . <b>LE33.Gate Out</b>	<i>Signal: Output of the logic gate</i>
Logics . <b>LE33.Timer Out</b>	<i>Signal: Timer Output</i>
Logics . <b>LE33.Out</b>	<i>Signal: Latched Output (Q)</i>
Logics . <b>LE33.Out inverted</b>	<i>Signal: Negated Latched Output (Q NOT)</i>
Logics . <b>LE34.Gate Out</b>	<i>Signal: Output of the logic gate</i>
Logics . <b>LE34.Timer Out</b>	<i>Signal: Timer Output</i>
Logics . <b>LE34.Out</b>	<i>Signal: Latched Output (Q)</i>
Logics . <b>LE34.Out inverted</b>	<i>Signal: Negated Latched Output (Q NOT)</i>
Logics . <b>LE35.Gate Out</b>	<i>Signal: Output of the logic gate</i>
Logics . <b>LE35.Timer Out</b>	<i>Signal: Timer Output</i>
Logics . <b>LE35.Out</b>	<i>Signal: Latched Output (Q)</i>
Logics . <b>LE35.Out inverted</b>	<i>Signal: Negated Latched Output (Q NOT)</i>
Logics . <b>LE36.Gate Out</b>	<i>Signal: Output of the logic gate</i>

<b>Trigger</b>	<b>Description</b>
Logics . <b>LE36.Timer Out</b>	<i>Signal: Timer Output</i>
Logics . <b>LE36.Out</b>	<i>Signal: Latched Output (Q)</i>
Logics . <b>LE36.Out inverted</b>	<i>Signal: Negated Latched Output (Q NOT)</i>
Logics . <b>LE37.Gate Out</b>	<i>Signal: Output of the logic gate</i>
Logics . <b>LE37.Timer Out</b>	<i>Signal: Timer Output</i>
Logics . <b>LE37.Out</b>	<i>Signal: Latched Output (Q)</i>
Logics . <b>LE37.Out inverted</b>	<i>Signal: Negated Latched Output (Q NOT)</i>
Logics . <b>LE38.Gate Out</b>	<i>Signal: Output of the logic gate</i>
Logics . <b>LE38.Timer Out</b>	<i>Signal: Timer Output</i>
Logics . <b>LE38.Out</b>	<i>Signal: Latched Output (Q)</i>
Logics . <b>LE38.Out inverted</b>	<i>Signal: Negated Latched Output (Q NOT)</i>
Logics . <b>LE39.Gate Out</b>	<i>Signal: Output of the logic gate</i>
Logics . <b>LE39.Timer Out</b>	<i>Signal: Timer Output</i>
Logics . <b>LE39.Out</b>	<i>Signal: Latched Output (Q)</i>
Logics . <b>LE39.Out inverted</b>	<i>Signal: Negated Latched Output (Q NOT)</i>
Logics . <b>LE40.Gate Out</b>	<i>Signal: Output of the logic gate</i>
Logics . <b>LE40.Timer Out</b>	<i>Signal: Timer Output</i>
Logics . <b>LE40.Out</b>	<i>Signal: Latched Output (Q)</i>
Logics . <b>LE40.Out inverted</b>	<i>Signal: Negated Latched Output (Q NOT)</i>
Logics . <b>LE41.Gate Out</b>	<i>Signal: Output of the logic gate</i>
Logics . <b>LE41.Timer Out</b>	<i>Signal: Timer Output</i>
Logics . <b>LE41.Out</b>	<i>Signal: Latched Output (Q)</i>
Logics . <b>LE41.Out inverted</b>	<i>Signal: Negated Latched Output (Q NOT)</i>
Logics . <b>LE42.Gate Out</b>	<i>Signal: Output of the logic gate</i>
Logics . <b>LE42.Timer Out</b>	<i>Signal: Timer Output</i>
Logics . <b>LE42.Out</b>	<i>Signal: Latched Output (Q)</i>
Logics . <b>LE42.Out inverted</b>	<i>Signal: Negated Latched Output (Q NOT)</i>
Logics . <b>LE43.Gate Out</b>	<i>Signal: Output of the logic gate</i>

<b>Trigger</b>	<b>Description</b>
Logics . <b>LE43.Timer Out</b>	<i>Signal: Timer Output</i>
Logics . <b>LE43.Out</b>	<i>Signal: Latched Output (Q)</i>
Logics . <b>LE43.Out inverted</b>	<i>Signal: Negated Latched Output (Q NOT)</i>
Logics . <b>LE44.Gate Out</b>	<i>Signal: Output of the logic gate</i>
Logics . <b>LE44.Timer Out</b>	<i>Signal: Timer Output</i>
Logics . <b>LE44.Out</b>	<i>Signal: Latched Output (Q)</i>
Logics . <b>LE44.Out inverted</b>	<i>Signal: Negated Latched Output (Q NOT)</i>
Logics . <b>LE45.Gate Out</b>	<i>Signal: Output of the logic gate</i>
Logics . <b>LE45.Timer Out</b>	<i>Signal: Timer Output</i>
Logics . <b>LE45.Out</b>	<i>Signal: Latched Output (Q)</i>
Logics . <b>LE45.Out inverted</b>	<i>Signal: Negated Latched Output (Q NOT)</i>
Logics . <b>LE46.Gate Out</b>	<i>Signal: Output of the logic gate</i>
Logics . <b>LE46.Timer Out</b>	<i>Signal: Timer Output</i>
Logics . <b>LE46.Out</b>	<i>Signal: Latched Output (Q)</i>
Logics . <b>LE46.Out inverted</b>	<i>Signal: Negated Latched Output (Q NOT)</i>
Logics . <b>LE47.Gate Out</b>	<i>Signal: Output of the logic gate</i>
Logics . <b>LE47.Timer Out</b>	<i>Signal: Timer Output</i>
Logics . <b>LE47.Out</b>	<i>Signal: Latched Output (Q)</i>
Logics . <b>LE47.Out inverted</b>	<i>Signal: Negated Latched Output (Q NOT)</i>
Logics . <b>LE48.Gate Out</b>	<i>Signal: Output of the logic gate</i>
Logics . <b>LE48.Timer Out</b>	<i>Signal: Timer Output</i>
Logics . <b>LE48.Out</b>	<i>Signal: Latched Output (Q)</i>
Logics . <b>LE48.Out inverted</b>	<i>Signal: Negated Latched Output (Q NOT)</i>
Logics . <b>LE49.Gate Out</b>	<i>Signal: Output of the logic gate</i>
Logics . <b>LE49.Timer Out</b>	<i>Signal: Timer Output</i>
Logics . <b>LE49.Out</b>	<i>Signal: Latched Output (Q)</i>
Logics . <b>LE49.Out inverted</b>	<i>Signal: Negated Latched Output (Q NOT)</i>
Logics . <b>LE50.Gate Out</b>	<i>Signal: Output of the logic gate</i>



<b>Trigger</b>	<b>Description</b>
Logics . <b>LE50.Timer Out</b>	<i>Signal: Timer Output</i>
Logics . <b>LE50.Out</b>	<i>Signal: Latched Output (Q)</i>
Logics . <b>LE50.Out inverted</b>	<i>Signal: Negated Latched Output (Q NOT)</i>
Logics . <b>LE51.Gate Out</b>	<i>Signal: Output of the logic gate</i>
Logics . <b>LE51.Timer Out</b>	<i>Signal: Timer Output</i>
Logics . <b>LE51.Out</b>	<i>Signal: Latched Output (Q)</i>
Logics . <b>LE51.Out inverted</b>	<i>Signal: Negated Latched Output (Q NOT)</i>
Logics . <b>LE52.Gate Out</b>	<i>Signal: Output of the logic gate</i>
Logics . <b>LE52.Timer Out</b>	<i>Signal: Timer Output</i>
Logics . <b>LE52.Out</b>	<i>Signal: Latched Output (Q)</i>
Logics . <b>LE52.Out inverted</b>	<i>Signal: Negated Latched Output (Q NOT)</i>
Logics . <b>LE53.Gate Out</b>	<i>Signal: Output of the logic gate</i>
Logics . <b>LE53.Timer Out</b>	<i>Signal: Timer Output</i>
Logics . <b>LE53.Out</b>	<i>Signal: Latched Output (Q)</i>
Logics . <b>LE53.Out inverted</b>	<i>Signal: Negated Latched Output (Q NOT)</i>
Logics . <b>LE54.Gate Out</b>	<i>Signal: Output of the logic gate</i>
Logics . <b>LE54.Timer Out</b>	<i>Signal: Timer Output</i>
Logics . <b>LE54.Out</b>	<i>Signal: Latched Output (Q)</i>
Logics . <b>LE54.Out inverted</b>	<i>Signal: Negated Latched Output (Q NOT)</i>
Logics . <b>LE55.Gate Out</b>	<i>Signal: Output of the logic gate</i>
Logics . <b>LE55.Timer Out</b>	<i>Signal: Timer Output</i>
Logics . <b>LE55.Out</b>	<i>Signal: Latched Output (Q)</i>
Logics . <b>LE55.Out inverted</b>	<i>Signal: Negated Latched Output (Q NOT)</i>
Logics . <b>LE56.Gate Out</b>	<i>Signal: Output of the logic gate</i>
Logics . <b>LE56.Timer Out</b>	<i>Signal: Timer Output</i>
Logics . <b>LE56.Out</b>	<i>Signal: Latched Output (Q)</i>
Logics . <b>LE56.Out inverted</b>	<i>Signal: Negated Latched Output (Q NOT)</i>
Logics . <b>LE57.Gate Out</b>	<i>Signal: Output of the logic gate</i>

<b>Trigger</b>	<b>Description</b>
Logics . <b>LE57.Timer Out</b>	<i>Signal: Timer Output</i>
Logics . <b>LE57.Out</b>	<i>Signal: Latched Output (Q)</i>
Logics . <b>LE57.Out inverted</b>	<i>Signal: Negated Latched Output (Q NOT)</i>
Logics . <b>LE58.Gate Out</b>	<i>Signal: Output of the logic gate</i>
Logics . <b>LE58.Timer Out</b>	<i>Signal: Timer Output</i>
Logics . <b>LE58.Out</b>	<i>Signal: Latched Output (Q)</i>
Logics . <b>LE58.Out inverted</b>	<i>Signal: Negated Latched Output (Q NOT)</i>
Logics . <b>LE59.Gate Out</b>	<i>Signal: Output of the logic gate</i>
Logics . <b>LE59.Timer Out</b>	<i>Signal: Timer Output</i>
Logics . <b>LE59.Out</b>	<i>Signal: Latched Output (Q)</i>
Logics . <b>LE59.Out inverted</b>	<i>Signal: Negated Latched Output (Q NOT)</i>
Logics . <b>LE60.Gate Out</b>	<i>Signal: Output of the logic gate</i>
Logics . <b>LE60.Timer Out</b>	<i>Signal: Timer Output</i>
Logics . <b>LE60.Out</b>	<i>Signal: Latched Output (Q)</i>
Logics . <b>LE60.Out inverted</b>	<i>Signal: Negated Latched Output (Q NOT)</i>
Logics . <b>LE61.Gate Out</b>	<i>Signal: Output of the logic gate</i>
Logics . <b>LE61.Timer Out</b>	<i>Signal: Timer Output</i>
Logics . <b>LE61.Out</b>	<i>Signal: Latched Output (Q)</i>
Logics . <b>LE61.Out inverted</b>	<i>Signal: Negated Latched Output (Q NOT)</i>
Logics . <b>LE62.Gate Out</b>	<i>Signal: Output of the logic gate</i>
Logics . <b>LE62.Timer Out</b>	<i>Signal: Timer Output</i>
Logics . <b>LE62.Out</b>	<i>Signal: Latched Output (Q)</i>
Logics . <b>LE62.Out inverted</b>	<i>Signal: Negated Latched Output (Q NOT)</i>
Logics . <b>LE63.Gate Out</b>	<i>Signal: Output of the logic gate</i>
Logics . <b>LE63.Timer Out</b>	<i>Signal: Timer Output</i>
Logics . <b>LE63.Out</b>	<i>Signal: Latched Output (Q)</i>
Logics . <b>LE63.Out inverted</b>	<i>Signal: Negated Latched Output (Q NOT)</i>
Logics . <b>LE64.Gate Out</b>	<i>Signal: Output of the logic gate</i>

<b>Trigger</b>	<b>Description</b>
Logics . <b>LE64.Timer Out</b>	<i>Signal: Timer Output</i>
Logics . <b>LE64.Out</b>	<i>Signal: Latched Output (Q)</i>
Logics . <b>LE64.Out inverted</b>	<i>Signal: Negated Latched Output (Q NOT)</i>
Logics . <b>LE65.Gate Out</b>	<i>Signal: Output of the logic gate</i>
Logics . <b>LE65.Timer Out</b>	<i>Signal: Timer Output</i>
Logics . <b>LE65.Out</b>	<i>Signal: Latched Output (Q)</i>
Logics . <b>LE65.Out inverted</b>	<i>Signal: Negated Latched Output (Q NOT)</i>
Logics . <b>LE66.Gate Out</b>	<i>Signal: Output of the logic gate</i>
Logics . <b>LE66.Timer Out</b>	<i>Signal: Timer Output</i>
Logics . <b>LE66.Out</b>	<i>Signal: Latched Output (Q)</i>
Logics . <b>LE66.Out inverted</b>	<i>Signal: Negated Latched Output (Q NOT)</i>
Logics . <b>LE67.Gate Out</b>	<i>Signal: Output of the logic gate</i>
Logics . <b>LE67.Timer Out</b>	<i>Signal: Timer Output</i>
Logics . <b>LE67.Out</b>	<i>Signal: Latched Output (Q)</i>
Logics . <b>LE67.Out inverted</b>	<i>Signal: Negated Latched Output (Q NOT)</i>
Logics . <b>LE68.Gate Out</b>	<i>Signal: Output of the logic gate</i>
Logics . <b>LE68.Timer Out</b>	<i>Signal: Timer Output</i>
Logics . <b>LE68.Out</b>	<i>Signal: Latched Output (Q)</i>
Logics . <b>LE68.Out inverted</b>	<i>Signal: Negated Latched Output (Q NOT)</i>
Logics . <b>LE69.Gate Out</b>	<i>Signal: Output of the logic gate</i>
Logics . <b>LE69.Timer Out</b>	<i>Signal: Timer Output</i>
Logics . <b>LE69.Out</b>	<i>Signal: Latched Output (Q)</i>
Logics . <b>LE69.Out inverted</b>	<i>Signal: Negated Latched Output (Q NOT)</i>
Logics . <b>LE70.Gate Out</b>	<i>Signal: Output of the logic gate</i>
Logics . <b>LE70.Timer Out</b>	<i>Signal: Timer Output</i>
Logics . <b>LE70.Out</b>	<i>Signal: Latched Output (Q)</i>
Logics . <b>LE70.Out inverted</b>	<i>Signal: Negated Latched Output (Q NOT)</i>
Logics . <b>LE71.Gate Out</b>	<i>Signal: Output of the logic gate</i>

<b>Trigger</b>	<b>Description</b>
Logics . <b>LE71.Timer Out</b>	<i>Signal: Timer Output</i>
Logics . <b>LE71.Out</b>	<i>Signal: Latched Output (Q)</i>
Logics . <b>LE71.Out inverted</b>	<i>Signal: Negated Latched Output (Q NOT)</i>
Logics . <b>LE72.Gate Out</b>	<i>Signal: Output of the logic gate</i>
Logics . <b>LE72.Timer Out</b>	<i>Signal: Timer Output</i>
Logics . <b>LE72.Out</b>	<i>Signal: Latched Output (Q)</i>
Logics . <b>LE72.Out inverted</b>	<i>Signal: Negated Latched Output (Q NOT)</i>
Logics . <b>LE73.Gate Out</b>	<i>Signal: Output of the logic gate</i>
Logics . <b>LE73.Timer Out</b>	<i>Signal: Timer Output</i>
Logics . <b>LE73.Out</b>	<i>Signal: Latched Output (Q)</i>
Logics . <b>LE73.Out inverted</b>	<i>Signal: Negated Latched Output (Q NOT)</i>
Logics . <b>LE74.Gate Out</b>	<i>Signal: Output of the logic gate</i>
Logics . <b>LE74.Timer Out</b>	<i>Signal: Timer Output</i>
Logics . <b>LE74.Out</b>	<i>Signal: Latched Output (Q)</i>
Logics . <b>LE74.Out inverted</b>	<i>Signal: Negated Latched Output (Q NOT)</i>
Logics . <b>LE75.Gate Out</b>	<i>Signal: Output of the logic gate</i>
Logics . <b>LE75.Timer Out</b>	<i>Signal: Timer Output</i>
Logics . <b>LE75.Out</b>	<i>Signal: Latched Output (Q)</i>
Logics . <b>LE75.Out inverted</b>	<i>Signal: Negated Latched Output (Q NOT)</i>
Logics . <b>LE76.Gate Out</b>	<i>Signal: Output of the logic gate</i>
Logics . <b>LE76.Timer Out</b>	<i>Signal: Timer Output</i>
Logics . <b>LE76.Out</b>	<i>Signal: Latched Output (Q)</i>
Logics . <b>LE76.Out inverted</b>	<i>Signal: Negated Latched Output (Q NOT)</i>
Logics . <b>LE77.Gate Out</b>	<i>Signal: Output of the logic gate</i>
Logics . <b>LE77.Timer Out</b>	<i>Signal: Timer Output</i>
Logics . <b>LE77.Out</b>	<i>Signal: Latched Output (Q)</i>
Logics . <b>LE77.Out inverted</b>	<i>Signal: Negated Latched Output (Q NOT)</i>
Logics . <b>LE78.Gate Out</b>	<i>Signal: Output of the logic gate</i>

Trigger	Description
Logics . <b>LE78.Timer Out</b>	Signal: Timer Output
Logics . <b>LE78.Out</b>	Signal: Latched Output (Q)
Logics . <b>LE78.Out inverted</b>	Signal: Negated Latched Output (Q NOT)
Logics . <b>LE79.Gate Out</b>	Signal: Output of the logic gate
Logics . <b>LE79.Timer Out</b>	Signal: Timer Output
Logics . <b>LE79.Out</b>	Signal: Latched Output (Q)
Logics . <b>LE79.Out inverted</b>	Signal: Negated Latched Output (Q NOT)
Logics . <b>LE80.Gate Out</b>	Signal: Output of the logic gate
Logics . <b>LE80.Timer Out</b>	Signal: Timer Output
Logics . <b>LE80.Out</b>	Signal: Latched Output (Q)
Logics . <b>LE80.Out inverted</b>	Signal: Negated Latched Output (Q NOT)

### **Mode**

general operation mode

Selection list referenced by the following parameters:

-  TCS . Mode

Mode	Description
<b>Closed</b>	Selects that the breaker is going to be monitored when the breaker is closed.
<b>Either</b>	Selects that the breaker is going to be monitored when the breaker is either closed or open.

### **PSet-Switch**

Switching Parameter Set

Selection list referenced by the following parameters:

-  Sys . PSet-Switch

<b>PSet-Switch</b>	<b>Description</b>
<b>PS1</b>	<i>The currently active Parameter Set is PS1</i>
<b>PS2</b>	<i>The currently active Parameter Set is PS2</i>
<b>PS3</b>	<i>The currently active Parameter Set is PS3</i>
<b>PS4</b>	<i>The currently active Parameter Set is PS4</i>
<b>PSS via Inp fct</b>	<i>Parameter Set Switch via input function</i>
<b>PSS via Scada</b>	<i>Parameter Set Switch via Scada. Write into this output byte the integer of the parameter set that should become active (e.g. 4 =&gt; Switch onto parameter set 4).</i>

### **1..n, PSS**

List of the available Parameter Setting Group Switching Signals

Selection list referenced by the following parameters:

-  Sys . PS1: activated by

<b>1..n, PSS</b>	<b>Description</b>
<b>"_"</b>	<i>No assignment</i>
<b>CTS . Alarm</b>	<i>Signal: Alarm Current Transformer Measuring Circuit Supervision</i>
<b>DI Slot X1 . DI 1</b>	<i>Signal: Digital Input</i>
<b>DI Slot X1 . DI 2</b>	<i>Signal: Digital Input</i>
<b>DI Slot X1 . DI 3</b>	<i>Signal: Digital Input</i>
<b>DI Slot X1 . DI 4</b>	<i>Signal: Digital Input</i>
<b>DI Slot X1 . DI 5</b>	<i>Signal: Digital Input</i>
<b>DI Slot X1 . DI 6</b>	<i>Signal: Digital Input</i>
<b>DI Slot X1 . DI 7</b>	<i>Signal: Digital Input</i>
<b>DI Slot X1 . DI 8</b>	<i>Signal: Digital Input</i>
<b>DI Slot X1 . DI 1</b>	<i>Signal: Digital Input</i>
<b>DI Slot X1 . DI 2</b>	<i>Signal: Digital Input</i>
<b>DI Slot X1 . DI 3</b>	<i>Signal: Digital Input</i>
<b>DI Slot X1 . DI 4</b>	<i>Signal: Digital Input</i>
<b>Logics . LE1.Gate Out</b>	<i>Signal: Output of the logic gate</i>
<b>Logics . LE1.Timer Out</b>	<i>Signal: Timer Output</i>

<b>1..n, PSS</b>	<b>Description</b>
Logics . <b>LE1.Out</b>	<i>Signal: Latched Output (Q)</i>
Logics . <b>LE1.Out inverted</b>	<i>Signal: Negated Latched Output (Q NOT)</i>
Logics . <b>LE2.Gate Out</b>	<i>Signal: Output of the logic gate</i>
Logics . <b>LE2.Timer Out</b>	<i>Signal: Timer Output</i>
Logics . <b>LE2.Out</b>	<i>Signal: Latched Output (Q)</i>
Logics . <b>LE2.Out inverted</b>	<i>Signal: Negated Latched Output (Q NOT)</i>
Logics . <b>LE3.Gate Out</b>	<i>Signal: Output of the logic gate</i>
Logics . <b>LE3.Timer Out</b>	<i>Signal: Timer Output</i>
Logics . <b>LE3.Out</b>	<i>Signal: Latched Output (Q)</i>
Logics . <b>LE3.Out inverted</b>	<i>Signal: Negated Latched Output (Q NOT)</i>
Logics . <b>LE4.Gate Out</b>	<i>Signal: Output of the logic gate</i>
Logics . <b>LE4.Timer Out</b>	<i>Signal: Timer Output</i>
Logics . <b>LE4.Out</b>	<i>Signal: Latched Output (Q)</i>
Logics . <b>LE4.Out inverted</b>	<i>Signal: Negated Latched Output (Q NOT)</i>
Logics . <b>LE5.Gate Out</b>	<i>Signal: Output of the logic gate</i>
Logics . <b>LE5.Timer Out</b>	<i>Signal: Timer Output</i>
Logics . <b>LE5.Out</b>	<i>Signal: Latched Output (Q)</i>
Logics . <b>LE5.Out inverted</b>	<i>Signal: Negated Latched Output (Q NOT)</i>
Logics . <b>LE6.Gate Out</b>	<i>Signal: Output of the logic gate</i>
Logics . <b>LE6.Timer Out</b>	<i>Signal: Timer Output</i>
Logics . <b>LE6.Out</b>	<i>Signal: Latched Output (Q)</i>
Logics . <b>LE6.Out inverted</b>	<i>Signal: Negated Latched Output (Q NOT)</i>
Logics . <b>LE7.Gate Out</b>	<i>Signal: Output of the logic gate</i>
Logics . <b>LE7.Timer Out</b>	<i>Signal: Timer Output</i>
Logics . <b>LE7.Out</b>	<i>Signal: Latched Output (Q)</i>
Logics . <b>LE7.Out inverted</b>	<i>Signal: Negated Latched Output (Q NOT)</i>
Logics . <b>LE8.Gate Out</b>	<i>Signal: Output of the logic gate</i>
Logics . <b>LE8.Timer Out</b>	<i>Signal: Timer Output</i>

<b>1..n, PSS</b>	<b>Description</b>
Logics . <b>LE8.Out</b>	<i>Signal: Latched Output (Q)</i>
Logics . <b>LE8.Out inverted</b>	<i>Signal: Negated Latched Output (Q NOT)</i>
Logics . <b>LE9.Gate Out</b>	<i>Signal: Output of the logic gate</i>
Logics . <b>LE9.Timer Out</b>	<i>Signal: Timer Output</i>
Logics . <b>LE9.Out</b>	<i>Signal: Latched Output (Q)</i>
Logics . <b>LE9.Out inverted</b>	<i>Signal: Negated Latched Output (Q NOT)</i>
Logics . <b>LE10.Gate Out</b>	<i>Signal: Output of the logic gate</i>
Logics . <b>LE10.Timer Out</b>	<i>Signal: Timer Output</i>
Logics . <b>LE10.Out</b>	<i>Signal: Latched Output (Q)</i>
Logics . <b>LE10.Out inverted</b>	<i>Signal: Negated Latched Output (Q NOT)</i>
Logics . <b>LE11.Gate Out</b>	<i>Signal: Output of the logic gate</i>
Logics . <b>LE11.Timer Out</b>	<i>Signal: Timer Output</i>
Logics . <b>LE11.Out</b>	<i>Signal: Latched Output (Q)</i>
Logics . <b>LE11.Out inverted</b>	<i>Signal: Negated Latched Output (Q NOT)</i>
Logics . <b>LE12.Gate Out</b>	<i>Signal: Output of the logic gate</i>
Logics . <b>LE12.Timer Out</b>	<i>Signal: Timer Output</i>
Logics . <b>LE12.Out</b>	<i>Signal: Latched Output (Q)</i>
Logics . <b>LE12.Out inverted</b>	<i>Signal: Negated Latched Output (Q NOT)</i>
Logics . <b>LE13.Gate Out</b>	<i>Signal: Output of the logic gate</i>
Logics . <b>LE13.Timer Out</b>	<i>Signal: Timer Output</i>
Logics . <b>LE13.Out</b>	<i>Signal: Latched Output (Q)</i>
Logics . <b>LE13.Out inverted</b>	<i>Signal: Negated Latched Output (Q NOT)</i>
Logics . <b>LE14.Gate Out</b>	<i>Signal: Output of the logic gate</i>
Logics . <b>LE14.Timer Out</b>	<i>Signal: Timer Output</i>
Logics . <b>LE14.Out</b>	<i>Signal: Latched Output (Q)</i>
Logics . <b>LE14.Out inverted</b>	<i>Signal: Negated Latched Output (Q NOT)</i>
Logics . <b>LE15.Gate Out</b>	<i>Signal: Output of the logic gate</i>
Logics . <b>LE15.Timer Out</b>	<i>Signal: Timer Output</i>



<b>1..n, PSS</b>	<b>Description</b>
Logics . <b>LE15.Out</b>	<i>Signal: Latched Output (Q)</i>
Logics . <b>LE15.Out inverted</b>	<i>Signal: Negated Latched Output (Q NOT)</i>
Logics . <b>LE16.Gate Out</b>	<i>Signal: Output of the logic gate</i>
Logics . <b>LE16.Timer Out</b>	<i>Signal: Timer Output</i>
Logics . <b>LE16.Out</b>	<i>Signal: Latched Output (Q)</i>
Logics . <b>LE16.Out inverted</b>	<i>Signal: Negated Latched Output (Q NOT)</i>
Logics . <b>LE17.Gate Out</b>	<i>Signal: Output of the logic gate</i>
Logics . <b>LE17.Timer Out</b>	<i>Signal: Timer Output</i>
Logics . <b>LE17.Out</b>	<i>Signal: Latched Output (Q)</i>
Logics . <b>LE17.Out inverted</b>	<i>Signal: Negated Latched Output (Q NOT)</i>
Logics . <b>LE18.Gate Out</b>	<i>Signal: Output of the logic gate</i>
Logics . <b>LE18.Timer Out</b>	<i>Signal: Timer Output</i>
Logics . <b>LE18.Out</b>	<i>Signal: Latched Output (Q)</i>
Logics . <b>LE18.Out inverted</b>	<i>Signal: Negated Latched Output (Q NOT)</i>
Logics . <b>LE19.Gate Out</b>	<i>Signal: Output of the logic gate</i>
Logics . <b>LE19.Timer Out</b>	<i>Signal: Timer Output</i>
Logics . <b>LE19.Out</b>	<i>Signal: Latched Output (Q)</i>
Logics . <b>LE19.Out inverted</b>	<i>Signal: Negated Latched Output (Q NOT)</i>
Logics . <b>LE20.Gate Out</b>	<i>Signal: Output of the logic gate</i>
Logics . <b>LE20.Timer Out</b>	<i>Signal: Timer Output</i>
Logics . <b>LE20.Out</b>	<i>Signal: Latched Output (Q)</i>
Logics . <b>LE20.Out inverted</b>	<i>Signal: Negated Latched Output (Q NOT)</i>
Logics . <b>LE21.Gate Out</b>	<i>Signal: Output of the logic gate</i>
Logics . <b>LE21.Timer Out</b>	<i>Signal: Timer Output</i>
Logics . <b>LE21.Out</b>	<i>Signal: Latched Output (Q)</i>
Logics . <b>LE21.Out inverted</b>	<i>Signal: Negated Latched Output (Q NOT)</i>
Logics . <b>LE22.Gate Out</b>	<i>Signal: Output of the logic gate</i>
Logics . <b>LE22.Timer Out</b>	<i>Signal: Timer Output</i>

<b>1..n, PSS</b>	<b>Description</b>
Logics . <b>LE22.Out</b>	<i>Signal: Latched Output (Q)</i>
Logics . <b>LE22.Out inverted</b>	<i>Signal: Negated Latched Output (Q NOT)</i>
Logics . <b>LE23.Gate Out</b>	<i>Signal: Output of the logic gate</i>
Logics . <b>LE23.Timer Out</b>	<i>Signal: Timer Output</i>
Logics . <b>LE23.Out</b>	<i>Signal: Latched Output (Q)</i>
Logics . <b>LE23.Out inverted</b>	<i>Signal: Negated Latched Output (Q NOT)</i>
Logics . <b>LE24.Gate Out</b>	<i>Signal: Output of the logic gate</i>
Logics . <b>LE24.Timer Out</b>	<i>Signal: Timer Output</i>
Logics . <b>LE24.Out</b>	<i>Signal: Latched Output (Q)</i>
Logics . <b>LE24.Out inverted</b>	<i>Signal: Negated Latched Output (Q NOT)</i>
Logics . <b>LE25.Gate Out</b>	<i>Signal: Output of the logic gate</i>
Logics . <b>LE25.Timer Out</b>	<i>Signal: Timer Output</i>
Logics . <b>LE25.Out</b>	<i>Signal: Latched Output (Q)</i>
Logics . <b>LE25.Out inverted</b>	<i>Signal: Negated Latched Output (Q NOT)</i>
Logics . <b>LE26.Gate Out</b>	<i>Signal: Output of the logic gate</i>
Logics . <b>LE26.Timer Out</b>	<i>Signal: Timer Output</i>
Logics . <b>LE26.Out</b>	<i>Signal: Latched Output (Q)</i>
Logics . <b>LE26.Out inverted</b>	<i>Signal: Negated Latched Output (Q NOT)</i>
Logics . <b>LE27.Gate Out</b>	<i>Signal: Output of the logic gate</i>
Logics . <b>LE27.Timer Out</b>	<i>Signal: Timer Output</i>
Logics . <b>LE27.Out</b>	<i>Signal: Latched Output (Q)</i>
Logics . <b>LE27.Out inverted</b>	<i>Signal: Negated Latched Output (Q NOT)</i>
Logics . <b>LE28.Gate Out</b>	<i>Signal: Output of the logic gate</i>
Logics . <b>LE28.Timer Out</b>	<i>Signal: Timer Output</i>
Logics . <b>LE28.Out</b>	<i>Signal: Latched Output (Q)</i>
Logics . <b>LE28.Out inverted</b>	<i>Signal: Negated Latched Output (Q NOT)</i>
Logics . <b>LE29.Gate Out</b>	<i>Signal: Output of the logic gate</i>
Logics . <b>LE29.Timer Out</b>	<i>Signal: Timer Output</i>

<b>1..n, PSS</b>	<b>Description</b>
Logics . <b>LE29.Out</b>	<i>Signal: Latched Output (Q)</i>
Logics . <b>LE29.Out inverted</b>	<i>Signal: Negated Latched Output (Q NOT)</i>
Logics . <b>LE30.Gate Out</b>	<i>Signal: Output of the logic gate</i>
Logics . <b>LE30.Timer Out</b>	<i>Signal: Timer Output</i>
Logics . <b>LE30.Out</b>	<i>Signal: Latched Output (Q)</i>
Logics . <b>LE30.Out inverted</b>	<i>Signal: Negated Latched Output (Q NOT)</i>
Logics . <b>LE31.Gate Out</b>	<i>Signal: Output of the logic gate</i>
Logics . <b>LE31.Timer Out</b>	<i>Signal: Timer Output</i>
Logics . <b>LE31.Out</b>	<i>Signal: Latched Output (Q)</i>
Logics . <b>LE31.Out inverted</b>	<i>Signal: Negated Latched Output (Q NOT)</i>
Logics . <b>LE32.Gate Out</b>	<i>Signal: Output of the logic gate</i>
Logics . <b>LE32.Timer Out</b>	<i>Signal: Timer Output</i>
Logics . <b>LE32.Out</b>	<i>Signal: Latched Output (Q)</i>
Logics . <b>LE32.Out inverted</b>	<i>Signal: Negated Latched Output (Q NOT)</i>
Logics . <b>LE33.Gate Out</b>	<i>Signal: Output of the logic gate</i>
Logics . <b>LE33.Timer Out</b>	<i>Signal: Timer Output</i>
Logics . <b>LE33.Out</b>	<i>Signal: Latched Output (Q)</i>
Logics . <b>LE33.Out inverted</b>	<i>Signal: Negated Latched Output (Q NOT)</i>
Logics . <b>LE34.Gate Out</b>	<i>Signal: Output of the logic gate</i>
Logics . <b>LE34.Timer Out</b>	<i>Signal: Timer Output</i>
Logics . <b>LE34.Out</b>	<i>Signal: Latched Output (Q)</i>
Logics . <b>LE34.Out inverted</b>	<i>Signal: Negated Latched Output (Q NOT)</i>
Logics . <b>LE35.Gate Out</b>	<i>Signal: Output of the logic gate</i>
Logics . <b>LE35.Timer Out</b>	<i>Signal: Timer Output</i>
Logics . <b>LE35.Out</b>	<i>Signal: Latched Output (Q)</i>
Logics . <b>LE35.Out inverted</b>	<i>Signal: Negated Latched Output (Q NOT)</i>
Logics . <b>LE36.Gate Out</b>	<i>Signal: Output of the logic gate</i>
Logics . <b>LE36.Timer Out</b>	<i>Signal: Timer Output</i>

<b>1..n, PSS</b>	<b>Description</b>
Logics . <b>LE36.Out</b>	<i>Signal: Latched Output (Q)</i>
Logics . <b>LE36.Out inverted</b>	<i>Signal: Negated Latched Output (Q NOT)</i>
Logics . <b>LE37.Gate Out</b>	<i>Signal: Output of the logic gate</i>
Logics . <b>LE37.Timer Out</b>	<i>Signal: Timer Output</i>
Logics . <b>LE37.Out</b>	<i>Signal: Latched Output (Q)</i>
Logics . <b>LE37.Out inverted</b>	<i>Signal: Negated Latched Output (Q NOT)</i>
Logics . <b>LE38.Gate Out</b>	<i>Signal: Output of the logic gate</i>
Logics . <b>LE38.Timer Out</b>	<i>Signal: Timer Output</i>
Logics . <b>LE38.Out</b>	<i>Signal: Latched Output (Q)</i>
Logics . <b>LE38.Out inverted</b>	<i>Signal: Negated Latched Output (Q NOT)</i>
Logics . <b>LE39.Gate Out</b>	<i>Signal: Output of the logic gate</i>
Logics . <b>LE39.Timer Out</b>	<i>Signal: Timer Output</i>
Logics . <b>LE39.Out</b>	<i>Signal: Latched Output (Q)</i>
Logics . <b>LE39.Out inverted</b>	<i>Signal: Negated Latched Output (Q NOT)</i>
Logics . <b>LE40.Gate Out</b>	<i>Signal: Output of the logic gate</i>
Logics . <b>LE40.Timer Out</b>	<i>Signal: Timer Output</i>
Logics . <b>LE40.Out</b>	<i>Signal: Latched Output (Q)</i>
Logics . <b>LE40.Out inverted</b>	<i>Signal: Negated Latched Output (Q NOT)</i>
Logics . <b>LE41.Gate Out</b>	<i>Signal: Output of the logic gate</i>
Logics . <b>LE41.Timer Out</b>	<i>Signal: Timer Output</i>
Logics . <b>LE41.Out</b>	<i>Signal: Latched Output (Q)</i>
Logics . <b>LE41.Out inverted</b>	<i>Signal: Negated Latched Output (Q NOT)</i>
Logics . <b>LE42.Gate Out</b>	<i>Signal: Output of the logic gate</i>
Logics . <b>LE42.Timer Out</b>	<i>Signal: Timer Output</i>
Logics . <b>LE42.Out</b>	<i>Signal: Latched Output (Q)</i>
Logics . <b>LE42.Out inverted</b>	<i>Signal: Negated Latched Output (Q NOT)</i>
Logics . <b>LE43.Gate Out</b>	<i>Signal: Output of the logic gate</i>
Logics . <b>LE43.Timer Out</b>	<i>Signal: Timer Output</i>

<b>1..n, PSS</b>	<b>Description</b>
Logics . <b>LE43.Out</b>	<i>Signal: Latched Output (Q)</i>
Logics . <b>LE43.Out inverted</b>	<i>Signal: Negated Latched Output (Q NOT)</i>
Logics . <b>LE44.Gate Out</b>	<i>Signal: Output of the logic gate</i>
Logics . <b>LE44.Timer Out</b>	<i>Signal: Timer Output</i>
Logics . <b>LE44.Out</b>	<i>Signal: Latched Output (Q)</i>
Logics . <b>LE44.Out inverted</b>	<i>Signal: Negated Latched Output (Q NOT)</i>
Logics . <b>LE45.Gate Out</b>	<i>Signal: Output of the logic gate</i>
Logics . <b>LE45.Timer Out</b>	<i>Signal: Timer Output</i>
Logics . <b>LE45.Out</b>	<i>Signal: Latched Output (Q)</i>
Logics . <b>LE45.Out inverted</b>	<i>Signal: Negated Latched Output (Q NOT)</i>
Logics . <b>LE46.Gate Out</b>	<i>Signal: Output of the logic gate</i>
Logics . <b>LE46.Timer Out</b>	<i>Signal: Timer Output</i>
Logics . <b>LE46.Out</b>	<i>Signal: Latched Output (Q)</i>
Logics . <b>LE46.Out inverted</b>	<i>Signal: Negated Latched Output (Q NOT)</i>
Logics . <b>LE47.Gate Out</b>	<i>Signal: Output of the logic gate</i>
Logics . <b>LE47.Timer Out</b>	<i>Signal: Timer Output</i>
Logics . <b>LE47.Out</b>	<i>Signal: Latched Output (Q)</i>
Logics . <b>LE47.Out inverted</b>	<i>Signal: Negated Latched Output (Q NOT)</i>
Logics . <b>LE48.Gate Out</b>	<i>Signal: Output of the logic gate</i>
Logics . <b>LE48.Timer Out</b>	<i>Signal: Timer Output</i>
Logics . <b>LE48.Out</b>	<i>Signal: Latched Output (Q)</i>
Logics . <b>LE48.Out inverted</b>	<i>Signal: Negated Latched Output (Q NOT)</i>
Logics . <b>LE49.Gate Out</b>	<i>Signal: Output of the logic gate</i>
Logics . <b>LE49.Timer Out</b>	<i>Signal: Timer Output</i>
Logics . <b>LE49.Out</b>	<i>Signal: Latched Output (Q)</i>
Logics . <b>LE49.Out inverted</b>	<i>Signal: Negated Latched Output (Q NOT)</i>
Logics . <b>LE50.Gate Out</b>	<i>Signal: Output of the logic gate</i>
Logics . <b>LE50.Timer Out</b>	<i>Signal: Timer Output</i>

<b>1..n, PSS</b>	<b>Description</b>
Logics . <b>LE50.Out</b>	<i>Signal: Latched Output (Q)</i>
Logics . <b>LE50.Out inverted</b>	<i>Signal: Negated Latched Output (Q NOT)</i>
Logics . <b>LE51.Gate Out</b>	<i>Signal: Output of the logic gate</i>
Logics . <b>LE51.Timer Out</b>	<i>Signal: Timer Output</i>
Logics . <b>LE51.Out</b>	<i>Signal: Latched Output (Q)</i>
Logics . <b>LE51.Out inverted</b>	<i>Signal: Negated Latched Output (Q NOT)</i>
Logics . <b>LE52.Gate Out</b>	<i>Signal: Output of the logic gate</i>
Logics . <b>LE52.Timer Out</b>	<i>Signal: Timer Output</i>
Logics . <b>LE52.Out</b>	<i>Signal: Latched Output (Q)</i>
Logics . <b>LE52.Out inverted</b>	<i>Signal: Negated Latched Output (Q NOT)</i>
Logics . <b>LE53.Gate Out</b>	<i>Signal: Output of the logic gate</i>
Logics . <b>LE53.Timer Out</b>	<i>Signal: Timer Output</i>
Logics . <b>LE53.Out</b>	<i>Signal: Latched Output (Q)</i>
Logics . <b>LE53.Out inverted</b>	<i>Signal: Negated Latched Output (Q NOT)</i>
Logics . <b>LE54.Gate Out</b>	<i>Signal: Output of the logic gate</i>
Logics . <b>LE54.Timer Out</b>	<i>Signal: Timer Output</i>
Logics . <b>LE54.Out</b>	<i>Signal: Latched Output (Q)</i>
Logics . <b>LE54.Out inverted</b>	<i>Signal: Negated Latched Output (Q NOT)</i>
Logics . <b>LE55.Gate Out</b>	<i>Signal: Output of the logic gate</i>
Logics . <b>LE55.Timer Out</b>	<i>Signal: Timer Output</i>
Logics . <b>LE55.Out</b>	<i>Signal: Latched Output (Q)</i>
Logics . <b>LE55.Out inverted</b>	<i>Signal: Negated Latched Output (Q NOT)</i>
Logics . <b>LE56.Gate Out</b>	<i>Signal: Output of the logic gate</i>
Logics . <b>LE56.Timer Out</b>	<i>Signal: Timer Output</i>
Logics . <b>LE56.Out</b>	<i>Signal: Latched Output (Q)</i>
Logics . <b>LE56.Out inverted</b>	<i>Signal: Negated Latched Output (Q NOT)</i>
Logics . <b>LE57.Gate Out</b>	<i>Signal: Output of the logic gate</i>
Logics . <b>LE57.Timer Out</b>	<i>Signal: Timer Output</i>

<b>1..n, PSS</b>	<b>Description</b>
Logics . <b>LE57.Out</b>	<i>Signal: Latched Output (Q)</i>
Logics . <b>LE57.Out inverted</b>	<i>Signal: Negated Latched Output (Q NOT)</i>
Logics . <b>LE58.Gate Out</b>	<i>Signal: Output of the logic gate</i>
Logics . <b>LE58.Timer Out</b>	<i>Signal: Timer Output</i>
Logics . <b>LE58.Out</b>	<i>Signal: Latched Output (Q)</i>
Logics . <b>LE58.Out inverted</b>	<i>Signal: Negated Latched Output (Q NOT)</i>
Logics . <b>LE59.Gate Out</b>	<i>Signal: Output of the logic gate</i>
Logics . <b>LE59.Timer Out</b>	<i>Signal: Timer Output</i>
Logics . <b>LE59.Out</b>	<i>Signal: Latched Output (Q)</i>
Logics . <b>LE59.Out inverted</b>	<i>Signal: Negated Latched Output (Q NOT)</i>
Logics . <b>LE60.Gate Out</b>	<i>Signal: Output of the logic gate</i>
Logics . <b>LE60.Timer Out</b>	<i>Signal: Timer Output</i>
Logics . <b>LE60.Out</b>	<i>Signal: Latched Output (Q)</i>
Logics . <b>LE60.Out inverted</b>	<i>Signal: Negated Latched Output (Q NOT)</i>
Logics . <b>LE61.Gate Out</b>	<i>Signal: Output of the logic gate</i>
Logics . <b>LE61.Timer Out</b>	<i>Signal: Timer Output</i>
Logics . <b>LE61.Out</b>	<i>Signal: Latched Output (Q)</i>
Logics . <b>LE61.Out inverted</b>	<i>Signal: Negated Latched Output (Q NOT)</i>
Logics . <b>LE62.Gate Out</b>	<i>Signal: Output of the logic gate</i>
Logics . <b>LE62.Timer Out</b>	<i>Signal: Timer Output</i>
Logics . <b>LE62.Out</b>	<i>Signal: Latched Output (Q)</i>
Logics . <b>LE62.Out inverted</b>	<i>Signal: Negated Latched Output (Q NOT)</i>
Logics . <b>LE63.Gate Out</b>	<i>Signal: Output of the logic gate</i>
Logics . <b>LE63.Timer Out</b>	<i>Signal: Timer Output</i>
Logics . <b>LE63.Out</b>	<i>Signal: Latched Output (Q)</i>
Logics . <b>LE63.Out inverted</b>	<i>Signal: Negated Latched Output (Q NOT)</i>
Logics . <b>LE64.Gate Out</b>	<i>Signal: Output of the logic gate</i>
Logics . <b>LE64.Timer Out</b>	<i>Signal: Timer Output</i>

<b>1..n, PSS</b>	<b>Description</b>
Logics . <b>LE64.Out</b>	<i>Signal: Latched Output (Q)</i>
Logics . <b>LE64.Out inverted</b>	<i>Signal: Negated Latched Output (Q NOT)</i>
Logics . <b>LE65.Gate Out</b>	<i>Signal: Output of the logic gate</i>
Logics . <b>LE65.Timer Out</b>	<i>Signal: Timer Output</i>
Logics . <b>LE65.Out</b>	<i>Signal: Latched Output (Q)</i>
Logics . <b>LE65.Out inverted</b>	<i>Signal: Negated Latched Output (Q NOT)</i>
Logics . <b>LE66.Gate Out</b>	<i>Signal: Output of the logic gate</i>
Logics . <b>LE66.Timer Out</b>	<i>Signal: Timer Output</i>
Logics . <b>LE66.Out</b>	<i>Signal: Latched Output (Q)</i>
Logics . <b>LE66.Out inverted</b>	<i>Signal: Negated Latched Output (Q NOT)</i>
Logics . <b>LE67.Gate Out</b>	<i>Signal: Output of the logic gate</i>
Logics . <b>LE67.Timer Out</b>	<i>Signal: Timer Output</i>
Logics . <b>LE67.Out</b>	<i>Signal: Latched Output (Q)</i>
Logics . <b>LE67.Out inverted</b>	<i>Signal: Negated Latched Output (Q NOT)</i>
Logics . <b>LE68.Gate Out</b>	<i>Signal: Output of the logic gate</i>
Logics . <b>LE68.Timer Out</b>	<i>Signal: Timer Output</i>
Logics . <b>LE68.Out</b>	<i>Signal: Latched Output (Q)</i>
Logics . <b>LE68.Out inverted</b>	<i>Signal: Negated Latched Output (Q NOT)</i>
Logics . <b>LE69.Gate Out</b>	<i>Signal: Output of the logic gate</i>
Logics . <b>LE69.Timer Out</b>	<i>Signal: Timer Output</i>
Logics . <b>LE69.Out</b>	<i>Signal: Latched Output (Q)</i>
Logics . <b>LE69.Out inverted</b>	<i>Signal: Negated Latched Output (Q NOT)</i>
Logics . <b>LE70.Gate Out</b>	<i>Signal: Output of the logic gate</i>
Logics . <b>LE70.Timer Out</b>	<i>Signal: Timer Output</i>
Logics . <b>LE70.Out</b>	<i>Signal: Latched Output (Q)</i>
Logics . <b>LE70.Out inverted</b>	<i>Signal: Negated Latched Output (Q NOT)</i>
Logics . <b>LE71.Gate Out</b>	<i>Signal: Output of the logic gate</i>
Logics . <b>LE71.Timer Out</b>	<i>Signal: Timer Output</i>



<b>1..n, PSS</b>	<b>Description</b>
Logics . <b>LE71.Out</b>	<i>Signal: Latched Output (Q)</i>
Logics . <b>LE71.Out inverted</b>	<i>Signal: Negated Latched Output (Q NOT)</i>
Logics . <b>LE72.Gate Out</b>	<i>Signal: Output of the logic gate</i>
Logics . <b>LE72.Timer Out</b>	<i>Signal: Timer Output</i>
Logics . <b>LE72.Out</b>	<i>Signal: Latched Output (Q)</i>
Logics . <b>LE72.Out inverted</b>	<i>Signal: Negated Latched Output (Q NOT)</i>
Logics . <b>LE73.Gate Out</b>	<i>Signal: Output of the logic gate</i>
Logics . <b>LE73.Timer Out</b>	<i>Signal: Timer Output</i>
Logics . <b>LE73.Out</b>	<i>Signal: Latched Output (Q)</i>
Logics . <b>LE73.Out inverted</b>	<i>Signal: Negated Latched Output (Q NOT)</i>
Logics . <b>LE74.Gate Out</b>	<i>Signal: Output of the logic gate</i>
Logics . <b>LE74.Timer Out</b>	<i>Signal: Timer Output</i>
Logics . <b>LE74.Out</b>	<i>Signal: Latched Output (Q)</i>
Logics . <b>LE74.Out inverted</b>	<i>Signal: Negated Latched Output (Q NOT)</i>
Logics . <b>LE75.Gate Out</b>	<i>Signal: Output of the logic gate</i>
Logics . <b>LE75.Timer Out</b>	<i>Signal: Timer Output</i>
Logics . <b>LE75.Out</b>	<i>Signal: Latched Output (Q)</i>
Logics . <b>LE75.Out inverted</b>	<i>Signal: Negated Latched Output (Q NOT)</i>
Logics . <b>LE76.Gate Out</b>	<i>Signal: Output of the logic gate</i>
Logics . <b>LE76.Timer Out</b>	<i>Signal: Timer Output</i>
Logics . <b>LE76.Out</b>	<i>Signal: Latched Output (Q)</i>
Logics . <b>LE76.Out inverted</b>	<i>Signal: Negated Latched Output (Q NOT)</i>
Logics . <b>LE77.Gate Out</b>	<i>Signal: Output of the logic gate</i>
Logics . <b>LE77.Timer Out</b>	<i>Signal: Timer Output</i>
Logics . <b>LE77.Out</b>	<i>Signal: Latched Output (Q)</i>
Logics . <b>LE77.Out inverted</b>	<i>Signal: Negated Latched Output (Q NOT)</i>
Logics . <b>LE78.Gate Out</b>	<i>Signal: Output of the logic gate</i>
Logics . <b>LE78.Timer Out</b>	<i>Signal: Timer Output</i>

<b>1..n, PSS</b>	<b>Description</b>
Logics . <b>LE78.Out</b>	<i>Signal: Latched Output (Q)</i>
Logics . <b>LE78.Out inverted</b>	<i>Signal: Negated Latched Output (Q NOT)</i>
Logics . <b>LE79.Gate Out</b>	<i>Signal: Output of the logic gate</i>
Logics . <b>LE79.Timer Out</b>	<i>Signal: Timer Output</i>
Logics . <b>LE79.Out</b>	<i>Signal: Latched Output (Q)</i>
Logics . <b>LE79.Out inverted</b>	<i>Signal: Negated Latched Output (Q NOT)</i>
Logics . <b>LE80.Gate Out</b>	<i>Signal: Output of the logic gate</i>
Logics . <b>LE80.Timer Out</b>	<i>Signal: Timer Output</i>
Logics . <b>LE80.Out</b>	<i>Signal: Latched Output (Q)</i>
Logics . <b>LE80.Out inverted</b>	<i>Signal: Negated Latched Output (Q NOT)</i>

### **Measuring method**

Measuring method: fundamental or rms or 3rd harmonic (only generator protection relays)

Selection list referenced by the following parameters:

-  I[1] . Measuring method

<b>Measuring method</b>	<b>Description</b>
<b>Fundamental</b>	<i>Protection is based on Fundamental (1st. Harmonic)</i>
<b>True RMS</b>	<i>Protection is based on root-mean-square value (True RMS)</i>
<b>I2</b>	<i>Protection is based on negative phase sequence current</i>

### **Char**

Characteristic

Selection list referenced by the following parameters:

-  I[1] . Char

Char	Description
<b>DEFT</b>	<i>DEFT</i>
<b>IEC NINV</b>	<i>IEC Normal Inverse</i>
<b>IEC VINV</b>	<i>IEC Very Inverse [VINV]</i>
<b>IEC EINV</b>	<i>IEC Extremely Inverse - Characteristic</i>
<b>IEC LINV</b>	<i>IEC Long Time Inverse - Characteristic [LINV]</i>
<b>RINV</b>	<i>R Inverse [RINV] - Characteristic</i>
<b>ANSI MINV</b>	<i>ANSI Moderately Inverse [MINV] - Characteristic</i>
<b>ANSI VINV</b>	<i>ANSI Very Inverse [VINV]</i>
<b>ANSI EINV</b>	<i>ANSI Extremely Inverse - Characteristic</i>
<b>Therm Flat</b>	<i>Therm Flat [TF] - Characteristic</i>
<b>IT</b>	<i>IT - Characteristic</i>
<b>I2T</b>	<i>I2T - Characteristic</i>
<b>I4T</b>	<i>I4T - Characteristic</i>

### **Reset Mode**

Selection list referenced by the following parameters:

-  I[1] . Reset Mode

Reset Mode	Description
<b>instantaneous</b>	<i>Instantaneous reset: when the current drops below the pickup setting, the TOC time resets to zero within 2 cycles.</i>
<b>delayed</b>	<i>Reset after a fixed time.  (Remark: This delay is then defined by the parameter »t-reset delay«.)</i>
<b>calculated</b>	<i>Calculated reset, which is defined by ANSI C37.112 and IEC.</i>

### **Measuring Channel**

Selection list referenced by the following parameters:

-  IG[1] . IG Source

Measuring Channel	Description
CT . <b>sensitive measurement</b>	<i>sensitive measurement</i>
CT . <b>measured</b>	<i>measured</i>
CT . <b>calculated</b>	<i>calculated</i>

**Measuring method**

Measuring method: fundamental or rms or 3rd harmonic (only generator protection relays)

Selection list referenced by the following parameters:

-  IG[1] . Measuring method

Measuring method	Description
<b>Fundamental</b>	<i>Protection is based on Fundamental (1st. Harmonic)</i>
<b>True RMS</b>	<i>Protection is based on root-mean-square value (True RMS)</i>

**VTS Block**

Blocking of the module if the voltage transformer supervision detects a fault.

Selection list referenced by the following parameters:

-  IG[1] . Meas Circuit Superv

VTS Block	Description
Sys . <b>inactive</b>	<i>inactive</i>

**Char**

Characteristic

Selection list referenced by the following parameters:

-  IG[1] . Char

Char	Description
<b>DEFT</b>	<i>DEFT</i>
<b>IEC NINV</b>	<i>IEC Normal Inverse</i>
<b>IEC VINV</b>	<i>IEC Very Inverse [VINV]</i>
<b>IEC EINV</b>	<i>IEC Extremely Inverse - Characteristic</i>
<b>IEC LINV</b>	<i>IEC Long Time Inverse - Characteristic [LINV]</i>
<b>RINV</b>	<i>R Inverse [RINV] - Characteristic</i>
<b>ANSI MINV</b>	<i>ANSI Moderately Inverse [MINV] - Characteristic</i>
<b>ANSI VINV</b>	<i>ANSI Very Inverse [VINV]</i>
<b>ANSI EINV</b>	<i>ANSI Extremely Inverse - Characteristic</i>
<b>Therm Flat</b>	<i>Therm Flat [TF] - Characteristic</i>
<b>IT</b>	<i>IT - Characteristic</i>
<b>I2T</b>	<i>I2T - Characteristic</i>
<b>I4T</b>	<i>I4T - Characteristic</i>
<b>RXIDG</b>	<i>Special Overcurrent Curve</i>

### **Reset Mode**

Selection list referenced by the following parameters:


-  IG[1] . Reset Mode

Reset Mode	Description
<b>instantaneous</b>	<i>Instantaneous reset: when the current drops below the pickup setting, the TOC time resets to zero within 2 cycles.</i>
<b>delayed</b>	<i>Reset after a fixed time.  (Remark: This delay is then defined by the parameter »t-reset delay«.)</i>
<b>calculated</b>	<i>Calculated reset, which is defined by ANSI C37.112 and IEC.</i>

### **Char**

Characteristic

Selection list referenced by the following parameters:

-  I2>[1] . Char

Char	Description
DEFT	DEFT
INV	INV

**Alarm Mode**

Indicates if one, two of three or all phases are required for operation

Selection list referenced by the following parameters:

-  I<[1] . Alarm Mode

Alarm Mode	Description
any one	any one: Trip Command, if the tripping criterion is fulfilled within at least one phase.
all	all: Trip Command for 3p-faults, i.e. if the tripping criterion is fulfilled in all three phases.

**VTS Block**

Blocking of the module if the voltage transformer supervision detects a fault.

Selection list referenced by the following parameters:

-  I<[1] . MeasCircSv Curr

VTS Block	Description
Sys . inactive	inactive
CTS . active	active

**NonIL ResetMode**

Non-Interlocking ResetMode

Selection list referenced by the following parameters:

-  Ctrl . Res NonIL

NonIL ResetMode	Description
<b>single Operation</b>	<i>single Operation</i>
<b>timeout</b>	<i>timeout</i>
<b>permanent</b>	<i>permanent</i>

### **Manipulate Position**

WARNING! Fake Position - Manual Position Manipulation

Selection list referenced by the following parameters:







-  SG[1] . Manipulate Position

Manipulate Position	Description
<b>inactive</b>	<i>inactive</i>
<b>Pos OFF</b>	<i>Signal: Circuit Breaker is in OFF-Position</i>
<b>Pos ON</b>	<i>Signal: Circuit Breaker is in ON-Position</i>

### **1..n, Trip Cmds**

List of available Trip Commands

Selection list referenced by the following parameters:




-  SG[1] . Off Cmd1
-  SG[1] . Off Cmd2
-  SG[1] . Off Cmd3
-  SG[1] . Off Cmd4
-  SG[1] . Off Cmd5
-  SG[1] . Off Cmd6
- *[...]*

1..n, Trip Cmds	Description
<b>"_"</b>	<i>No assignment</i>
<b>MStart . TripCmd</b>	<i>Signal: Trip Command</i>
<b>I[1] . TripCmd</b>	<i>Signal: Trip Command</i>

<b>1..n, Trip Cmds</b>	<b>Description</b>
I[2] . <b>TripCmd</b>	<i>Signal: Trip Command</i>
I[3] . <b>TripCmd</b>	<i>Signal: Trip Command</i>
I[4] . <b>TripCmd</b>	<i>Signal: Trip Command</i>
I[5] . <b>TripCmd</b>	<i>Signal: Trip Command</i>
I[6] . <b>TripCmd</b>	<i>Signal: Trip Command</i>
IG[1] . <b>TripCmd</b>	<i>Signal: Trip Command</i>
IG[2] . <b>TripCmd</b>	<i>Signal: Trip Command</i>
IG[3] . <b>TripCmd</b>	<i>Signal: Trip Command</i>
IG[4] . <b>TripCmd</b>	<i>Signal: Trip Command</i>
ThR . <b>TripCmd</b>	<i>Signal: Trip Command</i>
Jam[1] . <b>TripCmd</b>	<i>Signal: Trip Command</i>
Jam[2] . <b>TripCmd</b>	<i>Signal: Trip Command</i>
I<[1] . <b>TripCmd</b>	<i>Signal: Trip Command</i>
I<[2] . <b>TripCmd</b>	<i>Signal: Trip Command</i>
I<[3] . <b>TripCmd</b>	<i>Signal: Trip Command</i>
I2>[1] . <b>TripCmd</b>	<i>Signal: Trip Command</i>
I2>[2] . <b>TripCmd</b>	<i>Signal: Trip Command</i>
ExP[1] . <b>TripCmd</b>	<i>Signal: Trip Command</i>
ExP[2] . <b>TripCmd</b>	<i>Signal: Trip Command</i>
ExP[3] . <b>TripCmd</b>	<i>Signal: Trip Command</i>
ExP[4] . <b>TripCmd</b>	<i>Signal: Trip Command</i>
RTD . <b>TripCmd</b>	<i>Signal: Trip Command</i>

### **1..n, DI-LogicList**

Selection list referenced by the following parameters:

-  SG[1] . Aux ON
-  SG[1] . Aux OFF
-  SG[1] . Ready
-  SG[1] . Removed
-  SG[1] . SCmd ON



-  SG[1] . SCmd OFF

<b>1..n, DI-LogicList</b>	<b>Description</b>
<b>"_"</b>	<i>No assignment</i>
DI Slot X1 . <b>DI 1</b>	<i>Signal: Digital Input</i>
DI Slot X1 . <b>DI 2</b>	<i>Signal: Digital Input</i>
DI Slot X1 . <b>DI 3</b>	<i>Signal: Digital Input</i>
DI Slot X1 . <b>DI 4</b>	<i>Signal: Digital Input</i>
DI Slot X1 . <b>DI 5</b>	<i>Signal: Digital Input</i>
DI Slot X1 . <b>DI 6</b>	<i>Signal: Digital Input</i>
DI Slot X1 . <b>DI 7</b>	<i>Signal: Digital Input</i>
DI Slot X1 . <b>DI 8</b>	<i>Signal: Digital Input</i>
DI Slot X1 . <b>DI 1</b>	<i>Signal: Digital Input</i>
DI Slot X1 . <b>DI 2</b>	<i>Signal: Digital Input</i>
DI Slot X1 . <b>DI 3</b>	<i>Signal: Digital Input</i>
DI Slot X1 . <b>DI 4</b>	<i>Signal: Digital Input</i>
DNP3 . <b>BinaryOutput0</b>	<i>Virtual Digital Output (DNP). This corresponds to a virtual binary input of the protective device.</i>
DNP3 . <b>BinaryOutput1</b>	<i>Virtual Digital Output (DNP). This corresponds to a virtual binary input of the protective device.</i>
DNP3 . <b>BinaryOutput2</b>	<i>Virtual Digital Output (DNP). This corresponds to a virtual binary input of the protective device.</i>
DNP3 . <b>BinaryOutput3</b>	<i>Virtual Digital Output (DNP). This corresponds to a virtual binary input of the protective device.</i>
DNP3 . <b>BinaryOutput4</b>	<i>Virtual Digital Output (DNP). This corresponds to a virtual binary input of the protective device.</i>
DNP3 . <b>BinaryOutput5</b>	<i>Virtual Digital Output (DNP). This corresponds to a virtual binary input of the protective device.</i>
DNP3 . <b>BinaryOutput6</b>	<i>Virtual Digital Output (DNP). This corresponds to a virtual binary input of the protective device.</i>
DNP3 . <b>BinaryOutput7</b>	<i>Virtual Digital Output (DNP). This corresponds to a virtual binary input of the protective device.</i>
DNP3 . <b>BinaryOutput8</b>	<i>Virtual Digital Output (DNP). This corresponds to a virtual binary input of the protective device.</i>
DNP3 . <b>BinaryOutput9</b>	<i>Virtual Digital Output (DNP). This corresponds to a virtual binary input of the protective device.</i>
DNP3 . <b>BinaryOutput10</b>	<i>Virtual Digital Output (DNP). This corresponds to a virtual binary input of the protective device.</i>

<b>1..n, DI-LogicList</b>	<b>Description</b>
DNP3 . <b>BinaryOutput11</b>	<i>Virtual Digital Output (DNP). This corresponds to a virtual binary input of the protective device.</i>
DNP3 . <b>BinaryOutput12</b>	<i>Virtual Digital Output (DNP). This corresponds to a virtual binary input of the protective device.</i>
DNP3 . <b>BinaryOutput13</b>	<i>Virtual Digital Output (DNP). This corresponds to a virtual binary input of the protective device.</i>
DNP3 . <b>BinaryOutput14</b>	<i>Virtual Digital Output (DNP). This corresponds to a virtual binary input of the protective device.</i>
DNP3 . <b>BinaryOutput15</b>	<i>Virtual Digital Output (DNP). This corresponds to a virtual binary input of the protective device.</i>
DNP3 . <b>BinaryOutput16</b>	<i>Virtual Digital Output (DNP). This corresponds to a virtual binary input of the protective device.</i>
DNP3 . <b>BinaryOutput17</b>	<i>Virtual Digital Output (DNP). This corresponds to a virtual binary input of the protective device.</i>
DNP3 . <b>BinaryOutput18</b>	<i>Virtual Digital Output (DNP). This corresponds to a virtual binary input of the protective device.</i>
DNP3 . <b>BinaryOutput19</b>	<i>Virtual Digital Output (DNP). This corresponds to a virtual binary input of the protective device.</i>
DNP3 . <b>BinaryOutput20</b>	<i>Virtual Digital Output (DNP). This corresponds to a virtual binary input of the protective device.</i>
DNP3 . <b>BinaryOutput21</b>	<i>Virtual Digital Output (DNP). This corresponds to a virtual binary input of the protective device.</i>
DNP3 . <b>BinaryOutput22</b>	<i>Virtual Digital Output (DNP). This corresponds to a virtual binary input of the protective device.</i>
DNP3 . <b>BinaryOutput23</b>	<i>Virtual Digital Output (DNP). This corresponds to a virtual binary input of the protective device.</i>
DNP3 . <b>BinaryOutput24</b>	<i>Virtual Digital Output (DNP). This corresponds to a virtual binary input of the protective device.</i>
DNP3 . <b>BinaryOutput25</b>	<i>Virtual Digital Output (DNP). This corresponds to a virtual binary input of the protective device.</i>
DNP3 . <b>BinaryOutput26</b>	<i>Virtual Digital Output (DNP). This corresponds to a virtual binary input of the protective device.</i>
DNP3 . <b>BinaryOutput27</b>	<i>Virtual Digital Output (DNP). This corresponds to a virtual binary input of the protective device.</i>
DNP3 . <b>BinaryOutput28</b>	<i>Virtual Digital Output (DNP). This corresponds to a virtual binary input of the protective device.</i>
DNP3 . <b>BinaryOutput29</b>	<i>Virtual Digital Output (DNP). This corresponds to a virtual binary input of the protective device.</i>
DNP3 . <b>BinaryOutput30</b>	<i>Virtual Digital Output (DNP). This corresponds to a virtual binary input of the protective device.</i>

<b>1..n, DI-LogicList</b>	<b>Description</b>
DNP3 . <b>BinaryOutput31</b>	<i>Virtual Digital Output (DNP). This corresponds to a virtual binary input of the protective device.</i>
IEC104 . <b>Scada Cmd 1</b>	<i>Scada Command</i>
IEC104 . <b>Scada Cmd 2</b>	<i>Scada Command</i>
IEC104 . <b>Scada Cmd 3</b>	<i>Scada Command</i>
IEC104 . <b>Scada Cmd 4</b>	<i>Scada Command</i>
IEC104 . <b>Scada Cmd 5</b>	<i>Scada Command</i>
IEC104 . <b>Scada Cmd 6</b>	<i>Scada Command</i>
IEC104 . <b>Scada Cmd 7</b>	<i>Scada Command</i>
IEC104 . <b>Scada Cmd 8</b>	<i>Scada Command</i>
IEC104 . <b>Scada Cmd 9</b>	<i>Scada Command</i>
IEC104 . <b>Scada Cmd 10</b>	<i>Scada Command</i>
IEC104 . <b>Scada Cmd 11</b>	<i>Scada Command</i>
IEC104 . <b>Scada Cmd 12</b>	<i>Scada Command</i>
IEC104 . <b>Scada Cmd 13</b>	<i>Scada Command</i>
IEC104 . <b>Scada Cmd 14</b>	<i>Scada Command</i>
IEC104 . <b>Scada Cmd 15</b>	<i>Scada Command</i>
IEC104 . <b>Scada Cmd 16</b>	<i>Scada Command</i>
Logics . <b>LE1.Gate Out</b>	<i>Signal: Output of the logic gate</i>
Logics . <b>LE1.Timer Out</b>	<i>Signal: Timer Output</i>
Logics . <b>LE1.Out</b>	<i>Signal: Latched Output (Q)</i>
Logics . <b>LE1.Out inverted</b>	<i>Signal: Negated Latched Output (Q NOT)</i>
Logics . <b>LE2.Gate Out</b>	<i>Signal: Output of the logic gate</i>
Logics . <b>LE2.Timer Out</b>	<i>Signal: Timer Output</i>
Logics . <b>LE2.Out</b>	<i>Signal: Latched Output (Q)</i>
Logics . <b>LE2.Out inverted</b>	<i>Signal: Negated Latched Output (Q NOT)</i>
Logics . <b>LE3.Gate Out</b>	<i>Signal: Output of the logic gate</i>
Logics . <b>LE3.Timer Out</b>	<i>Signal: Timer Output</i>
Logics . <b>LE3.Out</b>	<i>Signal: Latched Output (Q)</i>
Logics . <b>LE3.Out inverted</b>	<i>Signal: Negated Latched Output (Q NOT)</i>

<b>1..n, DI-LogicList</b>	<b>Description</b>
Logics . <b>LE4.Gate Out</b>	<i>Signal: Output of the logic gate</i>
Logics . <b>LE4.Timer Out</b>	<i>Signal: Timer Output</i>
Logics . <b>LE4.Out</b>	<i>Signal: Latched Output (Q)</i>
Logics . <b>LE4.Out inverted</b>	<i>Signal: Negated Latched Output (Q NOT)</i>
Logics . <b>LE5.Gate Out</b>	<i>Signal: Output of the logic gate</i>
Logics . <b>LE5.Timer Out</b>	<i>Signal: Timer Output</i>
Logics . <b>LE5.Out</b>	<i>Signal: Latched Output (Q)</i>
Logics . <b>LE5.Out inverted</b>	<i>Signal: Negated Latched Output (Q NOT)</i>
Logics . <b>LE6.Gate Out</b>	<i>Signal: Output of the logic gate</i>
Logics . <b>LE6.Timer Out</b>	<i>Signal: Timer Output</i>
Logics . <b>LE6.Out</b>	<i>Signal: Latched Output (Q)</i>
Logics . <b>LE6.Out inverted</b>	<i>Signal: Negated Latched Output (Q NOT)</i>
Logics . <b>LE7.Gate Out</b>	<i>Signal: Output of the logic gate</i>
Logics . <b>LE7.Timer Out</b>	<i>Signal: Timer Output</i>
Logics . <b>LE7.Out</b>	<i>Signal: Latched Output (Q)</i>
Logics . <b>LE7.Out inverted</b>	<i>Signal: Negated Latched Output (Q NOT)</i>
Logics . <b>LE8.Gate Out</b>	<i>Signal: Output of the logic gate</i>
Logics . <b>LE8.Timer Out</b>	<i>Signal: Timer Output</i>
Logics . <b>LE8.Out</b>	<i>Signal: Latched Output (Q)</i>
Logics . <b>LE8.Out inverted</b>	<i>Signal: Negated Latched Output (Q NOT)</i>
Logics . <b>LE9.Gate Out</b>	<i>Signal: Output of the logic gate</i>
Logics . <b>LE9.Timer Out</b>	<i>Signal: Timer Output</i>
Logics . <b>LE9.Out</b>	<i>Signal: Latched Output (Q)</i>
Logics . <b>LE9.Out inverted</b>	<i>Signal: Negated Latched Output (Q NOT)</i>
Logics . <b>LE10.Gate Out</b>	<i>Signal: Output of the logic gate</i>
Logics . <b>LE10.Timer Out</b>	<i>Signal: Timer Output</i>
Logics . <b>LE10.Out</b>	<i>Signal: Latched Output (Q)</i>
Logics . <b>LE10.Out inverted</b>	<i>Signal: Negated Latched Output (Q NOT)</i>

<b>1..n, DI-LogicList</b>	<b>Description</b>
Logics . <b>LE11.Gate Out</b>	<i>Signal: Output of the logic gate</i>
Logics . <b>LE11.Timer Out</b>	<i>Signal: Timer Output</i>
Logics . <b>LE11.Out</b>	<i>Signal: Latched Output (Q)</i>
Logics . <b>LE11.Out inverted</b>	<i>Signal: Negated Latched Output (Q NOT)</i>
Logics . <b>LE12.Gate Out</b>	<i>Signal: Output of the logic gate</i>
Logics . <b>LE12.Timer Out</b>	<i>Signal: Timer Output</i>
Logics . <b>LE12.Out</b>	<i>Signal: Latched Output (Q)</i>
Logics . <b>LE12.Out inverted</b>	<i>Signal: Negated Latched Output (Q NOT)</i>
Logics . <b>LE13.Gate Out</b>	<i>Signal: Output of the logic gate</i>
Logics . <b>LE13.Timer Out</b>	<i>Signal: Timer Output</i>
Logics . <b>LE13.Out</b>	<i>Signal: Latched Output (Q)</i>
Logics . <b>LE13.Out inverted</b>	<i>Signal: Negated Latched Output (Q NOT)</i>
Logics . <b>LE14.Gate Out</b>	<i>Signal: Output of the logic gate</i>
Logics . <b>LE14.Timer Out</b>	<i>Signal: Timer Output</i>
Logics . <b>LE14.Out</b>	<i>Signal: Latched Output (Q)</i>
Logics . <b>LE14.Out inverted</b>	<i>Signal: Negated Latched Output (Q NOT)</i>
Logics . <b>LE15.Gate Out</b>	<i>Signal: Output of the logic gate</i>
Logics . <b>LE15.Timer Out</b>	<i>Signal: Timer Output</i>
Logics . <b>LE15.Out</b>	<i>Signal: Latched Output (Q)</i>
Logics . <b>LE15.Out inverted</b>	<i>Signal: Negated Latched Output (Q NOT)</i>
Logics . <b>LE16.Gate Out</b>	<i>Signal: Output of the logic gate</i>
Logics . <b>LE16.Timer Out</b>	<i>Signal: Timer Output</i>
Logics . <b>LE16.Out</b>	<i>Signal: Latched Output (Q)</i>
Logics . <b>LE16.Out inverted</b>	<i>Signal: Negated Latched Output (Q NOT)</i>
Logics . <b>LE17.Gate Out</b>	<i>Signal: Output of the logic gate</i>
Logics . <b>LE17.Timer Out</b>	<i>Signal: Timer Output</i>
Logics . <b>LE17.Out</b>	<i>Signal: Latched Output (Q)</i>
Logics . <b>LE17.Out inverted</b>	<i>Signal: Negated Latched Output (Q NOT)</i>

<b>1..n, DI-LogicList</b>	<b>Description</b>
Logics . <b>LE18.Gate Out</b>	<i>Signal: Output of the logic gate</i>
Logics . <b>LE18.Timer Out</b>	<i>Signal: Timer Output</i>
Logics . <b>LE18.Out</b>	<i>Signal: Latched Output (Q)</i>
Logics . <b>LE18.Out inverted</b>	<i>Signal: Negated Latched Output (Q NOT)</i>
Logics . <b>LE19.Gate Out</b>	<i>Signal: Output of the logic gate</i>
Logics . <b>LE19.Timer Out</b>	<i>Signal: Timer Output</i>
Logics . <b>LE19.Out</b>	<i>Signal: Latched Output (Q)</i>
Logics . <b>LE19.Out inverted</b>	<i>Signal: Negated Latched Output (Q NOT)</i>
Logics . <b>LE20.Gate Out</b>	<i>Signal: Output of the logic gate</i>
Logics . <b>LE20.Timer Out</b>	<i>Signal: Timer Output</i>
Logics . <b>LE20.Out</b>	<i>Signal: Latched Output (Q)</i>
Logics . <b>LE20.Out inverted</b>	<i>Signal: Negated Latched Output (Q NOT)</i>
Logics . <b>LE21.Gate Out</b>	<i>Signal: Output of the logic gate</i>
Logics . <b>LE21.Timer Out</b>	<i>Signal: Timer Output</i>
Logics . <b>LE21.Out</b>	<i>Signal: Latched Output (Q)</i>
Logics . <b>LE21.Out inverted</b>	<i>Signal: Negated Latched Output (Q NOT)</i>
Logics . <b>LE22.Gate Out</b>	<i>Signal: Output of the logic gate</i>
Logics . <b>LE22.Timer Out</b>	<i>Signal: Timer Output</i>
Logics . <b>LE22.Out</b>	<i>Signal: Latched Output (Q)</i>
Logics . <b>LE22.Out inverted</b>	<i>Signal: Negated Latched Output (Q NOT)</i>
Logics . <b>LE23.Gate Out</b>	<i>Signal: Output of the logic gate</i>
Logics . <b>LE23.Timer Out</b>	<i>Signal: Timer Output</i>
Logics . <b>LE23.Out</b>	<i>Signal: Latched Output (Q)</i>
Logics . <b>LE23.Out inverted</b>	<i>Signal: Negated Latched Output (Q NOT)</i>
Logics . <b>LE24.Gate Out</b>	<i>Signal: Output of the logic gate</i>
Logics . <b>LE24.Timer Out</b>	<i>Signal: Timer Output</i>
Logics . <b>LE24.Out</b>	<i>Signal: Latched Output (Q)</i>
Logics . <b>LE24.Out inverted</b>	<i>Signal: Negated Latched Output (Q NOT)</i>

<b>1..n, DI-LogicList</b>	<b>Description</b>
Logics . <b>LE25.Gate Out</b>	<i>Signal: Output of the logic gate</i>
Logics . <b>LE25.Timer Out</b>	<i>Signal: Timer Output</i>
Logics . <b>LE25.Out</b>	<i>Signal: Latched Output (Q)</i>
Logics . <b>LE25.Out inverted</b>	<i>Signal: Negated Latched Output (Q NOT)</i>
Logics . <b>LE26.Gate Out</b>	<i>Signal: Output of the logic gate</i>
Logics . <b>LE26.Timer Out</b>	<i>Signal: Timer Output</i>
Logics . <b>LE26.Out</b>	<i>Signal: Latched Output (Q)</i>
Logics . <b>LE26.Out inverted</b>	<i>Signal: Negated Latched Output (Q NOT)</i>
Logics . <b>LE27.Gate Out</b>	<i>Signal: Output of the logic gate</i>
Logics . <b>LE27.Timer Out</b>	<i>Signal: Timer Output</i>
Logics . <b>LE27.Out</b>	<i>Signal: Latched Output (Q)</i>
Logics . <b>LE27.Out inverted</b>	<i>Signal: Negated Latched Output (Q NOT)</i>
Logics . <b>LE28.Gate Out</b>	<i>Signal: Output of the logic gate</i>
Logics . <b>LE28.Timer Out</b>	<i>Signal: Timer Output</i>
Logics . <b>LE28.Out</b>	<i>Signal: Latched Output (Q)</i>
Logics . <b>LE28.Out inverted</b>	<i>Signal: Negated Latched Output (Q NOT)</i>
Logics . <b>LE29.Gate Out</b>	<i>Signal: Output of the logic gate</i>
Logics . <b>LE29.Timer Out</b>	<i>Signal: Timer Output</i>
Logics . <b>LE29.Out</b>	<i>Signal: Latched Output (Q)</i>
Logics . <b>LE29.Out inverted</b>	<i>Signal: Negated Latched Output (Q NOT)</i>
Logics . <b>LE30.Gate Out</b>	<i>Signal: Output of the logic gate</i>
Logics . <b>LE30.Timer Out</b>	<i>Signal: Timer Output</i>
Logics . <b>LE30.Out</b>	<i>Signal: Latched Output (Q)</i>
Logics . <b>LE30.Out inverted</b>	<i>Signal: Negated Latched Output (Q NOT)</i>
Logics . <b>LE31.Gate Out</b>	<i>Signal: Output of the logic gate</i>
Logics . <b>LE31.Timer Out</b>	<i>Signal: Timer Output</i>
Logics . <b>LE31.Out</b>	<i>Signal: Latched Output (Q)</i>
Logics . <b>LE31.Out inverted</b>	<i>Signal: Negated Latched Output (Q NOT)</i>

<b>1..n, DI-LogicList</b>	<b>Description</b>
Logics . <b>LE32.Gate Out</b>	<i>Signal: Output of the logic gate</i>
Logics . <b>LE32.Timer Out</b>	<i>Signal: Timer Output</i>
Logics . <b>LE32.Out</b>	<i>Signal: Latched Output (Q)</i>
Logics . <b>LE32.Out inverted</b>	<i>Signal: Negated Latched Output (Q NOT)</i>
Logics . <b>LE33.Gate Out</b>	<i>Signal: Output of the logic gate</i>
Logics . <b>LE33.Timer Out</b>	<i>Signal: Timer Output</i>
Logics . <b>LE33.Out</b>	<i>Signal: Latched Output (Q)</i>
Logics . <b>LE33.Out inverted</b>	<i>Signal: Negated Latched Output (Q NOT)</i>
Logics . <b>LE34.Gate Out</b>	<i>Signal: Output of the logic gate</i>
Logics . <b>LE34.Timer Out</b>	<i>Signal: Timer Output</i>
Logics . <b>LE34.Out</b>	<i>Signal: Latched Output (Q)</i>
Logics . <b>LE34.Out inverted</b>	<i>Signal: Negated Latched Output (Q NOT)</i>
Logics . <b>LE35.Gate Out</b>	<i>Signal: Output of the logic gate</i>
Logics . <b>LE35.Timer Out</b>	<i>Signal: Timer Output</i>
Logics . <b>LE35.Out</b>	<i>Signal: Latched Output (Q)</i>
Logics . <b>LE35.Out inverted</b>	<i>Signal: Negated Latched Output (Q NOT)</i>
Logics . <b>LE36.Gate Out</b>	<i>Signal: Output of the logic gate</i>
Logics . <b>LE36.Timer Out</b>	<i>Signal: Timer Output</i>
Logics . <b>LE36.Out</b>	<i>Signal: Latched Output (Q)</i>
Logics . <b>LE36.Out inverted</b>	<i>Signal: Negated Latched Output (Q NOT)</i>
Logics . <b>LE37.Gate Out</b>	<i>Signal: Output of the logic gate</i>
Logics . <b>LE37.Timer Out</b>	<i>Signal: Timer Output</i>
Logics . <b>LE37.Out</b>	<i>Signal: Latched Output (Q)</i>
Logics . <b>LE37.Out inverted</b>	<i>Signal: Negated Latched Output (Q NOT)</i>
Logics . <b>LE38.Gate Out</b>	<i>Signal: Output of the logic gate</i>
Logics . <b>LE38.Timer Out</b>	<i>Signal: Timer Output</i>
Logics . <b>LE38.Out</b>	<i>Signal: Latched Output (Q)</i>
Logics . <b>LE38.Out inverted</b>	<i>Signal: Negated Latched Output (Q NOT)</i>



<b>1..n, DI-LogicList</b>	<b>Description</b>
Logics . <b>LE39.Gate Out</b>	<i>Signal: Output of the logic gate</i>
Logics . <b>LE39.Timer Out</b>	<i>Signal: Timer Output</i>
Logics . <b>LE39.Out</b>	<i>Signal: Latched Output (Q)</i>
Logics . <b>LE39.Out inverted</b>	<i>Signal: Negated Latched Output (Q NOT)</i>
Logics . <b>LE40.Gate Out</b>	<i>Signal: Output of the logic gate</i>
Logics . <b>LE40.Timer Out</b>	<i>Signal: Timer Output</i>
Logics . <b>LE40.Out</b>	<i>Signal: Latched Output (Q)</i>
Logics . <b>LE40.Out inverted</b>	<i>Signal: Negated Latched Output (Q NOT)</i>
Logics . <b>LE41.Gate Out</b>	<i>Signal: Output of the logic gate</i>
Logics . <b>LE41.Timer Out</b>	<i>Signal: Timer Output</i>
Logics . <b>LE41.Out</b>	<i>Signal: Latched Output (Q)</i>
Logics . <b>LE41.Out inverted</b>	<i>Signal: Negated Latched Output (Q NOT)</i>
Logics . <b>LE42.Gate Out</b>	<i>Signal: Output of the logic gate</i>
Logics . <b>LE42.Timer Out</b>	<i>Signal: Timer Output</i>
Logics . <b>LE42.Out</b>	<i>Signal: Latched Output (Q)</i>
Logics . <b>LE42.Out inverted</b>	<i>Signal: Negated Latched Output (Q NOT)</i>
Logics . <b>LE43.Gate Out</b>	<i>Signal: Output of the logic gate</i>
Logics . <b>LE43.Timer Out</b>	<i>Signal: Timer Output</i>
Logics . <b>LE43.Out</b>	<i>Signal: Latched Output (Q)</i>
Logics . <b>LE43.Out inverted</b>	<i>Signal: Negated Latched Output (Q NOT)</i>
Logics . <b>LE44.Gate Out</b>	<i>Signal: Output of the logic gate</i>
Logics . <b>LE44.Timer Out</b>	<i>Signal: Timer Output</i>
Logics . <b>LE44.Out</b>	<i>Signal: Latched Output (Q)</i>
Logics . <b>LE44.Out inverted</b>	<i>Signal: Negated Latched Output (Q NOT)</i>
Logics . <b>LE45.Gate Out</b>	<i>Signal: Output of the logic gate</i>
Logics . <b>LE45.Timer Out</b>	<i>Signal: Timer Output</i>
Logics . <b>LE45.Out</b>	<i>Signal: Latched Output (Q)</i>
Logics . <b>LE45.Out inverted</b>	<i>Signal: Negated Latched Output (Q NOT)</i>

<b>1..n, DI-LogicList</b>	<b>Description</b>
Logics . <b>LE46.Gate Out</b>	<i>Signal: Output of the logic gate</i>
Logics . <b>LE46.Timer Out</b>	<i>Signal: Timer Output</i>
Logics . <b>LE46.Out</b>	<i>Signal: Latched Output (Q)</i>
Logics . <b>LE46.Out inverted</b>	<i>Signal: Negated Latched Output (Q NOT)</i>
Logics . <b>LE47.Gate Out</b>	<i>Signal: Output of the logic gate</i>
Logics . <b>LE47.Timer Out</b>	<i>Signal: Timer Output</i>
Logics . <b>LE47.Out</b>	<i>Signal: Latched Output (Q)</i>
Logics . <b>LE47.Out inverted</b>	<i>Signal: Negated Latched Output (Q NOT)</i>
Logics . <b>LE48.Gate Out</b>	<i>Signal: Output of the logic gate</i>
Logics . <b>LE48.Timer Out</b>	<i>Signal: Timer Output</i>
Logics . <b>LE48.Out</b>	<i>Signal: Latched Output (Q)</i>
Logics . <b>LE48.Out inverted</b>	<i>Signal: Negated Latched Output (Q NOT)</i>
Logics . <b>LE49.Gate Out</b>	<i>Signal: Output of the logic gate</i>
Logics . <b>LE49.Timer Out</b>	<i>Signal: Timer Output</i>
Logics . <b>LE49.Out</b>	<i>Signal: Latched Output (Q)</i>
Logics . <b>LE49.Out inverted</b>	<i>Signal: Negated Latched Output (Q NOT)</i>
Logics . <b>LE50.Gate Out</b>	<i>Signal: Output of the logic gate</i>
Logics . <b>LE50.Timer Out</b>	<i>Signal: Timer Output</i>
Logics . <b>LE50.Out</b>	<i>Signal: Latched Output (Q)</i>
Logics . <b>LE50.Out inverted</b>	<i>Signal: Negated Latched Output (Q NOT)</i>
Logics . <b>LE51.Gate Out</b>	<i>Signal: Output of the logic gate</i>
Logics . <b>LE51.Timer Out</b>	<i>Signal: Timer Output</i>
Logics . <b>LE51.Out</b>	<i>Signal: Latched Output (Q)</i>
Logics . <b>LE51.Out inverted</b>	<i>Signal: Negated Latched Output (Q NOT)</i>
Logics . <b>LE52.Gate Out</b>	<i>Signal: Output of the logic gate</i>
Logics . <b>LE52.Timer Out</b>	<i>Signal: Timer Output</i>
Logics . <b>LE52.Out</b>	<i>Signal: Latched Output (Q)</i>
Logics . <b>LE52.Out inverted</b>	<i>Signal: Negated Latched Output (Q NOT)</i>

<b>1..n, DI-LogicList</b>	<b>Description</b>
Logics . <b>LE53.Gate Out</b>	<i>Signal: Output of the logic gate</i>
Logics . <b>LE53.Timer Out</b>	<i>Signal: Timer Output</i>
Logics . <b>LE53.Out</b>	<i>Signal: Latched Output (Q)</i>
Logics . <b>LE53.Out inverted</b>	<i>Signal: Negated Latched Output (Q NOT)</i>
Logics . <b>LE54.Gate Out</b>	<i>Signal: Output of the logic gate</i>
Logics . <b>LE54.Timer Out</b>	<i>Signal: Timer Output</i>
Logics . <b>LE54.Out</b>	<i>Signal: Latched Output (Q)</i>
Logics . <b>LE54.Out inverted</b>	<i>Signal: Negated Latched Output (Q NOT)</i>
Logics . <b>LE55.Gate Out</b>	<i>Signal: Output of the logic gate</i>
Logics . <b>LE55.Timer Out</b>	<i>Signal: Timer Output</i>
Logics . <b>LE55.Out</b>	<i>Signal: Latched Output (Q)</i>
Logics . <b>LE55.Out inverted</b>	<i>Signal: Negated Latched Output (Q NOT)</i>
Logics . <b>LE56.Gate Out</b>	<i>Signal: Output of the logic gate</i>
Logics . <b>LE56.Timer Out</b>	<i>Signal: Timer Output</i>
Logics . <b>LE56.Out</b>	<i>Signal: Latched Output (Q)</i>
Logics . <b>LE56.Out inverted</b>	<i>Signal: Negated Latched Output (Q NOT)</i>
Logics . <b>LE57.Gate Out</b>	<i>Signal: Output of the logic gate</i>
Logics . <b>LE57.Timer Out</b>	<i>Signal: Timer Output</i>
Logics . <b>LE57.Out</b>	<i>Signal: Latched Output (Q)</i>
Logics . <b>LE57.Out inverted</b>	<i>Signal: Negated Latched Output (Q NOT)</i>
Logics . <b>LE58.Gate Out</b>	<i>Signal: Output of the logic gate</i>
Logics . <b>LE58.Timer Out</b>	<i>Signal: Timer Output</i>
Logics . <b>LE58.Out</b>	<i>Signal: Latched Output (Q)</i>
Logics . <b>LE58.Out inverted</b>	<i>Signal: Negated Latched Output (Q NOT)</i>
Logics . <b>LE59.Gate Out</b>	<i>Signal: Output of the logic gate</i>
Logics . <b>LE59.Timer Out</b>	<i>Signal: Timer Output</i>
Logics . <b>LE59.Out</b>	<i>Signal: Latched Output (Q)</i>
Logics . <b>LE59.Out inverted</b>	<i>Signal: Negated Latched Output (Q NOT)</i>

<b>1..n, DI-LogicList</b>	<b>Description</b>
Logics . <b>LE60.Gate Out</b>	<i>Signal: Output of the logic gate</i>
Logics . <b>LE60.Timer Out</b>	<i>Signal: Timer Output</i>
Logics . <b>LE60.Out</b>	<i>Signal: Latched Output (Q)</i>
Logics . <b>LE60.Out inverted</b>	<i>Signal: Negated Latched Output (Q NOT)</i>
Logics . <b>LE61.Gate Out</b>	<i>Signal: Output of the logic gate</i>
Logics . <b>LE61.Timer Out</b>	<i>Signal: Timer Output</i>
Logics . <b>LE61.Out</b>	<i>Signal: Latched Output (Q)</i>
Logics . <b>LE61.Out inverted</b>	<i>Signal: Negated Latched Output (Q NOT)</i>
Logics . <b>LE62.Gate Out</b>	<i>Signal: Output of the logic gate</i>
Logics . <b>LE62.Timer Out</b>	<i>Signal: Timer Output</i>
Logics . <b>LE62.Out</b>	<i>Signal: Latched Output (Q)</i>
Logics . <b>LE62.Out inverted</b>	<i>Signal: Negated Latched Output (Q NOT)</i>
Logics . <b>LE63.Gate Out</b>	<i>Signal: Output of the logic gate</i>
Logics . <b>LE63.Timer Out</b>	<i>Signal: Timer Output</i>
Logics . <b>LE63.Out</b>	<i>Signal: Latched Output (Q)</i>
Logics . <b>LE63.Out inverted</b>	<i>Signal: Negated Latched Output (Q NOT)</i>
Logics . <b>LE64.Gate Out</b>	<i>Signal: Output of the logic gate</i>
Logics . <b>LE64.Timer Out</b>	<i>Signal: Timer Output</i>
Logics . <b>LE64.Out</b>	<i>Signal: Latched Output (Q)</i>
Logics . <b>LE64.Out inverted</b>	<i>Signal: Negated Latched Output (Q NOT)</i>
Logics . <b>LE65.Gate Out</b>	<i>Signal: Output of the logic gate</i>
Logics . <b>LE65.Timer Out</b>	<i>Signal: Timer Output</i>
Logics . <b>LE65.Out</b>	<i>Signal: Latched Output (Q)</i>
Logics . <b>LE65.Out inverted</b>	<i>Signal: Negated Latched Output (Q NOT)</i>
Logics . <b>LE66.Gate Out</b>	<i>Signal: Output of the logic gate</i>
Logics . <b>LE66.Timer Out</b>	<i>Signal: Timer Output</i>
Logics . <b>LE66.Out</b>	<i>Signal: Latched Output (Q)</i>
Logics . <b>LE66.Out inverted</b>	<i>Signal: Negated Latched Output (Q NOT)</i>

<b>1..n, DI-LogicList</b>	<b>Description</b>
Logics . <b>LE67.Gate Out</b>	<i>Signal: Output of the logic gate</i>
Logics . <b>LE67.Timer Out</b>	<i>Signal: Timer Output</i>
Logics . <b>LE67.Out</b>	<i>Signal: Latched Output (Q)</i>
Logics . <b>LE67.Out inverted</b>	<i>Signal: Negated Latched Output (Q NOT)</i>
Logics . <b>LE68.Gate Out</b>	<i>Signal: Output of the logic gate</i>
Logics . <b>LE68.Timer Out</b>	<i>Signal: Timer Output</i>
Logics . <b>LE68.Out</b>	<i>Signal: Latched Output (Q)</i>
Logics . <b>LE68.Out inverted</b>	<i>Signal: Negated Latched Output (Q NOT)</i>
Logics . <b>LE69.Gate Out</b>	<i>Signal: Output of the logic gate</i>
Logics . <b>LE69.Timer Out</b>	<i>Signal: Timer Output</i>
Logics . <b>LE69.Out</b>	<i>Signal: Latched Output (Q)</i>
Logics . <b>LE69.Out inverted</b>	<i>Signal: Negated Latched Output (Q NOT)</i>
Logics . <b>LE70.Gate Out</b>	<i>Signal: Output of the logic gate</i>
Logics . <b>LE70.Timer Out</b>	<i>Signal: Timer Output</i>
Logics . <b>LE70.Out</b>	<i>Signal: Latched Output (Q)</i>
Logics . <b>LE70.Out inverted</b>	<i>Signal: Negated Latched Output (Q NOT)</i>
Logics . <b>LE71.Gate Out</b>	<i>Signal: Output of the logic gate</i>
Logics . <b>LE71.Timer Out</b>	<i>Signal: Timer Output</i>
Logics . <b>LE71.Out</b>	<i>Signal: Latched Output (Q)</i>
Logics . <b>LE71.Out inverted</b>	<i>Signal: Negated Latched Output (Q NOT)</i>
Logics . <b>LE72.Gate Out</b>	<i>Signal: Output of the logic gate</i>
Logics . <b>LE72.Timer Out</b>	<i>Signal: Timer Output</i>
Logics . <b>LE72.Out</b>	<i>Signal: Latched Output (Q)</i>
Logics . <b>LE72.Out inverted</b>	<i>Signal: Negated Latched Output (Q NOT)</i>
Logics . <b>LE73.Gate Out</b>	<i>Signal: Output of the logic gate</i>
Logics . <b>LE73.Timer Out</b>	<i>Signal: Timer Output</i>
Logics . <b>LE73.Out</b>	<i>Signal: Latched Output (Q)</i>
Logics . <b>LE73.Out inverted</b>	<i>Signal: Negated Latched Output (Q NOT)</i>

<b>1..n, DI-LogicList</b>	<b>Description</b>
Logics . <b>LE74.Gate Out</b>	<i>Signal: Output of the logic gate</i>
Logics . <b>LE74.Timer Out</b>	<i>Signal: Timer Output</i>
Logics . <b>LE74.Out</b>	<i>Signal: Latched Output (Q)</i>
Logics . <b>LE74.Out inverted</b>	<i>Signal: Negated Latched Output (Q NOT)</i>
Logics . <b>LE75.Gate Out</b>	<i>Signal: Output of the logic gate</i>
Logics . <b>LE75.Timer Out</b>	<i>Signal: Timer Output</i>
Logics . <b>LE75.Out</b>	<i>Signal: Latched Output (Q)</i>
Logics . <b>LE75.Out inverted</b>	<i>Signal: Negated Latched Output (Q NOT)</i>
Logics . <b>LE76.Gate Out</b>	<i>Signal: Output of the logic gate</i>
Logics . <b>LE76.Timer Out</b>	<i>Signal: Timer Output</i>
Logics . <b>LE76.Out</b>	<i>Signal: Latched Output (Q)</i>
Logics . <b>LE76.Out inverted</b>	<i>Signal: Negated Latched Output (Q NOT)</i>
Logics . <b>LE77.Gate Out</b>	<i>Signal: Output of the logic gate</i>
Logics . <b>LE77.Timer Out</b>	<i>Signal: Timer Output</i>
Logics . <b>LE77.Out</b>	<i>Signal: Latched Output (Q)</i>
Logics . <b>LE77.Out inverted</b>	<i>Signal: Negated Latched Output (Q NOT)</i>
Logics . <b>LE78.Gate Out</b>	<i>Signal: Output of the logic gate</i>
Logics . <b>LE78.Timer Out</b>	<i>Signal: Timer Output</i>
Logics . <b>LE78.Out</b>	<i>Signal: Latched Output (Q)</i>
Logics . <b>LE78.Out inverted</b>	<i>Signal: Negated Latched Output (Q NOT)</i>
Logics . <b>LE79.Gate Out</b>	<i>Signal: Output of the logic gate</i>
Logics . <b>LE79.Timer Out</b>	<i>Signal: Timer Output</i>
Logics . <b>LE79.Out</b>	<i>Signal: Latched Output (Q)</i>
Logics . <b>LE79.Out inverted</b>	<i>Signal: Negated Latched Output (Q NOT)</i>
Logics . <b>LE80.Gate Out</b>	<i>Signal: Output of the logic gate</i>
Logics . <b>LE80.Timer Out</b>	<i>Signal: Timer Output</i>
Logics . <b>LE80.Out</b>	<i>Signal: Latched Output (Q)</i>
Logics . <b>LE80.Out inverted</b>	<i>Signal: Negated Latched Output (Q NOT)</i>

**LE1.Gate**

Logic gate

Selection list referenced by the following parameters:



-  Logics . LE1.Gate

LE1.Gate	Description
AND	AND Gate
OR	OR Gate
NAND	NAND Gate
NOR	NOR Gate

**Mode**

general operation mode

Selection list referenced by the following parameters:

-  BO Slot X2 . Disarm Mode
-  BO Slot X2 . Force Mode

Mode	Description
permanent	permanent
timeout	timeout

**active/inactive**

Selection list referenced by the following parameters:



-  BO Slot X2 . DISARMED

active/inactive	Description
inactive	inactive
active	active

**Mode**

general operation mode

Selection list referenced by the following parameters:

-  BO Slot X2 . Disarm Mode
-  BO Slot X2 . Force Mode

Mode	Description
permanent	<i>permanent</i>
timeout	<i>timeout</i>

**active/inactive**



Selection list referenced by the following parameters:

-  BO Slot X2 . DISARMED

active/inactive	Description
inactive	<i>inactive</i>
active	<i>active</i>

**Relay operating modes**

Selection list referenced by the following parameters:



-  BO Slot X2 . Force all Outs
-  BO Slot X2 . Force OR1

Relay operating modes	Description
Normal	<i>Normal</i>
De-Energized	<i>De-Energized</i>
Energized	<i>Energized</i>



**Relay operating modes**

Selection list referenced by the following parameters:

-  BO Slot X2 . Force all Outs
-  BO Slot X2 . Force OR1

Relay operating modes	Description
Normal	<i>Normal</i>
De-Energized	<i>De-Energized</i>
Energized	<i>Energized</i>

**Mode**

general operation mode

Selection list referenced by the following parameters:

-  URTD . Force Mode

Mode	Description
permanent	<i>permanent</i>
timeout	<i>timeout</i>

**active/inactive**

Selection list referenced by the following parameters:

-  URTD . Function

active/inactive	Description
inactive	<i>inactive</i>
active	<i>active</i>

**State**

Selection list referenced by the following parameters:

-  Sgen . State

State	Description
Off	Off
PreFault	Pre Fault Duration
FaultSimulation	Duration of Fault Simulation
PostFault	Post Fault Duration
Init Res	Init Reset

**TripCmd Mode**

Trip Command Mode: Select between two operating modes for the Fault Simulator: "cold simulation" (without tripping the circuit breaker), or "hot simulation" (i.e. the simulation is authorized to trip the circuit breaker)

Selection list referenced by the following parameters:

-  Sgen . TripCmd Mode

TripCmd Mode	Description
No TripCmd	No Trip Command: The TripCmd of all protection functions is blocked. The protection function will possibly trip but not generate a TripCmd.
With TripCmd	With Trip Command: The trip of a protection function generates a TripCmd, that can open the circuit breaker.

# Index

.....	383, 384
<b>1</b>	
1...n Operating Modes .....	290, 361
1..n, AnalogOutputList .....	361
1..n, Assignment List .....	290, 372, 373
1..n, DI-LogicList .....	440
1..n, Dig Inputs .....	387
1..n, InSq .....	386
1..n, OnOffList .....	370
1..n, PSS .....	422
1..n, TRN List .....	386
1..n, TrendRecList .....	368
1..n, Trip Cmds .....	388, 439
1..n, Zero speed .....	386
<b>A</b>	
Ack via »C« key .....	364
AdaptSet .....	389
Alarm Mode .....	438
active/inactive .....	385, 455, 456, 457
<b>B</b>	
Baud rate .....	276, 371, 375, 376
Byte Frame .....	371, 375, 377
<b>C</b>	
CBF .....	220, 220, 221, 222, 222, 222
CT .....	60, 61, 62, 65
CTS .....	227, 227, 227, 228, 228
Char .....	434, 436, 437
Communication Start Variants .....	372
Config status .....	277, 376, 379
Config. Device Reset .....	280
Ctrl .....	230, 230, 230, 231, 231, 232
Current Trips .....	407
<b>D</b>	
DNP3 .....	82, 87, 87, 88, 88
Date .....	381
Day of clock change .....	382

Debouncing time	288, 289
Device planning	283, 283, 284, 284, 284, 285
Disturb rec	252, 253, 253, 253, 254
Duration	365, 365
<b>E</b>	
Earth overcurrent	281
EmgOvr	387
Event rec	251, 251
ExP[1]	182, 182, 183, 184, 184, 185
External Trips	407
<b>F</b>	
Fault	275
Fault rec	255, 255, 255
Field Para	59
fN	384
<b>H</b>	
HMI	55, 56, 56
<b>I</b>	
I2>[1]	177, 177, 178, 179, 180, 181
I<[1]	170, 170, 171, 172, 172, 173
I>	281
IEC 61850	97, 97, 97, 98, 99, 101, 101
IEC103	102, 104, 105, 105
IEC104	107, 110, 110, 110, 111
IG[1]	152, 152, 154, 156, 157, 159
IRIG-B	116, 116, 116, 117, 117
IRIG-B00X	383
I[1]	144, 144, 145, 148, 149, 150
<b>J</b>	
Jam[1]	166, 166, 167, 168, 168, 169
<b>L</b>	
LE1.Gate	455
LED active color	364
Logics	261, 262, 263, 263
<b>M</b>	
MLS	174, 174, 174, 175, 175

MStart	129, 134, 135, 135, 136, 140, 140, 141
Manipulate Position	439
Measuring Channel	435
Measuring method	434, 436
Modbus	90, 93, 93, 93, 94, 95
Mode	278, 282, 283, 283, 285, 286, 286, 287, 363, 421, 455, 456, 457
Month of clock change	381
Motor Stop	384
<b>N</b>	
No of Equations:	286
Nom voltage	288, 289
NonIL ResetMode	438
<b>O</b>	
Optical rest position	371, 374, 377
<b>P</b>	
PNO Id	277
PSet-Switch	421
Phase Sequence	384
Polarity	385
Port selection	374, 378
Profibus	112, 112, 113, 113, 114, 115
Prot	125, 126, 126, 126
<b>R</b>	
RTD	194, 194, 195, 209, 209, 218
Ratio prim/sec	385
Rec state	275
Record-Mode	367
Relay operating modes	456, 457
Reset Mode	435, 437
Resolution	367, 368
<b>S</b>	
SG[1]	233, 237, 237, 238, 242, 245, 246, 247, 247
SNTP	118, 118, 119, 119, 119, 120
SSV	265, 265, 265
Scada	80, 80
Scale Factor	374
Scaling	287

Scheme .....	406
Selection .....	367
Server State .....	278
Sgen. .... 267, 267, 268, 268, 269, 270, 271	
Start rec .....	259, 259, 260
State .....	275, 276, 278, 457
Statistics .....	76, 77, 78, 78, 78
Switching Authority .....	280
Sys .....	67, 69, 70, 71, 73
SysA .....	248, 248, 249, 249
<b>T</b>	
TCS .....	224, 224, 225, 225, 226
TLS Certificate .....	280
Tcplp .....	81
ThR .....	160, 161, 163, 163, 163, 165
Time Zones .....	379
TimeSync .....	122, 124
Timezone .....	377, 378
Trend rec .....	256, 258, 258, 258
Trigger .....	407, 408
TripCmd Mode .....	458
TripCmd Selection .....	406
Type of Output .....	363
Type of SCADA mapping .....	375, 378, 379
Type of passw. def. ....	279
true or not true .....	279
<b>U</b>	
URTD .....	186, 186, 190, 191, 192
Units .....	288
Used Protocol .....	285, 382
<b>V</b>	
VTS Block .....	436, 438
<b>W</b>	
Window configuration .....	366
<b>Y</b>	
yes/no .....	282

-

\_AL\_ResponseType\_k ..... 372


**We appreciate your comments about the content of our publications.**

**Send comments to: [kemp.doc@woodward.com](mailto:kemp.doc@woodward.com)**

**Please reference publication MRM4-3.6-EN-REF**

---

**<http://wwdmanuals.com/mrm4-2>**



Woodward Kempen GmbH reserves the right to update any portion of this publication at any time. Information provided by Woodward Kempen GmbH is believed to be correct and reliable. However, Woodward Kempen GmbH assumes no responsibility unless otherwise expressly undertaken.



Woodward Kempen GmbH  
Krefelder Weg 47 • D-47906 Kempen (Germany)  
Postfach 10 07 55 (P.O.Box) • D-47884 Kempen (Germany)  
Telephone: : +49 (0) 21 52 145 1

**Internet: — [www.woodward.com](http://www.woodward.com)**

**Sales**

Telephone: : +49 (0) 21 52 145 331  
Fax: : +49 (0) 21 52 145 354  
Email: : [SalesPGD\\_EMEA@woodward.com](mailto:SalesPGD_EMEA@woodward.com)

**Service**

Telephone: : +49 (0) 21 52 145 600  
Fax: : +49 (0) 21 52 145 455  
Email: : [SupportPGD\\_Europe@woodward.com](mailto:SupportPGD_Europe@woodward.com)

Woodward has company-owned plants, subsidiaries, and branches, as well as authorized distributors and other authorized service and sales facilities throughout the world.

Complete address / phone / fax / email information for all locations is available on our website.