



High **PROTEC**

IEC 61850 | PIXIT

MRM4

Software-Version: 3.6.b

Protocol Implementation Extra Information for Testing (PIXIT)

UCA International Users Group Testing Sub Committee

English

Contents of this document

This document is applicable for MRM4 Version 3.6.b (Firmware-Build 41481).

Each chapter specifies the PIXIT for each applicable ACSI service model as structured in IEC 61850-10.

PIXIT for Association model

Description	Value / Clarification										
Maximum number of clients that can set-up an association simultaneously	4										
TCP_KEEPALIVE values	Keep Alive Time : configurable between 1 – 7200s Keep Alive Interval : configurable between 1 – 60s Keep Alive Retry : fix 3										
Lost connection detection time	A lost connection is detected after Keep Alive Time + (Keep Alive Retry + 1) * Keep Alive Interval										
Is authentication supported?	N										
What association parameters are necessary for successful association?	<table border="0"> <tr> <td>Transport selector</td> <td>Y</td> </tr> <tr> <td>Session selector</td> <td>Y</td> </tr> <tr> <td>Presentation selector</td> <td>Y</td> </tr> <tr> <td>AP Title</td> <td>N</td> </tr> <tr> <td>AE Qualifier</td> <td>N</td> </tr> </table>	Transport selector	Y	Session selector	Y	Presentation selector	Y	AP Title	N	AE Qualifier	N
Transport selector	Y										
Session selector	Y										
Presentation selector	Y										
AP Title	N										
AE Qualifier	N										
If association parameters are necessary for association, describe the correct values e.g.	<table border="0"> <tr> <td>Transport selector</td> <td>0001</td> </tr> <tr> <td>Session selector</td> <td>0001</td> </tr> <tr> <td>Presentation selector</td> <td>00000001</td> </tr> <tr> <td>AP Title</td> <td>any</td> </tr> <tr> <td>AE Qualifier</td> <td>any</td> </tr> </table>	Transport selector	0001	Session selector	0001	Presentation selector	00000001	AP Title	any	AE Qualifier	any
Transport selector	0001										
Session selector	0001										
Presentation selector	00000001										
AP Title	any										
AE Qualifier	any										
What is the maximum and minimum MMS PDU size?	<table border="0"> <tr> <td>Max MMS PDU size</td> <td>64kB</td> </tr> <tr> <td>Min MMS PDU size</td> <td>4000</td> </tr> </table>	Max MMS PDU size	64kB	Min MMS PDU size	4000						
Max MMS PDU size	64kB										
Min MMS PDU size	4000										
What is the maximum start-up time after a power supply interrupt?	max 300 seconds until HMI is operable max 30 seconds until protection and IEC61850 is operable										

PIXIT for Server model

Description	Value / Clarification
<p>Which analogue value (MX) quality bits are supported (can be set by server)?</p>	<p>Validity:</p> <ul style="list-style-type: none"> Y Good, N Invalid, N Reserved, N Questionable N Overflow N OutofRange N BadReference N Oscillatory N Failure N OldData N Inconsistent N Inaccurate <p>Source:</p> <ul style="list-style-type: none"> Y Process N Substituted N Test N OperatorBlocked
<p>Which status value (ST) quality bits are supported (can be set by server)?</p>	<p>Validity:</p> <ul style="list-style-type: none"> Y Good Y Invalid N Reserved Y Questionable N BadReference N Oscillatory Y Failure N OldData Y Inconsistent N Inaccurate <p>Source:</p> <ul style="list-style-type: none"> Y Process N Substituted N Test N OperatorBlocked

Description	Value / Clarification
What is the maximum number of data values in one GetDataValues request?	Not restricted; MMS PDU is the limit.
What is the maximum number of data values in one SetDataValues request?	Not restricted; MMS PDU is the limit.
Deadband calculation for measurement	0 – Deadbanding disabled. Measurements follow the instantaneous value. 1 – 100000 - The delta sum up from the last updated value every second. If the sum is bigger than the deadband measurement value will be updated.

PIXIT for Data set model

Description	Value / Clarification
What is the maximum number of data elements in one data set (compare ICD setting)?	60
How many persistent data sets can be created by one or more clients?	15 (If there are datasets defined in the SCL file, only the remaining amount can be created by the clients during run-time.)
How many non-persistent data sets can be created by one or more clients?	15

PIXIT for Reporting model

Description	Value / Clarification																		
The supported trigger conditions are (compare PICS)	<table> <tr><td>integrity</td><td>Y</td></tr> <tr><td>data change</td><td>Y</td></tr> <tr><td>quality change</td><td>Y</td></tr> <tr><td>data update</td><td>N</td></tr> <tr><td>general interrogation</td><td>Y</td></tr> </table>	integrity	Y	data change	Y	quality change	Y	data update	N	general interrogation	Y								
integrity	Y																		
data change	Y																		
quality change	Y																		
data update	N																		
general interrogation	Y																		
The supported optional fields are	<table> <tr><td>sequence-number</td><td>Y</td></tr> <tr><td>report-time-stamp</td><td>Y</td></tr> <tr><td>reason-for-inclusion</td><td>Y</td></tr> <tr><td>data-set-name</td><td>Y</td></tr> <tr><td>data-reference</td><td>Y</td></tr> <tr><td>buffer-overflow</td><td>Y</td></tr> <tr><td>entryID</td><td>Y</td></tr> <tr><td>conf-rev</td><td>Y</td></tr> <tr><td>segmentation</td><td>Y</td></tr> </table>	sequence-number	Y	report-time-stamp	Y	reason-for-inclusion	Y	data-set-name	Y	data-reference	Y	buffer-overflow	Y	entryID	Y	conf-rev	Y	segmentation	Y
sequence-number	Y																		
report-time-stamp	Y																		
reason-for-inclusion	Y																		
data-set-name	Y																		
data-reference	Y																		
buffer-overflow	Y																		
entryID	Y																		
conf-rev	Y																		
segmentation	Y																		
Can the server send segmented reports?	Y																		
Mechanism on second internal data change notification of the same analogue data value within buffer period (Compare IEC 61850-7-2 §14.2.2.9)	The last data value within buffer period will be reported.																		
Multi client URCB approach (compare IEC 61850-7-2 §14.2.1)	Each URCB is visible to all clients																		
What is the format of EntryID?	Octet string, the last 4 bytes are used as counter.																		
What is the buffer size for each BRCB or how many reports can be buffered?	10000 bytes for each BRCB																		
Pre-configured RCB attributes that cannot be changed online when RptEna = FALSE (see also the ICD report settings)	All RCB attributes can be changed online.																		
May the reported data set contain: - structured data objects? - data attributes? - timestamp data attributes?	<table> <tr><td>Y</td></tr> <tr><td>Y</td></tr> <tr><td>Y</td></tr> </table>	Y	Y	Y															
Y																			
Y																			
Y																			
What is the scan cycle for binary events? Is this fixed, configurable?	<p>There is no scan cycle for binary events. Reporting works event driven</p> <p>Fixed</p>																		

PIXIT for Generic substation events model

Description	Value / Clarification
<p>What elements of a subscribed GOOSE header are checked to decide the message is valid and the allData values are accepted? If yes, describe the conditions.</p> <p>Note: the VLAN tag may be removed by a ethernet switch and should not be checked</p>	<p>N source MAC address</p> <p>Y destination MAC address</p> <p>Y Ethertype = 0x88B8</p> <p>N APPID</p> <p>Y gocbRef</p> <p>Y timeAllowedtoLive</p> <p>Y datSet</p> <p>Y goID</p> <p>N t</p> <p>Y stNum</p> <p>Y sqNum</p> <p>Y test</p> <p>Y confRev</p> <p>Y ndsCom</p> <p>Y numDatSetEntries</p>
<p>What is the behavior when one or more subscribed GOOSE messages aren't received or are syntactically incorrect (missing GOOSE)?</p> <p>device reaction:</p> <ol style="list-style-type: none"> Messages will be ignored. Status change will be ignored by the DUT and the quality is set as INVALID Status change will be accepted by the DUT and the quality is set as QUESTIONABLE Status change will be accepted by the DUT and the quality is set as GOOD 	<p>Reaction to received incorrect or missing GOOSE message:</p> <ul style="list-style-type: none"> wrong destination MAC address (1) Ethertype != 0x88B8 (1) wrong gocbRef (1) timeAllowedtoLive exceeded: <ul style="list-style-type: none"> by factor 1: (3) by factor 2: (2) wrong datSet (2) wrong goID (2) unexpected stNum (3) unexpected sqNum (3) test flag set (1) wrong confRev (2) ndsCom flag set (2) numDatSetEntries != data entries in received message (1) unexpected datatype in received message (2) numDatSetEntries < expected (2) numDatSetEntries > expected (4)

Description	Value / Clarification																					
Can the test flag in the published GOOSE be turned on / off ?	N																					
What is the behavior when the GOOSE publish configuration is incorrect?	Wrong GOOSE configuration in SCD-File is not possible, because it is checked when downloading it to the device. Changing the GOOSE configuration during runtime is not supported.																					
When is a subscribed GOOSE marked as lost? (TAL = time allowed to live value from the last received GOOSE message)	message does not arrive prior to TAL																					
What is the behavior when a subscribed GOOSE message is out-of-order?	This means that the DUT receives unexpected sqNum and/ or stNum. DUT reaction see item above.																					
What is the behavior when a subscribed GOOSE message is duplicated?	This means that the DUT receives unexpected sqNum and stNum. DUT reaction see item above.																					
Does the device subscribe to GOOSE messages with/without the VLAN tag?	Y with the VLAN tag Y without the VLAN tag																					
May the GOOSE data set contain: - structured data objects? - data attributes? - timestamp data attributes?	<table border="0"> <thead> <tr> <th data-bbox="810 1043 943 1070">Subscribed</th> <th data-bbox="1038 1043 1150 1070">Published</th> </tr> </thead> <tbody> <tr> <td data-bbox="810 1093 826 1120">N</td> <td data-bbox="1038 1093 1054 1120">N</td> </tr> <tr> <td data-bbox="810 1142 826 1169">Y</td> <td data-bbox="1038 1142 1054 1169">Y</td> </tr> <tr> <td data-bbox="810 1191 826 1218">Y</td> <td data-bbox="1038 1191 1054 1218">Y</td> </tr> </tbody> </table>	Subscribed	Published	N	N	Y	Y	Y	Y													
Subscribed	Published																					
N	N																					
Y	Y																					
Y	Y																					
What is the slow retransmission time? Is it fixed or configurable?	33 sec with TAL = 66 sec Fixed																					
What is the fast retransmission scheme? Is it fixed or configurable?	<p>Fixed scheme</p> <p>retrans: retrans time before next message</p> <table border="0"> <thead> <tr> <th data-bbox="810 1514 895 1541">sqNum</th> <th data-bbox="967 1514 1051 1541">retrans</th> <th data-bbox="1110 1514 1163 1541">TAL</th> </tr> </thead> <tbody> <tr> <td data-bbox="810 1563 826 1590">0</td> <td data-bbox="967 1563 1067 1590">32 msec</td> <td data-bbox="1110 1563 1211 1590">64 msec</td> </tr> <tr> <td data-bbox="810 1612 826 1639">1</td> <td data-bbox="967 1612 1067 1639">32 msec</td> <td data-bbox="1110 1612 1211 1639">64 msec</td> </tr> <tr> <td data-bbox="810 1662 826 1688">2</td> <td data-bbox="967 1662 1067 1688">64 msec</td> <td data-bbox="1110 1662 1227 1688">128 msec</td> </tr> <tr> <td data-bbox="810 1711 826 1738">3</td> <td data-bbox="967 1711 1067 1738">128 msec</td> <td data-bbox="1110 1711 1227 1738">256 msec</td> </tr> <tr> <td data-bbox="810 1760 826 1787">4</td> <td data-bbox="967 1760 1067 1787">256 msec</td> <td data-bbox="1110 1760 1227 1787">512 msec</td> </tr> <tr> <td data-bbox="810 1809 895 1836">... until</td> <td data-bbox="967 1809 1051 1836">33 sec</td> <td data-bbox="1190 1809 1275 1836">66 sec</td> </tr> </tbody> </table>	sqNum	retrans	TAL	0	32 msec	64 msec	1	32 msec	64 msec	2	64 msec	128 msec	3	128 msec	256 msec	4	256 msec	512 msec	... until	33 sec	66 sec
sqNum	retrans	TAL																				
0	32 msec	64 msec																				
1	32 msec	64 msec																				
2	64 msec	128 msec																				
3	128 msec	256 msec																				
4	256 msec	512 msec																				
... until	33 sec	66 sec																				
Can the Goose publish be turned on / off by using SetGoCBValues(GoEna)?	N																					

TAL = Time Allowed to Live

PIXIT for Control model

Description	Value / Clarification
What control modes are supported (compare PICS)?	N status-only Y direct-with-normal-security N sbo-with-normal-security N direct-with-enhanced-security Y sbo-with-enhanced-security
Is the control model fixed, configurable and/or online changeable?	Fixed
Is Time activated operate (operTm) supported?	N
Is "operate-many" supported?	N
What is the behavior of the DUT when the test attribute is set in the SelectWithValue and/or Operate request?	DUT ignores the test value and execute the command as usual
What are the conditions for the time (T) attribute in the SelectWithValue and/or Operate request?	DUT ignores the time value and execute the command as usual
Is pulse configuration supported?	N
What is the behavior of the DUT when the check conditions are set Is this behavior fixed, configurable, online changeable?	DUT ignores the check value transmitted by IEC61850 and performs the check depending on the device settings. Behavior is fixed
What additional cause diagnosis are supported?	Y Blocked-by-switching-hierarchy Y Select-failed N Invalid-position Y Position-reached Y Parameter-change-in-execution N Step-limit N Blocked-by-Mode N Blocked-by-process Y Blocked-by-interlocking Y Blocked-by-synchrocheck Y Command-already-in-execution N Blocked-by-health Y 1-of-n-control N Abortion-by-cancel Y Time-limit-over N Abortion-by-trip
How to force a "test-not-ok" respond with SelectWithValue request?	Double select of the same object.
How to force a "test-not-ok" respond with Select request?	n.a.

Description	Value / Clarification
How to force a "test-not-ok" respond with Operate request?	DOns: n.a. SBOns: n.a. DOes: n.a. SBOes: Send an Operate with actual value to an unselected SBOes object.
Which origin categories are supported?	Values 0 – 8 are supported
What happens if the orCat is not supported? Does the IED accept an selectwithvalue/operate with the same ctVal as the current status value? Does the IED accept a select/operate on the same control object from 2 different clients at the same time? Does the IED accept a select/selectwithvalue from the same client when the control object is already selected (tissue 334)? Is for SBOes the internal validation performed during the SelectWithValue and/or Operate step? Can a control operation be blocked by Mod=Off or Blocked? Does the IED support local / remote operation? Is it possible to select more than one switch at the same time?	DOns: Error message "not supported" SBOns: n.a. DOes: n.a. SBOes: Error message "not supported" DOns: Y SBOns: n.a. DOes: n.a. SBOes: N The DUT performs the check during the SelectWithValue phase. DOns: N SBOns: n.a. DOes: n.a. SBOes: N SBOns: n.a. SBOes: N SelectWithValue or Operate It depends on the performed validation step. N Y N The DUT allows to select only one switch at a time

PIXIT for Time and time synchronisation model

Description	Value / Clarification
What quality bits are supported?	N LeapSecondsKnown N ClockFailure Y ClockNotSynchronized
Describe the behavior when the time synchronization signal/messages are lost	The quality bit "ClockNotSynchronized" is set to TRUE after a fixed time period.
When is the time quality bit "Clock failure" set?	Not supported
When is the time quality bit "Clock not synchronised" set?	90 seconds after receiving the last synchronization signal/messages
Is the timestamp of a binary event adjusted to the configured scan cycle?	N (Timestamps of binary events lying in the past are not adjusted when the system clock is updated.)
Does the device support time zone and daylight saving?	Y
Which attributes of the SNTP response packet are validated?	N Leap indicator not equal to 3? Y Mode is equal to SERVER N OriginateTimestamp is equal to value sent by the SNTP client as Transmit Timestamp N RX/TX timestamp fields are checked for reasonableness Y SNTP version (3 and 4 accepted)