

# IEC 61850 - PIXIT



Protocol Implementation Extra Information for Testing (PIXIT)

UCA International Users Group Testing Sub Committee

Version: 3.7

Original document

**English** 

#### Original reference manual

#### **SEG Electronics GmbH**

Krefelder Weg 47 • D-47906 Kempen (Germany)

Telephone: +49 (0) 21 52 145 1

Internet: www.SEGelectronics.de

Sales

Telephone: +49 (0) 21 52 145 331

Fax: +49 (0) 21 52 145 354

E-mail: info@SEGelectronics.de

Service

Telephone: +49 (0) 21 52 145 614

Fax: +49 (0) 21 52 145 354

E-mail: info@SEGelectronics.de

© 2020 SEG Electronics GmbH. All rights reserved.

## **Table of Contents**

1	Contents of this document	4
2	PIXIT for Association model	5
3	PIXIT for Server model	6
4	PIXIT for Data set model	8
5	PIXIT for Reporting model	9
6	PIXIT for Generic substation events model	0
7	PIXIT for Control model	2
8	PIXIT for Time and time synchronisation model	4

#### 1 Contents of this document

This document is applicable for MRU4 Version 3.7.

Each chapter specifies the PIXIT for each applicable ACSI service model as structured in IEC 61850-10.

## 2 PIXIT for Association model

Maximum number of clients that can set-up an association simultaneously  TCP_KEEPALIVE values  Keep Alive Time: configurable between 1 - 7200s  Keep Alive Interval: configurable between 1 - 60s  Keep Alive Interval: configurable between 1 - 60s  Keep Alive Retry: fix 3  Lost connection detection time  A lost connection is detected after  Keep Alive Time + (Keep Alive Retry + 1) * Keep Alive Interval  Is authentication supported?  N  What association parameters are necessary for successful association?  Session selector: Y  AP Title: N  AE Qualifier: N  If association parameters are necessary for association, describe the correct values e. g.  Transport selector: 0001  Session selector: 0001  Presentation selector: 000000001  AP Title: any  AE Qualifier: any  What is the maximum and minimum MMS PDU size: 64kB  Min MMS PDU size: 4000  What is the maximum start-up time after a power supply interrupt?  max 300 seconds until HMI is operable  max 30 seconds until protection and IEC61850 is operable	Description	Value / Clarification
Keep Alive Interval: configurable between 1 - 60s Keep Alive Retry: fix 3  Lost connection detection time  A lost connection is detected after Keep Alive Time + (Keep Alive Retry + 1) * Keep Alive Interval  Is authentication supported?  N  What association parameters are necessary for successful association?  Fresentation selector: Y Presentation selector: Y AP Title: N AE Qualifier: N  If association parameters are necessary for association, describe the correct values e. g.  Transport selector: 0001 Session selector: 0001 Presentation selector: 000000001 AP Title: any AE Qualifier: any  What is the maximum and minimum MMS PDU size: 64kB Min MMS PDU size: 4000  What is the maximum start-up time after a power supply interrupt?  max 300 seconds until HMI is operable		4
Lost connection detection time  A lost connection is detected after Keep Alive Time + (Keep Alive Retry + 1) * Keep Alive Interval  Is authentication supported?  N What association parameters are necessary for successful association?  Fransport selector: Y Presentation selector: Y AP Title: N AE Qualifier: N  If association parameters are necessary for association, describe the correct values e. g.  Fransport selector: 0001 Session selector: 0001 Presentation selector: 0001 Presentation selector: 00000001 AP Title: any AE Qualifier: any  What is the maximum and minimum MMS PDU size: 64kB Min MMS PDU size: 4000  What is the maximum start-up time after a power supply interrupt?  max 300 seconds until HMI is operable	TCP_KEEPALIVE values	
Keep Alive Time + (Keep Alive Retry + 1) * Keep Alive Interval		
Is authentication supported?  What association parameters are necessary for successful association?  Fresentation selector: Y  AP Title: N  AE Qualifier: N  If association parameters are necessary for association, describe the correct values e. g.  Fresentation selector: 0001  Session selector: 0001  Presentation selector: 00001  Presentation selector: 000000001  AP Title: any  AE Qualifier: any  What is the maximum and minimum MMS PDU size: 64kB  Min MMS PDU size: 4000  What is the maximum start-up time after a power supply interrupt?  max 300 seconds until HMI is operable	Lost connection detection time	
What association parameters are necessary for successful association?  Session selector: Y Presentation selector: Y AP Title: N AE Qualifier: N  If association parameters are necessary for association, describe the correct values e. g.  Transport selector: 0001 Session selector: 0001 Presentation selector: 000000001 AP Title: any AE Qualifier: any  What is the maximum and minimum MMS PDU size: 64kB Min MMS PDU size: 64kB Min MMS PDU size: 4000  What is the maximum start-up time after a power supply interrupt?  max 300 seconds until HMI is operable		Keep Alive Time + (Keep Alive Retry + 1) * Keep Alive Interval
necessary for successful association?  Session selector: Y Presentation selector: Y AP Title: N AE Qualifier: N  If association parameters are necessary for association, describe the correct values e. g.  Transport selector: 0001 Session selector: 0001 Presentation selector: 000000001 AP Title: any AE Qualifier: any  What is the maximum and minimum MMS PDU size: 64kB Min MMS PDU size: 4000  What is the maximum start-up time after a power supply interrupt?  max 300 seconds until HMI is operable	Is authentication supported?	N
Presentation selector: Y  AP Title: N  AE Qualifier: N  If association parameters are necessary for association, describe the correct values e. g.  Transport selector: 0001 Session selector: 00001 Presentation selector: 000000001  AP Title: any AE Qualifier: any  What is the maximum and minimum MMS PDU size: 64kB Min MMS PDU size: 4000  What is the maximum start-up time after a power supply interrupt?  max 300 seconds until HMI is operable	What association parameters are	Transport selector: Y
AP Title: N  AE Qualifier: N  If association parameters are necessary for association, describe the correct values e. g.  Transport selector: 0001 Session selector: 00001 Presentation selector: 000000001 AP Title: any AE Qualifier: any  What is the maximum and minimum MMS PDU size: 64kB Min MMS PDU size: 4000  What is the maximum start-up time after a power supply interrupt?  max 300 seconds until HMI is operable	necessary for successful association?	Session selector: Y
AE Qualifier: N  If association parameters are necessary for association, describe the correct values e. g.  Transport selector: 0001 Session selector: 000000001 AP Title: any AE Qualifier: any  What is the maximum and minimum MMS PDU size: 64kB Min MMS PDU size: 4000  What is the maximum start-up time after a power supply interrupt?  Max MMS PDU size: 4000		Presentation selector: Y
If association parameters are necessary for association, describe the correct values e. g.  Transport selector: 0001 Session selector: 000000001 Presentation selector: 000000001 AP Title: any AE Qualifier: any  What is the maximum and minimum MMS PDU size: 64kB size?  Min MMS PDU size: 4000  What is the maximum start-up time after a power supply interrupt?  max 300 seconds until HMI is operable		AP Title: N
Session selector: 0001  Presentation selector: 00000001  AP Title: any  AE Qualifier: any  What is the maximum and minimum MMS PDU size: 64kB  Size?  Min MMS PDU size: 4000  What is the maximum start-up time after a power supply interrupt?  max 300 seconds until HMI is operable		AE Qualifier: N
Session selector: 0001 Presentation selector: 00000001  AP Title: any AE Qualifier: any  What is the maximum and minimum MMS PDU size: 64kB size?  Min MMS PDU size: 4000  What is the maximum start-up time after a power supply interrupt?  max 300 seconds until HMI is operable		Transport selector: 0001
AP Title: any  AE Qualifier: any  What is the maximum and minimum MMS PDU size: 64kB size?  Min MMS PDU size: 4000  What is the maximum start-up time after a power supply interrupt?  max 300 seconds until HMI is operable		Session selector: 0001
AE Qualifier: any  What is the maximum and minimum MMS PDU size: 64kB size?  Min MMS PDU size: 4000  What is the maximum start-up time after a power supply interrupt?  max 300 seconds until HMI is operable		Presentation selector: 00000001
What is the maximum and minimum MMS PDU size: 64kB size?  Min MMS PDU size: 4000  What is the maximum start-up time after a power supply interrupt?  max 300 seconds until HMI is operable		AP Title: any
size?  Min MMS PDU size: 4000  What is the maximum start-up time after a power supply interrupt?  max 300 seconds until HMI is operable		AE Qualifier: any
What is the maximum start-up time after a power supply interrupt?  Min MMS PDU size: 4000  max 300 seconds until HMI is operable		Max MMS PDU size: 64kB
power supply interrupt?	Size!	Min MMS PDU size: 4000
max 30 seconds until protection and IEC61850 is operable	What is the maximum start-up time after a nower supply interrupt?	max 300 seconds until HMI is operable
	ромет заррту пітентарт:	max 30 seconds until protection and IEC61850 is operable

## 3 PIXIT for Server model

Description	Value / Clarification
Which analog value (MX) quality bits are supported (can be set by server)?	Validity:
	Y Good,
	N Invalid,
	N Reserved,
	N Questionable
	N Overflow
	N OutofRange
	N BadReference
	N Oscillatory
	N Failure
	N OldData
	N Inconsistent
	N Inaccurate
	Source:
	Y Process
	N Substituted
	N Test
	N OperatorBlocked
Which status value (ST) quality bits are	Validity:
supported (can be set by server)?	Y Good
	Y Invalid
	N Reserved
	Y Questionable
	N BadReference
	N Oscillatory
	Y Failure
	N OldData
	Y Inconsistent
	N Inaccurate
	Source:
	Y Process
	N Substituted
	N Test
	N OperatorBlocked
What is the maximum number of data values in one GetDataValues request?	Not restricted; MMS PDU is the limit.

Description	Value / Clarification
What is the maximum number of data values in one SetDataValues request?	Not restricted; MMS PDU is the limit.
Deadband calculation for measurement	<ul> <li>0 - Deadbanding disabled. Measurements follow the instantaneous value.</li> <li>1 - 100000 — The delta sum up from the last updated value every second. If the sum is bigger than the deadband measurement value will be updated.</li> </ul>

## 4 PIXIT for Data set model

Description	Value / Clarification
What is the maximum number of data elements in one data set (compare ICD setting)?	60
How many persistent data sets can be created by one or more clients?	15 (If there are datasets defined in the SCL file, only the remaining amount can be created by the clients during run-time.)
How many non-persistent data sets can be created by one or more clients?	15

## 5 PIXIT for Reporting model

Description	Value / Clarification
The supported trigger conditions are	integrity: Y
(compare PICS)	data change: Y
	quality change: Y
	data update: N
	general interrogation: Y
The supported optional fields are	sequence-number: Y
	report-time-stamp: Y
	reason-for-inclusion: Y
	data-set-name: Y
	data-reference: Y
	buffer-overflow: Y
	entryID: Y
	conf-rev: Y
	segmentation: Y
Can the server send segmented reports?	Υ
Mechanism on second internal data change notification of the same analogue data value within buffer period (Compare IEC 61850-7-2 \$14.2.2.9)	The last data value within buffer period will be reported.
Multi client URCB approach	Each URCB is visible to all clients
(compare IEC 61850-7-2 \$14.2.1)	
What is the format of EntryID?	Octet string, the last 4 bytes are used as counter.
What is the buffer size for each BRCB or how many reports can be buffered?	10000 bytes for each BRCB
Pre-configured RCB attributes that cannot be changed online when RptEna = FALSE	All RCB attributes can be changed online.
(see also the ICD report settings)	
May the reported data set contain:	
structured data objects?	• Y
<ul><li>data attributes?</li><li>timestamp data attributes?</li></ul>	• Y • Y
• What is the scan cycle for binary events?	There is no scan cycle for binary events.
	Reporting works event driven.
<ul><li>Is this fixed, configurable?</li></ul>	• Fixed

## 6 PIXIT for Generic substation events model

Description	Value / Clarification
What elements of a subscribed GOOSE header are checked to decide the message is valid and the allData values are accepted? If yes, describe the conditions.  Note: the VLAN tag may be removed by a ethernet switch and should not be checked	<pre>N source MAC address Y destination MAC address Y Ethertype = 0x88B8 N APPID Y gocbRef Y timeAllowedtoLive Y datSet Y goID N t Y stNum Y sqNum Y test Y confRev Y numDatSetEntries</pre>
What is the behavior when one or more subscribed GOOSE messages aren't received or are syntactically incorrect (missing GOOSE)? device reaction:  • (1) Messages will be ignored.  • (2) Status change will be ignored by the DUT and the quality is set as INVALID  • (3) Status change will be accepted by the DUT and the quality is set as QUESTIONABLE  • (4) Status change will be accepted by the DUT and the quality is set as GOOD	Reaction to received incorrect or missing GOOSE message:  • wrong destination MAC address (1)  • Ethertype != 0x88B8 (1)  • wrong gocbRef (1)  • timeAllowedtoLive exceeded:  • by factor 1: (3)  • by factor 2: (2)  • wrong datSet (2)  • wrong goID (2)  • unexpected stNum (3)  • unexpected sqNum (3)  • test flag set (1)  • wrong confRev (2)  • ndsCom flag set (2)  • numDatSetEntries != data entries in received message (1)  • unexpected datatype in received message (2)  • numDatSetEntries < expected (2)  • numDatSetEntries > expected (4)
Can the test flag in the published GOOSE be turned on / off ?	N
What is the behavior when the GOOSE publish configuration is incorrect?	Wrong GOOSE configuration in SCD-File is not possible, because it is checked when downloading it to the device.  Changing the GOOSE configuration during runtime is not supported.
When is a subscribed GOOSE marked as lost?	message does not arrive prior to TAL

Description	Value / Clarification		
(TAL = time allowed to live value from the last received GOOSE message)			
What is the behavior when a subscribed GOOSE message is out-of-order?	This means that the DU DUT reaction see item a	T receives unexpected sq bove.	Num and/ or stNum.
What is the behavior when a subscribed GOOSE message is duplicated?	This means that the DU reaction see item above	T receives unexpected sq e.	Num and stNum. DUT
Does the device subscribe to GOOSE messages with/without the VLAN tag?	Y with the VLAN tag Y without the VLAN tag		
<ul><li>May the GOOSE data set contain:</li><li>structured data objects?</li><li>data attributes?</li><li>timestamp data attributes?</li></ul>	<ul><li>Subscribed / Published</li><li>N / N</li><li>Y / Y</li><li>Y / Y</li></ul>		
What is the slow retransmission time?  Is it fixed or configurable?	33 sec with TAL = 66 se	C	
What is the fast retransmission scheme?  Is it fixed or configurable?	Fixed scheme retrans: retrans time <b>be</b>	fore next message	
	sqNum	retrans	TAL
	0	32 msec	64 msec
	1	32 msec	64 msec
	2	64 msec	128 msec
	3	128 msec	256 msec
	4	256 msec	512 msec
	until	33 sec	66 sec
Can the Goose publish be turned on / off by using SetGoCBValues(GoEna)?	N		

TAL = Time Allowed to Live

## **7** PIXIT for Control model

Description	Value / Clarification
What control modes are supported	N status-only
(compare PICS)?	Y direct-with-normal-security
	N sbo-with-normal-security
	N direct-with-enhanced-security
	Y sbo-with-enhanced-security
Is the control model fixed, configurable and/or online changeable?	Fixed
Is Time activated operate (operTm) supported?	N
Is "operate-many" supported?	N
What is the behavior of the DUT when the test attribute is set in the SelectWithValue and/or Operate request?	DUT ignores the test value and execute the command as usual
What are the conditions for the time (T) attribute in the SelectWithValue and/or Operate request?	DUT ignores the time value and execute the command as usual
Is pulse configuration supported?	N
What is the behavior of the DUT when the check conditions are set	DUT ignores the check value transmitted by IEC61850 and performs the check depending on the device settings.
Is this behavior fixed, configurable, online changeable?	Behavior is fixed
What additional cause diagnosis are supported?	Y Blocked-by-switching-hierarchy Y Select-failed N Invalid-position Y Position-reached Y Parameter-change-in-execution N Step-limit N Blocked-by-Mode N Blocked-by-process Y Blocked-by-interlocking Y Blocked-by-synchrocheck Y Command-already-in-execution N Blocked-by-health Y 1-of-n-control N Abortion-by-cancel Y Time-limit-over N Abortion-by-trip
How to force a "test-not-ok" respond with SelectWithValue request?	Double select of the same object.

Description	Value / Clarification
How to force a "test-not-ok" respond with Select request?	n.a.
How to force a "test-not-ok" respond with Operate request?	DOns: n.a.
Operate request:	SBOns: n.a.
	DOes:n.a.
	SBOes: Send an Operate with actual value to an unselected SBOes object.
Which origin categories are supported?	Values 0 - 8 are supported
What happens if the orCat is not supported?	DOns: Error message "not supported"
	SBOns: n.a.
	DOes: n.a.
	SBOes: Error message "not supported"
Does the IED accept an selectwithvalue/	DOns: Y
operate with the same ctlVal as the current status value?	SBOns: n.a.
	DOes: n.a.
	SBOes: N
	The DUT performs the check during the SelectWithValue phase.
Does the IED accept a select/operate on the same control object from 2 different clients at	DOns: N
the same time?	SBOns: n.a.
	DOes: n.a.
	SBOes: N
Does the IED accept a select/selectwithvalue	SBOns: n.a.
from the same client when the control object is already selected (tissue 334)?	SBOes: N
Is for SBOes the internal validation performed	SelectWithValue or Operate
during the SelectWithValue and/or Operate step?	It depends on the performed validation step.
Can a control operation be blocked by Mod=Off or Blocked?	N
Does the IED support local / remote operation?	Υ
Is it possible to select more than one switch at the same time?	N
are sume time:	The DUT allows to select only one switch at a time

## 8 PIXIT for Time and time synchronisation model

Description	Value / Clarification
What quality bits are supported?	<ul><li>N LeapSecondsKnown</li><li>N ClockFailure</li><li>Y ClockNotSynchronized</li></ul>
Describe the behavior when the time synchronization signal/messages are lost	The quality bit "ClockNotSynchronized" is set to TRUE after a fixed time period.
When is the time quality bit "Clock failure" set?	Not supported
When is the time quality bit "Clock not synchronised" set?	90 seconds after receiving the last synchronization signal/messages
Is the timestamp of a binary event adjusted to the configured scan cycle?	N (Timestamps of binary events lying in the past are not adjusted when the system clock is updated.)
Does the device support time zone and daylight saving?	Υ
Which attributes of the SNTP response packet are validated?	<ul> <li>N Leap indicator not equal to 3?</li> <li>Y Mode is equal to SERVER</li> <li>N OriginateTimestamp is equal to value sent by the SNTP client as Transmit Timestamp</li> <li>N RX/TX timestamp fields are checked for reasonableness</li> <li>Y SNTP version (3 and 4 accepted)</li> </ul>



## High PROTEG

docs.SEGelectronics.de/HighPROTEC



SEG Electronics GmbH reserves the right to update any portion of this publication at any time. Information provided by SEG Electronics GmbH is believed to be correct and reliable. However, SEG Electronics GmbH assumes no responsibility unless otherwise expressly undertaken.



SEG Electronics GmbH Krefelder Weg 47 • D-47906 Kempen (Germany) Telephone: +49 (0) 21 52 145 1

Internet: www.SEGelectronics.de

Sales Telephone: +49 (0) 21 52 145 331 Fax: +49 (0) 21 52 145 354

Service Telephone: +49 (0) 21 52 145 614 Fax: +49 (0) 21 52 145 354

Complete address / phone / fax / email information for all locations is available on our website.