



High PROTEC

IEC 61850 | PICS

MRU4

Software-Version: 2.2.e

IEC 61850 PICS

Protocol Implementation Conformance Statement (PICS)

UCA International Users Group Testing Sub Committee

English

General

This document is applicable for MRU4 Version 2.2.e (Firmware-Build 21029).

- ACSI basic conformance statement
- ACSI models conformance statement
- ACSI service conformance statement

The statements specify the communication features mapped to IEC 61850-8-1.

ASCI basic conformance statement

The basic conformance statement is defined in Table A.1.

Table A.1 – Basic conformance statement

		Client/ Subscriber	Server/ Publisher	Value/ Comments
Client-Server roles				
B11	Server side (of TWO-PARTY-APPLICATION-ASSOCIATION)	–	Y	
B12	Client side of (TWO-PARTY-APPLICATION-ASSOCIATION)	–	–	
SCSMs supported				
B21	SCSM : IEC 6185-8-1 used	–	Y	
B22	SCSM : IEC 6185-9-1 used	–	N	
B23	SCSM : IEC 6185-9-2 used	–	Y	
B24	SCSM : other	–	N	
Generic substation event model (GSE)				
B31	Publisher side	–	Y	
B32	Subscriber side	Y	–	
Transmission of sampled value model (SVC)				
B41	Publisher side	–	N	
B42	Subscriber side	–	–	
– Y = supported N or empty = not supported				

ACSI models conformance statement

The ACSI models conformance statement is defined in Table A.2.

Table A.2 – ACSI models conformance statement

		Client/ Subscriber	Server/ Publisher	Value/ Comments
If Server or Client side (B11/12) supported				
M1	Logical device	–	Y	
M2	Logical node	–	Y	
M3	Data	–	Y	
M4	Data set	–	Y	
M5	Substitution	–	N	
M6	Setting group control	–	N	
	Reporting			
M7	Buffered report control	–	Y	
M7-1	sequence-number	–	Y	
M7-2	report-time-stamp	–	Y	
M7-3	reason-for-inclusion	–	Y	
M7-4	data-set-name	–	Y	
M7-5	data-reference	–	Y	
M7-6	buffer-overflow	–	Y	
M7-7	entryID	–	Y	
M7-8	BufTim	–	Y	
M7-9	IntgPd	–	Y	
M7-10	GI	–	Y	
M7-11	conf-revision	–	Y	
M8	Unbuffered report control	–	Y	
M8-1	sequence-number	–	Y	
M8-2	report-time-stamp	–	Y	
M8-3	reason-for-inclusion	–	Y	
M8-4	data-set-name	–	Y	
M8-5	data-reference	–	Y	

		Client/ Subscriber	Server/ Publisher	Value/ Comments
M8-6	BufTim	–	Y	
M8-7	IntgPd	–	Y	
M8-8	GI	–	Y	
M8-9	conf-revision	–	N	
	Logging	–	N	
M9	Log control	–	N	
M9-1	IntgPd	–	N	
M10	Log	–	N	
M11	Control	–	Y	
If GSE (B31/32) is supported				
M12	GOOSE	Y	Y	
M13	GSSE	N	N	
If SVC (41/42) is supported				
M14	Multicast SVC	–	N	
M15	Unicast SVC	–	N	
If Server or Client side (B11/12) supported				
M16	Time	Y	N	scheduled
M17	File Transfer	N	N	scheduled
Y = service is supported				
N or empty = service is not supported				

ACSI service conformance statement

The ACSI service conformance statement is defined in Table A.3 (depending on the statements in Table A.1).

Table A.3 – ACSI service Conformance statement

	Services	AA: TP/MC	Client (C)	Server (S)	Comments
Server					
S1	ServerDirectory	TP	–	Y	

Application association					
S2	Associate		–	Y	
S3	Abort		–	Y	
S4	Release		–	Y	

Logical device					
S5	LogicalDeviceDirectory	TP	–	Y	

Logical node					
S6	LogicalNodeDirectory	TP	–	Y	
S7	GetAllDataValues	TP	–	Y	

Data					
S8	GetDataValues	TP	–	Y	
S9	SetDataValues	TP	–	Y	
S10	GetDataDirectory	TP	–	Y	
S11	GetDataDefinition	TP	–	Y	

Data set					
S12	GetDataSetValues	TP	–	Y	
S13	SetDataSetValues	TP	–	Y	
S14	CreateDataSet	TP	–	Y	
S15	DeleteDataSet	TP	–	Y	
S16	GetDataSetDirectory	TP	–	Y	

Substitution					
---------------------	--	--	--	--	--

	Services	AA: TP/MC	Client (C)	Server (S)	Comments
S17	SetDataValues	TP	–	N	

Setting group control					
S18	SelectActiveSG	TP	–	N	scheduled
S19	SelectEditSG	TP	–	N	
S20	SetSGValues	TP	–	N	
S21	ConfirmEditSGValues	TP	–	N	
S22	GetSGValues	TP	–	N	
S23	GetSGCBValues	TP	–	N	

Reporting					
Buffered report control block (BRCB)					
S24	Report	TP	–	Y	
S24-1	data-change (dchg)		–	Y	
S24-2	qchg-change (qchg)		–	Y	
S24-3	data-update (dupd)		–	N	
S25	GetBRCBValues	TP	–	Y	
S26	SetBRCBValues	TP	–	Y	
Unbuffered report control block (URCB)					
S27	Report	TP	–	Y	
S27-1	data-change (dchg)		–	Y	
S27-2	qchg-change (qchg)		–	Y	
S27-3	data-update (dup)		–	N	
S28	GetURCBValues	TP	–	Y	
S29	SetURCBValues	TP	–	Y	

Logging					
Log control block					
S30	GetLCBValues	TP	–	N	
S31	SetLCBValues	TP	–	N	
Log					
S32	QueryLogByTime	TP	–	N	

	Services	AA: TP/MC	Client (C)	Server (S)	Comments
S33	QueryLogByEntry	TP	–	N	
S34	GetLogStatusValues	TP	–	N	

Generic substation event model (GSE)					
GOOSE-CONTROL-BLOCK					
S35	SendGOOSEMessage	MC	–	Y	
S36	GetReference	TP	–	Y	
S37	GetGOOSEElementNumber	TP	–	Y	
S38	GetGoCBValues	TP	–	Y	
S39	SetGoCBValues	TP	–	N	
GSSE-CONTROL-BLOCK					
S40	SendGSSEMessage	MC	–	N	
S41	GetReference	TP	–	N	
S42	GetGSSElementNumber	TP	–	N	
S43	GetGsCBValues	TP	–	N	
S44	SetGsCBValues	TP	–	N	

Transmission of sampled value model (SVC)					
Multicast SVC					
S45	SendMSVMessage	MC	–	N	
S46	GetMSVCBValues	TP	–	N	
S47	SetMSVCBValues	TP	–	N	
Unicast SVC					
S48	SendUSVMessage	TP	–	N	
S49	GetUSVCBValues	TP	–	N	
S50	SetUSVCBValues	TP	–	N	

Control					
S51	Select		–	N	

	Services	AA: TP/MC	Client (C)	Server (S)	Comments
S52	SelectWithValue	TP	–	Y	
S53	Cancel	TP	–	Y	
S54	Operate	TP	–	Y	
S55	Command-Termination	TP	–	Y	
S56	TimeActivated-Operate	TP	–	N	

File transfer					
S57	GetFile	TP	–	N	
S58	SetFile	TP	–	N	
S59	DeleteFile	TP	–	N	
S60	GetFileAttributeValue	TP	–	N	

Time					
T1	Time resolution of internal clock		10	–	nearest negative power of 2 in seconds
T2	Time accuracy of internal clock		N	–	T0
			Y	–	T1
			N	–	T2
			N	–	T3
			N	–	T4
			N	–	T5
T3	Supported TimeStamp resolution		10	–	nearest negative power of 2 in seconds

Revision history

Revision	Remarks
1.0	First version
1.1	Added corporate design